

**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/  
**WATER PRODUCTION REPORT**

Date: 1.1.2022

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/664.60	200	0.6''	42
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		5.4

**PRODUCTION DETAILS** **TOTAL PRODUCTION : 922.59 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	78.11	Due to increase in ammonia level
ii)	Wazirabad	124	-Do-	122.18	
iii)	Haiderpur	220	WJC Canal	208.52	Raw water shortage
iv)	Nangloi	40	-Do-	41.10	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	21.29	
vi)	Dwarka		WJC Canal	49.36	
vii)	Bawana		WJC Canal	18.40	Raw water shortage

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	107.42	
viii)	Sonia Vihar	144	-Do-	139.15	
1)	Production of Water Treatment Plants			785.53	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazirabad	11	Recycled process waste at Wzd. Plant	10.24	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.10	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	3.31	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			29.65	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells			95.00	
	Total	(1+2+3)		910.18	

**5. MAJOR UGRs' LEVELS IN METERS.**

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	4.35
Greater Kailash (N)	4.80	3.35
Deer Park	4.50	3.90
Janak Puri	3.00	3.40
Kalka Ji	3.65	4.26

## 6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e..31.12.21 -----910.18 MGD

Member (WS)

### Copy to: -

1. Pr. Secretary to Lt. Governor
2. P.S. to Chief Minister, Delhi
3. P.S. to Chief Secretary, Delhi
4. Principal Secretary (UD) Govt., of NCT of Delhi
5. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
6. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
  - a. Hudson Lane, Civil Lines ,Delhi-110009
7. CE(WW)
8. CE (East)

**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/  
**WATER PRODUCTION REPORT**

Date: 2.1.2022

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/664.50	100	0.3''	46
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		7

**PRODUCTION DETAILS**

**TOTAL PRODUCTION : 932.42 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	85.33	Due to increase in ammonia level
ii)	Wazirabad	124	-Do-	123.71	
iii)	Haiderpur	220	WJC Canal	219.36	
iv)	Nangloi	40	-Do-	42.26	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	21.20	
vi)	Dwarka		WJC Canal	49.56	
vii)	Bawana		WJC Canal	19.60	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	107.53	
viii)	Sonia Vihar	144	-Do-	139.28	
1)	Production of Water Treatment Plants			807.83	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazirabad	11	Recycled process waste at Wzd. Plant	10.23	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.10	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	3.26	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			29.59	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells			95.00	
	Total	(1+2+3)		932.42	

**5. MAJOR UGRs' LEVELS IN METERS.**

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	4.26
Greater Kailash (N)	4.80	3.35
Deer Park	4.50	4.20
Janak Puri	3.00	3.40

Kalka Ji	3.65	4.26
----------	------	------

#### 6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Afected

Note :- Total supply of water in last 24 hours i.e. 1.1.2022 -----932.42 MGD

Member (WS)

Copy to: -

1. Pr. Secretary to Lt. Governor
2. P.S. to Chief Minister, Delhi
3. P.S. to Chief Secretary, Delhi
4. Principal Secretary (UD) Govt., of NCT of Delhi
5. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
6. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,  
a. Hudson Lane, Civil Lines ,Delhi-110009
7. CE(WW)
8. CE (East)
9. Dir F & A
10. E.E. (EDP) for uploading on Website
11. Office copy

**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/  
**WATER PRODUCTION REPORT**

Date: 3.1.2022

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/664.60	100	3"	33
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		7.5

**PRODUCTION DETAILS**

**TOTAL PRODUCTION : 890.80 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	86.73	
ii)	Wazirabad	124	-Do-	123.21	
iii)	Haiderpur	220	WJC Canal	219.35	
iv)	Nangloi	40	-Do-	43.00	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	21.02	
vi)	Dwarka		WJC Canal	51.44	
vii)	Bawana		WJC Canal	19.21	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	107.65	
viii)	Sonia Vihar	144	-Do-	139.21	
1)	Production of Water Treatment Plants			810.82	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.28	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.10	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	3.29	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			29.67	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells		95.00	
	Total	(1+2+3)	935.49	

**5. MAJOR UGRs' LEVELS IN METERS.**

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	4.05
Greater Kailash (N)	4.80	3.04
Deer Park	4.50	4.10
Janak Puri	3.00	3.40
Kalka Ji	3.65	4.14

**6. TRANSMISSION MAIN**

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

**Note :- Total supply of water in last 24 hours i.e 2.1.2022 -----935.49 MGD**

**Member (WS)**

**Copy to: -**

9. Pr. Secretary to Lt. Governor
10. P.S. to Chief Minister, Delhi
11. P.S. to Chief Secretary, Delhi
12. Principal Secretary (UD) Govt., of NCT of Delhi
13. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
14. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
  - a. Hudson Lane, Civil Lines ,Delhi-110009
15. CE(WW)
16. CE (East)

**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/  
**WATER PRODUCTION REPORT**

Date: 4.1.2022

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/664.60	200	0.6"	37
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		7.5

**PRODUCTION DETAILS**

**TOTAL PRODUCTION : 937.49 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	93.01	
ii)	Wazirabad	124	-Do-	120.75	
iii)	Haiderpur	220	WJC Canal	215.93	
iv)	Nangloi	40	-Do-	43.84	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	21.36	
vi)	Dwarka		WJC Canal	52.05	
vii)	Bawana		WJC Canal	20.00	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	105.32	
viii)	Sonia Vihar	144	-Do-	139.77	
1)	Production of Water Treatment Plants			812.03	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.25	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.00	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.21	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			30.46	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells			95.00	
	Total	(1+2+3)		937.49	

**5. MAJOR UGRs' LEVELS IN METERS.**

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	4.87
Greater Kailash (N)	4.80	3.35
Deer Park	4.50	4.30

Janak Puri	3.00	3.40
Kalka Ji	3.65	4.14

#### 6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e. 3.1.2022 -----937.49 MGD

Member (WS)

Copy to: -

12. Pr. Secretary to Lt. Governor
13. P.S. to Chief Minister, Delhi
14. P.S. to Chief Secretary, Delhi
15. Principal Secretary (UD) Govt., of NCT of Delhi
16. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
17. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,  
a. Hudson Lane, Civil Lines ,Delhi-110009
18. CE(WW)
19. CE (East)
20. Dir F & A
21. E.E. (EDP) for uploading on Website
22. Office copy



**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/  
**WATER PRODUCTION REPORT**

Date: 28.12.21

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/664.60	200	0.6"	45
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		7.5

**PRODUCTION DETAILS**

**TOTAL PRODUCTION : 928.58 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	93.25	
ii)	Wazirabad	124	-Do-	115.69	
iii)	Haiderpur	220	WJC Canal	213.28	
iv)	Nangloi	40	-Do-	43.63	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	21.03	
vi)	Dwarka		WJC Canal	50.63	
vii)	Bawana		WJC Canal	20.00	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	108.56	
viii)	Sonia Vihar	144	-Do-	137.92	
1)	Production of Water Treatment Plants			803.99	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.27	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.20	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	3.12	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			29.59	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells			95.00	
	Total	(1+2+3)		928.58	

**5. MAJOR UGRs' LEVELS IN METERS.**

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	
Greater Kailash (N)	4.80	
Deer Park	4.50	4.20
Janak Puri	3.00	3.40
Kalka Ji	3.65	4.26

**6. TRANSMISSION MAIN**

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected
	Ch.I & II closed due to electricity drid fail	8.42pm to 9.40pm	

**Note :- Total supply of water in last 24 hours i.e..4.1.2022 -----928.58 MGD**

**Member (WS)**

**Copy to: -**

17. Pr. Secretary to Lt. Governor
18. P.S. to Chief Minister, Delhi
19. P.S. to Chief Secretary, Delhi
20. Principal Secretary (UD) Govt., of NCT of Delhi
21. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
22. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
  - a. Hudson Lane, Civil Lines ,Delhi-110009
23. CE(WW)
24. CE (East)

**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II, KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/  
**WATER PRODUCTION REPORT**

Date: 6.1.2022

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/664.60	200	0.6"	39
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		7.5

**PRODUCTION DETAILS**

**TOTAL PRODUCTION : 927.91 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	94.49	
ii)	Wazirabad	124	-Do-	115.59	
iii)	Haiderpur	220	WJC Canal	210.88	
iv)	Nangloi	40	-Do-	43.68	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	20.99	
vi)	Dwarka		WJC Canal	51.93	
vii)	Bawana		WJC Canal	20.00	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	107.47	
viii)	Sonia Vihar	144	-Do-	138.27	
1)	Production of Water Treatment Plants			803.30	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazirabad	11	Recycled process waste at Wzd. Plant	10.16	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.20	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	3.25	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			29.61	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells			95.00	
	Total	(1+2+3)		927.91	

**5. MAJOR UGRs' LEVELS IN METERS.**

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	4.05
Greater Kailash (N)	4.80	3.35
Deer Park	4.50	4.30

Janak Puri	3.00	3.40
Kalka Ji	3.65	4.26

#### 6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected
	H.P. less pumping due to less raw water		

Note :- Total supply of water in last 24 hours i.e. 5.1.2022 -----927.91 MGD

Member (WS)

Copy to: -

23. Pr. Secretary to Lt. Governor
24. P.S. to Chief Minister, Delhi
25. P.S. to Chief Secretary, Delhi
26. Principal Secretary (UD) Govt., of NCT of Delhi
27. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
28. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,  
a. Hudson Lane, Civil Lines ,Delhi-110009
29. CE(WW)
30. CE (East)
31. Dir F & A
32. E.E. (EDP) for uploading on Website
33. Office copy

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/664.60	200	0.6''	35
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		7.5

## PRODUCTION DETAILS TOTAL PRODUCTION : 915.68 MGD

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

## YAMUNA WATER

i)	Chandrawal	98	Wazirabad Pond	89.30	Increase in ammonia
ii)	Wazirabad	124	-Do-	118.62	
iii)	Haiderpur	220	WJC Canal	209.68	
iv)	Nangloi	40	-Do-	39.35	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	21.08	
vi)	Dwarka		WJC Canal	45.36	
vii)	Bawana		WJC Canal	19.11	

## GANGA WATER

vii)	Bhagirathi	100	Upper Ganga Canal	107.64	
viii)	Sonia Vihar	144	-Do-	140.64	
1)	Production of Water Treatment Plants			790.89	

## RECYCLING /PROCESS WASTE WATER PLANTS

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.23	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.30	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	3.26	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			29.79	

## GROUND WATER SOURCES

3)	Production from Ranney wells & Tube wells			95.00	
	Total	(1+2+3)		915.68	

## 5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	4.05
Greater Kailash (N)	4.80	3.35
Deer Park	4.50	4.30
Janak Puri	3.00	3.40
Kalka Ji	3.65	4.26

## 6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e.6.1.2022 -----915.68 MGD

Member (WS)

### Copy to: -

25. Pr. Secretary to Lt. Governor
26. P.S. to Chief Minister, Delhi
27. P.S. to Chief Secretary, Delhi
28. Principal Secretary (UD) Govt., of NCT of Delhi
29. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
30. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
  - a. Hudson Lane, Civil Lines ,Delhi-110009
31. CE(WW)
32. CE (East)

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/664.60	200	0.6''	47
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		7.5

## PRODUCTION DETAILS TOTAL PRODUCTION : 928.04 MGD

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

## YAMUNA WATER

i)	Chandrawal	98	Wazirabad Pond	93.66	
ii)	Wazirabad	124	-Do-	116.90	
iii)	Haiderpur	220	WJC Canal	219.15	
iv)	Nangloi	40	-Do-	43.86	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	21.01	
vi)	Dwarka		WJC Canal	47.70	
vii)	Bawana		WJC Canal	20.00	

## GANGA WATER

vii)	Bhagirathi	100	Upper Ganga Canal	89.33	
viii)	Sonia Vihar	144	-Do-	138.93	
1)	Production of Water Treatment Plants			790.54	

## RECYCLING /PROCESS WASTE WATER PLANTS

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.20	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.30	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	3.20	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			29.70	

## GROUND WATER SOURCES

3)	Production from Ranney wells & Tube wells			95.00	
	Total	(1+2+3)		915.24	

## 5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	3.805
Greater Kailash (N)	4.80	3.04
Deer Park	4.50	4.00
Janak Puri	3.00	3.40
Kalka Ji	3.65	4.26

## 6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e.7.1.2022 -----915.24MGD

Member (WS)

### Copy to: -

1. Pr. Secretary to Lt. Governor
2. P.S. to Chief Minister, Delhi
3. P.S. to Chief Secretary, Delhi
4. Principal Secretary (UD) Govt., of NCT of Delhi
5. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
6. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
  - a. Hudson Lane, Civil Lines ,Delhi-110009
7. CE(WW)
8. CE (East)



Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/664.60	200	0.6''	42
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		7.5

## PRODUCTION DETAILS

TOTAL PRODUCTION : 928.04 MGD

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

## YAMUNA WATER

i)	Chandrawal	98	Wazirabad Pond	93.42	
ii)	Wazirabad	124	-Do-	121.18	
iii)	Haiderpur	220	WJC Canal	219.26	
iv)	Nangloi	40	-Do-	43.70	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	21.59	
vi)	Dwarka		WJC Canal	50.34	
vii)	Bawana		WJC Canal	20.00	

## GANGA WATER

vii)	Bhagirathi	100	Upper Ganga Canal	104.83	
viii)	Sonia Vihar	144	-Do-	140.30	
1)	Production of Water Treatment Plants			814.62	

## RECYCLING /PROCESS WASTE WATER PLANTS

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.25	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.20	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	3.23	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			29.68	

## GROUND WATER SOURCES

3)	Production from Ranney wells & Tube wells			95.00	
	Total	(1+2+3)		939.30	

## 5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	4.45
Greater Kailash (N)	4.80	3.35
Deer Park	4.50	4.40
Janak Puri	3.00	3.40
Kalka Ji	3.65	3.96

## 6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e.8.1.2022 -----915.24MGD

Member (WS)

### Copy to: -

1. Pr. Secretary to Lt. Governor
2. P.S. to Chief Minister, Delhi
3. P.S. to Chief Secretary, Delhi
4. Principal Secretary (UD) Govt., of NCT of Delhi
5. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
6. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
  - a. Hudson Lane, Civil Lines ,Delhi-110009
7. CE(WW)
8. CE (East)

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/665.3	900	2.3''	45
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		7.5

## PRODUCTION DETAILS TOTAL PRODUCTION : 943.85 MGD

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

## YAMUNA WATER

i)	Chandrawal	98	Wazirabad Pond	93.05	
ii)	Wazirabad	124	-Do-	123.35	
iii)	Haiderpur	220	WJC Canal	219.15	
iv)	Nangloi	40	-Do-	43.45	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	21.94	
vi)	Dwarka		WJC Canal	50.39	
vii)	Bawana		WJC Canal	20.02	

## GANGA WATER

vii)	Bhagirathi	100	Upper Ganga Canal	106.98	
viii)	Sonia Vihar	144	-Do-	140.75	
1)	Production of Water Treatment Plants			819.08	

## RECYCLING /PROCESS WASTE WATER PLANTS

i)	Wazirabad	11	Recycled process waste at Wzd. Plant	10.26	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.30	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	3.21	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			29.77	

## GROUND WATER SOURCES

3)	Production from Ranney wells & Tube wells			95.00	
	Total	(1+2+3)		943.85	

## 5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	4.57
Greater Kailash (N)	4.80	3.96
Deer Park	4.50	4.20
Janak Puri	3.00	3.40
Kalka Ji	3.65	4.14

## 6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e.9.1.2022 -----943.85MGD

Member (WS)

### Copy to: -

1. Pr. Secretary to Lt. Governor
2. P.S. to Chief Minister, Delhi
3. P.S. to Chief Secretary, Delhi
4. Principal Secretary (UD) Govt., of NCT of Delhi
5. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
6. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
  - a. Hudson Lane, Civil Lines ,Delhi-110009
7. CE(WW)
8. CE (East)

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/664.80	400	1"	47
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		7.5

## PRODUCTION DETAILS TOTAL PRODUCTION : 929.36 MGD

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

## YAMUNA WATER

i)	Chandrawal	98	Wazirabad Pond	86.60	
ii)	Wazirabad	124	-Do-	123.59	
iii)	Haiderpur	220	WJC Canal	219.26	
iv)	Nangloi	40	-Do-	43.47	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	21.85	
vi)	Dwarka		WJC Canal	42.68	
vii)	Bawana		WJC Canal	20.00	

## GANGA WATER

vii)	Bhagirathi	100	Upper Ganga Canal	106.90	
viii)	Sonia Vihar	144	-Do-	140.39	
1)	Production of Water Treatment Plants			804.74	

## RECYCLING /PROCESS WASTE WATER PLANTS

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.26	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.20	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	3.16	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			29.62	

## GROUND WATER SOURCES

3)	Production from Ranney wells & Tube wells			95.00	
	Total	(1+2+3)		929.36	

## 5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	4.57
Greater Kailash (N)	4.80	3.96
Deer Park	4.50	4.20
Janak Puri	3.00	3.40
Kalka Ji	3.65	3.84

## 6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e.10.1.2022 -----929.36MGD

Member (WS)

### Copy to: -

1. Pr. Secretary to Lt. Governor
2. P.S. to Chief Minister, Delhi
3. P.S. to Chief Secretary, Delhi
4. Principal Secretary (UD) Govt., of NCT of Delhi
5. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
6. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
  - a. Hudson Lane, Civil Lines ,Delhi-110009
7. CE(WW)
8. CE (East)

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/666.70	2800	7"	45
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		7.5

**PRODUCTION DETAILS** **TOTAL PRODUCTION : 936.37 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	95.19	
ii)	Wazirabad	124	-Do-	123.14	
iii)	Haiderpur	220	WJC Canal	219.46	
iv)	Nangloi	40	-Do-	43.26	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	21.57	
vi)	Dwarka		WJC Canal	46.12	
vii)	Bawana		WJC Canal	20.01	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	107.15	
viii)	Sonia Vihar	144	-Do-	135.93	
1)	Production of Water Treatment Plants			811.83	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazirabad	11	Recycled process waste at Wzd. Plant	10.27	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.00	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	3.27	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			29.54	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells			95.00	
	Total	(1+2+3)		936.37	

**5. MAJOR UGRs' LEVELS IN METERS.**

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	4.45
Greater Kailash (N)	4.80	3.04
Deer Park	4.50	4.20
Janak Puri	3.00	3.40
Kalka Ji	3.65	3.35

## 6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e.11.1.2022 -----936.37MGD

Member (WS)

### Copy to: -

1. Pr. Secretary to Lt. Governor
2. P.S. to Chief Minister, Delhi
3. P.S. to Chief Secretary, Delhi
4. Principal Secretary (UD) Govt., of NCT of Delhi
5. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
6. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
  - a. Hudson Lane, Civil Lines ,Delhi-110009
7. CE(WW)
8. CE (East)



Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/664.00	8000	20''	180
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		7.5

## PRODUCTION DETAILS TOTAL PRODUCTION : 859.61 MGD

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

## YAMUNA WATER

i)	Chandrawal	98	Wazirabad Pond	95.33	
ii)	Wazirabad	124	-Do-	72.87	
iii)	Haiderpur	220	WJC Canal	218.68	
iv)	Nangloi	40	-Do-	44.30	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	21.75	
vi)	Dwarka		WJC Canal	50.40	
vii)	Bawana		WJC Canal	16.30	

## GANGA WATER

vii)	Bhagirathi	100	Upper Ganga Canal	107.29	
viii)	Sonia Vihar	144	-Do-	138.22	
1)	Production of Water Treatment Plants			735.14	

## RECYCLING /PROCESS WASTE WATER PLANTS

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.26	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.00	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	3.21	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			29.47	

## GROUND WATER SOURCES

3)	Production from Ranney wells & Tube wells			95.00	
	Total	(1+2+3)		859.61	

## 5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	3.5
Greater Kailash (N)	4.80	3.04
Deer Park	4.50	4.1
Janak Puri	3.00	3.40
Kalka Ji	3.65	4.26

## 6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected
	Bawana line leakage		

Note :- Total supply of water in last 24 hours i.e.12.1.2022 -----859.61MGD

Member (WS)

### Copy to: -

1. Pr. Secretary to Lt. Governor
2. P.S. to Chief Minister, Delhi
3. P.S. to Chief Secretary, Delhi
4. Principal Secretary (UD) Govt., of NCT of Delhi
5. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
6. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
  - a. Hudson Lane, Civil Lines ,Delhi-110009
7. CE(WW)
8. CE (East)

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/667.60	6400	16''	320
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		7.5

## PRODUCTION DETAILS TOTAL PRODUCTION : 928.04 MGD

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

## YAMUNA WATER

i)	Chandrawal	98	Wazirabad Pond	93.98	
ii)	Wazirabad	124	-Do-	119.05	
iii)	Haiderpur	220	WJC Canal	217.15	
iv)	Nangloi	40	-Do-	43.86	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	21.62	
vi)	Dwarka		WJC Canal	50.39	
vii)	Bawana		WJC Canal	20.00	

## GANGA WATER

vii)	Bhagirathi	100	Upper Ganga Canal	137.75	
viii)	Sonia Vihar	144	-Do-	106.85	
1)	Production of Water Treatment Plants			810.65	

## RECYCLING /PROCESS WASTE WATER PLANTS

i)	Wazirabad	11	Recycled process waste at Wzd. Plant	10.21	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.10	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	3.19	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			29.50	

## GROUND WATER SOURCES

3)	Production from Ranney wells & Tube wells			95.00	
	Total	(1+2+3)		935.15	

## 5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	3.805
Greater Kailash (N)	4.80	3.04
Deer Park	4.50	4.20
Janak Puri	3.00	3.40
Kalka Ji	3.65	4.26

## 6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e.13.1.2022 -----935.15MGD

Member (WS)

### Copy to: -

1. Pr. Secretary to Lt. Governor
2. P.S. to Chief Minister, Delhi
3. P.S. to Chief Secretary, Delhi
4. Principal Secretary (UD) Govt., of NCT of Delhi
5. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
6. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
  - a. Hudson Lane, Civil Lines ,Delhi-110009
7. CE(WW)
8. CE (East)

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/667.30	5200	13''	440
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		7.3,6.0

**PRODUCTION DETAILS** **TOTAL PRODUCTION : 927.23 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	95.20	
ii)	Wazirabad	124	-Do-	122.76	
iii)	Haiderpur	220	WJC Canal	210.36	
iv)	Nangloi	40	-Do-	42.71	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	21.33	
vi)	Dwarka		WJC Canal	49.18	
vii)	Bawana		WJC Canal	20.00	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	106.86	
viii)	Sonia Vihar	144	-Do-	134.94	
1)	Production of Water Treatment Plants			803.34	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.18	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	15.50	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	3.21	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			29.70	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells			95.00	
	Total	(1+2+3)		927.23	

**5. MAJOR UGRs' LEVELS IN METERS.**

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	4.45
Greater Kailash (N)	4.80	3.35
Deer Park	4.50	3.35
Janak Puri	3.00	2.80
Kalka Ji	3.65	4.29

## 6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e.14.1.2022 -----927.23MGD

Member (WS)

### Copy to: -

1. Pr. Secretary to Lt. Governor
2. P.S. to Chief Minister, Delhi
3. P.S. to Chief Secretary, Delhi
4. Principal Secretary (UD) Govt., of NCT of Delhi
5. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
6. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
  - a. Hudson Lane, Civil Lines ,Delhi-110009
7. CE(WW)
8. CE (East)

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/667.00	4000	10''	440
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		7.8

## PRODUCTION DETAILS

TOTAL PRODUCTION : 938.49 MGD

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

## YAMUNA WATER

i)	Chandrawal	98	Wazirabad Pond	94.66	
ii)	Wazirabad	124	-Do-	123.86	
iii)	Haiderpur	220	WJC Canal	217.88	
iv)	Nangloi	40	-Do-	44.56	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	21.32	
vi)	Dwarka		WJC Canal	48.98	
vii)	Bawana		WJC Canal	20.00	

## GANGA WATER

vii)	Bhagirathi	100	Upper Ganga Canal	107.63	
viii)	Sonia Vihar	144	-Do-	134.99	
1)	Production of Water Treatment Plants			813.88	

## RECYCLING /PROCESS WASTE WATER PLANTS

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.23	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.20	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	3.18	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			29.61	

## GROUND WATER SOURCES

3)	Production from Ranney wells & Tube wells			95.00	
	Total	(1+2+3)		938.49	

## 5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	4.45
Greater Kailash (N)	4.80	3.35
Deer Park	4.50	4.10
Janak Puri	3.00	3.40
Kalka Ji	3.65	3.84

## 6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e.15.1.2022 -----938.49MGD

Member (WS)

### Copy to: -

1. Pr. Secretary to Lt. Governor
2. P.S. to Chief Minister, Delhi
3. P.S. to Chief Secretary, Delhi
4. Principal Secretary (UD) Govt., of NCT of Delhi
5. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
6. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
  - a. Hudson Lane, Civil Lines ,Delhi-110009
7. CE(WW)
8. CE (East)



Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/667.90	3600	9"	410
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		7

## PRODUCTION DETAILS TOTAL PRODUCTION : 956.62 MGD

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

## YAMUNA WATER

i)	Chandrawal	98	Wazirabad Pond	94.98	
ii)	Wazirabad	124	-Do-	133.88	
iii)	Haiderpur	220	WJC Canal	219.36	
iv)	Nangloi	40	-Do-	43.83	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	21.58	
vi)	Dwarka		WJC Canal	50.35	
vii)	Bawana		WJC Canal	20.01	

## GANGA WATER

vii)	Bhagirathi	100	Upper Ganga Canal	107.42	
viii)	Sonia Vihar	144	-Do-	140.47	
1)	Production of Water Treatment Plants			831.88	

## RECYCLING /PROCESS WASTE WATER PLANTS

i)	Wazirabad	11	Recycled process waste at Wzd. Plant	10.26	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.10	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	3.38	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			29.74	

## GROUND WATER SOURCES

3)	Production from Ranney wells & Tube wells			95.00	
	Total	(1+2+3)		956.62	

## 5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	4.45
Greater Kailash (N)	4.80	3.35
Deer Park	4.50	4.00
Janak Puri	3.00	2.80
Kalka Ji	3.65	3.40

## 6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e.16.1.2022 -----956.62MGD

Member (WS)

### Copy to: -

1. Pr. Secretary to Lt. Governor
2. P.S. to Chief Minister, Delhi
3. P.S. to Chief Secretary, Delhi
4. Principal Secretary (UD) Govt., of NCT of Delhi
5. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
6. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
  - a. Hudson Lane, Civil Lines ,Delhi-110009
7. CE(WW)
8. CE (East)

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/666.80	3200	8"	182
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		7

## PRODUCTION DETAILS

TOTAL PRODUCTION : 921.69 MGD

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

## YAMUNA WATER

i)	Chandrawal	98	Wazirabad Pond	94.61	
ii)	Wazirabad	124	-Do-	123.77	
iii)	Haiderpur	220	WJC Canal	214.74	
iv)	Nangloi	40	-Do-	43.94	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	21.78	
vi)	Dwarka		WJC Canal	50.02	
vii)	Bawana		WJC Canal	20.00	

## GANGA WATER

vii)	Bhagirathi	100	Upper Ganga Canal	89.30	
viii)	Sonia Vihar	144	-Do-	140.57	
1)	Production of Water Treatment Plants			798.73	

## RECYCLING /PROCESS WASTE WATER PLANTS

i)	Wazirabad	11	Recycled process waste at Wzd. Plant	8.57	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.10	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	3.29	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			27.96	

## GROUND WATER SOURCES

3)	Production from Ranney wells & Tube wells			95.00	
	Total	(1+2+3)		921.69	

## 5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	4.45
Greater Kailash (N)	4.80	3.65
Deer Park	4.50	4.20
Janak Puri	3.00	3.40
Kalka Ji	3.65	4.54

## 6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e.17.1.2022 -----921.69MGD

Member (WS)

### Copy to: -

1. Pr. Secretary to Lt. Governor
2. P.S. to Chief Minister, Delhi
3. P.S. to Chief Secretary, Delhi
4. Principal Secretary (UD) Govt., of NCT of Delhi
5. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
6. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
  - a. Hudson Lane, Civil Lines ,Delhi-110009
7. CE(WW)
8. CE (East)

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/667.80	3200	8"	120
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		7

## PRODUCTION DETAILS TOTAL PRODUCTION : 914.19 MGD

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

## YAMUNA WATER

i)	Chandrawal	98	Wazirabad Pond	94.67	
ii)	Wazirabad	124	-Do-	123.84	
iii)	Haiderpur	220	WJC Canal	219.25	
iv)	Nangloi	40	-Do-	40.36	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	21.50	
vi)	Dwarka		WJC Canal	44.71	
vii)	Bawana		WJC Canal	20.00	

## GANGA WATER

vii)	Bhagirathi	100	Upper Ganga Canal	86.87	
viii)	Sonia Vihar	144	-Do-	140.44	
1)	Production of Water Treatment Plants			791.64	

## RECYCLING /PROCESS WASTE WATER PLANTS

i)	Wazirabad	11	Recycled process waste at Wzd. Plant	8.35	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.20	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	3.00	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			27.55	

## GROUND WATER SOURCES

3)	Production from Ranney wells & Tube wells			95.00	
	Total	(1+2+3)		914.19	

## 5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	4.45
Greater Kailash (N)	4.80	3.65
Deer Park	4.50	4.20
Janak Puri	3.00	3.40
Kalka Ji	3.65	3.96

## 6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected
	B.P to jal vihar mzin 1200mm line close due to line repair work	18.1.22(12.30pm to 1.20pm)19.1.22	

Note :- Total supply of water in last 24 hours i.e.18.1.2022 -----914.19MGD

Member (WS)

### Copy to: -

1. Pr. Secretary to Lt. Governor
2. P.S. to Chief Minister, Delhi
3. P.S. to Chief Secretary, Delhi
4. Principal Secretary (UD) Govt., of NCT of Delhi
5. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
6. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
  - a. Hudson Lane, Civil Lines ,Delhi-110009
7. CE(WW)
8. CE (East)