

**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/

Date: 01.03.2020

**WATER PRODUCTION REPORT**

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/665.00	600	1.6'	32
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		7.5

**PRODUCTION DETAILS**

**TOTAL PRODUCTION : 916.00 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
--------------------------	-----------------------------------	------------------	-----------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	94	
ii)	Wazirabad	124	-Do-	123.50	
iii)	Haiderpur	220	WJC Canal	208.50	
iv)	Nangloi	40	-Do-	43	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	20	
vi)	Dwarka		WJC Canal	50.5	
vii)	Bawana		WJC Canal	15.5	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	105.5	
viii)	Sonia Vihar	144	-Do-	138.00	
1)	Production of Water Treatment Plants			798.50	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	5	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			31.5	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells		86	
	Total	(1+2+3)	916.00	

## 5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	4.29
Greater Kailash (N)	4.80	3.65
Deer Park	4.50	3.90
Janak Puri	3.00	3.45
Kalka Ji	3.65	4.26

## 6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected
1.	H.P. II Delhi Cantt. 1000mm line repair work	1.30 pm to 3.05 pm	
2.	Sonia Vihar maintenance work at plant	10.20 am to 11.00 am	
3.	Bawana 900 mm line repair work	4.00 pm to till now	

Note :- Total supply of water in last 24 hours i.e. 29.02.2020 -----928.00 MGD

Member (WS)

Copy to: -

1. Pr. Secretary to Lt. Governor
2. P.S. to Chief Minister, Delhi
3. P.S. to Chief Secretary, Delhi
4. Principal Secretary (UD) Govt., of NCT of Delhi
5. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
6. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
  - a. Hudson Lane, Civil Lines ,Delhi-110009
7. CE(WW)
8. CE (East)
9. Dir F & A
10. E.E. (EDP) for uploading on Website
11. Office copy

**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/

Date: 02.03.2020

**WATER PRODUCTION REPORT**

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/665.00	600	1.6'	32
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		7.5

**PRODUCTION DETAILS**

**TOTAL PRODUCTION : 924.50 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
--------------------------	-----------------------------------	------------------	-----------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	94	
ii)	Wazirabad	124	-Do-	123.50	
iii)	Haiderpur	220	WJC Canal	212.00	
iv)	Nangloi	40	-Do-	43	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	21.5	
vi)	Dwarka		WJC Canal	50.5	
vii)	Bawana		WJC Canal	16	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	106.00	
viii)	Sonia Vihar	144	-Do-	140.50	
1)	Production of Water Treatment Plants			807.00	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.5	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	5	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			31.5	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells		86	
	Total	(1+2+3)	924.50	

## 5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	4.29
Greater Kailash (N)	4.80	3.65
Deer Park	4.50	4.00
Janak Puri	3.00	3.45
Kalka Ji	3.65	4.30

## 6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected
1.	H.P. 1000 mm Palam main line repair work		

Note :- Total supply of water in last 24 hours i.e..01.03.2020 -----924.50 MGD

Member (WS)

Copy to: -

1. Pr. Secretary to Lt. Governor
2. P.S. to Chief Minister, Delhi
3. P.S. to Chief Secretary, Delhi
4. Principal Secretary (UD) Govt., of NCT of Delhi
5. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
6. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,  
a. Hudson Lane, Civil Lines ,Delhi-110009
7. CE(WW)
8. CE (East)

**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/

Date: 03.03.2020

**WATER PRODUCTION REPORT**

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/665.00	600	1.6'	29
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		7.6

**PRODUCTION DETAILS**

**TOTAL PRODUCTION : 926.50 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
--------------------------	-----------------------------------	------------------	-----------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	94	
ii)	Wazirabad	124	-Do-	123.50	
iii)	Haiderpur	220	WJC Canal	213.50	
iv)	Nangloi	40	-Do-	43	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	21.5	
vi)	Dwarka		WJC Canal	50.5	
vii)	Bawana		WJC Canal	16	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	106.5	
viii)	Sonia Vihar	144	-Do-	140.50	
1)	Production of Water Treatment Plants			809.00	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.5	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	5	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			31.5	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells		86	
	Total	(1+2+3)	926.50	

## 5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	4.29
Greater Kailash (N)	4.80	3.65
Deer Park	4.50	3.90
Janak Puri	3.00	3.45
Kalka Ji	3.65	4.54

## 6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e. 02.03.2020 -----926.50 MGD

Member (WS)

Copy to: -

1. Pr. Secretary to Lt. Governor
2. P.S. to Chief Minister, Delhi
3. P.S. to Chief Secretary, Delhi
4. Principal Secretary (UD) Govt., of NCT of Delhi
5. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
6. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,  
a. Hudson Lane, Civil Lines ,Delhi-110009
7. CE(WW)
8. CE (East)
9. Dir F & A
10. E.E. (EDP) for uploading on Website
11. Office copy

**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/

Date: 04.03.2020

**WATER PRODUCTION REPORT**

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/664.80	400	1'	29
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		6.3

**PRODUCTION DETAILS**

**TOTAL PRODUCTION : 923.50 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
--------------------------	-----------------------------------	------------------	-----------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	91	
ii)	Wazirabad	124	-Do-	123.50	
iii)	Haiderpur	220	WJC Canal	213.50	
iv)	Nangloi	40	-Do-	43	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	22	
vi)	Dwarka		WJC Canal	50	
vii)	Bawana		WJC Canal	15.5	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	106.50	
viii)	Sonia Vihar	144	-Do-	141.00	
1)	Production of Water Treatment Plants			806.00	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.5	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	5	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			31.5	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells		86	
	Total	(1+2+3)	923.50	

## 5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	4.20
Greater Kailash (N)	4.80	3.65
Deer Park	4.50	4.00
Janak Puri	3.00	3.45
Kalka Ji	3.65	4.26

## 6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e..03.03.2020 -----923.50 MGD

Member (WS)

Copy to: -

1. Pr. Secretary to Lt. Governor
2. P.S. to Chief Minister, Delhi
3. P.S. to Chief Secretary, Delhi
4. Principal Secretary (UD) Govt., of NCT of Delhi
5. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
6. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,  
a. Hudson Lane, Civil Lines ,Delhi-110009
7. CE(WW)
8. CE (East)



**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/

Date: 05.03.2020

**WATER PRODUCTION REPORT**

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/664.80	400	1'	30
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		7.6

**PRODUCTION DETAILS**

**TOTAL PRODUCTION : 925.50 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
--------------------------	-----------------------------------	------------------	-----------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	91.5	
ii)	Wazirabad	124	-Do-	123.50	
iii)	Haiderpur	220	WJC Canal	213.50	
iv)	Nangloi	40	-Do-	43	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	22	
vi)	Dwarka		WJC Canal	50.5	
vii)	Bawana		WJC Canal	16.5	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	106.5	
viii)	Sonia Vihar	144	-Do-	141.00	
1)	Production of Water Treatment Plants			<b>808.00</b>	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.5	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	5	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			<b>31.5</b>	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells		<b>86</b>	
	Total	(1+2+3)	<b>925.50</b>	

## 5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	4.11
Greater Kailash (N)	4.80	3.65
Deer Park	4.50	4.10
Janak Puri	3.00	3.45
Kalka Ji	3.65	4.14

## 6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e. 04.03.2020 -----925.50 MGD

Member (WS)

Copy to: -

1. Pr. Secretary to Lt. Governor
2. P.S. to Chief Minister, Delhi
3. P.S. to Chief Secretary, Delhi
4. Principal Secretary (UD) Govt., of NCT of Delhi
5. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
6. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,  
a. Hudson Lane, Civil Lines ,Delhi-110009
7. CE(WW)
8. CE (East)
9. Dir F & A
10. E.E. (EDP) for uploading on Website
11. Office copy

**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/

Date: 06.03.2020

**WATER PRODUCTION REPORT**

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/665.00	600	1.6'	28
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		7.0,4.8

**PRODUCTION DETAILS**

**TOTAL PRODUCTION : 925.50 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
--------------------------	-----------------------------------	------------------	-----------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	91	
ii)	Wazirabad	124	-Do-	123.50	
iii)	Haiderpur	220	WJC Canal	213.50	
iv)	Nangloi	40	-Do-	43	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	22	
vi)	Dwarka		WJC Canal	50	
vii)	Bawana		WJC Canal	18	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	106.00	
viii)	Sonia Vihar	144	-Do-	141.00	
1)	Production of Water Treatment Plants			808.00	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.5	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	5	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			31.5	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells		86	
	Total	(1+2+3)	925.50	

**5. MAJOR UGRs' LEVELS IN METERS.**

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	4.11
Greater Kailash (N)	4.80	3.65
Deer Park	4.50	4.10
Janak Puri	3.00	3.45
Kalka Ji	3.65	4.57

**6. TRANSMISSION MAIN**

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

**Note :- Total supply of water in last 24 hours i.e..05.03.2020 -----925.50 MGD**

**Member (WS)**

**Copy to: -**

1. Pr. Secretary to Lt. Governor
2. P.S. to Chief Minister, Delhi
3. P.S. to Chief Secretary, Delhi
4. Principal Secretary (UD) Govt., of NCT of Delhi
5. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
6. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,  
a. Hudson Lane, Civil Lines ,Delhi-110009
7. CE(WW)
8. CE (East)

**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/

Date: 07.03.2020

**WATER PRODUCTION REPORT**

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/665.00			
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		7.0,4.8

**PRODUCTION DETAILS**

**TOTAL PRODUCTION : 925.50 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
--------------------------	-----------------------------------	------------------	-----------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	91.5	
ii)	Wazirabad	124	-Do-	123.50	
iii)	Haiderpur	220	WJC Canal	213.50	
iv)	Nangloi	40	-Do-	43	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	21	
vi)	Dwarka		WJC Canal	50.5	
vii)	Bawana		WJC Canal	19	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	106.5	
viii)	Sonia Vihar	144	-Do-	141.00	
1)	Production of Water Treatment Plants			809.50	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.5	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	5	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			31.5	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells		86	
	Total	(1+2+3)	927.00	

**5. MAJOR UGRs' LEVELS IN METERS.**

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	4.11
Greater Kailash (N)	4.80	3.65
Deer Park	4.50	4.10
Janak Puri	3.00	3.45
Kalka Ji	3.65	4.29

**6. TRANSMISSION MAIN**

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e. 06.03.2020 -----927.00 MGD

Member (WS)

Copy to: -

12. Pr. Secretary to Lt. Governor
13. P.S. to Chief Minister, Delhi
14. P.S. to Chief Secretary, Delhi
15. Principal Secretary (UD) Govt., of NCT of Delhi
16. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
17. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,  
a. Hudson Lane, Civil Lines ,Delhi-110009
18. CE(WW)
19. CE (East)
20. Dir F & A
21. E.E. (EDP) for uploading on Website
22. Office copy

**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/

Date: 08.03.2020

**WATER PRODUCTION REPORT**

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/665.20	800	2'	28
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		7

**PRODUCTION DETAILS**

**TOTAL PRODUCTION : 922.00 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
--------------------------	-----------------------------------	------------------	-----------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	91.5	
ii)	Wazirabad	124	-Do-	123.50	
iii)	Haiderpur	220	WJC Canal	213.50	
iv)	Nangloi	40	-Do-	43	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	18	
vi)	Dwarka		WJC Canal	50	
vii)	Bawana		WJC Canal	18	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	106.00	
viii)	Sonia Vihar	144	-Do-	141.00	
1)	Production of Water Treatment Plants			804.50	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.5	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	5	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			31.5	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells		86	
	Total	(1+2+3)	922.00	

**5. MAJOR UGRs' LEVELS IN METERS.**

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	4.11
Greater Kailash (N)	4.80	3.65
Deer Park	4.50	4.10
Janak Puri	3.00	3.45
Kalka Ji	3.65	3.23

**6. TRANSMISSION MAIN**

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e..07.03.2020 -----922.00 MGD

Member (WS)

Copy to: -

9. Pr. Secretary to Lt. Governor
10. P.S. to Chief Minister, Delhi
11. P.S. to Chief Secretary, Delhi
12. Principal Secretary (UD) Govt., of NCT of Delhi
13. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
14. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,  
a. Hudson Lane, Civil Lines ,Delhi-110009
15. CE(WW)
16. CE (East)



**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/

Date: 09.03.2020

**WATER PRODUCTION REPORT**

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/665.20	800	2'	32
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		6.8

**PRODUCTION DETAILS**

**TOTAL PRODUCTION : 919.00 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
--------------------------	-----------------------------------	------------------	-----------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	91.5	
ii)	Wazirabad	124	-Do-	123.50	
iii)	Haiderpur	220	WJC Canal	213.50	
iv)	Nangloi	40	-Do-	43	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	22	
vi)	Dwarka		WJC Canal	50	
vii)	Bawana		WJC Canal	19.5	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	107	
viii)	Sonia Vihar	144	-Do-	132.00	
1)	Production of Water Treatment Plants			802.00	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.5	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.5	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			31	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells		86	
	Total	(1+2+3)	919.00	

**5. MAJOR UGRs' LEVELS IN METERS.**

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	4.11
Greater Kailash (N)	4.80	3.65
Deer Park	4.50	4.00
Janak Puri	3.00	3.45
Kalka Ji	3.65	4.29

**6. TRANSMISSION MAIN**

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected
1.	Sonia vihar line leakage	4.30 am to 7.00 am	
2.	Bhagirathi plant leakage	6.40 pm to 8.20 pm	

**Note :- Total supply of water in last 24 hours i.e. 08.03.2020 -----919.00 MGD**

**Member (WS)**

**Copy to: -**

23. Pr. Secretary to Lt. Governor
24. P.S. to Chief Minister, Delhi
25. P.S. to Chief Secretary, Delhi
26. Principal Secretary (UD) Govt., of NCT of Delhi
27. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
28. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,  
a. Hudson Lane, Civil Lines ,Delhi-110009
29. CE(WW)
30. CE (East)
31. Dir F & A
32. E.E. (EDP) for uploading on Website
33. Office copy

**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/

Date: 10.03.2020

**WATER PRODUCTION REPORT**

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/666.20	1800	4.6'	31
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		7

**PRODUCTION DETAILS**

**TOTAL PRODUCTION : 929.50 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
--------------------------	-----------------------------------	------------------	-----------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	92	
ii)	Wazirabad	124	-Do-	123.50	
iii)	Haiderpur	220	WJC Canal	213.50	
iv)	Nangloi	40	-Do-	43	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	22	
vi)	Dwarka		WJC Canal	50.5	
vii)	Bawana		WJC Canal	19.5	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	107.5	
viii)	Sonia Vihar	144	-Do-	141.00	
1)	Production of Water Treatment Plants			812.50	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.5	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.5	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			31	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells		86	
	Total	(1+2+3)	929.50	

## 5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	4.11
Greater Kailash (N)	4.80	3.65
Deer Park	4.50	3.90
Janak Puri	3.00	3.45
Kalka Ji	3.65	4.54

## 6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e. 09.03.2020 -----929.50 MGD

Member (WS)

Copy to: -

1. Pr. Secretary to Lt. Governor
2. P.S. to Chief Minister, Delhi
3. P.S. to Chief Secretary, Delhi
4. Principal Secretary (UD) Govt., of NCT of Delhi
5. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
6. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,  
a. Hudson Lane, Civil Lines ,Delhi-110009
7. CE(WW)
8. CE (East)
9. Dir F & A
10. E.E. (EDP) for uploading on Website
11. Office copy

**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/

Date: 11.03.2020

**WATER PRODUCTION REPORT**

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/667.20	4800	12'	32
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		7

**PRODUCTION DETAILS**

**TOTAL PRODUCTION : 928.00 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
--------------------------	-----------------------------------	------------------	-----------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	93	
ii)	Wazirabad	124	-Do-	123.50	
iii)	Haiderpur	220	WJC Canal	213.50	
iv)	Nangloi	40	-Do-	43	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	22	
vi)	Dwarka		WJC Canal	50.5	
vii)	Bawana		WJC Canal	19	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	106.50	
viii)	Sonia Vihar	144	-Do-	139.50	
1)	Production of Water Treatment Plants			810.50	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.5	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	5	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			31.5	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells		86	
	Total	(1+2+3)	928.00	

## 5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	3.19
Greater Kailash (N)	4.80	3.04
Deer Park	4.50	4.10
Janak Puri	3.00	3.45
Kalka Ji	3.65	4.57

## 6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e..10.03.2020 -----928.00 MGD

Member (WS)

Copy to: -

1. Pr. Secretary to Lt. Governor
2. P.S. to Chief Minister, Delhi
3. P.S. to Chief Secretary, Delhi
4. Principal Secretary (UD) Govt., of NCT of Delhi
5. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
6. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,  
a. Hudson Lane, Civil Lines ,Delhi-110009
7. CE(WW)
8. CE (East)

**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/

Date: 12.03.2020

**WATER PRODUCTION REPORT**

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/667.50	6000	15'	29
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		6.4,4.7

**PRODUCTION DETAILS**

**TOTAL PRODUCTION : 909.00 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
--------------------------	-----------------------------------	------------------	-----------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	83	Increase in ammonia level
ii)	Wazirabad	124	-Do-	113.00	Increase in ammonia level
iii)	Haiderpur	220	WJC Canal	213.50	
iv)	Nangloi	40	-Do-	43	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	22	
vi)	Dwarka		WJC Canal	50	
vii)	Bawana		WJC Canal	19.5	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	106.5	
viii)	Sonia Vihar	144	-Do-	141.00	
1)	Production of Water Treatment Plants			791.50	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.5	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	5	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			31.5	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells		86	
	Total	(1+2+3)	909.00	

## 5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	3.68
Greater Kailash (N)	4.80	3.35
Deer Park	4.50	3.90
Janak Puri	3.00	3.45
Kalka Ji	3.65	3.84

## 6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected
1.	Chandrawal I & II less pumping due to Increase in ammonia level		

Note :- Total supply of water in last 24 hours i.e. 11.03.2020 -----909.00 MGD

Member (WS)

Copy to: -

12. Pr. Secretary to Lt. Governor
13. P.S. to Chief Minister, Delhi
14. P.S. to Chief Secretary, Delhi
15. Principal Secretary (UD) Govt., of NCT of Delhi
16. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
17. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,  
a. Hudson Lane, Civil Lines ,Delhi-110009
18. CE(WW)
19. CE (East)
20. Dir F & A
21. E.E. (EDP) for uploading on Website
22. Office copy



**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/

Date: 13.03.2020

**WATER PRODUCTION REPORT**

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/667.20	4800	12'	32
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		6.9,4.3

**PRODUCTION DETAILS**

**TOTAL PRODUCTION : 908.50 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
--------------------------	-----------------------------------	------------------	-----------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	82	
ii)	Wazirabad	124	-Do-	113.00	
iii)	Haiderpur	220	WJC Canal	213.00	
iv)	Nangloi	40	-Do-	43	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	22	
vi)	Dwarka		WJC Canal	50.5	
vii)	Bawana		WJC Canal	19.5	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	106.50	
viii)	Sonia Vihar	144	-Do-	141.50	
1)	Production of Water Treatment Plants			791.00	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.5	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	5	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			31.5	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells		86	
	Total	(1+2+3)	908.50	

**5. MAJOR UGRs' LEVELS IN METERS.**

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	3.84
Greater Kailash (N)	4.80	3.35
Deer Park	4.50	3.70
Janak Puri	3.00	3.45
Kalka Ji	3.65	4.26

**6. TRANSMISSION MAIN**

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected
1.	Chandrawal I & II less pumping due to Increase in ammonia level		

Note :- Total supply of water in last 24 hours i.e..12.03.2020 -----908.50 MGD

Member (WS)

Copy to: -

9. Pr. Secretary to Lt. Governor
10. P.S. to Chief Minister, Delhi
11. P.S. to Chief Secretary, Delhi
12. Principal Secretary (UD) Govt., of NCT of Delhi
13. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
14. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,  
a. Hudson Lane, Civil Lines ,Delhi-110009
15. CE(WW)
16. CE (East)

**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/

Date: 14.03.2020

**WATER PRODUCTION REPORT**

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/666.70	2800	1'	30
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		7.4,4.8

**PRODUCTION DETAILS**

**TOTAL PRODUCTION : 924.00 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
--------------------------	-----------------------------------	------------------	-----------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	91.5	
ii)	Wazirabad	124	-Do-	123.50	
iii)	Haiderpur	220	WJC Canal	209.00	
iv)	Nangloi	40	-Do-	43	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	22	
vi)	Dwarka		WJC Canal	50.5	
vii)	Bawana		WJC Canal	19.5	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	106.5	
viii)	Sonia Vihar	144	-Do-	141.00	
1)	Production of Water Treatment Plants			806.50	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.5	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.5	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			31.5	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells		86	
	Total	(1+2+3)	924.00	

## 5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	4.11
Greater Kailash (N)	4.80	3.35
Deer Park	4.50	3.90
Janak Puri	3.00	3.45
Kalka Ji	3.65	4.29

## 6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e. 13.03.2020 -----924.00 MGD

Member (WS)

Copy to: -

1. Pr. Secretary to Lt. Governor
2. P.S. to Chief Minister, Delhi
3. P.S. to Chief Secretary, Delhi
4. Principal Secretary (UD) Govt., of NCT of Delhi
5. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
6. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,  
a. Hudson Lane, Civil Lines ,Delhi-110009
7. CE(WW)
8. CE (East)
9. Dir F & A
10. E.E. (EDP) for uploading on Website
11. Office copy

**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/

Date: 15.03.2020

**WATER PRODUCTION REPORT**

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/666.70	2800	7'	30
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		7.5

**PRODUCTION DETAILS**

**TOTAL PRODUCTION : 928.00 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
--------------------------	-----------------------------------	------------------	-----------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	91.5	
ii)	Wazirabad	124	-Do-	123.50	
iii)	Haiderpur	220	WJC Canal	213.50	
iv)	Nangloi	40	-Do-	43	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	22	
vi)	Dwarka		WJC Canal	50.5	
vii)	Bawana		WJC Canal	19	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	106.50	
viii)	Sonia Vihar	144	-Do-	141.00	
1)	Production of Water Treatment Plants			810.50	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.5	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	5	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			31.5	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells		86	
	Total	(1+2+3)	928.00	

## 5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	4.11
Greater Kailash (N)	4.80	3.65
Deer Park	4.50	3.80
Janak Puri	3.00	3.45
Kalka Ji	3.65	4.54

## 6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e..14.03.2020 -----928.00 MGD

Member (WS)

Copy to: -

1. Pr. Secretary to Lt. Governor
2. P.S. to Chief Minister, Delhi
3. P.S. to Chief Secretary, Delhi
4. Principal Secretary (UD) Govt., of NCT of Delhi
5. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
6. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,  
a. Hudson Lane, Civil Lines ,Delhi-110009
7. CE(WW)
8. CE (East)

**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/

Date: 16.03.2020

**WATER PRODUCTION REPORT**

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/669.70	17600	44'	750
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		7.8,4.9

**PRODUCTION DETAILS**

**TOTAL PRODUCTION : 926.50 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
--------------------------	-----------------------------------	------------------	-----------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	91.5	
ii)	Wazirabad	124	-Do-	123.50	
iii)	Haiderpur	220	WJC Canal	213.50	
iv)	Nangloi	40	-Do-	43	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	22	
vi)	Dwarka		WJC Canal	50.5	
vii)	Bawana		WJC Canal	19	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	106.5	
viii)	Sonia Vihar	144	-Do-	139.50	
1)	Production of Water Treatment Plants			809.00	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.5	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	5	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			31.5	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells		86	
	Total	(1+2+3)	926.50	

**5. MAJOR UGRs' LEVELS IN METERS.**

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	4.11
Greater Kailash (N)	4.80	3.35
Deer Park	4.50	4.00
Janak Puri	3.00	3.45
Kalka Ji	3.65	4.29

**6. TRANSMISSION MAIN**

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected
1.	Sonia Vihar Tahirpur line flow very low		

Note :- Total supply of water in last 24 hours i.e. 15.03.2020 -----926.50 MGD

Member (WS)

Copy to: -

12. Pr. Secretary to Lt. Governor
13. P.S. to Chief Minister, Delhi
14. P.S. to Chief Secretary, Delhi
15. Principal Secretary (UD) Govt., of NCT of Delhi
16. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
17. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,  
a. Hudson Lane, Civil Lines ,Delhi-110009
18. CE(WW)
19. CE (East)
20. Dir F & A
21. E.E. (EDP) for uploading on Website
22. Office copy



**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/

Date: 17.03.2020

**WATER PRODUCTION REPORT**

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/666.00	14400	36'	1000
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		7.3,4.3

**PRODUCTION DETAILS**

**TOTAL PRODUCTION : 870.50 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
--------------------------	-----------------------------------	------------------	-----------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	91.5	
ii)	Wazirabad	124	-Do-	123.50	
iii)	Haiderpur	220	WJC Canal	213.50	
iv)	Nangloi	40	-Do-	42.5	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	22	
vi)	Dwarka		WJC Canal	50	
vii)	Bawana		WJC Canal	18.5	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	105.50	
viii)	Sonia Vihar	144	-Do-	86	
1)	Production of Water Treatment Plants			753.00	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.5	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	5	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			31.5	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells		86	
	Total	(1+2+3)	870.50	

**5. MAJOR UGRs' LEVELS IN METERS.**

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	4.11
Greater Kailash (N)	4.80	1.52
Deer Park	4.50	3.80
Janak Puri	3.00	3.45
Kalka Ji	3.65	3.65

**6. TRANSMISSION MAIN**

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected
1.	Sonia Vihar Tahirpur line flow very low	9.10 am to 12.45 pm	

**Note :- Total supply of water in last 24 hours i.e..16.03.2020 -----870.50 MGD**

**Member (WS)**

**Copy to: -**

9. Pr. Secretary to Lt. Governor
10. P.S. to Chief Minister, Delhi
11. P.S. to Chief Secretary, Delhi
12. Principal Secretary (UD) Govt., of NCT of Delhi
13. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
14. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,  
a. Hudson Lane, Civil Lines ,Delhi-110009
15. CE(WW)
16. CE (East)

**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/

Date: 18.03.2020

**WATER PRODUCTION REPORT**

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/668.30	9200	23'	930
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		6.4,4.3

**PRODUCTION DETAILS**

**TOTAL PRODUCTION : 925.50 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
--------------------------	-----------------------------------	------------------	-----------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	91	
ii)	Wazirabad	124	-Do-	123.50	
iii)	Haiderpur	220	WJC Canal	213.50	
iv)	Nangloi	40	-Do-	43	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	22	
vi)	Dwarka		WJC Canal	50.5	
vii)	Bawana		WJC Canal	19	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	106	
viii)	Sonia Vihar	144	-Do-	139.50	
1)	Production of Water Treatment Plants			808.00	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.5	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	5	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			31.5	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells		86	
	Total	(1+2+3)	925.50	

**5. MAJOR UGRs' LEVELS IN METERS.**

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	4.11
Greater Kailash (N)	4.80	3.65
Deer Park	4.50	4.10
Janak Puri	3.00	3.45
Kalka Ji	3.65	4.14

**6. TRANSMISSION MAIN**

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Afected
1.			

Note :- Total supply of water in last 24 hours i.e. 17.03.2020 -----925.50 MGD

Member (WS)

Copy to: -

23. Pr. Secretary to Lt. Governor
24. P.S. to Chief Minister, Delhi
25. P.S. to Chief Secretary, Delhi
26. Principal Secretary (UD) Govt., of NCT of Delhi
27. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
28. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,  
a. Hudson Lane, Civil Lines ,Delhi-110009
29. CE(WW)
30. CE (East)
31. Dir F & A
32. E.E. (EDP) for uploading on Website
33. Office copy

**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/

Date: 19.03.2020

**WATER PRODUCTION REPORT**

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/664.40	9600	24'	320
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		7.4

**PRODUCTION DETAILS**

**TOTAL PRODUCTION : 928.50 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
--------------------------	-----------------------------------	------------------	-----------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	91.5	
ii)	Wazirabad	124	-Do-	123.50	
iii)	Haiderpur	220	WJC Canal	213.50	
iv)	Nangloi	40	-Do-	43	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	22	
vi)	Dwarka		WJC Canal	50.5	
vii)	Bawana		WJC Canal	19	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	106.50	
viii)	Sonia Vihar	144	-Do-	141.50	
1)	Production of Water Treatment Plants			811.00	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.5	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	5	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			31.5	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells		86	
	Total	(1+2+3)	928.50	

**5. MAJOR UGRs' LEVELS IN METERS.**

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	4.11
Greater Kailash (N)	4.80	3.35
Deer Park	4.50	3.80
Janak Puri	3.00	3.45
Kalka Ji	3.65	4.14

**6. TRANSMISSION MAIN**

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected
1.			

**Note :- Total supply of water in last 24 hours i.e..18.03.2020 -----925.50 MGD**

**Member (WS)**

**Copy to: -**

17. Pr. Secretary to Lt. Governor
18. P.S. to Chief Minister, Delhi
19. P.S. to Chief Secretary, Delhi
20. Principal Secretary (UD) Govt., of NCT of Delhi
21. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
22. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,  
a. Hudson Lane, Civil Lines ,Delhi-110009
23. CE(WW)
24. CE (East)

**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/

Date: 20.03.2020

**WATER PRODUCTION REPORT**

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/667.80	7200	18'	230
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		6.9,4.3

**PRODUCTION DETAILS**

**TOTAL PRODUCTION : 915.00 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
--------------------------	-----------------------------------	------------------	-----------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	87.5	
ii)	Wazirabad	124	-Do-	123.50	
iii)	Haiderpur	220	WJC Canal	206.00	
iv)	Nangloi	40	-Do-	43	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	22	
vi)	Dwarka		WJC Canal	50	
vii)	Bawana		WJC Canal	18	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	106	
viii)	Sonia Vihar	144	-Do-	141.50	
1)	Production of Water Treatment Plants			<b>797.50</b>	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.5	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	5	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			<b>31.5</b>	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells		<b>86</b>	
	Total	(1+2+3)	<b>915.00</b>	

**5. MAJOR UGRs' LEVELS IN METERS.**

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	4.27
Greater Kailash (N)	4.80	3.66
Deer Park	4.50	4.00
Janak Puri	3.00	3.45
Kalka Ji	3.65	4.27

**6. TRANSMISSION MAIN**

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected
1.			

Note :- Total supply of water in last 24 hours i.e. 19.03.2020 -----915.00 MGD

Member (WS)

Copy to: -

34. Pr. Secretary to Lt. Governor
35. P.S. to Chief Minister, Delhi
36. P.S. to Chief Secretary, Delhi
37. Principal Secretary (UD) Govt., of NCT of Delhi
38. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
39. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,  
a. Hudson Lane, Civil Lines ,Delhi-110009
40. CE(WW)
41. CE (East)
42. Dir F & A
43. E.E. (EDP) for uploading on Website
44. Office copy