

**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/

Date: 01.09.20

**WATER PRODUCTION REPORT**

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/669.00	12000	30''	1200
Western Jamuna Canal Level at Haiderpur		<b>NORMAL (Ft.)</b>		<b>ACTUAL (Ft.)</b>
		710.0		7.3

**PRODUCTION DETAILS**

**TOTAL PRODUCTION : 918.60 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	73.28	
ii)	Wazirabad	124	-Do-	123.94	
iii)	Haiderpur	220	WJC Canal	213.57	
iv)	Nangloi	40	-Do-	43.49	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	21.84	
vi)	Dwarka		WJC Canal	50.39	
vii)	Bawana		WJC Canal	20.04	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	109.78	
viii )	Sonia Vihar	144	-Do-	141.34	
1)	Production of Water Treatment Plants			<b>797.67</b>	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.15	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.1	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.68	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			<b>30.93</b>	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells		90	
	Total	(1+2+3)	918.60	

## 5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	3.96
Greater Kailash (O)	5.12	3.99
Greater Kailash (N)	4.80	3.65
Deer Park	4.50	3.90
Janak Puri	3.00	3.25
Kalka Ji	3.65	4.45

## 6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected
1.	Chandrawal ch.I & ch.II pumping closed due to line repair work at Metcalf house	Ch.I 3.55 pm, ch.II 6.40 pm	

Note :- Total supply of water in last 24 hours i.e. 31.08.2020 -----918.60 MGD

Member (WS)

Copy to: -

1. Pr. Secretary to Lt. Governor
2. P.S. to Chief Minister, Delhi
3. P.S. to Chief Secretary, Delhi
4. Principal Secretary (UD) Govt., of NCT of Delhi
5. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
6. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,  
a. Hudson Lane, Civil Lines ,Delhi-110009
7. CE(WW)
8. CE (East)
9. Dir F & A
10. E.E. (EDP) for uploading on Website
11. Office copy

**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/

Date: 02.09.2020

**WATER PRODUCTION REPORT**

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/668.50	10000	25'	1010
Western Jamuna Canal Level at Haiderpur		<b>NORMAL (Ft.)</b>		<b>ACTUAL (Ft.)</b>
		710.0		6.6,5.2

**PRODUCTION DETAILS**

**TOTAL PRODUCTION : 896.45 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	51.18	
ii)	Wazirabad	124	-Do-	123.97	
iii)	Haiderpur	220	WJC Canal	213.48	
iv)	Nangloi	40	-Do-	43.57	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	21.86	
vi)	Dwarka		WJC Canal	50.37	
vii)	Bawana		WJC Canal	20.03	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	109.95	
viii)	Sonia Vihar	144	-Do-	141.10	
1)	Production of Water Treatment Plants			<b>775.51</b>	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazirabad	11	Recycled process waste at Wzd. Plant	10.22	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.02	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.70	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			<b>30.94</b>	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells		90	
	Total	(1+2+3)	896.45	

## 5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	3.96
Greater Kailash (O)	5.12	3.99
Greater Kailash (N)	4.80	3.65
Deer Park	4.50	3.90
Janak Puri	3.00	3.25
Kalka Ji	3.65	4.45

## 6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected
1.	Chandrawal ch.I & ch.II pumping closed due to line repair work at Metcalf house	31.08.20 (3.55 pm to 11.30 am) 01.09.20	

Note :- Total supply of water in last 24 hours i.e..01.09.2020 -----896.45 MGD

Member (WS)

Copy to: -

1. Pr. Secretary to Lt. Governor
2. P.S. to Chief Minister, Delhi
3. P.S. to Chief Secretary, Delhi
4. Principal Secretary (UD) Govt., of NCT of Delhi
5. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
6. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,  
a. Hudson Lane, Civil Lines ,Delhi-110009
7. CE(WW)
8. CE (East)

**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/

Date: 03.09.20

**WATER PRODUCTION REPORT**

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/667.80	7200	18''	800
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		7.1

**PRODUCTION DETAILS**

**TOTAL PRODUCTION : 938.07 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	93.90	
ii)	Wazirabad	124	-Do-	123.95	
iii)	Haiderpur	220	WJC Canal	211.93	
iv)	Nangloi	40	-Do-	43.33	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	21.85	
vi)	Dwarka		WJC Canal	50.38	
vii	Bawana		WJC Canal	20.02	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	109.82	
viii )	Sonia Vihar	144	-Do-	141.71	
1)	Production of Water Treatment Plants			816.89	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.02	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.2	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.78	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			30.18	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells		90	
	Total	(1+2+3)	938.07	

## 5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	3.96
Greater Kailash (O)	5.12	4.11
Greater Kailash (N)	4.80	3.65
Deer Park	4.50	3.40
Janak Puri	3.00	3.20
Kalka Ji	3.65	4.54

## 6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e. 02.09.2020 -----938.07 MGD

Member (WS)

Copy to: -

12. Pr. Secretary to Lt. Governor
13. P.S. to Chief Minister, Delhi
14. P.S. to Chief Secretary, Delhi
15. Principal Secretary (UD) Govt., of NCT of Delhi
16. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
17. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
  - a. Hudson Lane, Civil Lines ,Delhi-110009
18. CE(WW)
19. CE (East)
20. Dir F & A
21. E.E. (EDP) for uploading on Website
22. Office copy

**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/

Date: 04.09.20

**WATER PRODUCTION REPORT**

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/667.50	6000	15"	480
Western Jamuna Canal Level at Haiderpur		<b>NORMAL (Ft.)</b>		<b>ACTUAL (Ft.)</b>
		710.0		4.5

**PRODUCTION DETAILS**

**TOTAL PRODUCTION : 940.19 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	93.89	
ii)	Wazirabad	124	-Do-	123.93	
iii)	Haiderpur	220	WJC Canal	213.48	
iv)	Nangloi	40	-Do-	44.08	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	21.66	
vi)	Dwarka		WJC Canal	50.36	
vii)	Bawana		WJC Canal	20.05	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	109.56	
viii)	Sonia Vihar	144	-Do-	142.04	
1)	Production of Water Treatment Plants			<b>819.05</b>	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazirabad	11	Recycled process waste at Wzd. Plant	10.08	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.2	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.86	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			<b>31.14</b>	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells		90	
	Total	(1+2+3)	940.19	

## 5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	3.96
Greater Kailash (O)	5.12	4.11
Greater Kailash (N)	4.80	3.65
Deer Park	4.50	4.00
Janak Puri	3.00	3.25
Kalka Ji	3.65	4.57

## 6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e. 03.08.2020 -----940.19 MGD

Member (WS)

Copy to: -

1. Pr. Secretary to Lt. Governor
2. P.S. to Chief Minister, Delhi
3. P.S. to Chief Secretary, Delhi
4. Principal Secretary (UD) Govt., of NCT of Delhi
5. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
6. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
  - a. Hudson Lane, Civil Lines ,Delhi-110009
7. CE(WW)
8. CE (East)
9. Dir F & A
10. E.E. (EDP) for uploading on Website
11. Office copy



**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/

Date: 05.09.2020

**WATER PRODUCTION REPORT**

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/667.80	3200	8'	410
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		6.2

**PRODUCTION DETAILS**

**TOTAL PRODUCTION : 938.57 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	93.88	
ii)	Wazirabad	124	-Do-	123.95	
iii)	Haiderpur	220	WJC Canal	212.10	
iv)	Nangloi	40	-Do-	43.60	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	21.70	
vi)	Dwarka		WJC Canal	50.38	
vii)	Bawana		WJC Canal	20.02	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	109.82	
viii )	Sonia Vihar	144	-Do-	141.97	
1)	Production of Water Treatment Plants			817.42	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.1	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.2	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.85	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			31.15	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells		90	
	Total	(1+2+3)	938.57	

## 5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	3.96
Greater Kailash (O)	5.12	4.11
Greater Kailash (N)	4.80	3.65
Deer Park	4.50	4.00
Janak Puri	3.00	3.20
Kalka Ji	3.65	4.29

## 6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Afected
1.			

Note :- Total supply of water in last 24 hours i.e..04.09.2020 -----938.57 MGD

Member (WS)

Copy to: -

1. Pr. Secretary to Lt. Governor
2. P.S. to Chief Minister, Delhi
3. P.S. to Chief Secretary, Delhi
4. Principal Secretary (UD) Govt., of NCT of Delhi
5. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
6. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
  - a. Hudson Lane, Civil Lines ,Delhi-110009
7. CE(WW)
8. CE (East)

**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/

Date: 06.09.20

**WATER PRODUCTION REPORT**

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/666.70	2800	7'	170
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		6.7

**PRODUCTION DETAILS**

**TOTAL PRODUCTION : 938.86 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	93.87	
ii)	Wazirabad	124	-Do-	123.93	
iii)	Haiderpur	220	WJC Canal	213.58	
iv)	Nangloi	40	-Do-	43.52	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	21.54	
vi)	Dwarka		WJC Canal	50.37	
vii	Bawana		WJC Canal	20.05	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	109.88	
viii )	Sonia Vihar	144	-Do-	142.12	
1)	Production of Water Treatment Plants			818.86	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	9.03	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.1	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.87	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			30.00	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells		90	
	Total	(1+2+3)	938.86	

## 5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	3.96
Greater Kailash (O)	5.12	3.99
Greater Kailash (N)	4.80	3.65
Deer Park	4.50	4.00
Janak Puri	3.00	3.20
Kalka Ji	3.65	4.26

## 6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e. 05.09.2020 -----938.86 MGD

Member (WS)

Copy to: -

12. Pr. Secretary to Lt. Governor
13. P.S. to Chief Minister, Delhi
14. P.S. to Chief Secretary, Delhi
15. Principal Secretary (UD) Govt., of NCT of Delhi
16. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
17. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
  - a. Hudson Lane, Civil Lines ,Delhi-110009
18. CE(WW)
19. CE (East)
20. Dir F & A
21. E.E. (EDP) for uploading on Website
22. Office copy

**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/

Date: 07.09.20

**WATER PRODUCTION REPORT**

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/666.90	3600	9'	13
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		6.4,5.2

**PRODUCTION DETAILS**

**TOTAL PRODUCTION : 938.90 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	93.88	
ii)	Wazirabad	124	-Do-	122.30	
iii)	Haiderpur	220	WJC Canal	213.58	
iv)	Nangloi	40	-Do-	43.64	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	21.50	
vi)	Dwarka		WJC Canal	50.71	
vii	Bawana		WJC Canal	20.04	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	110.53	
viii )	Sonia Vihar	144	-Do-	141.64	
1)	Production of Water Treatment Plants			817.82	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.07	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.1	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.91	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			30.08	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells		90	
	Total	(1+2+3)	938.90	

## 5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	3.96
Greater Kailash (O)	5.12	4.11
Greater Kailash (N)	4.80	3.35
Deer Park	4.50	4.00
Janak Puri	3.00	3.20
Kalka Ji	3.65	4.29

## 6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e. 06.09.2020 -----938.90 MGD

Member (WS)

Copy to: -

1. Pr. Secretary to Lt. Governor
2. P.S. to Chief Minister, Delhi
3. P.S. to Chief Secretary, Delhi
4. Principal Secretary (UD) Govt., of NCT of Delhi
5. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
6. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
  - a. Hudson Lane, Civil Lines ,Delhi-110009
7. CE(WW)
8. CE (East)
9. Dir F & A
10. E.E. (EDP) for uploading on Website
11. Office copy

**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/

Date: 08.09.20

**WATER PRODUCTION REPORT**

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/666.50	2400	6'	160
Western Jamuna Canal Level at Haiderpur		<b>NORMAL (Ft.)</b>		<b>ACTUAL (Ft.)</b>
		710.0		6.9,5.4

**PRODUCTION DETAILS**

**TOTAL PRODUCTION : 928.45 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
--------------------------	--------------------------------------	------------------	-----------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	93.87	
ii)	Wazirabad	124	-Do-	123.95	
iii)	Haiderpur	220	WJC Canal	213.68	
iv)	Nangloi	40	-Do-	43.35	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	21.85	
vi)	Dwarka		WJC Canal	50.33	
vii)	Bawana		WJC Canal	20.02	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	101.13	
viii)	Sonia Vihar	144	-Do-	142.09	
1)	Production of Water Treatment Plants			<b>810.27</b>	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazirabad	11	Recycled process waste at Wzd. Plant	7.3	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.88	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			<b>28.18</b>	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells		90	
	Total	(1+2+3)	928.45	

## 5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	3.96
Greater Kailash (O)	5.12	3.80
Greater Kailash (N)	4.80	3.65
Deer Park	4.50	4.00
Janak Puri	3.00	3.30
Kalka Ji	3.65	4.26

## 6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected
	Wazirabad R/clear line close due to work in Jagatpur burari line	06.09.20(4.45 pm to 5.15 am) 07.09.20	

Note :- Total supply of water in last 24 hours i.e. 07.09.2020 -----928.45 MGD

Member (WS)

Copy to: -

1. Pr. Secretary to Lt. Governor
2. P.S. to Chief Minister, Delhi
3. P.S. to Chief Secretary, Delhi
4. Principal Secretary (UD) Govt., of NCT of Delhi
5. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
6. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,  
a. Hudson Lane, Civil Lines ,Delhi-110009
7. CE(WW)
8. CE (East)
9. Dir F & A
10. E.E. (EDP) for uploading on Website
11. Office copy



**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/

Date: 09.09.2020

**WATER PRODUCTION REPORT**

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/666.40	2000	5'	130
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		6.6,4.8

**PRODUCTION DETAILS**

**TOTAL PRODUCTION : 937.69 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	93.89	
ii)	Wazirabad	124	-Do-	123.93	
iii)	Haiderpur	220	WJC Canal	213.57	
iv)	Nangloi	40	-Do-	44.65	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	21.80	
vi)	Dwarka		WJC Canal	48	
vii)	Bawana		WJC Canal	20.04	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	110.59	
viii)	Sonia Vihar	144	-Do-	142.12	
1)	Production of Water Treatment Plants			818.59	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazirabad	11	Recycled process waste at Wzd. Plant	8.25	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.1	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.75	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			29.10	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells		90	
	Total	(1+2+3)	937.69	

## 5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	3.96
Greater Kailash (O)	5.12	4.11
Greater Kailash (N)	4.80	3.04
Deer Park	4.50	4.20
Janak Puri	3.00	3.20
Kalka Ji	3.65	4.26

## 6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Afected
1.			

Note :- Total supply of water in last 24 hours i.e..08.09.2020 -----937.69 MGD

Member (WS)

Copy to: -

1. Pr. Secretary to Lt. Governor
2. P.S. to Chief Minister, Delhi
3. P.S. to Chief Secretary, Delhi
4. Principal Secretary (UD) Govt., of NCT of Delhi
5. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
6. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
  - a. Hudson Lane, Civil Lines ,Delhi-110009
7. CE(WW)
8. CE (East)

**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/

Date: 10.09.20

**WATER PRODUCTION REPORT**

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/666.60	2400	6'	140
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		6.9

**PRODUCTION DETAILS**

**TOTAL PRODUCTION : 940.36 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	93.92	
ii)	Wazirabad	124	-Do-	123.95	
iii)	Haiderpur	220	WJC Canal	213.37	
iv)	Nangloi	40	-Do-	43.00	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	21.85	
vi)	Dwarka		WJC Canal	50.41	
vii	Bawana		WJC Canal	20.03	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	110.53	
viii )	Sonia Vihar	144	-Do-	142.09	
1)	Production of Water Treatment Plants			819.15	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazirabad	11	Recycled process waste at Wzd. Plant	10.23	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.2	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.78	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			31.21	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells		90	
	Total	(1+2+3)	940.36	

## 5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	3.96
Greater Kailash (O)	5.12	3.80
Greater Kailash (N)	4.80	3.35
Deer Park	4.50	4.70
Janak Puri	3.00	3.20
Kalka Ji	3.65	4.14

## 6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e. 09.09.2020 -----940.36 MGD

Member (WS)

Copy to: -

12. Pr. Secretary to Lt. Governor
13. P.S. to Chief Minister, Delhi
14. P.S. to Chief Secretary, Delhi
15. Principal Secretary (UD) Govt., of NCT of Delhi
16. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
17. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
  - a. Hudson Lane, Civil Lines ,Delhi-110009
18. CE(WW)
19. CE (East)
20. Dir F & A
21. E.E. (EDP) for uploading on Website
22. Office copy

**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/

Date: 11.09.20

**WATER PRODUCTION REPORT**

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/666.00	1600	4'	142
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		7.5,4.5

**PRODUCTION DETAILS**

**TOTAL PRODUCTION : 941.21 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	93.91	
ii)	Wazirabad	124	-Do-	123.94	
iii)	Haiderpur	220	WJC Canal	213.58	
iv)	Nangloi	40	-Do-	43.68	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	21.75	
vi)	Dwarka		WJC Canal	51	
vii	Bawana		WJC Canal	20.03	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	110.65	
viii )	Sonia Vihar	144	-Do-	141.13	
1)	Production of Water Treatment Plants			820.67	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazirabad	11	Recycled process waste at Wzd. Plant	9.75	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.1	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.69	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			30.54	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells		90	
	Total	(1+2+3)	941.21	

## 5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	3.96
Greater Kailash (O)	5.12	4.11
Greater Kailash (N)	4.80	3.65
Deer Park	4.50	4.00
Janak Puri	3.00	3.35
Kalka Ji	3.65	4.29

## 6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e. 10.09.2020 -----941.21 MGD

Member (WS)

Copy to: -

1. Pr. Secretary to Lt. Governor
2. P.S. to Chief Minister, Delhi
3. P.S. to Chief Secretary, Delhi
4. Principal Secretary (UD) Govt., of NCT of Delhi
5. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
6. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
  - a. Hudson Lane, Civil Lines ,Delhi-110009
7. CE(WW)
8. CE (East)
9. Dir F & A
10. E.E. (EDP) for uploading on Website
11. Office copy

**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/

Date: 12.09.2020

**WATER PRODUCTION REPORT**

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/666.00	1600	4'	130
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		6.9

**PRODUCTION DETAILS**

**TOTAL PRODUCTION : 942.48 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	93.89	
ii)	Wazirabad	124	-Do-	123.95	
iii)	Haiderpur	220	WJC Canal	213.28	
iv)	Nangloi	40	-Do-	43.45	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	21.59	
vi)	Dwarka		WJC Canal	52.40	
vii)	Bawana		WJC Canal	20.03	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	110.47	
viii)	Sonia Vihar	144	-Do-	142.07	
1)	Production of Water Treatment Plants			821.13	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazirabad	11	Recycled process waste at Wzd. Plant	10.28	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.4	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.67	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			31.35	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells		90	
	Total	(1+2+3)	942.48	

## 5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	3.96
Greater Kailash (O)	5.12	4.11
Greater Kailash (N)	4.80	3.65
Deer Park	4.50	4.10
Janak Puri	3.00	3.25
Kalka Ji	3.65	4.29

## 6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Afected
1.			

Note :- Total supply of water in last 24 hours i.e..11.09.2020 -----942.48 MGD

Member (WS)

Copy to: -

9. Pr. Secretary to Lt. Governor
10. P.S. to Chief Minister, Delhi
11. P.S. to Chief Secretary, Delhi
12. Principal Secretary (UD) Govt., of NCT of Delhi
13. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
14. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
  - a. Hudson Lane, Civil Lines ,Delhi-110009
15. CE(WW)
16. CE (East)



**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/

Date: 13.09.20

**WATER PRODUCTION REPORT**

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/666.00	1400	4'	120
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		6.5

**PRODUCTION DETAILS**

**TOTAL PRODUCTION : 941.70 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	93.90	
ii)	Wazirabad	124	-Do-	123.93	
iii)	Haiderpur	220	WJC Canal	213.47	
iv)	Nangloi	40	-Do-	43.59	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	21.70	
vi)	Dwarka		WJC Canal	52.19	
vii	Bawana		WJC Canal	20.04	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	109.70	
viii )	Sonia Vihar	144	-Do-	142.09	
1)	Production of Water Treatment Plants			820.61	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazirabad	11	Recycled process waste at Wzd. Plant	10.26	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.2	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.63	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			31.09	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells		90	
	Total	(1+2+3)	941.70	

## 5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	3.96
Greater Kailash (O)	5.12	4.11
Greater Kailash (N)	4.80	3.35
Deer Park	4.50	4.00
Janak Puri	3.00	3.20
Kalka Ji	3.65	4.54

## 6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e. 12.09.2020 -----941.70 MGD

Member (WS)

Copy to: -

23. Pr. Secretary to Lt. Governor
24. P.S. to Chief Minister, Delhi
25. P.S. to Chief Secretary, Delhi
26. Principal Secretary (UD) Govt., of NCT of Delhi
27. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
28. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
  - a. Hudson Lane, Civil Lines ,Delhi-110009
29. CE(WW)
30. CE (East)
31. Dir F & A
32. E.E. (EDP) for uploading on Website
33. Office copy

**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/

Date: 14.09.20

**WATER PRODUCTION REPORT**

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/665.40	1000	2'6"	112
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		6.6,4.7

**PRODUCTION DETAILS**

**TOTAL PRODUCTION : 940.40 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	93.89	
ii)	Wazirabad	124	-Do-	123.92	
iii)	Haiderpur	220	WJC Canal	213.58	
iv)	Nangloi	40	-Do-	43.64	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	21.62	
vi)	Dwarka		WJC Canal	52.43	
vii	Bawana		WJC Canal	20.05	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	108.89	
viii )	Sonia Vihar	144	-Do-	141.42	
1)	Production of Water Treatment Plants			819.44	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.20	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.1	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.86	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			30.96	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells		90	
	Total	(1+2+3)	940.40	

## 5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	3.96
Greater Kailash (O)	5.12	4.11
Greater Kailash (N)	4.80	3.65
Deer Park	4.50	4.00
Janak Puri	3.00	3.35
Kalka Ji	3.65	4.29

## 6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e. 13.09.2020 -----940.40 MGD

Member (WS)

Copy to: -

12. Pr. Secretary to Lt. Governor
13. P.S. to Chief Minister, Delhi
14. P.S. to Chief Secretary, Delhi
15. Principal Secretary (UD) Govt., of NCT of Delhi
16. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
17. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
  - a. Hudson Lane, Civil Lines ,Delhi-110009
18. CE(WW)
19. CE (East)
20. Dir F & A
21. E.E. (EDP) for uploading on Website
22. Office copy

**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/

Date: 15.09.20

**WATER PRODUCTION REPORT**

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/666.60	1200	3'	82
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		6.6

**PRODUCTION DETAILS**

**TOTAL PRODUCTION : 922.29 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
--------------------------	--------------------------------------	------------------	-----------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	93.88	
ii)	Wazirabad	124	-Do-	104.42	
iii)	Haiderpur	220	WJC Canal	213.19	
iv)	Nangloi	40	-Do-	43.76	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	21.57	
vi)	Dwarka		WJC Canal	52.41	
vii)	Bawana		WJC Canal	20.02	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	109.93	
viii)	Sonia Vihar	144	-Do-	142.04	
1)	Production of Water Treatment Plants			801.22	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.09	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.2	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.78	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			31.07	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells		90	
	Total	(1+2+3)	922.29	

## 5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	3.96
Greater Kailash (O)	5.12	3.80
Greater Kailash (N)	4.80	3.65
Deer Park	4.50	4.00
Janak Puri	3.00	3.25
Kalka Ji	3.65	4.54

## 6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e. 14.09.2020 -----922.29 MGD

Member (WS)

Copy to: -

1. Pr. Secretary to Lt. Governor
2. P.S. to Chief Minister, Delhi
3. P.S. to Chief Secretary, Delhi
4. Principal Secretary (UD) Govt., of NCT of Delhi
5. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
6. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
  - a. Hudson Lane, Civil Lines ,Delhi-110009
7. CE(WW)
8. CE (East)
9. Dir F & A
10. E.E. (EDP) for uploading on Website
11. Office copy

**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/

Date: 16.09.2020

**WATER PRODUCTION REPORT**

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/665.60	1200	3'	74
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		6.1

**PRODUCTION DETAILS**

**TOTAL PRODUCTION : 942.66 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	93.89	
ii)	Wazirabad	124	-Do-	123.94	
iii)	Haiderpur	220	WJC Canal	213.57	
iv)	Nangloi	40	-Do-	44.21	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	21.62	
vi)	Dwarka		WJC Canal	52.45	
vii)	Bawana		WJC Canal	20.04	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	109.75	
viii)	Sonia Vihar	144	-Do-	142.10	
1)	Production of Water Treatment Plants			821.55	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazirabad	11	Recycled process waste at Wzd. Plant	10.25	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.1	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.76	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			31.11	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells		90	
	Total	(1+2+3)	942.66	

## 5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	3.96
Greater Kailash (O)	5.12	3.99
Greater Kailash (N)	4.80	3.84
Deer Park	4.50	4.50
Janak Puri	3.00	3.20
Kalka Ji	3.65	4.29

## 6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Afected
1.	B.P. Tahirpur line maintenance work	5.10 pm to 6.30 PM	

Note :- Total supply of water in last 24 hours i.e..15.09.2020 -----942.66 MGD

Member (WS)

Copy to: -

1. Pr. Secretary to Lt. Governor
2. P.S. to Chief Minister, Delhi
3. P.S. to Chief Secretary, Delhi
4. Principal Secretary (UD) Govt., of NCT of Delhi
5. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
6. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
  - a. Hudson Lane, Civil Lines ,Delhi-110009
7. CE(WW)
8. CE (East)



**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/

Date: 17.09.20

**WATER PRODUCTION REPORT**

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/665.60	1200	3'	58
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		7.0,5.5

**PRODUCTION DETAILS**

**TOTAL PRODUCTION : 932.47 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	93.87	
ii)	Wazirabad	124	-Do-	123.95	
iii)	Haiderpur	220	WJC Canal	213.68	
iv)	Nangloi	40	-Do-	43.55	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	21.48	
vi)	Dwarka		WJC Canal	51.48	
vii)	Bawana		WJC Canal	20.04	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	101.47	
viii)	Sonia Vihar	144	-Do-	142.07	
1)	Production of Water Treatment Plants			811.59	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazirabad	11	Recycled process waste at Wzd. Plant	10.09	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.00	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.79	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			30.88	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells		90	
	Total	(1+2+3)	932.47	

## 5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	3.96
Greater Kailash (O)	5.12	4.11
Greater Kailash (N)	4.80	3.35
Deer Park	4.50	4.50
Janak Puri	3.00	3.30
Kalka Ji	3.65	4.57

## 6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e. 16.09.2020 -----932.47 MGD

Member (WS)

Copy to: -

12. Pr. Secretary to Lt. Governor
13. P.S. to Chief Minister, Delhi
14. P.S. to Chief Secretary, Delhi
15. Principal Secretary (UD) Govt., of NCT of Delhi
16. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
17. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
  - a. Hudson Lane, Civil Lines ,Delhi-110009
18. CE(WW)
19. CE (East)
20. Dir F & A
21. E.E. (EDP) for uploading on Website
22. Office copy

**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/

Date: 18.09.20

**WATER PRODUCTION REPORT**

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/665.20	800	2'	50
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		5.5

**PRODUCTION DETAILS**

**TOTAL PRODUCTION : 940.85 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	93.88	
ii)	Wazirabad	124	-Do-	123.93	
iii)	Haiderpur	220	WJC Canal	213.58	
iv)	Nangloi	40	-Do-	43.60	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	21.58	
vi)	Dwarka		WJC Canal	50.77	
vii)	Bawana		WJC Canal	20.04	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	110.38	
viii)	Sonia Vihar	144	-Do-	142.21	
1)	Production of Water Treatment Plants			819.97	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazirabad	11	Recycled process waste at Wzd. Plant	10.25	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.1	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.53	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			30.88	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells		90	
	Total	(1+2+3)	940.85	

## 5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	3.96
Greater Kailash (O)	5.12	4.05
Greater Kailash (N)	4.80	3.65
Deer Park	4.50	4.20
Janak Puri	3.00	3.15
Kalka Ji	3.65	4.54

## 6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e. 17.09.2020 -----940.85 MGD

Member (WS)

Copy to: -

1. Pr. Secretary to Lt. Governor
2. P.S. to Chief Minister, Delhi
3. P.S. to Chief Secretary, Delhi
4. Principal Secretary (UD) Govt., of NCT of Delhi
5. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
6. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
  - a. Hudson Lane, Civil Lines ,Delhi-110009
7. CE(WW)
8. CE (East)
9. Dir F & A
10. E.E. (EDP) for uploading on Website
11. Office copy

**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/

Date: 19.09.2020

**WATER PRODUCTION REPORT**

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/664.80	400	1'	43
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		6.2

**PRODUCTION DETAILS**

**TOTAL PRODUCTION : 940.21 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	93.91	
ii)	Wazirabad	124	-Do-	122.21	
iii)	Haiderpur	220	WJC Canal	213.38	
iv)	Nangloi	40	-Do-	43.48	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	21.60	
vi)	Dwarka		WJC Canal	50.60	
vii)	Bawana		WJC Canal	20.02	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	110.56	
viii)	Sonia Vihar	144	-Do-	142.19	
1)	Production of Water Treatment Plants			819.06	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazirabad	11	Recycled process waste at Wzd. Plant	10.24	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.30	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.61	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			31.15	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells		90	
	Total	(1+2+3)	940.21	

## 5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	3.96
Greater Kailash (O)	5.12	4.05
Greater Kailash (N)	4.80	3.50
Deer Park	4.50	4.20
Janak Puri	3.00	3.30
Kalka Ji	3.65	4.29

## 6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Afected
1.			

Note :- Total supply of water in last 24 hours i.e..18.09.2020 -----940.21 MGD

Member (WS)

Copy to: -

9. Pr. Secretary to Lt. Governor
10. P.S. to Chief Minister, Delhi
11. P.S. to Chief Secretary, Delhi
12. Principal Secretary (UD) Govt., of NCT of Delhi
13. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
14. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
  - a. Hudson Lane, Civil Lines ,Delhi-110009
15. CE(WW)
16. CE (East)

**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/

Date: 20.09.20

**WATER PRODUCTION REPORT**

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/664.80	400	1'	40
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		6.2

**PRODUCTION DETAILS**

**TOTAL PRODUCTION : 940.67 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	93.89	
ii)	Wazirabad	124	-Do-	123.95	
iii)	Haiderpur	220	WJC Canal	213.58	
iv)	Nangloi	40	-Do-	43.45	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	21.51	
vi)	Dwarka		WJC Canal	50.45	
vii)	Bawana		WJC Canal	20.03	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	110.69	
viii)	Sonia Vihar	144	-Do-	142.27	
1)	Production of Water Treatment Plants			819.82	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazirabad	11	Recycled process waste at Wzd. Plant	10.17	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.2	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.58	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			30.85	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells		90	
	Total	(1+2+3)	940.67	

## 5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	3.96
Greater Kailash (O)	5.12	4.11
Greater Kailash (N)	4.80	3.35
Deer Park	4.50	4.00
Janak Puri	3.00	3.20
Kalka Ji	3.65	4.54

## 6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e. 12.09.2020 -----941.70 MGD

Member (WS)

Copy to: -

23. Pr. Secretary to Lt. Governor
24. P.S. to Chief Minister, Delhi
25. P.S. to Chief Secretary, Delhi
26. Principal Secretary (UD) Govt., of NCT of Delhi
27. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
28. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
  - a. Hudson Lane, Civil Lines ,Delhi-110009
29. CE(WW)
30. CE (East)
31. Dir F & A
32. E.E. (EDP) for uploading on Website
33. Office copy



**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/

Date: 14.09.20

**WATER PRODUCTION REPORT**

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/665.40	1000	2'6"	112
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		6.6,4.7

**PRODUCTION DETAILS**

**TOTAL PRODUCTION : 940.40 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	93.89	
ii)	Wazirabad	124	-Do-	123.92	
iii)	Haiderpur	220	WJC Canal	213.58	
iv)	Nangloi	40	-Do-	43.64	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	21.62	
vi)	Dwarka		WJC Canal	52.43	
vii	Bawana		WJC Canal	20.05	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	108.89	
viii )	Sonia Vihar	144	-Do-	141.42	
1)	Production of Water Treatment Plants			819.44	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.20	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.1	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.86	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			30.96	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells		90	
	Total	(1+2+3)	940.40	

## 5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	3.96
Greater Kailash (O)	5.12	4.11
Greater Kailash (N)	4.80	3.65
Deer Park	4.50	4.00
Janak Puri	3.00	3.35
Kalka Ji	3.65	4.29

## 6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e. 13.09.2020 -----940.40 MGD

Member (WS)

Copy to: -

12. Pr. Secretary to Lt. Governor
13. P.S. to Chief Minister, Delhi
14. P.S. to Chief Secretary, Delhi
15. Principal Secretary (UD) Govt., of NCT of Delhi
16. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
17. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
  - a. Hudson Lane, Civil Lines ,Delhi-110009
18. CE(WW)
19. CE (East)
20. Dir F & A
21. E.E. (EDP) for uploading on Website
22. Office copy