

DELHI JAL BOARD
OFFICE OF MEMBER (WATER SUPPLY)
VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI

No. DJB/M (WS)/A-97/2017/
WATER PRODUCTION REPORT

Date: 01.09.21

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/665.60	1200	3'	2500
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		5.5,4.6

PRODUCTION DETAILS **TOTAL PRODUCTION : 944.85 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

YAMUNA WATER

i)	Chandrawal	98	Wazirabad Pond	94.60	
ii)	Wazirabad	124	-Do-	123.90	
iii)	Haiderpur	220	WJC Canal	218.06	
iv)	Nangloi	40	-Do-	42.46	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	21.08	
vi)	Dwarka		WJC Canal	52.31	
vii)	Bawana		WJC Canal	20.02	

GANGA WATER

viii)	Bhagirathi	100	Upper Ganga Canal	107.67	
ix)	Sonia Vihar	144	-Do-	139.60	
1)	Production of Water Treatment Plants			819.70	

RECYCLING /PROCESS WASTE WATER PLANTS

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.28	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.00	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	3.87	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			30.15	

GROUND WATER SOURCES

3)	Production from Ranney wells & Tube wells			95.00	
	Total	(1+2+3)		944.85	

5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	4.26
Greater Kailash (N)	4.80	3.35
Deer Park	4.50	4.00
Janak Puri	3.00	3.30
Kalka Ji	3.65	4.54

6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e..31.08.21 -----944.85 MGD

Member (WS)

Copy to: -

1. Pr. Secretary to Lt. Governor
2. P.S. to Chief Minister, Delhi
3. P.S. to Chief Secretary, Delhi
4. Principal Secretary (UD) Govt., of NCT of Delhi
5. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
6. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
 - a. Hudson Lane, Civil Lines ,Delhi-110009
7. CE(WW)
8. CE (East)

DELHI JAL BOARD
OFFICE OF MEMBER (WATER SUPPLY)
VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI

No. DJB/M (WS)/A-97/2017/
WATER PRODUCTION REPORT

Date: 02.09.21

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/666.00	1600	4'	1750
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		5.8,4.7

PRODUCTION DETAILS **TOTAL PRODUCTION : 948.33 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

YAMUNA WATER

i)	Chandrawal	98	Wazirabad Pond	94.79	
ii)	Wazirabad	124	-Do-	123.91	
iii)	Haiderpur	220	WJC Canal	219.25	
iv)	Nangloi	40	-Do-	44.46	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	20.88	
vi)	Dwarka		WJC Canal	52.28	
vii)	Bawana		WJC Canal	20.04	

GANGA WATER

vii)	Bhagirathi	100	Upper Ganga Canal	108.00	
viii)	Sonia Vihar	144	-Do-	139.17	
1)	Production of Water Treatment Plants			822.78	

RECYCLING /PROCESS WASTE WATER PLANTS

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.21	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.20	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.14	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			30.55	

GROUND WATER SOURCES

3)	Production from Ranney wells & Tube wells			95.00	
	Total	(1+2+3)		948.33	

5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	4.14
Greater Kailash (N)	4.80	3.35
Deer Park	4.50	4.00
Janak Puri	3.00	3.25

Kalka Ji	3.65	4.29
----------	------	------

6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e. 01.09.2021 -----948.33 MGD

Member (WS)

Copy to: -

1. Pr. Secretary to Lt. Governor
2. P.S. to Chief Minister, Delhi
3. P.S. to Chief Secretary, Delhi
4. Principal Secretary (UD) Govt., of NCT of Delhi
5. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
6. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
a. Hudson Lane, Civil Lines ,Delhi-110009
7. CE(WW)
8. CE (East)
9. Dir F & A
10. E.E. (EDP) for uploading on Website
11. Office copy

DELHI JAL BOARD
OFFICE OF MEMBER (WATER SUPPLY)
VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI

No. DJB/M (WS)/A-97/2017/
WATER PRODUCTION REPORT

Date: 03.09.21

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/666.40	2000	5'	950
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		6.6

PRODUCTION DETAILS **TOTAL PRODUCTION : 952.84 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

YAMUNA WATER

i)	Chandrawal	98	Wazirabad Pond	94.04	
ii)	Wazirabad	124	-Do-	128.88	
iii)	Haiderpur	220	WJC Canal	219.46	
iv)	Nangloi	40	-Do-	44.45	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	21.04	
vi)	Dwarka		WJC Canal	52.29	
vii)	Bawana		WJC Canal	20.02	

GANGA WATER

viii)	Bhagirathi	100	Upper Ganga Canal	108.99	
ix)	Sonia Vihar	144	-Do-	138.20	
1)	Production of Water Treatment Plants			827.37	

RECYCLING /PROCESS WASTE WATER PLANTS

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.27	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.00	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.20	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			30.47	

GROUND WATER SOURCES

3)	Production from Ranney wells & Tube wells		95.00	
	Total	(1+2+3)	952.84	

5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	4.14
Greater Kailash (N)	4.80	3.35
Deer Park	4.50	4.00
Janak Puri	3.00	3.30
Kalka Ji	3.65	4.26

6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e..02.09.21 -----952.84 MGD

Member (WS)

Copy to: -

9. Pr. Secretary to Lt. Governor
10. P.S. to Chief Minister, Delhi
11. P.S. to Chief Secretary, Delhi
12. Principal Secretary (UD) Govt., of NCT of Delhi
13. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
14. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
 - a. Hudson Lane, Civil Lines ,Delhi-110009
15. CE(WW)
16. CE (East)

DELHI JAL BOARD
OFFICE OF MEMBER (WATER SUPPLY)
VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI

No. DJB/M (WS)/A-97/2017/
WATER PRODUCTION REPORT

Date: 04.09.21

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/666.00	1600	4'	670
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		

PRODUCTION DETAILS **TOTAL PRODUCTION : 951.00 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

YAMUNA WATER

i)	Chandrawal	98	Wazirabad Pond	95.25	
ii)	Wazirabad	124	-Do-	123.87	
iii)	Haiderpur	220	WJC Canal	219.35	
iv)	Nangloi	40	-Do-	44.09	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	21.84	
vi)	Dwarka		WJC Canal	52.32	
vii)	Bawana		WJC Canal	20.01	

GANGA WATER

viii)	Bhagirathi	100	Upper Ganga Canal	109.30	
ix)	Sonia Vihar	144	-Do-	139.59	
1)	Production of Water Treatment Plants			825.62	

RECYCLING /PROCESS WASTE WATER PLANTS

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.28	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.10	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.00	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			30.38	

GROUND WATER SOURCES

3)	Production from Ranney wells & Tube wells		95.00	
	Total	(1+2+3)	951.00	

5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	3.65
Greater Kailash (N)	4.80	3.04
Deer Park	4.50	4.10
Janak Puri	3.00	3.35
Kalka Ji	3.65	4.54

m6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Afected

Note :- Total supply of water in last 24 hours i.e. 03.09.21 -----951.00 MGD

Member (WS)

Copy to: -

- 1. Pr. Secretary to Lt. Governor**
- 2. P.S. to Chief Minister, Delhi**
- 3. P.S. to Chief Secretary, Delhi**
- 4. Principal Secretary (UD) Govt., of NCT of Delhi**
- 5. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi**
- 6. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,**
- 7. Hudson Lane, Civil Lines ,Delhi-110009**
- 8. CE(WW)**
- 9. CE (East)**
- 10. Dir F & A**
- 11. E.E. (EDP) for uploading on Website**
- 12. Office copy**

DELHI JAL BOARD
OFFICE OF MEMBER (WATER SUPPLY)
VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI

No. DJB/M (WS)/A-97/2017/
WATER PRODUCTION REPORT

Date: 05.09.21

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/665.60	1200	3'	4.7
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		5.6

PRODUCTION DETAILS **TOTAL PRODUCTION : 949.70 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

YAMUNA WATER

i)	Chandrawal	98	Wazirabad Pond	94.84	
ii)	Wazirabad	124	-Do-	123.86	
iii)	Haiderpur	220	WJC Canal	219.15	
iv)	Nangloi	40	-Do-	44.30	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	21.22	
vi)	Dwarka		WJC Canal	52.31	
vii)	Bawana		WJC Canal	20.00	

GANGA WATER

viii)	Bhagirathi	100	Upper Ganga Canal	108.52	
ix)	Sonia Vihar	144	-Do-	140.02	
1)	Production of Water Treatment Plants			824.22	

RECYCLING /PROCESS WASTE WATER PLANTS

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.26	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.30	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	3.92	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			30.48	

GROUND WATER SOURCES

3)	Production from Ranney wells & Tube wells		95.00	
	Total	(1+2+3)	949.70	

5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	3.65
Greater Kailash (N)	4.80	3.04
Deer Park	4.50	4.00
Janak Puri	3.00	3.25
Kalka Ji	3.65	4.26

m6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Afected

Note :- Total supply of water in last 24 hours i.e. 04.09.21 -----949.09 MGD

Member (WS)

Copy to: -

- 13. Pr. Secretary to Lt. Governor**
- 14. P.S. to Chief Minister, Delhi**
- 15. P.S. to Chief Secretary, Delhi**
- 16. Principal Secretary (UD) Govt., of NCT of Delhi**
- 17. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi**
- 18. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,**
- 19. Hudson Lane, Civil Lines ,Delhi-110009**
- 20. CE(WW)**
- 21. CE (East)**
- 22. Dir F & A**
- 23. E.E. (EDP) for uploading on Website**
- 24. Office copy**

DELHI JAL BOARD
OFFICE OF MEMBER (WATER SUPPLY)
VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI

No. DJB/M (WS)/A-97/2017/

Date: 06.09.21

WATER PRODUCTION REPORT

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/665.60	1200	3'	410
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		6.2

PRODUCTION DETAILS

TOTAL PRODUCTION : 950.82 MGD

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

YAMUNA WATER

i)	Chandrawal	98	Wazirabad Pond	94.99	
ii)	Wazirabad	124	-Do-	123.90	
iii)	Haiderpur	220	WJC Canal	219.26	
iv)	Nangloi	40	-Do-	44.54	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	22.18	
vi)	Dwarka		WJC Canal	52.29	
vii)	Bawana		WJC Canal	20.00	

GANGA WATER

vii)	Bhagirathi	100	Upper Ganga Canal	108.74	
viii)	Sonia Vihar	144	-Do-	139.80	
1)	Production of Water Treatment Plants			825.70	

RECYCLING /PROCESS WASTE WATER PLANTS

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.26	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.20	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	3.66	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			30.12	

GROUND WATER SOURCES

3)	Production from Ranney wells & Tube wells			95.00	
	Total	(1+2+3)		950.82	

5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	3.96
Greater Kailash (N)	4.80	2.74
Deer Park	4.50	4.00
Janak Puri	3.00	3.30
Kalka Ji	3.65	4.45

6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e..05.09.21 -----950.82 MGD

Member (WS)

Copy to: -

17. Pr. Secretary to Lt. Governor
18. P.S. to Chief Minister, Delhi
19. P.S. to Chief Secretary, Delhi
20. Principal Secretary (UD) Govt., of NCT of Delhi
21. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
22. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
 - a. Hudson Lane, Civil Lines ,Delhi-110009
23. CE(WW)
24. CE (East)

DELHI JAL BOARD
OFFICE OF MEMBER (WATER SUPPLY)
VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI

No. DJB/M (WS)/A-97/2017/
WATER PRODUCTION REPORT

Date: 07.09.21

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/664.40	400	1'	340
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		7.6

PRODUCTION DETAILS

TOTAL PRODUCTION : 936.80 MGD

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

YAMUNA WATER

i)	Chandrawal	98	Wazirabad Pond	90.41	
ii)	Wazirabad	124	-Do-	120.09	
iii)	Haiderpur	220	WJC Canal	213.71	
iv)	Nangloi	40	-Do-	44.11	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	21.70	
vi)	Dwarka		WJC Canal	52.33	
vii)	Bawana		WJC Canal	20.03	

GANGA WATER

vii)	Bhagirathi	100	Upper Ganga Canal	109.41	
viii)	Sonia Vihar	144	-Do-	139.92	
1)	Production of Water Treatment Plants			811.71	

RECYCLING /PROCESS WASTE WATER PLANTS

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.26	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.10	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	3.73	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			30.09	

GROUND WATER SOURCES

3)	Production from Ranney wells & Tube wells			95.00	
	Total	(1+2+3)		936.80	

5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	3.96
Greater Kailash (N)	4.80	3.65
Deer Park	4.50	4.10
Janak Puri	3.00	3.25

Kalka Ji	3.65	3.84
----------	------	------

m6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e. 06.08.21 -----936.80 MGD

Member (WS)

Copy to: -

25. Pr. Secretary to Lt. Governor
26. P.S. to Chief Minister, Delhi
27. P.S. to Chief Secretary, Delhi
28. Principal Secretary (UD) Govt., of NCT of Delhi
29. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
30. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
31. Hudson Lane, Civil Lines ,Delhi-110009
32. CE(WW)
33. CE (East)
34. Dir F & A
35. E.E. (EDP) for uploading on Website
36. Office copy

DELHI JAL BOARD
OFFICE OF MEMBER (WATER SUPPLY)
VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI

No. DJB/M (WS)/A-97/2017/
WATER PRODUCTION REPORT

Date: 08.09.21

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/666.00	1600	4'	235
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		6.6,4.6

PRODUCTION DETAILS **TOTAL PRODUCTION : 939.42 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

YAMUNA WATER

i)	Chandrawal	98	Wazirabad Pond	91.78	
ii)	Wazirabad	124	-Do-	123.88	
iii)	Haiderpur	220	WJC Canal	215.27	
iv)	Nangloi	40	-Do-	40.45	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	22.00	
vi)	Dwarka		WJC Canal	52.36	
vii)	Bawana		WJC Canal	20.00	

GANGA WATER

viii)	Bhagirathi	100	Upper Ganga Canal	108.53	
ix)	Sonia Vihar	144	-Do-	140.16	
1)	Production of Water Treatment Plants			814.45	

RECYCLING /PROCESS WASTE WATER PLANTS

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.29	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.10	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	3.58	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			29.97	

GROUND WATER SOURCES

3)	Production from Ranney wells & Tube wells		95.00	
	Total	(1+2+3)	939.42	

5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	4.14
Greater Kailash (N)	4.80	3.65
Deer Park	4.50	4.20
Janak Puri	3.00	3.65
Kalka Ji	3.65	4.65

6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e..07.09.21 -----939.42 MGD

Member (WS)

Copy to: -

25. Pr. Secretary to Lt. Governor
26. P.S. to Chief Minister, Delhi
27. P.S. to Chief Secretary, Delhi
28. Principal Secretary (UD) Govt., of NCT of Delhi
29. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
30. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
 - a. Hudson Lane, Civil Lines ,Delhi-110009
31. CE(WW)
32. CE (East)

DELHI JAL BOARD
OFFICE OF MEMBER (WATER SUPPLY)
VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI

No. DJB/M (WS)/A-97/2017/
WATER PRODUCTION REPORT

Date: 09.09.21

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/665.60	1200	3'	230
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		7.1

PRODUCTION DETAILS **TOTAL PRODUCTION : 951.84 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

YAMUNA WATER

i)	Chandrawal	98	Wazirabad Pond	94.94	
ii)	Wazirabad	124	-Do-	123.89	
iii)	Haiderpur	220	WJC Canal	219.35	
iv)	Nangloi	40	-Do-	44.95	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	21.95	
vi)	Dwarka		WJC Canal	52.37	
vii)	Bawana		WJC Canal	20.00	

GANGA WATER

vii)	Bhagirathi	100	Upper Ganga Canal	109.22	
viii)	Sonia Vihar	144	-Do-	139.99	
1)	Production of Water Treatment Plants			826.66	

RECYCLING /PROCESS WASTE WATER PLANTS

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.26	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.10	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	3.82	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			30.18	

GROUND WATER SOURCES

3)	Production from Ranney wells & Tube wells			95.00	
	Total	(1+2+3)		951.84	

5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	4.26
Greater Kailash (N)	4.80	3.35
Deer Park	4.50	4.10
Janak Puri	3.00	3.20

Kalka Ji	3.65	4.26
----------	------	------

6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e. 09.09.2021 -----951.84 MGD

Member (WS)

Copy to: -

12. Pr. Secretary to Lt. Governor
13. P.S. to Chief Minister, Delhi
14. P.S. to Chief Secretary, Delhi
15. Principal Secretary (UD) Govt., of NCT of Delhi
16. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
17. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
a. Hudson Lane, Civil Lines ,Delhi-110009
18. CE(WW)
19. CE (East)
20. Dir F & A
21. E.E. (EDP) for uploading on Website
22. Office copy

DELHI JAL BOARD
OFFICE OF MEMBER (WATER SUPPLY)
VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI

No. DJB/M (WS)/A-97/2017/
WATER PRODUCTION REPORT

Date: 10.09.21

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/665.20	800	2'	350
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		6.6

PRODUCTION DETAILS

TOTAL PRODUCTION : 948.90 MGD

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

YAMUNA WATER

i)	Chandrawal	98	Wazirabad Pond	93.48	
ii)	Wazirabad	124	-Do-	123.90	
iii)	Haiderpur	220	WJC Canal	218.49	
iv)	Nangloi	40	-Do-	43.59	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	21.80	
vi)	Dwarka		WJC Canal	52.36	
vii)	Bawana		WJC Canal	20.00	

GANGA WATER

viii)	Bhagirathi	100	Upper Ganga Canal	109.83	
ix)	Sonia Vihar	144	-Do-	140.14	
1)	Production of Water Treatment Plants			823.59	

RECYCLING /PROCESS WASTE WATER PLANTS

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.25	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.30	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	3.76	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			30.31	

GROUND WATER SOURCES

3)	Production from Ranney wells & Tube wells			95.00	
	Total	(1+2+3)		948.90	

5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	4.26
Greater Kailash (N)	4.80	3.35
Deer Park	4.50	4.20
Janak Puri	3.00	3.40
Kalka Ji	3.65	3.65

6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e..09.09.21 -----948.90 MGD

Member (WS)

Copy to: -

33. Pr. Secretary to Lt. Governor
34. P.S. to Chief Minister, Delhi
35. P.S. to Chief Secretary, Delhi
36. Principal Secretary (UD) Govt., of NCT of Delhi
37. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
38. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
 - a. Hudson Lane, Civil Lines ,Delhi-110009
39. CE(WW)
40. CE (East)

DELHI JAL BOARD
OFFICE OF MEMBER (WATER SUPPLY)
VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI

No. DJB/M (WS)/A-97/2017/
WATER PRODUCTION REPORT

Date: 11.09.21

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/665.20	800	2'	235
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		7.4,5.4

PRODUCTION DETAILS

TOTAL PRODUCTION : 947.98 MGD

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

YAMUNA WATER

i)	Chandrawal	98	Wazirabad Pond	94.81	
ii)	Wazirabad	124	-Do-	122.37	
iii)	Haiderpur	220	WJC Canal	218.70	
iv)	Nangloi	40	-Do-	44.44	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	21.58	
vi)	Dwarka		WJC Canal	52.35	
vii)	Bawana		WJC Canal	20.00	

GANGA WATER

viii)	Bhagirathi	100	Upper Ganga Canal	108.70	
ix)	Sonia Vihar	144	-Do-	139.83	
1)	Production of Water Treatment Plants			822.78	

RECYCLING /PROCESS WASTE WATER PLANTS

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.18	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.30	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	3.72	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			30.20	

GROUND WATER SOURCES

3)	Production from Ranney wells & Tube wells		95.00	
	Total	(1+2+3)	947.98	

5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	4.35
Greater Kailash (N)	4.80	3.04
Deer Park	4.50	4.10
Janak Puri	3.00	3.40
Kalka Ji	3.65	4.26

m6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Afected

Note :- Total supply of water in last 24 hours i.e. 10.09.21 -----947.98 MGD

Member (WS)

Copy to: -

- 37. Pr. Secretary to Lt. Governor**
- 38. P.S. to Chief Minister, Delhi**
- 39. P.S. to Chief Secretary, Delhi**
- 40. Principal Secretary (UD) Govt., of NCT of Delhi**
- 41. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi**
- 42. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,**
- 43. Hudson Lane, Civil Lines ,Delhi-110009**
- 44. CE(WW)**
- 45. CE (East)**
- 46. Dir F & A**
- 47. E.E. (EDP) for uploading on Website**
- 48. Office copy**

DELHI JAL BOARD
OFFICE OF MEMBER (WATER SUPPLY)
VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI

No. DJB/M (WS)/A-97/2017/
WATER PRODUCTION REPORT

Date: 12.09.21

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/668.40	9600	24"	7.8
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		7.8

PRODUCTION DETAILS **TOTAL PRODUCTION : 910.81 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

YAMUNA WATER

i)	Chandrawal	98	Wazirabad Pond	88.26	
ii)	Wazirabad	124	-Do-	91.70	
iii)	Haiderpur	220	WJC Canal	219.26	
iv)	Nangloi	40	-Do-	45.03	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	21.65	
vi)	Dwarka		WJC Canal	51.72	
vii)	Bawana		WJC Canal	19.81	

GANGA WATER

viii)	Bhagirathi	100	Upper Ganga Canal	108.00	
ix)	Sonia Vihar	144	-Do-	140.00	
1)	Production of Water Treatment Plants			785.43	

RECYCLING /PROCESS WASTE WATER PLANTS

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.18	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.20	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.00	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			30.38	

GROUND WATER SOURCES

3)	Production from Ranney wells & Tube wells		95.00	
	Total	(1+2+3)	910.81	

5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	4.35
Greater Kailash (N)	4.80	3.04
Deer Park	4.50	4.10
Janak Puri	3.00	3.40
Kalka Ji	3.65	3.53

m6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Afected

Note :- Total supply of water in last 24 hours i.e. 11.09.21 -----910.81 MGD

Member (WS)

Copy to: -

- 49. Pr. Secretary to Lt. Governor**
- 50. P.S. to Chief Minister, Delhi**
- 51. P.S. to Chief Secretary, Delhi**
- 52. Principal Secretary (UD) Govt., of NCT of Delhi**
- 53. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi**
- 54. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,**
- 55. Hudson Lane, Civil Lines ,Delhi-110009**
- 56. CE(WW)**
- 57. CE (East)**
- 58. Dir F & A**
- 59. E.E. (EDP) for uploading on Website**
- 60. Office copy**

DELHI JAL BOARD
OFFICE OF MEMBER (WATER SUPPLY)
VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI

No. DJB/M (WS)/A-97/2017/

Date: 13.09.21

WATER PRODUCTION REPORT

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/668.40	9600	24'	1600
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		5.4,4.6

PRODUCTION DETAILS

TOTAL PRODUCTION : 943.48 MGD

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

YAMUNA WATER

i)	Chandrawal	98	Wazirabad Pond	94.02	
ii)	Wazirabad	124	-Do-	123.50	
iii)	Haiderpur	220	WJC Canal	219.36	
iv)	Nangloi	40	-Do-	44.09	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	21.62	
vi)	Dwarka		WJC Canal	52.37	
vii)	Bawana		WJC Canal	20.00	

GANGA WATER

vii)	Bhagirathi	100	Upper Ganga Canal	108.70	
viii)	Sonia Vihar	144	-Do-	136.94	
1)	Production of Water Treatment Plants			820.60	

RECYCLING /PROCESS WASTE WATER PLANTS

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.19	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.10	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	1.59	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			27.88	

GROUND WATER SOURCES

3)	Production from Ranney wells & Tube wells			95.00	
	Total	(1+2+3)		943.48	

5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	4.15
Greater Kailash (N)	4.80	3.04
Deer Park	4.50	4.10
Janak Puri	3.00	3.40
Kalka Ji	3.65	4.14

6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e..12.09.21 -----943.48 MGD

Member (WS)

Copy to: -

41. Pr. Secretary to Lt. Governor
42. P.S. to Chief Minister, Delhi
43. P.S. to Chief Secretary, Delhi
44. Principal Secretary (UD) Govt., of NCT of Delhi
45. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
46. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
 - a. Hudson Lane, Civil Lines ,Delhi-110009
47. CE(WW)
48. CE (East)

DELHI JAL BOARD
OFFICE OF MEMBER (WATER SUPPLY)
VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI

No. DJB/M (WS)/A-97/2017/
WATER PRODUCTION REPORT

Date: 14.09.21

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/668.70	10800	27"	1600
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		7.5

PRODUCTION DETAILS **TOTAL PRODUCTION : 950.39 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

YAMUNA WATER

i)	Chandrawal	98	Wazirabad Pond	94.80	
ii)	Wazirabad	124	-Do-	123.92	
iii)	Haiderpur	220	WJC Canal	219.35	
iv)	Nangloi	40	-Do-	44.41	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	22.16	
vi)	Dwarka		WJC Canal	52.36	
vii)	Bawana		WJC Canal	20.02	

GANGA WATER

vii)	Bhagirathi	100	Upper Ganga Canal	107.97	
viii)	Sonia Vihar	144	-Do-	140.01	
1)	Production of Water Treatment Plants			825.00	

RECYCLING /PROCESS WASTE WATER PLANTS

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.19	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.10	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.10	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			30.39	

GROUND WATER SOURCES

3)	Production from Ranney wells & Tube wells			95.00	
	Total	(1+2+3)		950.39	

5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	4.14
Greater Kailash (N)	4.80	3.04
Deer Park	4.50	4.00
Janak Puri	3.00	3.40

Kalka Ji	3.65	4.45
----------	------	------

m6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e. 13.08.21 -----950.39 MGD

Member (WS)

Copy to: -

61. Pr. Secretary to Lt. Governor
62. P.S. to Chief Minister, Delhi
63. P.S. to Chief Secretary, Delhi
64. Principal Secretary (UD) Govt., of NCT of Delhi
65. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
66. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
67. Hudson Lane, Civil Lines ,Delhi-110009
68. CE(WW)
69. CE (East)
70. Dir F & A
71. E.E. (EDP) for uploading on Website
72. Office copy

No. DJB/M (WS)/A-97/2017/
WATER PRODUCTION REPORT

Date: 15.09.21

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/669.40	15200	38'	2400
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		6.5,4.7

PRODUCTION DETAILS

TOTAL PRODUCTION : 946.35 MGD

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

YAMUNA WATER

i)	Chandrawal	98	Wazirabad Pond	93.64	
ii)	Wazirabad	124	-Do-	123.68	
iii)	Haiderpur	220	WJC Canal	219.36	
iv)	Nangloi	40	-Do-	44.70	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	22.11	
vi)	Dwarka		WJC Canal	52.29	
vii)	Bawana		WJC Canal	21.03	

GANGA WATER

viii)	Bhagirathi	100	Upper Ganga Canal	103.90	
ix)	Sonia Vihar	144	-Do-	140.18	
1)	Production of Water Treatment Plants			820.89	

RECYCLING /PROCESS WASTE WATER PLANTS

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.20	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.10	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.16	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			30.46	

GROUND WATER SOURCES

3)	Production from Ranney wells & Tube wells			95.00	
	Total	(1+2+3)		946.35	

5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	3.96
Greater Kailash (N)	4.80	--
Deer Park	4.50	4.20
Janak Puri	3.00	
Kalka Ji	3.65	4.45

6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e..14.09.21 -----946.35 MGD

Member (WS)

Copy to: -

49. Pr. Secretary to Lt. Governor
50. P.S. to Chief Minister, Delhi
51. P.S. to Chief Secretary, Delhi
52. Principal Secretary (UD) Govt., of NCT of Delhi
53. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
54. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
 - a. Hudson Lane, Civil Lines ,Delhi-110009
55. CE(WW)
56. CE (East)

DELHI JAL BOARD
OFFICE OF MEMBER (WATER SUPPLY)
VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI

No. DJB/M (WS)/A-97/2017/
WATER PRODUCTION REPORT

Date: 16.09.21

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/669.40	51930		
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		7.4,4.8

PRODUCTION DETAILS **TOTAL PRODUCTION : 949.48 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

YAMUNA WATER

i)	Chandrawal	98	Wazirabad Pond	94.16	
ii)	Wazirabad	124	-Do-	123.93	
iii)	Haiderpur	220	WJC Canal	219.15	
iv)	Nangloi	40	-Do-	43.65	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	21.65	
vi)	Dwarka		WJC Canal	52.32	
vii)	Bawana		WJC Canal	20.02	

GANGA WATER

vii)	Bhagirathi	100	Upper Ganga Canal	108.85	
viii)	Sonia Vihar	144	-Do-	140.05	
1)	Production of Water Treatment Plants			823.78	

RECYCLING /PROCESS WASTE WATER PLANTS

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.19	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.30	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.21	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			30.70	

GROUND WATER SOURCES

3)	Production from Ranney wells & Tube wells			95.00	
	Total	(1+2+3)		949.48	

5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	3.96
Greater Kailash (N)	4.80	3.04
Deer Park	4.50	4.10
Janak Puri	3.00	3.40

Kalka Ji	3.65	4.26
----------	------	------

6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e. 15.09.2021 -----949.48 MGD

Member (WS)

Copy to: -

23. Pr. Secretary to Lt. Governor
24. P.S. to Chief Minister, Delhi
25. P.S. to Chief Secretary, Delhi
26. Principal Secretary (UD) Govt., of NCT of Delhi
27. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
28. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
a. Hudson Lane, Civil Lines ,Delhi-110009
29. CE(WW)
30. CE (East)
31. Dir F & A
32. E.E. (EDP) for uploading on Website
33. Office copy

DELHI JAL BOARD
OFFICE OF MEMBER (WATER SUPPLY)
VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI

No. DJB/M (WS)/A-97/2017/
WATER PRODUCTION REPORT

Date: 17.09.21

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/671.20	26000	65'	4500
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		6.2

PRODUCTION DETAILS **TOTAL PRODUCTION : 949.97 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

YAMUNA WATER

i)	Chandrawal	98	Wazirabad Pond	95.07	
ii)	Wazirabad	124	-Do-	122.18	
iii)	Haiderpur	220	WJC Canal	219.25	
iv)	Nangloi	40	-Do-	44.49	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	22.80	
vi)	Dwarka		WJC Canal	52.28	
vii)	Bawana		WJC Canal	20.01	

GANGA WATER

viii)	Bhagirathi	100	Upper Ganga Canal	108.91	
ix)	Sonia Vihar	144	-Do-	140.36	
1)	Production of Water Treatment Plants			824.35	

RECYCLING /PROCESS WASTE WATER PLANTS

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.23	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.20	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.19	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			30.62	

GROUND WATER SOURCES

3)	Production from Ranney wells & Tube wells		95.00	
	Total	(1+2+3)	949.97	

5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	4.05
Greater Kailash (N)	4.80	3.04
Deer Park	4.50	4.00
Janak Puri	3.00	3.40
Kalka Ji	3.65	3.65

6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e..16.09.21 -----949.97 MGD

Member (WS)

Copy to: -

57. Pr. Secretary to Lt. Governor
58. P.S. to Chief Minister, Delhi
59. P.S. to Chief Secretary, Delhi
60. Principal Secretary (UD) Govt., of NCT of Delhi
61. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
62. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
 - a. Hudson Lane, Civil Lines ,Delhi-110009
63. CE(WW)
64. CE (East)