

**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/  
**WATER PRODUCTION REPORT**

Date: 02.03.21

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/667.40			31
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		5.6

**PRODUCTION DETAILS** **TOTAL PRODUCTION : 934.33 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	86.47	
ii)	Wazirabad	124	-Do-	123.90	
iii)	Haiderpur	220	WJC Canal	218.03	
iv)	Nangloi	40	-Do-	43.67	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	21.94	
vi)	Dwarka		WJC Canal	50.46	
vii)	Bawana		WJC Canal	20.01	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	108.79	
viii)	Sonia Vihar	144	-Do-	141.80	
1)	Production of Water Treatment Plants			815.07	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	8.47	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.00	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.79	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			29.26	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells			90	
	Total	(1+2+3)		934.33	

**5. MAJOR UGRs' LEVELS IN METERS.**

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	3.96
Greater Kailash (O)	5.12	4.35
Greater Kailash (N)	4.80	3.35
Deer Park	4.50	4.00
Janak Puri	3.00	3.35
Kalka Ji	3.65	4.54

**m6. TRANSMISSION MAIN**

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Afected

**Note :- Total supply of water in last 24 hours i.e. 01.03.21 -----934.33 MGD**

**Member (WS)**

**Copy to: -**

1. Pr. Secretary to Lt. Governor
2. P.S. to Chief Minister, Delhi
3. P.S. to Chief Secretary, Delhi
4. Principal Secretary (UD) Govt., of NCT of Delhi
5. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
6. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
  - a. Hudson Lane, Civil Lines ,Delhi-110009
7. CE(WW)
8. CE (East)
9. Dir F & A
10. E.E. (EDP) for uploading on Website
11. Office copy

**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/  
**WATER PRODUCTION REPORT**

Date: 03.03.21

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/667.40			36
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		6.5,4.6

**PRODUCTION DETAILS** **TOTAL PRODUCTION : 894.77 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	66.53	
ii)	Wazirabad	124	-Do-	110.83	
iii)	Haiderpur	220	WJC Canal	218.15	
iv)	Nangloi	40	-Do-	43.79	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	16.86	
vi)	Dwarka		WJC Canal	50.48	
vii)	Bawana		WJC Canal	20.01	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	107.12	
viii)	Sonia Vihar	144	-Do-	139.78	
1)	Production of Water Treatment Plants			773.55	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.43	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.10	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.69	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			31.22	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells		90	
	Total	(1+2+3)	894.77	

**5. MAJOR UGRs' LEVELS IN METERS.**

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	3.96
Greater Kailash (O)	5.12	4.26
Greater Kailash (N)	4.80	3.65
Deer Park	4.50	4.20
Janak Puri	3.00	3.35
Kalka Ji	3.65	3.65

## 6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e. 02.03.2021 -----894.77 MGD

Member (WS)

Copy to: -

12. Pr. Secretary to Lt. Governor
13. P.S. to Chief Minister, Delhi
14. P.S. to Chief Secretary, Delhi
15. Principal Secretary (UD) Govt., of NCT of Delhi
16. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
17. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
  - a. Hudson Lane, Civil Lines ,Delhi-110009
18. CE(WW)
19. CE (East)
20. Dir F & A
21. E.E. (EDP) for uploading on Website
22. Office copy

**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/  
**WATER PRODUCTION REPORT**

Date: 04.03.21

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/667.40			37
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		7.4

**PRODUCTION DETAILS** **TOTAL PRODUCTION : 889.31 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	88.24	
ii)	Wazirabad	124	-Do-	110.28	
iii)	Haiderpur	220	WJC Canal	196.12	
iv)	Nangloi	40	-Do-	44.11	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	12.70	
vi)	Dwarka		WJC Canal	50.45	
vii)	Bawana		WJC Canal	19.99	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	106.90	
viii)	Sonia Vihar	144	-Do-	139.45	
1)	Production of Water Treatment Plants			768.24	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.30	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.10	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.67	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			31.07	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells			90	
	Total	(1+2+3)		889.31	

**5. MAJOR UGRs' LEVELS IN METERS.**

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	3.96
Greater Kailash (O)	5.12	3.90
Greater Kailash (N)	4.80	3.04
Deer Park	4.50	3.80
Janak Puri	3.00	1.70
Kalka Ji	3.65	3.23

## 6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e..03.03.21 -----889.31 MGD

Member (WS)

Copy to: -

1. Pr. Secretary to Lt. Governor
2. P.S. to Chief Minister, Delhi
3. P.S. to Chief Secretary, Delhi
4. Principal Secretary (UD) Govt., of NCT of Delhi
5. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
6. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
  - a. Hudson Lane, Civil Lines ,Delhi-110009
7. CE(WW)
8. CE (East)

**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/  
**WATER PRODUCTION REPORT**

Date: 05.03.21

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/667.40			28
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		5.1

**PRODUCTION DETAILS** **TOTAL PRODUCTION : 897.18 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	91.41	
ii)	Wazirabad	124	-Do-	118.36	
iii)	Haiderpur	220	WJC Canal	193.40	
iv)	Nangloi	40	-Do-	43.84	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	13.08	
vi)	Dwarka		WJC Canal	50.47	
vii)	Bawana		WJC Canal	20.02	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	107.54	
viii)	Sonia Vihar	144	-Do-	140.13	
1)	Production of Water Treatment Plants			778.25	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.34	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	15.00	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	3.59	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			28.93	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells		90	
	Total	(1+2+3)	897.18	

**5. MAJOR UGRs' LEVELS IN METERS.**

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	3.96
Greater Kailash (O)	5.12	3.90
Greater Kailash (N)	4.80	3.04
Deer Park	4.50	3.50
Janak Puri	3.00	2.55
Kalka Ji	3.65	4.54

## 6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Afected

Note :- Total supply of water in last 24 hours i.e. 04.03.21 -----897.18 MGD

Member (WS)

Copy to: -

23. Pr. Secretary to Lt. Governor
24. P.S. to Chief Minister, Delhi
25. P.S. to Chief Secretary, Delhi
26. Principal Secretary (UD) Govt., of NCT of Delhi
27. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
28. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
  - a. Hudson Lane, Civil Lines ,Delhi-110009
29. CE(WW)
30. CE (East)
31. Dir F & A
32. E.E. (EDP) for uploading on Website
33. Office copy

No. DJB/M (WS)/A-97/2017/  
WATER PRODUCTION REPORT

Date: 06.03.21

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/667.40			38
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		5.5,3.9

## PRODUCTION DETAILS

TOTAL PRODUCTION : 854.67 MGD

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

## YAMUNA WATER

i)	Chandrawal	98	Wazirabad Pond	69.90	
ii)	Wazirabad	124	-Do-	103.64	
iii)	Haiderpur	220	WJC Canal	200.72	
iv)	Nangloi	40	-Do-	37.93	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	16.20	
vi)	Dwarka		WJC Canal	46.14	
vii)	Bawana		WJC Canal	17.54	

## GANGA WATER

vii)	Bhagirathi	100	Upper Ganga Canal	103.19	
viii)	Sonia Vihar	144	-Do-	139.14	
1)	Production of Water Treatment Plants			734.40	

## RECYCLING /PROCESS WASTE WATER PLANTS

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	9.47	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.10	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.70	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			30.27	

## GROUND WATER SOURCES

3)	Production from Ranney wells & Tube wells			90	
	Total	(1+2+3)		854.67	

## 5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	3.96
Greater Kailash (O)	5.12	3.90
Greater Kailash (N)	4.80	3.04
Deer Park	4.50	3.15
Janak Puri	3.00	2.45
Kalka Ji	3.65	4.14

**m6. TRANSMISSION MAIN**

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Afected
1.	Less pumping due to low level at Haiderpur canal		
	Less pumping in Chandrawal due to increase of ammonia level in raw water Yamuna		
	Less pumping at Nangloi due to low raw water level		

**Note :- Total supply of water in last 24 hours i.e. 05.03.21 -----854.67 MGD**

**Member (WS)**

**Copy to: -**

1. Pr. Secretary to Lt. Governor
2. P.S. to Chief Minister, Delhi
3. P.S. to Chief Secretary, Delhi
4. Principal Secretary (UD) Govt., of NCT of Delhi
5. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
6. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
  - a. Hudson Lane, Civil Lines ,Delhi-110009
7. CE(WW)
8. CE (East)
9. Dir F & A
10. E.E. (EDP) for uploading on Website
11. Office copy

**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/

Date: 07.03.21

**WATER PRODUCTION REPORT**

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/667.40			30
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		6.5

**PRODUCTION DETAILS**

**TOTAL PRODUCTION : 820.85 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	59.08	
ii)	Wazirabad	124	-Do-	78.31	
iii)	Haiderpur	220	WJC Canal	202.72	
iv)	Nangloi	40	-Do-	37.49	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	17.06	
vi)	Dwarka		WJC Canal	45.21	
vii)	Bawana			17.05	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	106.08	
viii)	Sonia Vihar	144	-Do-	138.16	
1)	Production of Water Treatment Plants			701.16	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	8.78	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.20	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.71	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			29.69	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells			90	
	Total	(1+2+3)		820.85	

**5. MAJOR UGRs' LEVELS IN METERS.**

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	3.96
Greater Kailash (O)	5.12	3.90
Greater Kailash (N)	4.80	3.04
Deer Park	4.50	3.80
Janak Puri	3.00	2.93
Kalka Ji	3.65	4.54

## 6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e. 06.03.2021 -----820.85 MGD

Member (WS)

Copy to: -

12. Pr. Secretary to Lt. Governor
13. P.S. to Chief Minister, Delhi
14. P.S. to Chief Secretary, Delhi
15. Principal Secretary (UD) Govt., of NCT of Delhi
16. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
17. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
  - a. Hudson Lane, Civil Lines ,Delhi-110009
18. CE(WW)
19. CE (East)
20. Dir F & A
21. E.E. (EDP) for uploading on Website
22. Office copy

No. DJB/M (WS)/A-97/2017/  
**WATER PRODUCTION REPORT**

Date: 08.03.21

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/667.40			39
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		6.5

**PRODUCTION DETAILS****TOTAL PRODUCTION : 822.27 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	71.56	
ii)	Wazirabad	124	-Do-	70.97	
iii)	Haiderpur	220	WJC Canal	204.94	
iv)	Nangloi	40	-Do-	38.10	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	16.35	
vi)	Dwarka		WJC Canal	39.26	
vii)	Bawana		WJC Canal	17.05	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	106.04	
viii)	Sonia Vihar	144	-Do-	138.35	
1)	Production of Water Treatment Plants			702.62	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	8.86	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.10	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.69	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			29.65	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells			90	
	Total	(1+2+3)		822.27	

**5. MAJOR UGRs' LEVELS IN METERS.**

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	3.96
Greater Kailash (O)	5.12	4.11
Greater Kailash (N)	4.80	3.04
Deer Park	4.50	3.80
Janak Puri	3.00	3.05
Kalka Ji	3.65	4.26

**m6. TRANSMISSION MAIN**

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Afected

**Note :- Total supply of water in last 24 hours i.e. 07.03.21 -----822.27 MGD**

**Member (WS)**

**Copy to: -**

1. Pr. Secretary to Lt. Governor
2. P.S. to Chief Minister, Delhi
3. P.S. to Chief Secretary, Delhi
4. Principal Secretary (UD) Govt., of NCT of Delhi
5. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
6. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
  - a. Hudson Lane, Civil Lines ,Delhi-110009
7. CE(WW)
8. CE (East)
9. Dir F & A
10. E.E. (EDP) for uploading on Website
11. Office copy

**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/  
**WATER PRODUCTION REPORT**

Date: 09.03.21

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/667.40			38
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		6.5

**PRODUCTION DETAILS** **TOTAL PRODUCTION : 834.30 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	83.60	Due to raw water shortage
ii)	Wazirabad	124	-Do-	75.91	Due to raw water shortage
iii)	Haiderpur	220	WJC Canal	207.61	Due to raw water shortage
iv)	Nangloi	40	-Do-	37.65	Due to raw water shortage
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	16.21	Due to raw water shortage
vi)	Dwarka		WJC Canal	39.28	
vii)	Bawana		WJC Canal	10.78	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	106.12	
viii)	Sonia Vihar	144	-Do-	137.51	
1)	Production of Water Treatment Plants			714.67	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	8.47	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.20	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.69	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			29.63	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells			90	
	Total	(1+2+3)		834.30	

**5. MAJOR UGRs' LEVELS IN METERS.**

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	3.96
Greater Kailash (O)	5.12	4.11
Greater Kailash (N)	4.80	3.04
Deer Park	4.50	3.60
Janak Puri	3.00	3.20
Kalka Ji	3.65	4.54

**m6. TRANSMISSION MAIN**

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Afected
	Bawana 1000 mm line closed due to repair work near karala	2.45 pm to 4.30 am	

**Note :- Total supply of water in last 24 hours i.e. 08.03.21 -----834.30 MGD**

**Member (WS)**

**Copy to: -**

1. Pr. Secretary to Lt. Governor
2. P.S. to Chief Minister, Delhi
3. P.S. to Chief Secretary, Delhi
4. Principal Secretary (UD) Govt., of NCT of Delhi
5. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
6. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
  - a. Hudson Lane, Civil Lines ,Delhi-110009
7. CE(WW)
8. CE (East)
9. Dir F & A
10. E.E. (EDP) for uploading on Website
11. Office copy

**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/  
**WATER PRODUCTION REPORT**

Date: 10.03.21

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/664.40			40
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		6.9,4.6

**PRODUCTION DETAILS**

**TOTAL PRODUCTION : 840.05 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	85.86	
ii)	Wazirabad	124	-Do-	76.04	
iii)	Haiderpur	220	WJC Canal	202.80	
iv)	Nangloi	40	-Do-	37.96	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	16.22	
vi)	Dwarka		WJC Canal	39.45	
vii)	Bawana		WJC Canal	18.15	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	105.23	
viii)	Sonia Vihar	144	-Do-	138.90	
1)	Production of Water Treatment Plants			720.61	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	8.56	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.20	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.68	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			29.24	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells			90	
	Total	(1+2+3)		840.05	

**5. MAJOR UGRs' LEVELS IN METERS.**

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	3.96
Greater Kailash (O)	5.12	3.68
Greater Kailash (N)	4.80	3.04
Deer Park	4.50	3.60
Janak Puri	3.00	3.30
Kalka Ji	3.65	4.29

## 6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e. 09.03.2021 -----840.05 MGD

Member (WS)

Copy to: -

12. Pr. Secretary to Lt. Governor
13. P.S. to Chief Minister, Delhi
14. P.S. to Chief Secretary, Delhi
15. Principal Secretary (UD) Govt., of NCT of Delhi
16. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
17. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
  - a. Hudson Lane, Civil Lines ,Delhi-110009
18. CE(WW)
19. CE (East)
20. Dir F & A
21. E.E. (EDP) for uploading on Website
22. Office copy

**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/  
**WATER PRODUCTION REPORT**

Date: 11.03.21

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/664.40			39
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		7.4

**PRODUCTION DETAILS** **TOTAL PRODUCTION : 830.49 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	86.50	
ii)	Wazirabad	124	-Do-	69.20	
iii)	Haiderpur	220	WJC Canal	200.68	
iv)	Nangloi	40	-Do-	37.67	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	16.49	
vi)	Dwarka		WJC Canal	39.44	
vii)	Bawana		WJC Canal	17.15	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	105.50	
viii)	Sonia Vihar	144	-Do-	138.08	
1)	Production of Water Treatment Plants			710.71	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	9.40	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.10	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.28	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			29.78	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells			90	
	Total	(1+2+3)		830.49	

**5. MAJOR UGRs' LEVELS IN METERS.**

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	3.96
Greater Kailash (O)	5.12	3.35
Greater Kailash (N)	4.80	3.04
Deer Park	4.50	3.70
Janak Puri	3.00	3.25
Kalka Ji	3.65	4.26

## 6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e..10.03.21 -----830.49 MGD

Member (WS)

Copy to: -

1. Pr. Secretary to Lt. Governor
2. P.S. to Chief Minister, Delhi
3. P.S. to Chief Secretary, Delhi
4. Principal Secretary (UD) Govt., of NCT of Delhi
5. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
6. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
  - a. Hudson Lane, Civil Lines ,Delhi-110009
7. CE(WW)
8. CE (East)

**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/  
**WATER PRODUCTION REPORT**

Date: 12.03.21

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/664.40			42
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		6.7

**PRODUCTION DETAILS**

**TOTAL PRODUCTION : 842.74 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	89.20	
ii)	Wazirabad	124	-Do-	70.93	
iii)	Haiderpur	220	WJC Canal	203.52	
iv)	Nangloi	40	-Do-	37.73	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	17.39	
vi)	Dwarka		WJC Canal	42.11	
vii)	Bawana		WJC Canal	16.50	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	106.51	
viii)	Sonia Vihar	144	-Do-	138.80	
1)	Production of Water Treatment Plants			722.69	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	9.53	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.20	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.32	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			30.05	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells			90	
	Total	(1+2+3)		842.74	

**5. MAJOR UGRs' LEVELS IN METERS.**

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	3.96
Greater Kailash (O)	5.12	3.35
Greater Kailash (N)	4.80	3.34
Deer Park	4.50	3.60
Janak Puri	3.00	3.40
Kalka Ji	3.65	4.26

## 6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Afected

Note :- Total supply of water in last 24 hours i.e. 11.03.21 -----842.74 MGD

Member (WS)

Copy to: -

23. Pr. Secretary to Lt. Governor
24. P.S. to Chief Minister, Delhi
25. P.S. to Chief Secretary, Delhi
26. Principal Secretary (UD) Govt., of NCT of Delhi
27. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
28. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
  - a. Hudson Lane, Civil Lines ,Delhi-110009
29. CE(WW)
30. CE (East)
31. Dir F & A
32. E.E. (EDP) for uploading on Website
33. Office copy

**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/  
**WATER PRODUCTION REPORT**

Date: 06.03.21

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/664.40			32
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		7.4

**PRODUCTION DETAILS** **TOTAL PRODUCTION : 815.55 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	87.82	
ii)	Wazirabad	124	-Do-	77.92	
iii)	Haiderpur	220	WJC Canal	202.19	
iv)	Nangloi	40	-Do-	37.60	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	17.50	
vi)	Dwarka		WJC Canal	43.41	
vii)	Bawana		WJC Canal	17.30	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	73.31	
viii)	Sonia Vihar	144	-Do-	139.31	
1)	Production of Water Treatment Plants			696.36	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	9.45	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.20	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	3.54	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			29.19	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells			90	
	Total	(1+2+3)		815.55	

**5. MAJOR UGRs' LEVELS IN METERS.**

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	3.96
Greater Kailash (O)	5.12	3.80
Greater Kailash (N)	4.80	3.35
Deer Park	4.50	3.80
Janak Puri	3.00	3.40
Kalka Ji	3.65	4.26

**m6. TRANSMISSION MAIN**

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Afected

**Note :- Total supply of water in last 24 hours i.e. 12.03.21 -----815.55 MGD**

**Member (WS)**

**Copy to: -**

1. Pr. Secretary to Lt. Governor
2. P.S. to Chief Minister, Delhi
3. P.S. to Chief Secretary, Delhi
4. Principal Secretary (UD) Govt., of NCT of Delhi
5. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
6. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
  - a. Hudson Lane, Civil Lines ,Delhi-110009
7. CE(WW)
8. CE (East)
9. Dir F & A
10. E.E. (EDP) for uploading on Website
11. Office copy

**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/  
**WATER PRODUCTION REPORT**

Date: 14.03.21

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/664.40			38
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		7.3

**PRODUCTION DETAILS** **TOTAL PRODUCTION : 785.13 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	83.42	
ii)	Wazirabad	124	-Do-	85.26	
iii)	Haiderpur	220	WJC Canal	206.75	
iv)	Nangloi	40	-Do-	37.80	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	17.28	
vi)	Dwarka		WJC Canal	43.48	
vii)	Bawana			17.00	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	35.46	
viii)	Sonia Vihar	144	-Do-	138.95	
1)	Production of Water Treatment Plants			665.40	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.23	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.10	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	3.40	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			29.73	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells			90	
	Total	(1+2+3)		785.13	

**5. MAJOR UGRs' LEVELS IN METERS.**

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	3.96
Greater Kailash (O)	5.12	3.38
Greater Kailash (N)	4.80	3.04
Deer Park	4.50	3.70
Janak Puri	3.00	3.40
Kalka Ji	3.65	4.26

## 6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e. 13.03.2021 -----785.13 MGD

Member (WS)

Copy to: -

12. Pr. Secretary to Lt. Governor
13. P.S. to Chief Minister, Delhi
14. P.S. to Chief Secretary, Delhi
15. Principal Secretary (UD) Govt., of NCT of Delhi
16. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
17. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
  - a. Hudson Lane, Civil Lines ,Delhi-110009
18. CE(WW)
19. CE (East)
20. Dir F & A
21. E.E. (EDP) for uploading on Website
22. Office copy

**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/  
**WATER PRODUCTION REPORT**

Date: 15.03.21

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/664.40			37
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		7.4

**PRODUCTION DETAILS** **TOTAL PRODUCTION : 818.47 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	85.12	
ii)	Wazirabad	124	-Do-	99.14	
iii)	Haiderpur	220	WJC Canal	210.69	
iv)	Nangloi	40	-Do-	37.99	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	15.50	
vi)	Dwarka		WJC Canal	43.55	
vii)	Bawana		WJC Canal	18.20	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	49.05	
viii)	Sonia Vihar	144	-Do-	138.73	
1)	Production of Water Treatment Plants			697.97	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.31	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.10	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.09	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			30.50	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells			90	
	Total	(1+2+3)		818.47	

**5. MAJOR UGRs' LEVELS IN METERS.**

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	3.96
Greater Kailash (O)	5.12	4.05
Greater Kailash (N)	4.80	3.35
Deer Park	4.50	3.70
Janak Puri	3.00	3.40
Kalka Ji	3.65	4.14

**m6. TRANSMISSION MAIN**

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Afected

**Note :- Total supply of water in last 24 hours i.e. 14.03.21 -----818.47 MGD**

**Member (WS)**

**Copy to: -**

1. Pr. Secretary to Lt. Governor
2. P.S. to Chief Minister, Delhi
3. P.S. to Chief Secretary, Delhi
4. Principal Secretary (UD) Govt., of NCT of Delhi
5. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
6. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
  - a. Hudson Lane, Civil Lines ,Delhi-110009
7. CE(WW)
8. CE (East)
9. Dir F & A
10. E.E. (EDP) for uploading on Website
11. Office copy

**DELHI JAL BOARD**  
**Advance Ledger Book**  
**Office of the Member (Drainage)**

Date Month	Vouch er Nos.	Description	Each Payment Amount	Total	Ledger Indent
1	2	3	4	5	6
		Balance in Hand	669.00		
		Recoupment of imprest vide cheque No of cv no.( )of dt.	4,331.00		
			5,000.00		
09.11.20	1	Paid to M/s Universal Book Store for photocopy paper vide cv no. 124on dated 09.11.20	850.00	850.00	
10.11.20	2	Pay for Spl.tea,coffee, biscuit, Tea Kada	290.00	1,140.00	
10.11.20	3	Pay to M/s bedi confectionery vide cv no. 8256 for milk	150.00	1,290.00	
10.11.20	4	Paid to Jal suvidha kendra for water jar vide cv no. nil	156.00	1,446.00	
11.11.20	5	Pay for Spl.tea,coffee, biscuit, Tea Kada	380.00	1,826.00	
12.11.20	6	Pay for Spl.tea,coffee, lunch,biscuit	290.00	2,116.00	
13.11.20	7	Pay for Spl.tea,coffee, biscuit	310.00	2,426.00	
16.11.20	8	Pay for Spl.tea, coffee, biscuit	290.00	2,716.00	
17.11.20	9	Pay for spl.tea coffee, biscuit	280.00	2,996.00	
17.11.20	10	Pay to M/s shivsji store vide cv no. 1871 for milk, green tea, biscuit, coffee, sugar cube	1,020.00	4,016.00	
18.11.20	11	Pay for Spl.tea,coffee, biscuit, Tea Kada	270.00	4,286.00	
19.11.20	12	Pay for Spl.tea,coffee, biscuit, Tea Kada	280.00	4,566.00	
20.11.20	13	Pay to m/s raj mandir vide cv no. 158412 for colin, sna	338.00	4,904.00	
		Four thousand nine hundered and four only	4904		
		Balance in Hand	96		
			5,000.00		

Enclosed :- 13 nos vouchers with sanction of Eo to M(Dr) on A/C of recoupment of imprest  
for meeting & seminar stationery expenses items for the office of Member(Dr)

EO to M(Dr)

<p style="text-align: center;"><b><u>DELHI JAL BOARD</u></b>  <b><u>Advance Ledger Book</u></b>  <b><u>Office of the Member (Drainage)</u></b></p>					
Date Month	Vouch er Nos.	Description	Each Payment Amount	Total	Ledger Indent
1	2	3	4	5	6
		Balance in Hand	96.00		
		Recoupment of imprest vide cheque No                      of	4,904.00		
		cv no.(            )of dt.	5,000.00		
23.11.20	1	Paid to M/s Shiv Traders for photocopy paper vide cv no. 061 on dated 23.11.20	900.00	900.00	
26.11.20	2	Pay to M/s Ram Swarop jagdish pd vide cv no. 0077546 for snack biscuit mosquito refil	231.00	1,131.00	
27.11.20	3	Pay to M/s sunshine super mart vide cv no. 17273 for milk, Sugar cube, green tea, biscuit, coffee, sugar cube	405.00	1,536.00	
03.12.20	4	Pay to M/s reliance store vide cv no 06 for tea, biscuit	313.00	1,849.00	
04.12.20	5	Pay to M/s Jal Suvida Kendra cv no nil for water	52	1,901.00	
04.12.20	6	Pay to M/s digital copier solution vide cv no. 3073 for gum, mask, pen, glue stick, fevicoal	465.00	2,366.00	
06.12.20	7	Pay to M/s hare krishna store vide cv no. nil for biscuit	220.00	2,586.00	
09.12.20	8	Pay for spl.tea coffee, biscuit	270.00	2,856.00	
10.12.20	9	Pay for Spl.tea,coffee, lunch	230.00	3,086.00	
11.12.20	10	Pay for spl.tea coffee, biscuit	290.00	3,376.00	
11.12.20	11	Pay to Mis Dilawar singh chair and key maker vide cv no 1396 for bush installed	150	3,526.00	
13.12.20	12	Pay to M/s Jal Suvida Kendra cv no nil for water	126.00	3,652.00	
14.12.20	13	Pay for spl.tea coffee, biscuit	240.00	3,892.00	
15.12.20	14	Pay for spl.tea coffee, biscuit	320.00	4,212.00	
15.12.20	15	Pay to M/s Rahul Thakur for H/R to perform CBI duty	400.00	4,612.00	
15.12.20	16	Pay to M/s Neha book & stationers vide cv no.333 for pen, feviquick	115.00	4,727.00	
16.12.20	17	Pay for spl.tea coffee, biscuit	270.00	4,997.00	
		Four thousand nine hundred and ninty seven only	4997		
		Balance in Hand	3		
			5,000.00		
<p>Enclosed :- 15 nos vouchers with sanction of Eo to M(Dr) on A/C of recoupment of imprest for meeting &amp; seminar, stationery expenses items for the office of Member(Dr)</p>					
				EO to M(Dr)	

[illegible]

11.12.20	10	Pay for spl.tea coffee, biscuit	150.00	3,376.00	
11.12.20	11	Pay to Mis Dilawar singh chair and key maker vide cv no 1396 for bush installed	126.00	3,526.00	
13.12.20	12	Pay to M/s Jal Suvida Kendra cv no nil for water	240.00	3,652.00	
14.12.20	13	Pay for spl.tea coffee, biscuit	320.00	3,892.00	
15.12.20	14	Pay for spl.tea coffee, biscuit	400.00	4,212.00	
15.12.20	15	Pay to M/s Rahul Thakur for H/R to perform CBI duty	115.00	4,612.00	
15.12.20	16	Pay to M/s Neha book & stationers vide cv no.333 for pen, feviquick	270.00	4,727.00	
16.12.20	17	Pay for spl.tea coffee, biscuit	4997	4,997.00	
			3		
		Balance in Hand	5,000.00		

Enclosed :  
- 15 nos  
vouchers  
with  
sanction  
of Eo to M  
(Dr) on  
A/C of  
recoupme  
nt of  
imprest  
for  
meeting &  
seminar,  
stationery  
expenses  
items for  
the office  
of  
Member  
(Dr)

EO to M(Dr)

**DELHI JAL BOARD**  
**Advance Ledger Book**  
**Office of the Member (Drainage)**

Date Month	Vouc her Nos.	Description	Each Payment Amount	Total	Ledger Indent
1	2	3	4	5	6
		Balance in Hand	3.00		
		Recoupment of imprest vide cheque No of cv no.( ) of dt.	4,997.00		
			5,000.00		

16.12.20	1	Paid to Jal suvidha kendra for water jar vide cv no. nil	52.00	52.00	
16.12.20	2	Pay to M/s shivsji store vide cv no. 2177 for milk, biscuit, coffee, sugar cube	845.00	897.00	
17.12.20	3	Pay for Spl.tea,coffee, biscuit, Tea Kada	270.00	1,167.00	
18.12.20	4	Pay for Spl.tea, coffee, biscuit,lunch spl.	300.00	1,467.00	
21.12.20	5	Pay for Spl.tea,coffee, biscuit, Tea Kada	290.00	1,757.00	
22.12.20	6	Pay to M/s Arora Stationers & supplier vide cv no. 8129 for photostat paper	840.00	2,597.00	
21.12.20	7	Pay to M/s Pritpal singh vide cv no. 323 for stamp rubber	100.00	2,697.00	
22.12.20	8	Pay to m/s Reliance fresh vide cv no. 69 for biscuit & vim powder	259.90	2,956.90	
22.12.20	9	Pay for spl.tea coffee, biscuit	310.00	3,266.90	
23.12.20	10	Pay for spl.tea coffee, biscuit	260.00	3,526.90	
24.12.20	11	Pay to M/s DD Motors vide cv no. STBMDLA454DB10-CBD8 for HSRP of Vehicle No. DL3CAQ0004	141.60	3,668.50	
28.12.20	12	Pay for Spl.tea,coffee, biscuit, Tea Kada	260.00	3,928.50	
29.12.20	13	Paid to Jal suvidha kendra for water jar vide cv no. nil	52.00	3,980.50	
29.12.20	14	Pay to M/s Om ji Om vide cv no. 21349 for lunch	88.00	4,068.50	
30.12.20	15	Pay for Spl.tea,coffee, biscuit, Tea Kada	260.00	4,328.50	
30.12.20	16	Pay to M/s Bagga Stationers vide cv no nil for appointment diary	150.00	4,478.50	
30.12.20	17	Pay to m/s Reliance fresh vide cv no. 47 for biscuit & snacks, Tea	301.90	4,780.40	
		Four thousand seven hundred eighty and forty only	4780.4		
		Balance in Hand	219.6		
			5,000.00		

Enclosed :- 17 nos vouchers with sanction of Eo to M(Dr) on A/C of recoupment of imprest for meeting & seminar stationery expenses items for the office of Member(Dr)

EO to M(Dr)

**DELHI JAL BOARD**  
**Advance Ledger Book**  
**Office of the Member (Drainage)**

Date Month	Voucher Nos.	Description	Each Payment Amount	Total	Ledger Indent
1	2	3	4	5	6
		Balance in Hand	219.60		

		Recoupment of imprest vide cheque No 192675 of cv no.( 3 )of dt.16.03.21	4,780.40		
			5,000.00		
29.12.20	1	Paid to M/s Raj mandir vide cv no 188629 for green tea, biscuit	279.00	279.00	
31.12.20	2	Pay for Spl.tea,coffee, biscuit, Tea Kada	250.00	529.00	
01.01.21	3	Pay for Spl.tea,coffee, biscuit, Tea Kada	290.00	819.00	
04.01.21	4	Pay for Spl.tea,coffee, biscuit, Tea Kada	310.00	1,129.00	
04.01.21	5	Pay for Spl.tea,coffee, biscuit, Tea Kada	330.00	1,459.00	
04.01.21	6	Paid to Jal suvidha kendra for water jar vide cv no. nil	156.00	1,615.00	
05.01.21	7	Pay to M/s Om ji Om vide cv no. 23585 for lunch	83.00	1,698.00	
06.01.21	8	Pay for spl.tea coffee, biscuit	280.00	1,978.00	
07.01.21	9	Pay for spl.tea coffee, biscuit	270.00	2,248.00	
07.01.21	10	Pay to M/s Shivaji Store vide cv no 2384 for biscuit, mi	825.00	3,073.00	
08.01.21	11	Paid to Jal suvidha kendra for water jar vide cv no. nil	104.00	3,177.00	
08.01.21	12	Pay for Spl.tea,coffee, biscuit, Tea Kada	300.00	3,477.00	
11.01.21	13	Pay for Spl.tea,coffee, biscuit, Tea Kada	340.00	3,817.00	
12.01.21	14	Paid to M/s Shiv Traders vide cv no. 092 for file board	1,000.00	4,817.00	
		Four thousand eight hundreded seventeen only	4817		
		Balance in Hand	183		
			5,000.00		

Enclosed :- 17 nos vouchers with sanction of Eo to M(Dr) on A/C of recoupment of imprest for meeting & seminar stationery expenses items for the office of Member(Dr)

EO to M(Dr)

**DELHI JAL BOARD**  
**Advance Ledger Book**  
**Office of the Member (Drainage)**

Date Month	Vouch er Nos.	Description	Each Payment Amount	Total	Ledger Indent
1	2	3	4	5	6
		Balance in Hand	183.00		
		Recoupment of imprest vide cheque No        of cv no. (    )of dt.	4,817.00		
			5,000.00		
12.01.21	1	Pay for Spl.tea,coffee, biscuit, Tea Kada	310.00	310.00	
13.01.21	2	Pay to M/s Shiv traders vide cv no. 060 for diary leather bound	1,250.00	1,560.00	

13.01.21	3	Pay for Spl.tea,coffee, biscuit, Tea Kada	290.00	1,850.00	
14.01.21	4	Pay to M/s Dilawar singh key maker vide cv no. 1419 for making key	100.00	1,950.00	
14.01.21	5	Pay for Spl.tea,coffee, biscuit, Tea Kada	290.00	2,240.00	
15.01.21	6	Pay for Spl.tea,coffee, biscuit, Tea Kada	310.00	2,550.00	
18.01.21	7	Paid to Jal suvidha kendra for water jar vide cv no. nil	52.00	2,602.00	
18.01.21	8	Pay to M/s Reliance fresh vide cv no. 29 for sugar biscuit	166.71	2,768.71	
18.01.21	9	Pay for spl.tea coffee, biscuit	295.00	3,063.71	
19.01.21	10	Pay for spl.tea coffee, biscuit	340.00	3,403.71	
19.01.21	11	Pay to m/s Bikaner Namkeen centre vide cv no. 5501 for snacks	390.00	3,793.71	
20.01.21	12	Pay for Spl.tea,coffee, biscuit, Tea Kada	335.00	4,128.71	
20.01.21	13	Pay to M/s Arora Stationers & supplier vide cv no. 8150 for photostat paper	840.00	4,968.71	
		Four thousand nine hundreded sixty eight & seventy one only	4968.71		
		Balance in Hand	31.29		
			5,000.00		
Enclosed :- 13 nos vouchers with sanction of Eo to M(Dr) on A/C of recoupment of imprest for meeting & seminar stationery expenses items for the office of Member(Dr)					
				EO to M(Dr)	

[illegible]

Sub. Voucher Sl. No.	Detail of Expenditure sanction Authority name number & date		Amount Rs. Paise
		B/F	4,969.00
	Bill number.....dated.....minus on basis		
	Rs. In words		4,969.00
Dated.....			
		E.O to Member(Dr)	
1. I certify that in view of interest of Delhi Jal Board paid expenditure in bill could not be postponed.			
2. I myself satisfied that advance payment is excess except then following payment. Payment has been made as per bill and payment will be made after withdraw amount.			
Dated.....			
		E.O to Member(Dr)	
Paid in Rs.			

AAO	AO	Accountant	
			Delhi Jal Board
Dated			Delhi Sarkar
Note :- Advance payment at sl. No.2 will apply only in repeat subject			
<b>DELHI JAL BOARD DELHI SARKAR Retailer Payment made by Member (Drainage)</b>			<b>FORM NO. 11</b>
Main Heading General heading Large heading	Ledger heading	Month..... . Voucher..... . Numbers	
Sub. Voucher Sl. No	Detail of Expenditure sanction Authority name number & date	Amount Rs. Paise	
	Cheque may be drawn in favour of EO to Member (Dr) on A/C of recoupment of imprest as per detail sheets and vouchers.	4,997.00	

[illegible]

	Rs. In words		4,997.00
Dated.....			
		E.O to Member(Dr)	
1. I certify that in view of interest of Delhi Jal Board paid expenditure in bill could not be postponed.			
2. I myself satisfied that advance payment is excess except then following payment. Payment has been made as per bill and payment will be made after withdraw amount.			
Dated.....			
		E.O to Member(Dr)	
Paid in Rs.			
AAO	AO	Accountant	
			Delhi Jal Board
Dated			Delhi Sarkar
Note :- Advance payment at sl. No.2 will apply only in repeat subject			



**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/  
**WATER PRODUCTION REPORT**

Date: 16.03.21

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/664.40			28
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		7

**PRODUCTION DETAILS** **TOTAL PRODUCTION : 885.84 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	85.53	
ii)	Wazirabad	124	-Do-	110.29	
iii)	Haiderpur	220	WJC Canal	208.68	
iv)	Nangloi	40	-Do-	37.75	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	14.45	
vi)	Dwarka		WJC Canal	45.57	
vii)	Bawana		WJC Canal	18.20	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	105.90	
viii)	Sonia Vihar	144	-Do-	138.92	
1)	Production of Water Treatment Plants			765.29	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.26	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.10	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.19	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			30.55	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells			90	
	Total	(1+2+3)		885.84	

**5. MAJOR UGRs' LEVELS IN METERS.**

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	3.96
Greater Kailash (O)	5.12	4.05
Greater Kailash (N)	4.80	3.04
Deer Park	4.50	3.70
Janak Puri	3.00	3.40
Kalka Ji	3.65	3.23

**m6. TRANSMISSION MAIN**

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Afected

**Note :- Total supply of water in last 24 hours i.e. 15.03.21 -----885.84 MGD**

**Member (WS)**

**Copy to: -**

1. Pr. Secretary to Lt. Governor
2. P.S. to Chief Minister, Delhi
3. P.S. to Chief Secretary, Delhi
4. Principal Secretary (UD) Govt., of NCT of Delhi
5. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
6. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
  - a. Hudson Lane, Civil Lines ,Delhi-110009
7. CE(WW)
8. CE (East)
9. Dir F & A
10. E.E. (EDP) for uploading on Website
11. Office copy

**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/  
**WATER PRODUCTION REPORT**

Date: 23.03.21

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/664.40			38
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		7

**PRODUCTION DETAILS** **TOTAL PRODUCTION : 876.74 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	84.82	
ii)	Wazirabad	124	-Do-	101.22	
iii)	Haiderpur	220	WJC Canal	211.47	
iv)	Nangloi	40	-Do-	37.63	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	14.42	
vi)	Dwarka		WJC Canal	43.49	
vii)	Bawana		WJC Canal	18.21	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	106.14	
viii)	Sonia Vihar	144	-Do-	138.40	
1)	Production of Water Treatment Plants			755.80	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.14	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.20	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.60	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			30.94	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells		90	
	Total	(1+2+3)	876.74	

**5. MAJOR UGRs' LEVELS IN METERS.**

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	3.96
Greater Kailash (O)	5.12	4.14
Greater Kailash (N)	4.80	3.04
Deer Park	4.50	3.70
Janak Puri	3.00	3.40
Kalka Ji	3.65	4.26

## 6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e. 22.03.2021 -----876.74 MGD

Member (WS)

Copy to: -

12. Pr. Secretary to Lt. Governor
13. P.S. to Chief Minister, Delhi
14. P.S. to Chief Secretary, Delhi
15. Principal Secretary (UD) Govt., of NCT of Delhi
16. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
17. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
  - a. Hudson Lane, Civil Lines ,Delhi-110009
18. CE(WW)
19. CE (East)
20. Dir F & A
21. E.E. (EDP) for uploading on Website
22. Office copy

**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/  
**WATER PRODUCTION REPORT**

Date: 24.03.21

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/664.40			38
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		7.5,5.1

**PRODUCTION DETAILS** **TOTAL PRODUCTION : 866.13 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	84.84	
ii)	Wazirabad	124	-Do-	87.56	
iii)	Haiderpur	220	WJC Canal	211.41	
iv)	Nangloi	40	-Do-	37.77	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	16.12	
vi)	Dwarka		WJC Canal	43.51	
vii)	Bawana		WJC Canal	19.50	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	106.03	
viii)	Sonia Vihar	144	-Do-	139.07	
1)	Production of Water Treatment Plants			745.81	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	9.81	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.10	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.41	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			30.32	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells			90	
	Total	(1+2+3)		866.13	

**5. MAJOR UGRs' LEVELS IN METERS.**

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	3.96
Greater Kailash (O)	5.12	3.65
Greater Kailash (N)	4.80	3.04
Deer Park	4.50	3.80
Janak Puri	3.00	3.40
Kalka Ji	3.65	4.29

## 6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e..23.03.21 -----866.13 MGD

Member (WS)

Copy to: -

1. Pr. Secretary to Lt. Governor
2. P.S. to Chief Minister, Delhi
3. P.S. to Chief Secretary, Delhi
4. Principal Secretary (UD) Govt., of NCT of Delhi
5. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
6. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
  - a. Hudson Lane, Civil Lines ,Delhi-110009
7. CE(WW)
8. CE (East)

**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/  
**WATER PRODUCTION REPORT**

Date: 25.03.21

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/664.40			41
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		7.6

**PRODUCTION DETAILS** **TOTAL PRODUCTION : 908.18 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	93.10	
ii)	Wazirabad	124	-Do-	93.30	
iii)	Haiderpur	220	WJC Canal	215.40	
iv)	Nangloi	40	-Do-	43.60	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	20.55	
vi)	Dwarka		WJC Canal	50.46	
vii)	Bawana		WJC Canal	19.80	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	105.75	
viii)	Sonia Vihar	144	-Do-	139.97	
1)	Production of Water Treatment Plants			781.93	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.27	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.20	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.78	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			31.25	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells		90	
	Total	(1+2+3)	908.18	

**5. MAJOR UGRs' LEVELS IN METERS.**

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	3.96
Greater Kailash (O)	5.12	3.90
Greater Kailash (N)	4.80	3.04
Deer Park	4.50	4.00
Janak Puri	3.00	3.40
Kalka Ji	3.65	4.54

## 6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Afected

Note :- Total supply of water in last 24 hours i.e. 24.03.21 -----908.18 MGD

Member (WS)

Copy to: -

23. Pr. Secretary to Lt. Governor
24. P.S. to Chief Minister, Delhi
25. P.S. to Chief Secretary, Delhi
26. Principal Secretary (UD) Govt., of NCT of Delhi
27. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
28. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
  - a. Hudson Lane, Civil Lines ,Delhi-110009
29. CE(WW)
30. CE (East)
31. Dir F & A
32. E.E. (EDP) for uploading on Website
33. Office copy

**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/  
**WATER PRODUCTION REPORT**

Date: 26.03.21

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/664.40			28
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		6.4

**PRODUCTION DETAILS** **TOTAL PRODUCTION : 898.26 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	92.32	
ii)	Wazirabad	124	-Do-	91.25	
iii)	Haiderpur	220	WJC Canal	212.41	
iv)	Nangloi	40	-Do-	43.75	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	21.35	
vi)	Dwarka		WJC Canal	50.44	
vii)	Bawana		WJC Canal	20.01	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	105.72	
viii)	Sonia Vihar	144	-Do-	140.05	
1)	Production of Water Treatment Plants			777.30	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.17	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.10	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.69	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			30.96	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells			90	
	Total	(1+2+3)		898.26	

**5. MAJOR UGRs' LEVELS IN METERS.**

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	3.96
Greater Kailash (O)	5.12	3.90
Greater Kailash (N)	4.80	3.04
Deer Park	4.50	3.60
Janak Puri	3.00	3.40
Kalka Ji	3.65	4.54

**m6. TRANSMISSION MAIN**

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Afected

**Note :- Total supply of water in last 24 hours i.e. 25.03.21 -----898.26 MGD**

**Member (WS)**

**Copy to: -**

1. Pr. Secretary to Lt. Governor
2. P.S. to Chief Minister, Delhi
3. P.S. to Chief Secretary, Delhi
4. Principal Secretary (UD) Govt., of NCT of Delhi
5. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
6. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
  - a. Hudson Lane, Civil Lines ,Delhi-110009
7. CE(WW)
8. CE (East)
9. Dir F & A
10. E.E. (EDP) for uploading on Website
11. Office copy

**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/  
**WATER PRODUCTION REPORT**

Date: 27.03.21

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/664.40			38
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		7.4

**PRODUCTION DETAILS** **TOTAL PRODUCTION : 905.86 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	92.38	
ii)	Wazirabad	124	-Do-	89.38	
iii)	Haiderpur	220	WJC Canal	217.71	
iv)	Nangloi	40	-Do-	44.14	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	19.60	
vi)	Dwarka		WJC Canal	50.45	
vii)	Bawana			20.02	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	106.16	
viii)	Sonia Vihar	144	-Do-	140.01	
1)	Production of Water Treatment Plants			779.85	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.08	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.10	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.83	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			31.01	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells			90	
	Total	(1+2+3)		905.86	

**5. MAJOR UGRs' LEVELS IN METERS.**

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	3.96
Greater Kailash (O)	5.12	4.05
Greater Kailash (N)	4.80	3.04
Deer Park	4.50	3.70
Janak Puri	3.00	3.40
Kalka Ji	3.65	4.26

## 6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e. 26.03.2021 -----905.86 MGD

Member (WS)

Copy to: -

12. Pr. Secretary to Lt. Governor
13. P.S. to Chief Minister, Delhi
14. P.S. to Chief Secretary, Delhi
15. Principal Secretary (UD) Govt., of NCT of Delhi
16. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
17. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
  - a. Hudson Lane, Civil Lines ,Delhi-110009
18. CE(WW)
19. CE (East)
20. Dir F & A
21. E.E. (EDP) for uploading on Website
22. Office copy

**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/  
**WATER PRODUCTION REPORT**

Date: 28.03.21

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/664.40			30
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		7.3

**PRODUCTION DETAILS** **TOTAL PRODUCTION : 886.56 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	91.34	
ii)	Wazirabad	124	-Do-	89.42	
iii)	Haiderpur	220	WJC Canal	211.67	
iv)	Nangloi	40	-Do-	43.60	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	19.37	
vi)	Dwarka		WJC Canal	50.46	
vii)	Bawana		WJC Canal	20.00	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	100.17	
viii)	Sonia Vihar	144	-Do-	140.00	
1)	Production of Water Treatment Plants			766.03	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.07	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.20	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.26	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			30.53	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells		90	
	Total	(1+2+3)	886.56	

**5. MAJOR UGRs' LEVELS IN METERS.**

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	3.96
Greater Kailash (O)	5.12	4.05
Greater Kailash (N)	4.80	3.04
Deer Park	4.50	3.70
Janak Puri	3.00	3.30
Kalka Ji	3.65	4.26

**m6. TRANSMISSION MAIN**

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Afected

**Note :- Total supply of water in last 24 hours i.e. 27.03.21 -----886.56 MGD**

**Member (WS)**

**Copy to: -**

1. Pr. Secretary to Lt. Governor
2. P.S. to Chief Minister, Delhi
3. P.S. to Chief Secretary, Delhi
4. Principal Secretary (UD) Govt., of NCT of Delhi
5. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
6. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
  - a. Hudson Lane, Civil Lines ,Delhi-110009
7. CE(WW)
8. CE (East)
9. Dir F & A
10. E.E. (EDP) for uploading on Website
11. Office copy

**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/  
**WATER PRODUCTION REPORT**

Date: 29.03.21

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/664.40			42
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		8

**PRODUCTION DETAILS** **TOTAL PRODUCTION : 896.77 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	92.18	
ii)	Wazirabad	124	-Do-	84.00	
iii)	Haiderpur	220	WJC Canal	213.99	
iv)	Nangloi	40	-Do-	44.55	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	19.22	
vi)	Dwarka		WJC Canal	50.48	
vii)	Bawana		WJC Canal	20.00	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	106.91	
viii)	Sonia Vihar	144	-Do-	139.95	
1)	Production of Water Treatment Plants			771.28	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.09	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.20	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.20	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			30.49	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells			90	
	Total	(1+2+3)		896.77	

**5. MAJOR UGRs' LEVELS IN METERS.**

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	3.96
Greater Kailash (O)	5.12	3.99
Greater Kailash (N)	4.80	3.04
Deer Park	4.50	3.70
Janak Puri	3.00	3.40
Kalka Ji	3.65	4.54

**m6. TRANSMISSION MAIN**

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Afected

**Note :- Total supply of water in last 24 hours i.e. 28.03.21 -----896.77 MGD**

**Member (WS)**

**Copy to: -**

1. Pr. Secretary to Lt. Governor
2. P.S. to Chief Minister, Delhi
3. P.S. to Chief Secretary, Delhi
4. Principal Secretary (UD) Govt., of NCT of Delhi
5. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
6. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
  - a. Hudson Lane, Civil Lines ,Delhi-110009
7. CE(WW)
8. CE (East)
9. Dir F & A
10. E.E. (EDP) for uploading on Website
11. Office copy

**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/

Date: 30.03.21

**WATER PRODUCTION REPORT**

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/664.40			27
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		7.1

**PRODUCTION DETAILS**

**TOTAL PRODUCTION : 900.71 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	92.32	
ii)	Wazirabad	124	-Do-	91.75	
iii)	Haiderpur	220	WJC Canal	212.96	
iv)	Nangloi	40	-Do-	43.48	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	19.07	
vi)	Dwarka		WJC Canal	50.46	
vii)	Bawana			20.01	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	106.97	
viii)	Sonia Vihar	144	-Do-	138.31	
1)	Production of Water Treatment Plants			775.33	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.03	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.00	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.35	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			31.38	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells			90	
	Total	(1+2+3)		900.71	

**5. MAJOR UGRs' LEVELS IN METERS.**

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	3.96
Greater Kailash (O)	5.12	3.99
Greater Kailash (N)	4.80	3.35
Deer Park	4.50	3.90
Janak Puri	3.00	3.30
Kalka Ji	3.65	4.26

## 6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e. 29.03.2021 -----900.71 MGD

Member (WS)

Copy to: -

12. Pr. Secretary to Lt. Governor
13. P.S. to Chief Minister, Delhi
14. P.S. to Chief Secretary, Delhi
15. Principal Secretary (UD) Govt., of NCT of Delhi
16. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
17. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
  - a. Hudson Lane, Civil Lines ,Delhi-110009
18. CE(WW)
19. CE (East)
20. Dir F & A
21. E.E. (EDP) for uploading on Website
22. Office copy

**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/  
**WATER PRODUCTION REPORT**

Date: 31.03.21

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/664.40			27
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		7.1

**PRODUCTION DETAILS** **TOTAL PRODUCTION : 911.31 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	90.90	
ii)	Wazirabad	124	-Do-	98.45	
iii)	Haiderpur	220	WJC Canal	216.38	
iv)	Nangloi	40	-Do-	43.86	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	19.33	
vi)	Dwarka		WJC Canal	50.47	
vii)	Bawana		WJC Canal	20.00	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	107.05	
viii)	Sonia Vihar	144	-Do-	138.71	
1)	Production of Water Treatment Plants			785.75	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.21	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.10	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.25	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			30.56	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells			90	
	Total	(1+2+3)		911.31	

**5. MAJOR UGRs' LEVELS IN METERS.**

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	3.96
Greater Kailash (O)	5.12	4.26
Greater Kailash (N)	4.80	3.04
Deer Park	4.50	3.70
Janak Puri	3.00	3.40
Kalka Ji	3.65	4.29

**m6. TRANSMISSION MAIN**

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Afected

**Note :- Total supply of water in last 24 hours i.e. 30.03.2021 -----911.31 MGD**

**Member (WS)**

**Copy to: -**

1. Pr. Secretary to Lt. Governor
2. P.S. to Chief Minister, Delhi
3. P.S. to Chief Secretary, Delhi
4. Principal Secretary (UD) Govt., of NCT of Delhi
5. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
6. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
  - a. Hudson Lane, Civil Lines ,Delhi-110009
7. CE(WW)
8. CE (East)
9. Dir F & A
10. E.E. (EDP) for uploading on Website
11. Office copy