

DELHI JAL BOARD
OFFICE OF MEMBER (WATER SUPPLY)
VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI

No. DJB/M (WS)/A-97/2017/

Date: 04.12.20

WATER PRODUCTION REPORT

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/664.50	100	1"	37
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		6.1,5.0

PRODUCTION DETAILS

TOTAL PRODUCTION : 934.88 MGD

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

YAMUNA WATER

i)	Chandrawal	98	Wazirabad Pond	93.50	
ii)	Wazirabad	124	-Do-	123.75	
iii)	Haiderpur	220	WJC Canal	217.59	
iv)	Nangloi	40	-Do-	44.12	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	21.77	
vi)	Dwarka		WJC Canal	50.46	
vii)	Bawana		WJC Canal	20.00	

GANGA WATER

vii)	Bhagirathi	100	Upper Ganga Canal	104.89	
viii)	Sonia Vihar	144	-Do-	136.76	
1)	Production of Water Treatment Plants			813.84	

RECYCLING /PROCESS WASTE WATER PLANTS

i)	Wazirabad	11	Recycled process waste at Wzd. Plant	10.11	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.20	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.73	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			31.04	

GROUND WATER SOURCES

3)	Production from Ranney wells & Tube wells		90	
	Total	(1+2+3)	934.88	

5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters) at 6.00 am	3.04
Jhandewalan	4.11	3.96
Greater Kailash (O)	5.12	3.99
Greater Kailash (N)	4.80	3.35
Deer Park	4.50	4.00
Janak Puri	3.00	3.15
Kalka Ji	3.65	4.54

6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected
	Sonia Vihar Tahir Pur main closed	2.59 pm to 5.50 pm	

Note :- Total supply of water in last 24 hours i.e. 03.12.2020 -----934.88 MGD

Member (WS)

Copy to: -

1. Pr. Secretary to Lt. Governor
2. P.S. to Chief Minister, Delhi
3. P.S. to Chief Secretary, Delhi
4. Principal Secretary (UD) Govt., of NCT of Delhi
5. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
6. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
 - a. Hudson Lane, Civil Lines ,Delhi-110009
7. CE(WW)
8. CE (East)
9. Dir F & A
10. E.E. (EDP) for uploading on Website
11. Office copy

DELHI JAL BOARD
OFFICE OF MEMBER (WATER SUPPLY)
VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI

No. DJB/M (WS)/A-97/2017/

Date: 05.12.2020

WATER PRODUCTION REPORT

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/664.40			36
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		5.6

PRODUCTION DETAILS

TOTAL PRODUCTION : 939.35 MGD

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

YAMUNA WATER

i)	Chandrawal	98	Wazirabad Pond	93.50	
ii)	Wazirabad	124	-Do-	123.94	
iii)	Haiderpur	220	WJC Canal	217.61	
iv)	Nangloi	40	-Do-	43.87	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	21.83	
vi)	Dwarka		WJC Canal	50.04	
vii)	Bawana		WJC Canal	20.02	

GANGA WATER

vii)	Bhagirathi	100	Upper Ganga Canal	106.11	
viii)	Sonia Vihar	144	-Do-	141.42	
1)	Production of Water Treatment Plants			818.34	

RECYCLING /PROCESS WASTE WATER PLANTS

i)	Wazirabad	11	Recycled process waste at Wzd. Plant	10.12	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	4.69	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	16.20	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			31.01	

GROUND WATER SOURCES

3)	Production from Ranney wells & Tube wells		90	
	Total	(1+2+3)	939.35	

5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters) at 6.00 am	3.04
Jhandewalan	4.11	3.96
Greater Kailash (O)	5.12	3.80
Greater Kailash (N)	4.80	3.35
Deer Park	4.50	4.00
Janak Puri	3.00	3.15
Kalka Ji	3.65	4.54

6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Afected

Note :- Total supply of water in last 24 hours i.e..04.12.2020 -----939.35 MGD

Member (WS)

Copy to: -

1. Pr. Secretary to Lt. Governor
2. P.S. to Chief Minister, Delhi
3. P.S. to Chief Secretary, Delhi
4. Principal Secretary (UD) Govt., of NCT of Delhi
5. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
6. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
a. Hudson Lane, Civil Lines ,Delhi-110009
7. CE(WW)
8. CE (East)

DELHI JAL BOARD
OFFICE OF MEMBER (WATER SUPPLY)
VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI

No. DJB/M (WS)/A-97/2017/

Date: 06.12.20

WATER PRODUCTION REPORT

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/664.40			35
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		5.2

PRODUCTION DETAILS

TOTAL PRODUCTION : 938.31 MGD

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

YAMUNA WATER

i)	Chandrawal	98	Wazirabad Pond	93.03	
ii)	Wazirabad	124	-Do-	124.22	
iii)	Haiderpur	220	WJC Canal	216.44	
iv)	Nangloi	40	-Do-	43.48	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	21.71	
vi)	Dwarka		WJC Canal	50.46	
vii	Bawana		WJC Canal	20.03	

GANGA WATER

vii)	Bhagirathi	100	Upper Ganga Canal	106.76	
viii)	Sonia Vihar	144	-Do-	141.47	
1)	Production of Water Treatment Plants			817.60	

RECYCLING /PROCESS WASTE WATER PLANTS

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.17	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.00	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.54	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			30.71	

GROUND WATER SOURCES

3)	Production from Ranney wells & Tube wells		90	
	Total	(1+2+3)	938.31	

5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters) at 6.00 am	3.04
Jhandewalan	4.11	3.96
Greater Kailash (O)	5.12	3.80
Greater Kailash (N)	4.80	3.35
Deer Park	4.50	3.80
Janak Puri	3.00	3.15
Kalka Ji	3.65	4.54

6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e. 05.12.2020 -----939.31 MGD

Member (WS)

Copy to: -

12. Pr. Secretary to Lt. Governor
13. P.S. to Chief Minister, Delhi
14. P.S. to Chief Secretary, Delhi
15. Principal Secretary (UD) Govt., of NCT of Delhi
16. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
17. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
a. Hudson Lane, Civil Lines ,Delhi-110009
18. CE(WW)
19. CE (East)
20. Dir F & A
21. E.E. (EDP) for uploading on Website
22. Office copy

DELHI JAL BOARD
OFFICE OF MEMBER (WATER SUPPLY)
VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI

No. DJB/M (WS)/A-97/2017/

Date: 07.12.20

WATER PRODUCTION REPORT

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/664.40			36
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		5.7,4.8

PRODUCTION DETAILS

TOTAL PRODUCTION : 934.09 MGD

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

YAMUNA WATER

i)	Chandrawal	98	Wazirabad Pond	92.91	
ii)	Wazirabad	124	-Do-	123.88	
iii)	Haiderpur	220	WJC Canal	217.59	
iv)	Nangloi	40	-Do-	41.15	
v)	Okhla	20	Recycled Process waste from Ch. & R. W.	21.68	
vi)	Dwarka		WJC Canal	50.43	
vii	Bawana		WJC Canal	21.68	

GANGA WATER

vii)	Bhagirathi	100	Upper Ganga Canal	106.78	
viii)	Sonia Vihar	144	-Do-	138.63	
1)	Production of Water Treatment Plants			813.08	

RECYCLING /PROCESS WASTE WATER PLANTS

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.16	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.20	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.65	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			31.01	

GROUND WATER SOURCES

3)	Production from Ranney wells & Tube wells		90	
	Total	(1+2+3)	934.09	

5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters) at 6.00 am	3.04
Jhandewalan	4.11	3.96
Greater Kailash (O)	5.12	4.05
Greater Kailash (N)	4.80	3.35
Deer Park	4.50	4.20
Janak Puri	3.00	3.20
Kalka Ji	3.65	4.29

6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e. 06.12.2020 -----934.09 MGD

Member (WS)

Copy to: -

1. Pr. Secretary to Lt. Governor
2. P.S. to Chief Minister, Delhi
3. P.S. to Chief Secretary, Delhi
4. Principal Secretary (UD) Govt., of NCT of Delhi
5. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
6. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
 - a. Hudson Lane, Civil Lines ,Delhi-110009
7. CE(WW)
8. CE (East)
9. Dir F & A
10. E.E. (EDP) for uploading on Website
11. Office copy

DELHI JAL BOARD
OFFICE OF MEMBER (WATER SUPPLY)
VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI

No. DJB/M (WS)/A-97/2017/

Date: 08.12.20

WATER PRODUCTION REPORT

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/664.40			39
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		6.1

PRODUCTION DETAILS

TOTAL PRODUCTION : 912.23 MGD

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
--------------------------	--------------------------------------	------------------	-----------------------	---------

YAMUNA WATER

i)	Chandrawal	98	Wazirabad Pond	92.78	
ii)	Wazirabad	124	-Do-	122.18	
iii)	Haiderpur	220	WJC Canal	210.42	
iv)	Nangloi	40	-Do-	44.03	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	21.19	
vi)	Dwarka		WJC Canal	47.05	
vii)	Bawana		WJC Canal	20.01	

GANGA WATER

vii)	Bhagirathi	100	Upper Ganga Canal	106.85	
viii)	Sonia Vihar	144	-Do-	126.64	
1)	Production of Water Treatment Plants			791.15	

RECYCLING /PROCESS WASTE WATER PLANTS

i)	Wazirabad	11	Recycled process waste at Wzd. Plant	10.17	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.20	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.71	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			31.08	

GROUND WATER SOURCES

3)	Production from Ranney wells & Tube wells		90	
	Total	(1+2+3)	912.23	

5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters) at 6.00 am	3.04
Jhandewalan	4.11	3.96
Greater Kailash (O)	5.12	3.90
Greater Kailash (N)	4.80	3.35
Deer Park	4.50	4.10
Janak Puri	3.00	3.20
Kalka Ji	3.65	4.54

6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected
	Dwarka –South delhi main pumping closed due to line work at Yamuna bridge	2.18 pm to 5.49 pm	

Note :- Total supply of water in last 24 hours i.e. 07.12.2020 -----912.13 MGD

Member (WS)

Copy to: -

1. Pr. Secretary to Lt. Governor
2. P.S. to Chief Minister, Delhi
3. P.S. to Chief Secretary, Delhi
4. Principal Secretary (UD) Govt., of NCT of Delhi
5. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
6. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
a. Hudson Lane, Civil Lines ,Delhi-110009
7. CE(WW)
8. CE (East)
9. Dir F & A
10. E.E. (EDP) for uploading on Website
11. Office copy

DELHI JAL BOARD
OFFICE OF MEMBER (WATER SUPPLY)
VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI

No. DJB/M (WS)/A-97/2017/

Date: 09.12.2020

WATER PRODUCTION REPORT

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/664.40			36
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		5.2,4.6

PRODUCTION DETAILS

TOTAL PRODUCTION : 884.13 MGD

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

YAMUNA WATER

i)	Chandrawal	98	Wazirabad Pond	93.00	
ii)	Wazirabad	124	-Do-	123.94	
iii)	Haiderpur	220	WJC Canal	217.81	
iv)	Nangloi	40	-Do-	44.07	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	21.55	
vi)	Dwarka		WJC Canal	50.47	
vii	Bawana		WJC Canal	20.00	

GANGA WATER

vii)	Bhagirathi	100	Upper Ganga Canal	106.74	
viii)	Sonia Vihar	144	-Do-	85.50	
1)	Production of Water Treatment Plants			763.08	

RECYCLING /PROCESS WASTE WATER PLANTS

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.16	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.00	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.89	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			31.05	

GROUND WATER SOURCES

3)	Production from Ranney wells & Tube wells		90	
	Total	(1+2+3)	884.13	

5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters) at 6.00 am	3.04
Jhandewalan	4.11	3.96
Greater Kailash (O)	5.12	4.20
Greater Kailash (N)	4.80	0.91
Deer Park	4.50	4.40
Janak Puri	3.00	3.30
Kalka Ji	3.65	4.29

6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Afected
	Sonia vihar shutdown	08.12.20(9.45 Am to 5.45 am)9.12.20	

Note :- Total supply of water in last 24 hours i.e..08.12.2020 -----884.13 MGD

Member (WS)

Copy to: -

1. Pr. Secretary to Lt. Governor
2. P.S. to Chief Minister, Delhi
3. P.S. to Chief Secretary, Delhi
4. Principal Secretary (UD) Govt., of NCT of Delhi
5. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
6. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
a. Hudson Lane, Civil Lines ,Delhi-110009
7. CE(WW)
8. CE (East)

DELHI JAL BOARD
OFFICE OF MEMBER (WATER SUPPLY)
VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI

No. DJB/M (WS)/A-97/2017/

Date: 10.12.20

WATER PRODUCTION REPORT

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/664.40			35
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		3.1,4.2

PRODUCTION DETAILS

TOTAL PRODUCTION : 916.61 MGD

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

YAMUNA WATER

i)	Chandrawal	98	Wazirabad Pond	93.02	
ii)	Wazirabad	124	-Do-	123.93	
iii)	Haiderpur	220	WJC Canal	217.71	
iv)	Nangloi	40	-Do-	43.68	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	21.62	
vi)	Dwarka		WJC Canal	50.48	
vii)	Bawana		WJC Canal	20.01	

GANGA WATER

vii)	Bhagirathi	100	Upper Ganga Canal	106.73	
viii)	Sonia Vihar	144	-Do-	119.33	
1)	Production of Water Treatment Plants			795.51	

RECYCLING /PROCESS WASTE WATER PLANTS

i)	Wazirabad	11	Recycled process waste at Wzd. Plant	10.16	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.10	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.84	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			31.10	

GROUND WATER SOURCES

3)	Production from Ranney wells & Tube wells		90	
	Total	(1+2+3)	916.61	

5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters) at 6.00 am	3.04
Jhandewalan	4.11	3.96
Greater Kailash (O)	5.12	4.05
Greater Kailash (N)	4.80	3.04
Deer Park	4.50	4.20
Janak Puri	3.00	3.35
Kalka Ji	3.65	4.29

6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected
	Sonia Vihar shut down due to work at raw water main	8.12.20(9.45 am to 5.45 am)09.12.20	

Note :- Total supply of water in last 24 hours i.e. 09.12.2020 -----916.61 MGD

Member (WS)

Copy to: -

12. Pr. Secretary to Lt. Governor
13. P.S. to Chief Minister, Delhi
14. P.S. to Chief Secretary, Delhi
15. Principal Secretary (UD) Govt., of NCT of Delhi
16. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
17. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
a. Hudson Lane, Civil Lines ,Delhi-110009
18. CE(WW)
19. CE (East)
20. Dir F & A
21. E.E. (EDP) for uploading on Website
22. Office copy

DELHI JAL BOARD
OFFICE OF MEMBER (WATER SUPPLY)
VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI

No. DJB/M (WS)/A-97/2017/

Date: 11.12.20

WATER PRODUCTION REPORT

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/664.40			39
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		5.4

PRODUCTION DETAILS

TOTAL PRODUCTION : 936.43 MGD

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

YAMUNA WATER

i)	Chandrawal	98	Wazirabad Pond	93.00	
ii)	Wazirabad	124	-Do-	123.92	
iii)	Haiderpur	220	WJC Canal	217.60	
iv)	Nangloi	40	-Do-	43.41	
v)	Okhla	20	Recycled Process waste from Ch. & R. W.	21.71	
vi)	Dwarka		WJC Canal	50.46	
vii	Bawana		WJC Canal	20.00	

GANGA WATER

vii)	Bhagirathi	100	Upper Ganga Canal	106.84	
viii)	Sonia Vihar	144	-Do-	138.26	
1)	Production of Water Treatment Plants			815.20	

RECYCLING /PROCESS WASTE WATER PLANTS

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.00	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.20	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	5.03	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			31.23	

GROUND WATER SOURCES

3)	Production from Ranney wells & Tube wells		90	
----	---	--	----	--

	Total	(1+2+3)		936.43	
--	--------------	----------------	--	---------------	--

5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters) at 6.00 am	3.04
Jhandewalan	4.11	3.96
Greater Kailash (O)	5.12	4.05
Greater Kailash (N)	4.80	3.35
Deer Park	4.50	4.20
Janak Puri	3.00	3.35
Kalka Ji	3.65	4.54

6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e. 10.12.2020 -----936.43 MGD

Member (WS)

Copy to: -

1. Pr. Secretary to Lt. Governor
2. P.S. to Chief Minister, Delhi
3. P.S. to Chief Secretary, Delhi
4. Principal Secretary (UD) Govt., of NCT of Delhi
5. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
6. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
 - a. Hudson Lane, Civil Lines ,Delhi-110009
7. CE(WW)
8. CE (East)
9. Dir F & A
10. E.E. (EDP) for uploading on Website
11. Office copy

DELHI JAL BOARD
OFFICE OF MEMBER (WATER SUPPLY)
VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI

No. DJB/M (WS)/A-97/2017/

Date: 12.12.20

WATER PRODUCTION REPORT

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/664.40			36
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		6.2,5.0

PRODUCTION DETAILS

TOTAL PRODUCTION : 937.18 MGD

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
--------------------------	--------------------------------------	------------------	-----------------------	---------

YAMUNA WATER

i)	Chandrawal	98	Wazirabad Pond	90.12	
ii)	Wazirabad	124	-Do-	123.95	
iii)	Haiderpur	220	WJC Canal	217.69	
iv)	Nangloi	40	-Do-	43.75	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	21.86	
vi)	Dwarka		WJC Canal	50.47	
vii)	Bawana		WJC Canal	20.02	

GANGA WATER

vii)	Bhagirathi	100	Upper Ganga Canal	106.69	
viii)	Sonia Vihar	144	-Do-	141.39	
1)	Production of Water Treatment Plants			815.94	

RECYCLING /PROCESS WASTE WATER PLANTS

i)	Wazirabad	11	Recycled process waste at Wzd. Plant	10.22	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.10	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.92	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			31.24	

GROUND WATER SOURCES

3)	Production from Ranney wells & Tube wells		90	
	Total	(1+2+3)	937.18	

5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters) at 6.00 am	3.04
Jhandewalan	4.11	3.96
Greater Kailash (O)	5.12	4.05
Greater Kailash (N)	4.80	3.65
Deer Park	4.50	4.70
Janak Puri	3.00	3.35
Kalka Ji	3.65	4.29

6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e. 11.12.2020 -----937.18 MGD

Member (WS)

Copy to: -

23. Pr. Secretary to Lt. Governor
24. P.S. to Chief Minister, Delhi
25. P.S. to Chief Secretary, Delhi
26. Principal Secretary (UD) Govt., of NCT of Delhi
27. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
28. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
 - a. Hudson Lane, Civil Lines ,Delhi-110009
29. CE(WW)
30. CE (East)
31. Dir F & A
32. E.E. (EDP) for uploading on Website
33. Office copy

DELHI JAL BOARD
OFFICE OF MEMBER (WATER SUPPLY)
VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI

No. DJB/M (WS)/A-97/2017/

Date: 13.12.2020

WATER PRODUCTION REPORT

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/664.40			
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		

PRODUCTION DETAILS

TOTAL PRODUCTION : 899.65 MGD

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

YAMUNA WATER

i)	Chandrawal	98	Wazirabad Pond	72.97	Increase in ammonia level
ii)	Wazirabad	124	-Do-	110.98	Increase in ammonia level
iii)	Haiderpur	220	WJC Canal	217.61	
iv)	Nangloi	40	-Do-	43.45	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	21.11	
vi)	Dwarka		WJC Canal	50.48	
vii)	Bawana		WJC Canal	20.02	

GANGA WATER

vii)	Bhagirathi	100	Upper Ganga Canal	103.69	
viii)	Sonia Vihar	144	-Do-	139.02	
1)	Production of Water Treatment Plants			779.33	

RECYCLING /PROCESS WASTE WATER PLANTS

i)	Wazirabad	11	Recycled process waste at Wzd. Plant	9.57	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.20	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.55	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			30.32	

GROUND WATER SOURCES

3)	Production from Ranney wells & Tube wells		90	
	Total	(1+2+3)	899.65	

5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters) at 6.00 am	3.04
Jhandewalan	4.11	3.96
Greater Kailash (O)	5.12	4.05
Greater Kailash (N)	4.80	3.65
Deer Park	4.50	4.10
Janak Puri	3.00	3.35
Kalka Ji	3.65	4.29

6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Afected

Note :- Total supply of water in last 24 hours i.e..12.12.2020 -----899.65 MGD

Member (WS)

Copy to: -

9. Pr. Secretary to Lt. Governor
10. P.S. to Chief Minister, Delhi
11. P.S. to Chief Secretary, Delhi
12. Principal Secretary (UD) Govt., of NCT of Delhi
13. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
14. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
a. Hudson Lane, Civil Lines ,Delhi-110009
15. CE(WW)
16. CE (East)

DELHI JAL BOARD
OFFICE OF MEMBER (WATER SUPPLY)
VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI

No. DJB/M (WS)/A-97/2017/

Date: 14.12.20

WATER PRODUCTION REPORT

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/664.90	500	1.3"	36
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		6.7,4.5

PRODUCTION DETAILS

TOTAL PRODUCTION : 799.73 MGD

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

YAMUNA WATER

i)	Chandrawal	98	Wazirabad Pond	65.20	Increase in ammonia level
ii)	Wazirabad	124	-Do-	36.34	Increase in ammonia level
iii)	Haiderpur	220	WJC Canal	216.07	
iv)	Nangloi	40	-Do-	40.11	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	16.97	
vi)	Dwarka		WJC Canal	47.95	
vii	Bawana		WJC Canal	18.77	

GANGA WATER

vii)	Bhagirathi	100	Upper Ganga Canal	106.54	
viii)	Sonia Vihar	144	-Do-	137.05	
1)	Production of Water Treatment Plants			685.00	

RECYCLING /PROCESS WASTE WATER PLANTS

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	3.99	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.20	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.54	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			24.73	

GROUND WATER SOURCES

3)	Production from Ranney wells & Tube wells		90	
	Total	(1+2+3)	799.73	

5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters) at 6.00 am	3.04
Jhandewalan	4.11	3.96
Greater Kailash (O)	5.12	4.11
Greater Kailash (N)	4.80	3.65
Deer Park	4.50	4.20
Janak Puri	3.00	3.25
Kalka Ji	3.65	4.29

6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected
	Less pumping due to low level at Yamuna River		

Note :- Total supply of water in last 24 hours i.e. 13.12.2020 -----799.73 MGD

Member (WS)

Copy to: -

34. Pr. Secretary to Lt. Governor
35. P.S. to Chief Minister, Delhi
36. P.S. to Chief Secretary, Delhi
37. Principal Secretary (UD) Govt., of NCT of Delhi
38. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
39. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
a. Hudson Lane, Civil Lines ,Delhi-110009
40. CE(WW)
41. CE (East)
42. Dir F & A
43. E.E. (EDP) for uploading on Website
44. Office copy

DELHI JAL BOARD
OFFICE OF MEMBER (WATER SUPPLY)
VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI

No. DJB/M (WS)/A-97/2017/

Date: 15.12.20

WATER PRODUCTION REPORT

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/664.40			35
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		7.7

PRODUCTION DETAILS

TOTAL PRODUCTION : 771.85 MGD

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

YAMUNA WATER

i)	Chandrawal	98	Wazirabad Pond	57.91	
ii)	Wazirabad	124	-Do-	51.26	
iii)	Haiderpur	220	WJC Canal	196.34	
iv)	Nangloi	40	-Do-	35.27	
v)	Okhla	20	Recycled Process waste from Ch. & R. W.	15.62	
vi)	Dwarka		WJC Canal	45.13	
vii)	Bawana		WJC Canal	15.03	

GANGA WATER

vii)	Bhagirathi	100	Upper Ganga Canal	106.32	
viii)	Sonia Vihar	144	-Do-	134.56	
1)	Production of Water Treatment Plants			657.44	

RECYCLING /PROCESS WASTE WATER PLANTS

i)	Wazirabad	11	Recycled process waste at Wzd. Plant	3.64	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.10	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.67	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			24.41	

GROUND WATER SOURCES

3)	Production from Ranney wells & Tube wells		90	
	Total	(1+2+3)	771.85	

5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters) at 6.00 am	3.04
Jhandewalan	4.11	3.96
Greater Kailash (O)	5.12	4.11
Greater Kailash (N)	4.80	3.65
Deer Park	4.50	3.70
Janak Puri	3.00	3.35
Kalka Ji	3.65	4.54

6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e. 14.12.2020 -----771.85 MGD

Member (WS)

Copy to: -

12. Pr. Secretary to Lt. Governor
13. P.S. to Chief Minister, Delhi
14. P.S. to Chief Secretary, Delhi
15. Principal Secretary (UD) Govt., of NCT of Delhi
16. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
17. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
a. Hudson Lane, Civil Lines ,Delhi-110009
18. CE(WW)
19. CE (East)
20. Dir F & A
21. E.E. (EDP) for uploading on Website
22. Office copy

DELHI JAL BOARD
OFFICE OF MEMBER (WATER SUPPLY)
VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI

No. DJB/M (WS)/A-97/2017/

Date: 16.12.20

WATER PRODUCTION REPORT

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/664.40			37
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		8.0,5.0

PRODUCTION DETAILS

TOTAL PRODUCTION : 863.77 MGD

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
--------------------------	--------------------------------------	------------------	-----------------------	---------

YAMUNA WATER

i)	Chandrawal	98	Wazirabad Pond	73.36	
ii)	Wazirabad	124	-Do-	102.17	
iii)	Haiderpur	220	WJC Canal	213.15	
iv)	Nangloi	40	-Do-	35.35	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	19.71	
vi)	Dwarka		WJC Canal	45.16	
vii)	Bawana		WJC Canal	15.03	

GANGA WATER

vii)	Bhagirathi	100	Upper Ganga Canal	106.06	
viii)	Sonia Vihar	144	-Do-	134.45	
1)	Production of Water Treatment Plants			744.44	

RECYCLING /PROCESS WASTE WATER PLANTS

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	8.57	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.10	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.66	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			29.33	

GROUND WATER SOURCES

3)	Production from Ranney wells & Tube wells		90	
	Total	(1+2+3)	863.77	

5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters) at 6.00 am	3.04
Jhandewalan	4.11	3.96
Greater Kailash (O)	5.12	4.30
Greater Kailash (N)	4.80	3.65
Deer Park	4.50	3.50
Janak Puri	3.00	3.35
Kalka Ji	3.65	4.29

6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected
	Sonia Vihar Shastri Park pump closed due to flushing	12.40 pm to 5.26 pm	
	Less pumping due to low level at Yamuna River, less supply of raw water to wazirabad from haiderpur		

Note :- Total supply of water in last 24 hours i.e. 15.12.2020 -----863.77 MGD

Member (WS)

Copy to: -

45. Pr. Secretary to Lt. Governor
46. P.S. to Chief Minister, Delhi
47. P.S. to Chief Secretary, Delhi
48. Principal Secretary (UD) Govt., of NCT of Delhi
49. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
50. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
 - a. Hudson Lane, Civil Lines ,Delhi-110009
51. CE(WW)
52. CE (East)
53. Dir F & A
54. E.E. (EDP) for uploading on Website
55. Office copy

DELHI JAL BOARD
OFFICE OF MEMBER (WATER SUPPLY)
VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI

No. DJB/M (WS)/A-97/2017/

Date: 17.12.2020

WATER PRODUCTION REPORT

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/664.40			36
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		6

PRODUCTION DETAILS

TOTAL PRODUCTION : 927.10 MGD

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

YAMUNA WATER

i)	Chandrawal	98	Wazirabad Pond	92.98	
ii)	Wazirabad	124	-Do-	123.94	
iii)	Haiderpur	220	WJC Canal	213.39	
iv)	Nangloi	40	-Do-	43.59	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	21.58	
vi)	Dwarka		WJC Canal	49.05	
vii)	Bawana		WJC Canal	20.02	

GANGA WATER

vii)	Bhagirathi	100	Upper Ganga Canal	106.33	
viii)	Sonia Vihar	144	-Do-	135.50	
1)	Production of Water Treatment Plants			806.38	

RECYCLING /PROCESS WASTE WATER PLANTS

i)	Wazirabad	11	Recycled process waste at Wzd. Plant	9.36	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.20	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.66	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			30.72	

GROUND WATER SOURCES

3)	Production from Ranney wells & Tube wells		90	
----	---	--	----	--

	Total	(1+2+3)		927.10	
--	--------------	----------------	--	---------------	--

5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters) at 6.00 am	3.04
Jhandewalan	4.11	3.96
Greater Kailash (O)	5.12	4.00
Greater Kailash (N)	4.80	3.35
Deer Park	4.50	4.10
Janak Puri	3.00	3.35
Kalka Ji	3.65	4.54

6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e..16.12.2020 -----927.10 MGD

Member (WS)

Copy to: -

17. Pr. Secretary to Lt. Governor
18. P.S. to Chief Minister, Delhi
19. P.S. to Chief Secretary, Delhi
20. Principal Secretary (UD) Govt., of NCT of Delhi
21. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
22. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
a. Hudson Lane, Civil Lines ,Delhi-110009
23. CE(WW)
24. CE (East)

DELHI JAL BOARD
OFFICE OF MEMBER (WATER SUPPLY)
VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI

No. DJB/M (WS)/A-97/2017/

Date: 18.12.20

WATER PRODUCTION REPORT

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/664.40			38
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		6.8

PRODUCTION DETAILS

TOTAL PRODUCTION : 931.35 MGD

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

YAMUNA WATER

i)	Chandrawal	98	Wazirabad Pond	92.99	
ii)	Wazirabad	124	-Do-	123.69	
iii)	Haiderpur	220	WJC Canal	216.95	
iv)	Nangloi	40	-Do-	43.45	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	21.69	
vi)	Dwarka		WJC Canal	50.46	
vii)	Bawana		WJC Canal	20.03	

GANGA WATER

vii)	Bhagirathi	100	Upper Ganga Canal	106.42	
viii)	Sonia Vihar	144	-Do-	134.89	
1)	Production of Water Treatment Plants			810.57	

RECYCLING /PROCESS WASTE WATER PLANTS

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.12	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.00	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.66	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			30.78	

GROUND WATER SOURCES

3)	Production from Ranney wells & Tube wells		90	
----	---	--	----	--

	Total	(1+2+3)		931.35	
--	--------------	----------------	--	---------------	--

5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters) at 6.00 am	3.04
Jhandewalan	4.11	3.96
Greater Kailash (O)	5.12	4.36
Greater Kailash (N)	4.80	3.35
Deer Park	4.50	4.20
Janak Puri	3.00	3.35
Kalka Ji	3.65	4.54

6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e. 17.12.2020 -----931.35 MGD

Member (WS)

Copy to: -

56. Pr. Secretary to Lt. Governor
57. P.S. to Chief Minister, Delhi
58. P.S. to Chief Secretary, Delhi
59. Principal Secretary (UD) Govt., of NCT of Delhi
60. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
61. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
a. Hudson Lane, Civil Lines ,Delhi-110009
62. CE(WW)
63. CE (East)
64. Dir F & A
65. E.E. (EDP) for uploading on Website
66. Office copy

DELHI JAL BOARD
OFFICE OF MEMBER (WATER SUPPLY)
VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI

No. DJB/M (WS)/A-97/2017/

Date: 19.12.20

WATER PRODUCTION REPORT

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/665.20	800	2"	35
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		6.3,4.9

PRODUCTION DETAILS

TOTAL PRODUCTION : 914.73 MGD

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

YAMUNA WATER

i)	Chandrawal	98	Wazirabad Pond	84.98	
ii)	Wazirabad	124	-Do-	118.33	
iii)	Haiderpur	220	WJC Canal	213.73	
iv)	Nangloi	40	-Do-	43.65	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	21.89	
vi)	Dwarka		WJC Canal	50.44	
vii)	Bawana		WJC Canal	20.02	

GANGA WATER

vii)	Bhagirathi	100	Upper Ganga Canal	105.49	
viii)	Sonia Vihar	144	-Do-	135.59	
1)	Production of Water Treatment Plants			794.12	

RECYCLING /PROCESS WASTE WATER PLANTS

i)	Wazirabad	11	Recycled process waste at Wzd. Plant	9.76	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.20	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.65	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			30.61	

GROUND WATER SOURCES

3)	Production from Ranney wells & Tube wells		90	
	Total	(1+2+3)	914.73	

5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters) at 6.00 am	3.04
Jhandewalan	4.11	3.96
Greater Kailash (O)	5.12	3.99
Greater Kailash (N)	4.80	3.35
Deer Park	4.50	4.30
Janak Puri	3.00	3.35
Kalka Ji	3.65	4.51

6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e. 18.12.2020 -----914.73 MGD

Member (WS)

Copy to: -

67. Pr. Secretary to Lt. Governor
68. P.S. to Chief Minister, Delhi
69. P.S. to Chief Secretary, Delhi
70. Principal Secretary (UD) Govt., of NCT of Delhi
71. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
72. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
 - a. Hudson Lane, Civil Lines ,Delhi-110009
73. CE(WW)
74. CE (East)
75. Dir F & A
76. E.E. (EDP) for uploading on Website
77. Office copy

DELHI JAL BOARD
OFFICE OF MEMBER (WATER SUPPLY)
VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI

No. DJB/M (WS)/A-97/2017/

Date: 20.12.20

WATER PRODUCTION REPORT

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/665.40	1000	2.6'	36
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		6.5

PRODUCTION DETAILS

TOTAL PRODUCTION : 837.73 MGD

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
--------------------------	--------------------------------------	------------------	-----------------------	---------

YAMUNA WATER

i)	Chandrawal	98	Wazirabad Pond	51.50	
ii)	Wazirabad	124	-Do-	72.51	
iii)	Haiderpur	220	WJC Canal	216.83	
iv)	Nangloi	40	-Do-	43.76	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	20.85	
vi)	Dwarka		WJC Canal	50.47	
vii)	Bawana		WJC Canal	20.02	

GANGA WATER

vii)	Bhagirathi	100	Upper Ganga Canal	105.02	
viii)	Sonia Vihar	144	-Do-	136.33	
1)	Production of Water Treatment Plants			717.29	

RECYCLING /PROCESS WASTE WATER PLANTS

i)	Wazirabad	11	Recycled process waste at Wzd. Plant	9.74	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.10	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.60	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			30.44	

GROUND WATER SOURCES

3)	Production from Ranney wells & Tube wells		90	
	Total	(1+2+3)	837.73	

5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters) at 6.00 am	3.04
Jhandewalan	4.11	3.96
Greater Kailash (O)	5.12	3.99
Greater Kailash (N)	4.80	3.35
Deer Park	4.50	4.30
Janak Puri	3.00	3.25
Kalka Ji	3.65	4.54

6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e. 19.12.2020 -----837.73 MGD

Member (WS)

Copy to: -

1. Pr. Secretary to Lt. Governor
2. P.S. to Chief Minister, Delhi
3. P.S. to Chief Secretary, Delhi
4. Principal Secretary (UD) Govt., of NCT of Delhi
5. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
6. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
 - a. Hudson Lane, Civil Lines ,Delhi-110009
7. CE(WW)
8. CE (East)
9. Dir F & A
10. E.E. (EDP) for uploading on Website
11. Office copy

DELHI JAL BOARD
OFFICE OF MEMBER (WATER SUPPLY)
VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI

No. DJB/M (WS)/A-97/2017/

Date: 21.12.2020

WATER PRODUCTION REPORT

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/664.40			38
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		6.5

PRODUCTION DETAILS

TOTAL PRODUCTION : 863.81 MGD

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

YAMUNA WATER

i)	Chandrawal	98	Wazirabad Pond	67.03	
ii)	Wazirabad	124	-Do-	84.49	
iii)	Haiderpur	220	WJC Canal	215.50	
iv)	Nangloi	40	-Do-	43.77	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	19.31	
vi)	Dwarka		WJC Canal	50.44	
vii)	Bawana		WJC Canal	20.02	

GANGA WATER

vii)	Bhagirathi	100	Upper Ganga Canal	106.07	
viii)	Sonia Vihar	144	-Do-	136.39	
1)	Production of Water Treatment Plants			743.02	

RECYCLING /PROCESS WASTE WATER PLANTS

i)	Wazirabad	11	Recycled process waste at Wzd. Plant	9.69	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.10	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.90	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			30.79	

GROUND WATER SOURCES

3)	Production from Ranney wells & Tube wells		90	
	Total	(1+2+3)	863.81	

5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters) at 6.00 am	3.04
Jhandewalan	4.11	3.96
Greater Kailash (O)	5.12	4.30
Greater Kailash (N)	4.80	3.65
Deer Park	4.50	4.20
Janak Puri	3.00	3.30
Kalka Ji	3.65	3.96

6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Afected

Note :- Total supply of water in last 24 hours i.e..20.12.2020 -----863.81 MGD

Member (WS)

Copy to: -

1. Pr. Secretary to Lt. Governor
2. P.S. to Chief Minister, Delhi
3. P.S. to Chief Secretary, Delhi
4. Principal Secretary (UD) Govt., of NCT of Delhi
5. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
6. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
a. Hudson Lane, Civil Lines ,Delhi-110009
7. CE(WW)
8. CE (East)

DELHI JAL BOARD
OFFICE OF MEMBER (WATER SUPPLY)
VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI

No. DJB/M (WS)/A-97/2017/

Date: 22.12.20

WATER PRODUCTION REPORT

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/664.40			34
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		6.8

PRODUCTION DETAILS

TOTAL PRODUCTION : 882.72 MGD

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

YAMUNA WATER

i)	Chandrawal	98	Wazirabad Pond	89.51	
ii)	Wazirabad	124	-Do-	90.25	
iii)	Haiderpur	220	WJC Canal	205.04	
iv)	Nangloi	40	-Do-	43.03	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	19.48	
vi)	Dwarka		WJC Canal	50.47	
vii	Bawana		WJC Canal	20.01	

GANGA WATER

vii)	Bhagirathi	100	Upper Ganga Canal	105.64	
viii)	Sonia Vihar	144	-Do-	138.67	
1)	Production of Water Treatment Plants			762.10	

RECYCLING /PROCESS WASTE WATER PLANTS

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	9.48	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.20	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.94	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			30.62	

GROUND WATER SOURCES

3)	Production from Ranney wells & Tube wells		90	
	Total	(1+2+3)	882.72	

5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters) at 6.00 am	3.04
Jhandewalan	4.11	3.96
Greater Kailash (O)	5.12	4.29
Greater Kailash (N)	4.80	3.35
Deer Park	4.50	4.30
Janak Puri	3.00	3.20
Kalka Ji	3.65	4.54

6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected
	Haider pur-1100mm north line due to repair work	8.20 am 21.12.20	

Note :- Total supply of water in last 24 hours i.e. 21.12.2020 -----882.72 MGD

Member (WS)

Copy to: -

12. Pr. Secretary to Lt. Governor
13. P.S. to Chief Minister, Delhi
14. P.S. to Chief Secretary, Delhi
15. Principal Secretary (UD) Govt., of NCT of Delhi
16. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
17. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
a. Hudson Lane, Civil Lines ,Delhi-110009
18. CE(WW)
19. CE (East)
20. Dir F & A
21. E.E. (EDP) for uploading on Website
22. Office copy

DELHI JAL BOARD
OFFICE OF MEMBER (WATER SUPPLY)
VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI

No. DJB/M (WS)/A-97/2017/

Date: 23.12.20

WATER PRODUCTION REPORT

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/664.40			38
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		6.9,5.0

PRODUCTION DETAILS

TOTAL PRODUCTION : 914.72 MGD

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

YAMUNA WATER

i)	Chandrawal	98	Wazirabad Pond	88.48	
ii)	Wazirabad	124	-Do-	119.97	
iii)	Haiderpur	220	WJC Canal	209.97	
iv)	Nangloi	40	-Do-	43.55	
v)	Okhla	20	Recycled Process waste from Ch. & R. W.	20.79	
vi)	Dwarka		WJC Canal	50.45	
vii)	Bawana		WJC Canal	20.02	

GANGA WATER

vii)	Bhagirathi	100	Upper Ganga Canal	106.12	
viii)	Sonia Vihar	144	-Do-	135.04	
1)	Production of Water Treatment Plants			793.54	

RECYCLING /PROCESS WASTE WATER PLANTS

i)	Wazirabad	11	Recycled process waste at Wzd. Plant	10.10	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.20	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.98	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			31.18	

GROUND WATER SOURCES

3)	Production from Ranney wells & Tube wells		90	
	Total	(1+2+3)	914.72	

5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters) at 6.00 am	3.04
Jhandewalan	4.11	3.96
Greater Kailash (O)	5.12	--
Greater Kailash (N)	4.80	3.65
Deer Park	4.50	4.50
Janak Puri	3.00	3.25
Kalka Ji	3.65	4.29

6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected
	Sonia Vihar Shastri Park closed due to maintenance work at UGR	1.02 Pm to 5.25 pm	

Note :- Total supply of water in last 24 hours i.e. 22.12.2020 -----914.72 MGD

Member (WS)

Copy to: -

1. Pr. Secretary to Lt. Governor
2. P.S. to Chief Minister, Delhi
3. P.S. to Chief Secretary, Delhi
4. Principal Secretary (UD) Govt., of NCT of Delhi
5. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
6. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
a. Hudson Lane, Civil Lines ,Delhi-110009
7. CE(WW)
8. CE (East)
9. Dir F & A
10. E.E. (EDP) for uploading on Website
11. Office copy

DELHI JAL BOARD
OFFICE OF MEMBER (WATER SUPPLY)
VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI

No. DJB/M (WS)/A-97/2017/

Date: 24.12.20

WATER PRODUCTION REPORT

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/664.40			35
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		6.4,4.0

PRODUCTION DETAILS

TOTAL PRODUCTION : 924.81 MGD

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
--------------------------	--------------------------------------	------------------	-----------------------	---------

YAMUNA WATER

i)	Chandrawal	98	Wazirabad Pond	89.13	
ii)	Wazirabad	124	-Do-	123.93	
iii)	Haiderpur	220	WJC Canal	217.84	
iv)	Nangloi	40	-Do-	44.03	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	21.86	
vi)	Dwarka		WJC Canal	50.44	
vii)	Bawana		WJC Canal	20.04	

GANGA WATER

vii)	Bhagirathi	100	Upper Ganga Canal	105.84	
viii)	Sonia Vihar	144	-Do-	135.56	
1)	Production of Water Treatment Plants			808.67	

RECYCLING /PROCESS WASTE WATER PLANTS

i)	Wazirabad	11	Recycled process waste at Wzd. Plant	5.29	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.00	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.85	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			26.14	

GROUND WATER SOURCES

3)	Production from Ranney wells & Tube wells		90	
	Total	(1+2+3)	924.81	

5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters) at 6.00 am	3.04
Jhandewalan	4.11	3.96
Greater Kailash (O)	5.12	4.35
Greater Kailash (N)	4.80	3.35
Deer Park	4.50	4.60
Janak Puri	3.00	3.27
Kalka Ji	3.65	4.54

6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e. 23.12.2020 -----924.81 MGD

Member (WS)

Copy to: -

23. Pr. Secretary to Lt. Governor
24. P.S. to Chief Minister, Delhi
25. P.S. to Chief Secretary, Delhi
26. Principal Secretary (UD) Govt., of NCT of Delhi
27. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
28. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
 - a. Hudson Lane, Civil Lines ,Delhi-110009
29. CE(WW)
30. CE (East)
31. Dir F & A
32. E.E. (EDP) for uploading on Website
33. Office copy

DELHI JAL BOARD
OFFICE OF MEMBER (WATER SUPPLY)
VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI

No. DJB/M (WS)/A-97/2017/

Date: 25.12.2020

WATER PRODUCTION REPORT

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/664.40			38
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		6.9

PRODUCTION DETAILS

TOTAL PRODUCTION : 926.78 MGD

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

YAMUNA WATER

i)	Chandrawal	98	Wazirabad Pond	90.11	
ii)	Wazirabad	124	-Do-	123.93	
iii)	Haiderpur	220	WJC Canal	217.42	
iv)	Nangloi	40	-Do-	43.73	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	21.61	
vi)	Dwarka		WJC Canal	50.46	
vii	Bawana		WJC Canal	20.01	

GANGA WATER

vii)	Bhagirathi	100	Upper Ganga Canal	106.31	
viii)	Sonia Vihar	144	-Do-	135.28	
1)	Production of Water Treatment Plants			808.86	

RECYCLING /PROCESS WASTE WATER PLANTS

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	6.75	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.20	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.97	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			27.92	

GROUND WATER SOURCES

3)	Production from Ranney wells & Tube wells		90	
	Total	(1+2+3)	926.78	

5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters) at 6.00 am	3.04
Jhandewalan	4.11	3.96
Greater Kailash (O)	5.12	4.26
Greater Kailash (N)	4.80	3.65
Deer Park	4.50	4.60
Janak Puri	3.00	3.25
Kalka Ji	3.65	4.54

6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Afected

Note :- Total supply of water in last 24 hours i.e..24.12.2020 -----926.78 MGD

Member (WS)

Copy to: -

9. Pr. Secretary to Lt. Governor
10. P.S. to Chief Minister, Delhi
11. P.S. to Chief Secretary, Delhi
12. Principal Secretary (UD) Govt., of NCT of Delhi
13. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
14. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
a. Hudson Lane, Civil Lines ,Delhi-110009
15. CE(WW)
16. CE (East)

DELHI JAL BOARD
OFFICE OF MEMBER (WATER SUPPLY)
VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI

No. DJB/M (WS)/A-97/2017/

Date: 26.12.20

WATER PRODUCTION REPORT

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/664.40			38
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		7.1

PRODUCTION DETAILS

TOTAL PRODUCTION : 934.46 MGD

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

YAMUNA WATER

i)	Chandrawal	98	Wazirabad Pond	91.64	
ii)	Wazirabad	124	-Do-	123.95	
iii)	Haiderpur	220	WJC Canal	217.51	
iv)	Nangloi	40	-Do-	43.68	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	22.06	
vi)	Dwarka		WJC Canal	50.48	
vii	Bawana		WJC Canal	20.02	

GANGA WATER

vii)	Bhagirathi	100	Upper Ganga Canal	106.39	
viii)	Sonia Vihar	144	-Do-	138.67	
1)	Production of Water Treatment Plants			814.40	

RECYCLING /PROCESS WASTE WATER PLANTS

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	8.33	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.30	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.93	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			30.06	

GROUND WATER SOURCES

3)	Production from Ranney wells & Tube wells		90	
	Total	(1+2+3)	934.46	

5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters) at 6.00 am	3.04
Jhandewalan	4.11	3.96
Greater Kailash (O)	5.12	4.35
Greater Kailash (N)	4.80	3.35
Deer Park	4.50	4.70
Janak Puri	3.00	3.20
Kalka Ji	3.65	4.54

6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e. 25.12.2020 -----934.46 MGD

Member (WS)

Copy to: -

34. Pr. Secretary to Lt. Governor
35. P.S. to Chief Minister, Delhi
36. P.S. to Chief Secretary, Delhi
37. Principal Secretary (UD) Govt., of NCT of Delhi
38. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
39. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
a. Hudson Lane, Civil Lines ,Delhi-110009
40. CE(WW)
41. CE (East)
42. Dir F & A
43. E.E. (EDP) for uploading on Website
44. Office copy

DELHI JAL BOARD
OFFICE OF MEMBER (WATER SUPPLY)
VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI

No. DJB/M (WS)/A-97/2017/

Date: 27.12.20

WATER PRODUCTION REPORT

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/664.40			36
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		7

PRODUCTION DETAILS

TOTAL PRODUCTION : 927.87 MGD

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

YAMUNA WATER

i)	Chandrawal	98	Wazirabad Pond	91.80	
ii)	Wazirabad	124	-Do-	123.95	
iii)	Haiderpur	220	WJC Canal	217.14	
iv)	Nangloi	40	-Do-	41.02	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	22.05	
vi)	Dwarka		WJC Canal	44.82	
vii)	Bawana		WJC Canal	20.03	

GANGA WATER

vii)	Bhagirathi	100	Upper Ganga Canal	106.76	
viii)	Sonia Vihar	144	-Do-	139.26	
1)	Production of Water Treatment Plants			806.83	

RECYCLING /PROCESS WASTE WATER PLANTS

i)	Wazirabad	11	Recycled process waste at Wzd. Plant	10.24	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.00	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.80	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			31.04	

GROUND WATER SOURCES

3)	Production from Ranney wells & Tube wells		90	
	Total	(1+2+3)	927.87	

5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters) at 6.00 am	3.04
Jhandewalan	4.11	3.96
Greater Kailash (O)	5.12	4.26
Greater Kailash (N)	4.80	3.65
Deer Park	4.50	4.30
Janak Puri	3.00	3.20
Kalka Ji	3.65	4.54

6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e. 26.12.2020 -----927.87 MGD

Member (WS)

Copy to: -

1. Pr. Secretary to Lt. Governor
2. P.S. to Chief Minister, Delhi
3. P.S. to Chief Secretary, Delhi
4. Principal Secretary (UD) Govt., of NCT of Delhi
5. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
6. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
 - a. Hudson Lane, Civil Lines ,Delhi-110009
7. CE(WW)
8. CE (East)
9. Dir F & A
10. E.E. (EDP) for uploading on Website
11. Office copy

DELHI JAL BOARD
OFFICE OF MEMBER (WATER SUPPLY)
VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI

No. DJB/M (WS)/A-97/2017/

Date: 28.12.2020

WATER PRODUCTION REPORT

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/664.40			36
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		5.2,7.3

PRODUCTION DETAILS

TOTAL PRODUCTION : 929.70 MGD

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

YAMUNA WATER

i)	Chandrawal	98	Wazirabad Pond	90.54	
ii)	Wazirabad	124	-Do-	123.94	
iii)	Haiderpur	220	WJC Canal	217.80	
iv)	Nangloi	40	-Do-	41.14	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	21.99	
vi)	Dwarka		WJC Canal	50.46	
vii	Bawana		WJC Canal	20.00	

GANGA WATER

vii)	Bhagirathi	100	Upper Ganga Canal	106.37	
viii)	Sonia Vihar	144	-Do-	136.46	
1)	Production of Water Treatment Plants			808.70	

RECYCLING /PROCESS WASTE WATER PLANTS

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.12	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.00	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.88	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			31.00	

GROUND WATER SOURCES

3)	Production from Ranney wells & Tube wells		90	
	Total	(1+2+3)	929.70	

5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters) at 6.00 am	3.04
Jhandewalan	4.11	3.96
Greater Kailash (O)	5.12	4.26
Greater Kailash (N)	4.80	3.65
Deer Park	4.50	4.30
Janak Puri	3.00	3.20
Kalka Ji	3.65	4.29

6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Afected

Note :- Total supply of water in last 24 hours i.e..27.12.2020 -----929.70 MGD

Member (WS)

Copy to: -

1. Pr. Secretary to Lt. Governor
2. P.S. to Chief Minister, Delhi
3. P.S. to Chief Secretary, Delhi
4. Principal Secretary (UD) Govt., of NCT of Delhi
5. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
6. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
a. Hudson Lane, Civil Lines ,Delhi-110009
7. CE(WW)
8. CE (East)

DELHI JAL BOARD
OFFICE OF MEMBER (WATER SUPPLY)
VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI

No. DJB/M (WS)/A-97/2017/

Date: 29.12.20

WATER PRODUCTION REPORT

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/665.40	1000	2.6"	38
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		7

PRODUCTION DETAILS

TOTAL PRODUCTION : 883.56 MGD

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

YAMUNA WATER

i)	Chandrawal	98	Wazirabad Pond	74.50	
ii)	Wazirabad	124	-Do-	104.22	
iii)	Haiderpur	220	WJC Canal	214.20	
iv)	Nangloi	40	-Do-	40.28	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	20.01	
vi)	Dwarka		WJC Canal	105.51	
vii	Bawana		WJC Canal	20.01	

GANGA WATER

vii)	Bhagirathi	100	Upper Ganga Canal	105.51	
viii)	Sonia Vihar	144	-Do-	138.15	
1)	Production of Water Treatment Plants			762.49	

RECYCLING /PROCESS WASTE WATER PLANTS

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	9.97	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.30	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.80	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			30.07	

GROUND WATER SOURCES

3)	Production from Ranney wells & Tube wells		90	
	Total	(1+2+3)	883.56	

5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters) at 6.00 am	3.04
Jhandewalan	4.11	3.96
Greater Kailash (O)	5.12	4.26
Greater Kailash (N)	4.80	3.65
Deer Park	4.50	4.20
Janak Puri	3.00	3.15
Kalka Ji	3.65	4.54

6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e. 28.12.2020 -----883.56 MGD

Member (WS)

Copy to: -

12. Pr. Secretary to Lt. Governor
13. P.S. to Chief Minister, Delhi
14. P.S. to Chief Secretary, Delhi
15. Principal Secretary (UD) Govt., of NCT of Delhi
16. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
17. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
a. Hudson Lane, Civil Lines ,Delhi-110009
18. CE(WW)
19. CE (East)
20. Dir F & A
21. E.E. (EDP) for uploading on Website
22. Office copy

DELHI JAL BOARD
OFFICE OF MEMBER (WATER SUPPLY)
VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI

No. DJB/M (WS)/A-97/2017/

Date: 30.12.20

WATER PRODUCTION REPORT

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/665.40			
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		

PRODUCTION DETAILS

TOTAL PRODUCTION : 827.59 MGD

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

YAMUNA WATER

i)	Chandrawal	98	Wazirabad Pond	52.72	
ii)	Wazirabad	124	-Do-	67.40	
iii)	Haiderpur	220	WJC Canal	217.60	
iv)	Nangloi	40	-Do-	40.56	
v)	Okhla	20	Recycled Process waste from Ch. & R. W.	20.38	
vi)	Dwarka		WJC Canal	50.47	
vii	Bawana		WJC Canal	20.00	

GANGA WATER

vii)	Bhagirathi	100	Upper Ganga Canal	105.91	
viii)	Sonia Vihar	144	-Do-	134.47	
1)	Production of Water Treatment Plants			709.51	

RECYCLING /PROCESS WASTE WATER PLANTS

i)	Wazirabad	11	Recycled process waste at Wzd. Plant	7.42	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.20	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.46	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			28.08	

GROUND WATER SOURCES

3)	Production from Ranney wells & Tube wells		90	
	Total	(1+2+3)	827.59	

5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters) at 6.00 am	3.04
Jhandewalan	4.11	3.96
Greater Kailash (O)	5.12	3.80
Greater Kailash (N)	4.80	3.35
Deer Park	4.50	4.40
Janak Puri	3.00	3.15
Kalka Ji	3.65	4.29

6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected
	Less production due to low raw water level at Yamuna River and due to increase in ammonia		
	Shastri Park pump closed	11.47 am to 4.31 am	

Note :- Total supply of water in last 24 hours i.e. 29.12.2020 -----827.59 MGD

Member (WS)

Copy to: -

1. Pr. Secretary to Lt. Governor
2. P.S. to Chief Minister, Delhi
3. P.S. to Chief Secretary, Delhi
4. Principal Secretary (UD) Govt., of NCT of Delhi
5. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
6. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
a. Hudson Lane, Civil Lines ,Delhi-110009
7. CE(WW)
8. CE (East)
9. Dir F & A
10. E.E. (EDP) for uploading on Website
11. Office copy

DELHI JAL BOARD
OFFICE OF MEMBER (WATER SUPPLY)
VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI

No. DJB/M (WS)/A-97/2017/

Date: 31.12.20

WATER PRODUCTION REPORT

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/664.40			38
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		3.4,5.0

PRODUCTION DETAILS

TOTAL PRODUCTION : 882.14 MGD

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
--------------------------	--------------------------------------	------------------	-----------------------	---------

YAMUNA WATER

i)	Chandrawal	98	Wazirabad Pond	78.90	
ii)	Wazirabad	124	-Do-	95.07	
iii)	Haiderpur	220	WJC Canal	216.26	
iv)	Nangloi	40	-Do-	41.17	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	19.63	
vi)	Dwarka		WJC Canal	50.26	
vii)	Bawana		WJC Canal	20.04	

GANGA WATER

vii)	Bhagirathi	100	Upper Ganga Canal	106.74	
viii)	Sonia Vihar	144	-Do-	135.89	
1)	Production of Water Treatment Plants			763.96	

RECYCLING /PROCESS WASTE WATER PLANTS

i)	Wazirabad	11	Recycled process waste at Wzd. Plant	7.88	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	4.30	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	16.00	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			28.18	

GROUND WATER SOURCES

3)	Production from Ranney wells & Tube wells		90	
	Total	(1+2+3)	882.14	

5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters) at 6.00 am	3.04
Jhandewalan	4.11	3.96
Greater Kailash (O)	5.12	3.44
Greater Kailash (N)	4.80	3.35
Deer Park	4.50	4.40
Janak Puri	3.00	3.20
Kalka Ji	3.65	4.57

6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected
	Sonia Vihar to Shastri Park 2 pump set closed	30.12.20 (11.42 pm to 4.38 pm) 31.12.20	

Note :- Total supply of water in last 24 hours i.e. 30.12.2020 -----882.14 MGD

Member (WS)

Copy to: -

23. Pr. Secretary to Lt. Governor
24. P.S. to Chief Minister, Delhi
25. P.S. to Chief Secretary, Delhi
26. Principal Secretary (UD) Govt., of NCT of Delhi
27. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
28. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
a. Hudson Lane, Civil Lines ,Delhi-110009
29. CE(WW)
30. CE (East)
31. Dir F & A
32. E.E. (EDP) for uploading on Website
33. Office copy