

**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/  
**WATER PRODUCTION REPORT**

Date: 06.08.21

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/669.70	17600	44'	1600
Western Jamuna Canal Level at Haiderpur		<b>NORMAL (Ft.)</b>		<b>ACTUAL (Ft.)</b>
		710.0		6.3,4.9

**PRODUCTION DETAILS** **TOTAL PRODUCTION : 947.21 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	94.92	
ii)	Wazirabad	124	-Do-	123.89	
iii)	Haiderpur	220	WJC Canal	214.98	
iv)	Nangloi	40	-Do-	43.87	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	22.40	
vi)	Dwarka		WJC Canal	52.43	
vii)	Bawana		WJC Canal	20.00	

**GANGA WATER**

viii)	Bhagirathi	100	Upper Ganga Canal	109.62	
ix)	Sonia Vihar	144	-Do-	139.07	
1)	Production of Water Treatment Plants			<b>821.18</b>	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.48	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.10	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.45	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			<b>31.03</b>	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells		95.00	
	Total	(1+2+3)	<b>947.21</b>	

**5. MAJOR UGRs' LEVELS IN METERS.**

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	4.05
Greater Kailash (N)	4.80	3.65
Deer Park	4.50	4.00
Janak Puri	3.00	3.40
Kalka Ji	3.65	3.40

## 6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected
	Sonia Vihar Shastri park pump closed	11.32 am to 2.35 pm	

Note :- Total supply of water in last 24 hours i.e..05.08.21 -----947.21 MGD

Member (WS)

Copy to: -

1. Pr. Secretary to Lt. Governor
2. P.S. to Chief Minister, Delhi
3. P.S. to Chief Secretary, Delhi
4. Principal Secretary (UD) Govt., of NCT of Delhi
5. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
6. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
  - a. Hudson Lane, Civil Lines ,Delhi-110009
7. CE(WW)
8. CE (East)

**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/  
**WATER PRODUCTION REPORT**

Date: 07.08.21

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/679.20	13600	34'	1450
Western Jamuna Canal Level at Haiderpur		<b>NORMAL (Ft.)</b>		<b>ACTUAL (Ft.)</b>
		710.0		5.6

**PRODUCTION DETAILS** **TOTAL PRODUCTION : 951.14 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	94.51	
ii)	Wazirabad	124	-Do-	123.86	
iii)	Haiderpur	220	WJC Canal	219.25	
iv)	Nangloi	40	-Do-	43.74	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	22.50	
vi)	Dwarka		WJC Canal	52.45	
vii)	Bawana		WJC Canal	20.01	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	107.66	
viii)	Sonia Vihar	144	-Do-	141.07	
1)	Production of Water Treatment Plants			<b>825.05</b>	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.48	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.20	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.41	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			<b>31.09</b>	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells			<b>95.00</b>	
	Total	(1+2+3)		<b>951.14</b>	

**5. MAJOR UGRs' LEVELS IN METERS.**

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	4.05
Greater Kailash (N)	4.80	3.04
Deer Park	4.50	4.00
Janak Puri	3.00	3.40

Kalka Ji	3.65	4.54
----------	------	------

#### 6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e. 06.08.2021 -----951.14 MGD

Member (WS)

#### Copy to: -

1. Pr. Secretary to Lt. Governor
2. P.S. to Chief Minister, Delhi
3. P.S. to Chief Secretary, Delhi
4. Principal Secretary (UD) Govt., of NCT of Delhi
5. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
6. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,  
a. Hudson Lane, Civil Lines ,Delhi-110009
7. CE(WW)
8. CE (East)
9. Dir F & A
10. E.E. (EDP) for uploading on Website
11. Office copy

**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/  
**WATER PRODUCTION REPORT**

Date: 08.08.21

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/669.20	13600	34"	1850
Western Jamuna Canal Level at Haiderpur		<b>NORMAL (Ft.)</b>		<b>ACTUAL (Ft.)</b>
		710.0		5

**PRODUCTION DETAILS** **TOTAL PRODUCTION : 951.85 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	94.64	
ii)	Wazirabad	124	-Do-	123.89	
iii)	Haiderpur	220	WJC Canal	219.03	
iv)	Nangloi	40	-Do-	43.44	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	22.60	
vi)	Dwarka		WJC Canal	52.42	
vii)	Bawana		WJC Canal	20.02	

**GANGA WATER**

viii)	Bhagirathi	100	Upper Ganga Canal	108.67	
ix)	Sonia Vihar	144	-Do-	141.03	
1)	Production of Water Treatment Plants			<b>825.74</b>	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.51	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.20	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.40	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			<b>31.11</b>	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells		95.00	
	Total	(1+2+3)	951.85	

**5. MAJOR UGRs' LEVELS IN METERS.**

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	4.26
Greater Kailash (N)	4.80	3.65
Deer Park	4.50	4.20
Janak Puri	3.00	3.40
Kalka Ji	3.65	4.54

## 6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e..07.08.21 -----951.85 MGD

Member (WS)

Copy to: -

9. Pr. Secretary to Lt. Governor
10. P.S. to Chief Minister, Delhi
11. P.S. to Chief Secretary, Delhi
12. Principal Secretary (UD) Govt., of NCT of Delhi
13. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
14. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
  - a. Hudson Lane, Civil Lines ,Delhi-110009
15. CE(WW)
16. CE (East)

**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/  
**WATER PRODUCTION REPORT**

Date: 09.08.21

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/667.90	7600	19'	1500
Western Jamuna Canal Level at Haiderpur		<b>NORMAL (Ft.)</b>		<b>ACTUAL (Ft.)</b>
		710.0		6.0,4.5

**PRODUCTION DETAILS**

**TOTAL PRODUCTION : 954.09 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	95.45	
ii)	Wazirabad	124	-Do-	123.88	
iii)	Haiderpur	220	WJC Canal	219.45	
iv)	Nangloi	40	-Do-	43.14	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	22.66	
vi)	Dwarka		WJC Canal	52.94	
vii)	Bawana		WJC Canal	20.02	

**GANGA WATER**

viii)	Bhagirathi	100	Upper Ganga Canal	109.66	
ix)	Sonia Vihar	144	-Do-	140.91	
1)	Production of Water Treatment Plants			<b>828.11</b>	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.57	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.00	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.41	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			<b>30.98</b>	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells		95.00	
	Total	(1+2+3)	954.09	

**5. MAJOR UGRs' LEVELS IN METERS.**

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	4.26
Greater Kailash (N)	4.80	4.26
Deer Park	4.50	4.00
Janak Puri	3.00	3.40
Kalka Ji	3.65	4.54

**m6. TRANSMISSION MAIN**

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Afected

**Note :- Total supply of water in last 24 hours i.e. 08.08.21 -----954.09 MGD**

**Member (WS)**

**Copy to: -**

- 1. Pr. Secretary to Lt. Governor**
- 2. P.S. to Chief Minister, Delhi**
- 3. P.S. to Chief Secretary, Delhi**
- 4. Principal Secretary (UD) Govt., of NCT of Delhi**
- 5. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi**
- 6. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,**
- 7. Hudson Lane, Civil Lines ,Delhi-110009**
- 8. CE(WW)**
- 9. CE (East)**
- 10. Dir F & A**
- 11. E.E. (EDP) for uploading on Website**
- 12. Office copy**



**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/  
**WATER PRODUCTION REPORT**

Date: 10.08.21

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/667.90	7600	19'	980
Western Jamuna Canal Level at Haiderpur		<b>NORMAL (Ft.)</b>		<b>ACTUAL (Ft.)</b>
		710.0		6.1,4.2

**PRODUCTION DETAILS**

**TOTAL PRODUCTION : 954.41 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	95.53	
ii)	Wazirabad	124	-Do-	123.47	
iii)	Haiderpur	220	WJC Canal	219.16	
iv)	Nangloi	40	-Do-	44.30	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	22.38	
vi)	Dwarka		WJC Canal	52.41	
vii)	Bawana		WJC Canal	20.00	

**GANGA WATER**

viii)	Bhagirathi	100	Upper Ganga Canal	110.23	
ix)	Sonia Vihar	144	-Do-	140.92	
1)	Production of Water Treatment Plants			<b>828.40</b>	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.63	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.30	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.08	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			<b>31.01</b>	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells		95.00	
	Total	(1+2+3)	954.41	

**5. MAJOR UGRs' LEVELS IN METERS.**

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	4.26
Greater Kailash (N)	4.80	3.65
Deer Park	4.50	4.00
Janak Puri	3.00	3.40
Kalka Ji	3.65	4.26

**m6. TRANSMISSION MAIN**

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Afected

**Note :- Total supply of water in last 24 hours i.e. 09.08.21 -----954.41 MGD**

**Member (WS)**

**Copy to: -**

- 13. Pr. Secretary to Lt. Governor**
- 14. P.S. to Chief Minister, Delhi**
- 15. P.S. to Chief Secretary, Delhi**
- 16. Principal Secretary (UD) Govt., of NCT of Delhi**
- 17. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi**
- 18. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,**
- 19. Hudson Lane, Civil Lines ,Delhi-110009**
- 20. CE(WW)**
- 21. CE (East)**
- 22. Dir F & A**
- 23. E.E. (EDP) for uploading on Website**
- 24. Office copy**

**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/

Date: 11.08.21

**WATER PRODUCTION REPORT**

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/667.60	6400	16'	570
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		5.7,4.5

**PRODUCTION DETAILS**

**TOTAL PRODUCTION : 955.41 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	95.63	
ii)	Wazirabad	124	-Do-	123.49	
iii)	Haiderpur	220	WJC Canal	219.36	
iv)	Nangloi	40	-Do-	45.05	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	22.78	
vi)	Dwarka		WJC Canal	52.43	
vii)	Bawana		WJC Canal	20.02	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	110.07	
viii)	Sonia Vihar	144	-Do-	141.43	
1)	Production of Water Treatment Plants			829.26	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.57	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.10	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.48	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			31.15	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells			95.00	
	Total	(1+2+3)		955.41	

**5. MAJOR UGRs' LEVELS IN METERS.**

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	4.26
Greater Kailash (N)	4.80	3.65
Deer Park	4.50	4.00
Janak Puri	3.00	3.40
Kalka Ji	3.65	4.26

## 6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e..10.08.21 -----955.41 MGD

Member (WS)

Copy to: -

17. Pr. Secretary to Lt. Governor
18. P.S. to Chief Minister, Delhi
19. P.S. to Chief Secretary, Delhi
20. Principal Secretary (UD) Govt., of NCT of Delhi
21. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
22. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
  - a. Hudson Lane, Civil Lines ,Delhi-110009
23. CE(WW)
24. CE (East)

**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/  
**WATER PRODUCTION REPORT**

Date: 12.08.21

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/668.30	9200	23''	950
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		6.3

**PRODUCTION DETAILS** **TOTAL PRODUCTION : 952.50 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	94.89	
ii)	Wazirabad	124	-Do-	123.91	
iii)	Haiderpur	220	WJC Canal	219.25	
iv)	Nangloi	40	-Do-	43.59	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	22.58	
vi)	Dwarka		WJC Canal	52.41	
vii)	Bawana		WJC Canal	20.00	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	108.97	
viii)	Sonia Vihar	144	-Do-	140.92	
1)	Production of Water Treatment Plants			826.52	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.49	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.20	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.29	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			30.98	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells			95.00	
	Total	(1+2+3)		952.50	

**5. MAJOR UGRs' LEVELS IN METERS.**

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	4.26
Greater Kailash (N)	4.80	3.65
Deer Park	4.50	3.90
Janak Puri	3.00	3.40

Kalka Ji	3.65	4.54
----------	------	------

**m6. TRANSMISSION MAIN**

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

**Note :- Total supply of water in last 24 hours i.e. 11.08.21 -----952.50 MGD**

**Member (WS)**

**Copy to: -**

25. Pr. Secretary to Lt. Governor
26. P.S. to Chief Minister, Delhi
27. P.S. to Chief Secretary, Delhi
28. Principal Secretary (UD) Govt., of NCT of Delhi
29. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
30. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
31. Hudson Lane, Civil Lines ,Delhi-110009
32. CE(WW)
33. CE (East)
34. Dir F & A
35. E.E. (EDP) for uploading on Website
36. Office copy

**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/  
**WATER PRODUCTION REPORT**

Date: 13.08.21

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/667.50	6000	15'	10.5
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		5.4

**PRODUCTION DETAILS** **TOTAL PRODUCTION : 944.81 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	95.70	
ii)	Wazirabad	124	-Do-	123.90	
iii)	Haiderpur	220	WJC Canal	211.19	
iv)	Nangloi	40	-Do-	44.40	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	22.79	
vi)	Dwarka		WJC Canal	52.42	
vii)	Bawana		WJC Canal	20.01	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	109.19	
viii)	Sonia Vihar	144	-Do-	139.65	
1)	Production of Water Treatment Plants			819.25	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.40	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.10	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.06	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			30.56	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells			95.00	
	Total	(1+2+3)		944.81	

**5. MAJOR UGRs' LEVELS IN METERS.**

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	4.26
Greater Kailash (N)	4.80	3.65
Deer Park	4.50	3.80
Janak Puri	3.00	3.40

Kalka Ji	3.65	4.54
----------	------	------

**m6. TRANSMISSION MAIN**

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected
	H.P.II delhi cantt. Main line closed due to interconnection work at peeragarhi and madhuban chowk	12.08.21(9.50 am to 2.10 am) 13.08.21	

**Note :- Total supply of water in last 24 hours i.e. 12.08.21 -----944.81 MGD**

**Member (WS)**

**Copy to: -**

37. Pr. Secretary to Lt. Governor
38. P.S. to Chief Minister, Delhi
39. P.S. to Chief Secretary, Delhi
40. Principal Secretary (UD) Govt., of NCT of Delhi
41. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
42. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
43. Hudson Lane, Civil Lines ,Delhi-110009
44. CE(WW)
45. CE (East)
46. Dir F & A
47. E.E. (EDP) for uploading on Website
48. Office copy



**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/  
**WATER PRODUCTION REPORT**

Date: 14.08.21

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/667.00	4000	10'	650
Western Jamuna Canal Level at Haiderpur		<b>NORMAL (Ft.)</b>		<b>ACTUAL (Ft.)</b>
		710.0		5.1,4.4

**PRODUCTION DETAILS** **TOTAL PRODUCTION : 950.73 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	95.29	
ii)	Wazirabad	124	-Do-	123.90	
iii)	Haiderpur	220	WJC Canal	218.38	
iv)	Nangloi	40	-Do-	44.64	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	22.31	
vi)	Dwarka		WJC Canal	52.40	
vii)	Bawana		WJC Canal	20.01	

**GANGA WATER**

viii)	Bhagirathi	100	Upper Ganga Canal	108.07	
ix)	Sonia Vihar	144	-Do-	140.10	
1)	Production of Water Treatment Plants			<b>825.10</b>	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.38	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.20	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.05	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			<b>30.63</b>	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells			<b>95.00</b>	
	Total	(1+2+3)		<b>950.73</b>	

**5. MAJOR UGRs' LEVELS IN METERS.**

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	4.14
Greater Kailash (N)	4.80	3.04
Deer Park	4.50	4.10
Janak Puri	3.00	3.40
Kalka Ji	3.65	4.29

## 6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e..13.08.21 -----950.73 MGD

Member (WS)

Copy to: -

25. Pr. Secretary to Lt. Governor
26. P.S. to Chief Minister, Delhi
27. P.S. to Chief Secretary, Delhi
28. Principal Secretary (UD) Govt., of NCT of Delhi
29. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
30. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
  - a. Hudson Lane, Civil Lines ,Delhi-110009
31. CE(WW)
32. CE (East)

**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/  
**WATER PRODUCTION REPORT**

Date: 15.08.21

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/660.70	2800	7'	530
Western Jamuna Canal Level at Haiderpur		<b>NORMAL (Ft.)</b>		<b>ACTUAL (Ft.)</b>
		710.0		5.6

**PRODUCTION DETAILS** **TOTAL PRODUCTION : 952.98 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	94.92	
ii)	Wazirabad	124	-Do-	123.89	
iii)	Haiderpur	220	WJC Canal	219.45	
iv)	Nangloi	40	-Do-	44.25	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	22.41	
vi)	Dwarka		WJC Canal	52.44	
vii)	Bawana		WJC Canal	20.00	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	109.45	
viii)	Sonia Vihar	144	-Do-	140.40	
1)	Production of Water Treatment Plants			<b>827.21</b>	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.61	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.00	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.46	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			<b>30.77</b>	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells			<b>95.00</b>	
	Total	(1+2+3)		<b>952.98</b>	

**5. MAJOR UGRs' LEVELS IN METERS.**

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	4.14
Greater Kailash (N)	4.80	3.04
Deer Park	4.50	4.00
Janak Puri	3.00	3.40

Kalka Ji	3.65	4.54
----------	------	------

#### 6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e. 14.08.2021 -----952.98 MGD

Member (WS)

#### Copy to: -

12. Pr. Secretary to Lt. Governor
13. P.S. to Chief Minister, Delhi
14. P.S. to Chief Secretary, Delhi
15. Principal Secretary (UD) Govt., of NCT of Delhi
16. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
17. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,  
a. Hudson Lane, Civil Lines ,Delhi-110009
18. CE(WW)
19. CE (East)
20. Dir F & A
21. E.E. (EDP) for uploading on Website
22. Office copy

**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/  
**WATER PRODUCTION REPORT**

Date: 16.08.21

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/666.40	2000	5'	220
Western Jamuna Canal Level at Haiderpur		<b>NORMAL (Ft.)</b>		<b>ACTUAL (Ft.)</b>
		710.0		6.1

**PRODUCTION DETAILS** **TOTAL PRODUCTION : 949.18 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	94.65	
ii)	Wazirabad	124	-Do-	123.02	
iii)	Haiderpur	220	WJC Canal	219.25	
iv)	Nangloi	40	-Do-	44.21	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	22.48	
vi)	Dwarka		WJC Canal	52.32	
vii)	Bawana		WJC Canal	20.02	

**GANGA WATER**

viii)	Bhagirathi	100	Upper Ganga Canal	107.82	
ix)	Sonia Vihar	144	-Do-	139.53	
1)	Production of Water Treatment Plants			<b>823.30</b>	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.38	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.20	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.30	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			<b>30.88</b>	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells		95.00	
	Total	(1+2+3)	<b>949.18</b>	

**5. MAJOR UGRs' LEVELS IN METERS.**

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	4.26
Greater Kailash (N)	4.80	--
Deer Park	4.50	4.00
Janak Puri	3.00	3.40
Kalka Ji	3.65	4.54

## 6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e..15.08.21 -----949.18 MGD

Member (WS)

Copy to: -

33. Pr. Secretary to Lt. Governor
34. P.S. to Chief Minister, Delhi
35. P.S. to Chief Secretary, Delhi
36. Principal Secretary (UD) Govt., of NCT of Delhi
37. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
38. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
  - a. Hudson Lane, Civil Lines ,Delhi-110009
39. CE(WW)
40. CE (East)

**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/  
**WATER PRODUCTION REPORT**

Date: 17.08.21

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/666.40	2000	5'	102
Western Jamuna Canal Level at Haiderpur		<b>NORMAL (Ft.)</b>		<b>ACTUAL (Ft.)</b>
		710.0		7.3

**PRODUCTION DETAILS**

**TOTAL PRODUCTION : 943.23 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	94.75	
ii)	Wazirabad	124	-Do-	123.89	
iii)	Haiderpur	220	WJC Canal	219.26	
iv)	Nangloi	40	-Do-	37.55	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	22.77	
vi)	Dwarka		WJC Canal	52.43	
vii)	Bawana		WJC Canal	20.00	

**GANGA WATER**

viii)	Bhagirathi	100	Upper Ganga Canal	107.86	
ix)	Sonia Vihar	144	-Do-	139.06	
1)	Production of Water Treatment Plants			<b>817.57</b>	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.29	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.20	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.17	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			<b>30.66</b>	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells		95.00	
	Total	(1+2+3)	<b>943.23</b>	

**5. MAJOR UGRs' LEVELS IN METERS.**

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	4.26
Greater Kailash (N)	4.80	3.65
Deer Park	4.50	4.00
Janak Puri	3.00	3.40
Kalka Ji	3.65	4.26

**m6. TRANSMISSION MAIN**

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Afected
	Nangloi shutdown	10.00 pm pumping Closed	

**Note :- Total supply of water in last 24 hours i.e. 16.08.21 -----943.23 MGD**

**Member (WS)**

**Copy to: -**

49. Pr. Secretary to Lt. Governor
50. P.S. to Chief Minister, Delhi
51. P.S. to Chief Secretary, Delhi
52. Principal Secretary (UD) Govt., of NCT of Delhi
53. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
54. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
55. Hudson Lane, Civil Lines ,Delhi-110009
56. CE(WW)
57. CE (East)
58. Dir F & A
59. E.E. (EDP) for uploading on Website
60. Office copy



**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/  
**WATER PRODUCTION REPORT**

Date: 18.08.21

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/665.10	1000	2.5'	300
Western Jamuna Canal Level at Haiderpur		<b>NORMAL (Ft.)</b>		<b>ACTUAL (Ft.)</b>
		710.0		5.6,4.3

**PRODUCTION DETAILS**

**TOTAL PRODUCTION : 905.46 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	95.57	
ii)	Wazirabad	124	-Do-	116.48	
iii)	Haiderpur	220	WJC Canal	219.25	
iv)	Nangloi	40	-Do-	7.75	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	22.93	
vi)	Dwarka		WJC Canal	52.42	
vii)	Bawana		WJC Canal	20.00	

**GANGA WATER**

viii)	Bhagirathi	100	Upper Ganga Canal	108.06	
ix)	Sonia Vihar	144	-Do-	140.35	
1)	Production of Water Treatment Plants			<b>779.81</b>	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.20	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.20	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.25	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			<b>30.65</b>	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells			<b>95.00</b>	
	Total	(1+2+3)		<b>905.46</b>	

**5. MAJOR UGRs' LEVELS IN METERS.**

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	4.26
Greater Kailash (N)	4.80	3.35
Deer Park	4.50	4.50
Janak Puri	3.00	3.40
Kalka Ji	3.65	4.26

**m6. TRANSMISSION MAIN**

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected
	Leakage in raw water line at mangolpuri near Rajdhani park	16.8.21 (8.00 pm to 8.00 pm) 17.08.21	

**Note :- Total supply of water in last 24 hours i.e. 17.08.21 -----905.46 MGD**

**Member (WS)**

**Copy to: -**

61. Pr. Secretary to Lt. Governor
62. P.S. to Chief Minister, Delhi
63. P.S. to Chief Secretary, Delhi
64. Principal Secretary (UD) Govt., of NCT of Delhi
65. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
66. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
67. Hudson Lane, Civil Lines ,Delhi-110009
68. CE(WW)
69. CE (East)
70. Dir F & A
71. E.E. (EDP) for uploading on Website
72. Office copy

**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/

Date: 19.08.21

**WATER PRODUCTION REPORT**

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/665.20	800	2'	136
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		5.2,4.6

**PRODUCTION DETAILS**

**TOTAL PRODUCTION : 949.34 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	95.34	
ii)	Wazirabad	124	-Do-	123.51	
iii)	Haiderpur	220	WJC Canal	218.57	
iv)	Nangloi	40	-Do-	44.26	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	22.29	
vi)	Dwarka		WJC Canal	52.44	
vii)	Bawana		WJC Canal	20.02	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	108.24	
viii)	Sonia Vihar	144	-Do-	139.42	
1)	Production of Water Treatment Plants			824.09	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.22	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.00	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.03	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			30.25	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells			95.00	
	Total	(1+2+3)		949.34	

**5. MAJOR UGRs' LEVELS IN METERS.**

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	3.80
Greater Kailash (N)	4.80	3.80
Deer Park	4.50	4.10
Janak Puri	3.00	3.40
Kalka Ji	3.65	4.54

## 6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e..18.08.21 -----949.34 MGD

Member (WS)

Copy to: -

41. Pr. Secretary to Lt. Governor
42. P.S. to Chief Minister, Delhi
43. P.S. to Chief Secretary, Delhi
44. Principal Secretary (UD) Govt., of NCT of Delhi
45. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
46. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
  - a. Hudson Lane, Civil Lines ,Delhi-110009
47. CE(WW)
48. CE (East)

**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/  
**WATER PRODUCTION REPORT**

Date: 20.08.21

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/665.00	600	1'-6"	105
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		6.2

**PRODUCTION DETAILS** **TOTAL PRODUCTION : 951.48 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	94.93	
ii)	Wazirabad	124	-Do-	123.89	
iii)	Haiderpur	220	WJC Canal	219.35	
iv)	Nangloi	40	-Do-	43.49	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	22.54	
vi)	Dwarka		WJC Canal	52.43	
vii)	Bawana		WJC Canal	20.02	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	107.80	
viii)	Sonia Vihar	144	-Do-	140.41	
1)	Production of Water Treatment Plants			825.86	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.21	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.10	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.31	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			30.62	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells			95.00	
	Total	(1+2+3)		951.48	

**5. MAJOR UGRs' LEVELS IN METERS.**

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	3.96
Greater Kailash (N)	4.80	3.35
Deer Park	4.50	4.00
Janak Puri	3.00	3.40

Kalka Ji	3.65	4.26
----------	------	------

**m6. TRANSMISSION MAIN**

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

**Note :- Total supply of water in last 24 hours i.e. 19.08.21 -----951.48 MGD**

**Member (WS)**

**Copy to: -**

73. Pr. Secretary to Lt. Governor
74. P.S. to Chief Minister, Delhi
75. P.S. to Chief Secretary, Delhi
76. Principal Secretary (UD) Govt., of NCT of Delhi
77. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
78. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
79. Hudson Lane, Civil Lines ,Delhi-110009
80. CE(WW)
81. CE (East)
82. Dir F & A
83. E.E. (EDP) for uploading on Website
84. Office copy

**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/  
**WATER PRODUCTION REPORT**

Date: 21.08.21

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/665.60	1200	3'	95
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		7.8

**PRODUCTION DETAILS** **TOTAL PRODUCTION : 952.70 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	93.81	
ii)	Wazirabad	124	-Do-	123.85	
iii)	Haiderpur	220	WJC Canal	219.45	
iv)	Nangloi	40	-Do-	44.57	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	22.68	
vi)	Dwarka		WJC Canal	52.40	
vii)	Bawana		WJC Canal	20.01	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	109.40	
viii)	Sonia Vihar	144	-Do-	141.04	
1)	Production of Water Treatment Plants			827.21	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.21	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.00	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.28	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			30.49	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells			95.00	
	Total	(1+2+3)		952.70	

**5. MAJOR UGRs' LEVELS IN METERS.**

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	4.20
Greater Kailash (N)	4.80	3.35
Deer Park	4.50	4.10
Janak Puri	3.00	3.40

Kalka Ji	3.65	4.54
----------	------	------

**m6. TRANSMISSION MAIN**

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

**Note :- Total supply of water in last 24 hours i.e. 20.08.21 -----952.70 MGD**

**Member (WS)**

**Copy to: -**

85. Pr. Secretary to Lt. Governor
86. P.S. to Chief Minister, Delhi
87. P.S. to Chief Secretary, Delhi
88. Principal Secretary (UD) Govt., of NCT of Delhi
89. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
90. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
91. Hudson Lane, Civil Lines ,Delhi-110009
92. CE(WW)
93. CE (East)
94. Dir F & A
95. E.E. (EDP) for uploading on Website
96. Office copy



**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/  
**WATER PRODUCTION REPORT**

Date: 22.08.21

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/666.20	1800	4'-6"	150
Western Jamuna Canal Level at Haiderpur		<b>NORMAL (Ft.)</b>		<b>ACTUAL (Ft.)</b>
		710.0		5.7

**PRODUCTION DETAILS** **TOTAL PRODUCTION : 948.70 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	94.79	
ii)	Wazirabad	124	-Do-	123.82	
iii)	Haiderpur	220	WJC Canal	219.36	
iv)	Nangloi	40	-Do-	44.79	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	22.59	
vi)	Dwarka		WJC Canal	52.42	
vii)	Bawana		WJC Canal	20.04	

**GANGA WATER**

viii)	Bhagirathi	100	Upper Ganga Canal	109.73	
ix)	Sonia Vihar	144	-Do-	140.78	
1)	Production of Water Treatment Plants			<b>827.82</b>	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	5.61	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.10	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.17	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			<b>25.88</b>	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells		95.00	
	Total	(1+2+3)	<b>948.70</b>	

**5. MAJOR UGRs' LEVELS IN METERS.**

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	4.20
Greater Kailash (N)	4.80	3.04
Deer Park	4.50	4.00
Janak Puri	3.00	3.40
Kalka Ji	3.65	4.26

**m6. TRANSMISSION MAIN**

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Afected

**Note :- Total supply of water in last 24 hours i.e. 21.08.21 -----948.70 MGD**

**Member (WS)**

**Copy to: -**

- 1. Pr. Secretary to Lt. Governor**
- 2. P.S. to Chief Minister, Delhi**
- 3. P.S. to Chief Secretary, Delhi**
- 4. Principal Secretary (UD) Govt., of NCT of Delhi**
- 5. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi**
- 6. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,**
- 7. Hudson Lane, Civil Lines ,Delhi-110009**
- 8. CE(WW)**
- 9. CE (East)**
- 10. Dir F & A**
- 11. E.E. (EDP) for uploading on Website**
- 12. Office copy**

**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/  
**WATER PRODUCTION REPORT**

Date: 23.08.21

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/667.20	4800	12"	155
Western Jamuna Canal Level at Haiderpur		<b>NORMAL (Ft.)</b>		<b>ACTUAL (Ft.)</b>
		710.0		6.7

**PRODUCTION DETAILS**

**TOTAL PRODUCTION : 951.15 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	95.07	
ii)	Wazirabad	124	-Do-	123.89	
iii)	Haiderpur	220	WJC Canal	219.45	
iv)	Nangloi	40	-Do-	44.57	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	22.79	
vi)	Dwarka		WJC Canal	52.44	
vii)	Bawana		WJC Canal	20.01	

**GANGA WATER**

viii)	Bhagirathi	100	Upper Ganga Canal	111.60	
ix)	Sonia Vihar	144	-Do-	141.03	
1)	Production of Water Treatment Plants			<b>830.65</b>	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	8.41	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.00	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	1.09	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			<b>25.50</b>	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells			<b>95.00</b>	
	Total	(1+2+3)		<b>951.15</b>	

**5. MAJOR UGRs' LEVELS IN METERS.**

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	4.14
Greater Kailash (N)	4.80	3.04
Deer Park	4.50	4.00
Janak Puri	3.00	3.40
Kalka Ji	3.65	4.54

**m6. TRANSMISSION MAIN**

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Afected

**Note :- Total supply of water in last 24 hours i.e. 22.08.21 -----951.15 MGD**

**Member (WS)**

**Copy to: -**

- 13. Pr. Secretary to Lt. Governor**
- 14. P.S. to Chief Minister, Delhi**
- 15. P.S. to Chief Secretary, Delhi**
- 16. Principal Secretary (UD) Govt., of NCT of Delhi**
- 17. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi**
- 18. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,**
- 19. Hudson Lane, Civil Lines ,Delhi-110009**
- 20. CE(WW)**
- 21. CE (East)**
- 22. Dir F & A**
- 23. E.E. (EDP) for uploading on Website**
- 24. Office copy**

**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/  
**WATER PRODUCTION REPORT**

Date: 24.08.21

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/667.20	4800	12'	155
Western Jamuna Canal Level at Haiderpur		<b>NORMAL (Ft.)</b>		<b>ACTUAL (Ft.)</b>
		710.0		6.7

**PRODUCTION DETAILS** **TOTAL PRODUCTION : 946.85 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	93.02	
ii)	Wazirabad	124	-Do-	123.86	
iii)	Haiderpur	220	WJC Canal	219.26	
iv)	Nangloi	40	-Do-	44.45	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	22.98	
vi)	Dwarka		WJC Canal	52.35	
vii)	Bawana		WJC Canal	20.03	

**GANGA WATER**

viii)	Bhagirathi	100	Upper Ganga Canal	112.27	
ix)	Sonia Vihar	144	-Do-	138.20	
1)	Production of Water Treatment Plants			<b>825.42</b>	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.23	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.20	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	0.00	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			<b>26.43</b>	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells		95.00	
	Total	(1+2+3)	<b>946.85</b>	

**5. MAJOR UGRs' LEVELS IN METERS.**

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	4.14
Greater Kailash (N)	4.80	3.04
Deer Park	4.50	4.00
Janak Puri	3.00	3.40
Kalka Ji	3.65	3.84

## 6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e..23.08.21 -----946.85 MGD

Member (WS)

Copy to: -

49. Pr. Secretary to Lt. Governor
50. P.S. to Chief Minister, Delhi
51. P.S. to Chief Secretary, Delhi
52. Principal Secretary (UD) Govt., of NCT of Delhi
53. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
54. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
  - a. Hudson Lane, Civil Lines ,Delhi-110009
55. CE(WW)
56. CE (East)

**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/  
**WATER PRODUCTION REPORT**

Date: 25.08.21

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/666.00	1600	4'	210
Western Jamuna Canal Level at Haiderpur		<b>NORMAL (Ft.)</b>		<b>ACTUAL (Ft.)</b>
		710.0		5.6,4.6

**PRODUCTION DETAILS** **TOTAL PRODUCTION : 930.07 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	87.33	
ii)	Wazirabad	124	-Do-	123.14	
iii)	Haiderpur	220	WJC Canal	218.35	
iv)	Nangloi	40	-Do-	44.68	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	22.63	
vi)	Dwarka		WJC Canal	51.95	
vii)	Bawana		WJC Canal	19.21	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	112.45	
viii)	Sonia Vihar	144	-Do-	139.04	
1)	Production of Water Treatment Plants			<b>827.21</b>	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.28	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.01	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	0.00	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			<b>26.29</b>	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells			<b>95.00</b>	
	Total	(1+2+3)		<b>930.07</b>	

**5. MAJOR UGRs' LEVELS IN METERS.**

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	4.14
Greater Kailash (N)	4.80	3.04
Deer Park	4.50	3.80
Janak Puri	3.00	3.56

Kalka Ji	3.65	4.51
----------	------	------

#### 6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Afected

Note :- Total supply of water in last 24 hours i.e. 24.08.2021 -----930.07 MGD

Member (WS)

#### Copy to: -

23. Pr. Secretary to Lt. Governor
24. P.S. to Chief Minister, Delhi
25. P.S. to Chief Secretary, Delhi
26. Principal Secretary (UD) Govt., of NCT of Delhi
27. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
28. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,  
a. Hudson Lane, Civil Lines ,Delhi-110009
29. CE(WW)
30. CE (East)
31. Dir F & A
32. E.E. (EDP) for uploading on Website
33. Office copy



**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/  
**WATER PRODUCTION REPORT**

Date: 26.08.21

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/666.40	2000	5'	180
Western Jamuna Canal Level at Haiderpur		<b>NORMAL (Ft.)</b>		<b>ACTUAL (Ft.)</b>
		710.0		6.1

**PRODUCTION DETAILS** **TOTAL PRODUCTION : 927.34 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	87.09	
ii)	Wazirabad	124	-Do-	110.64	
iii)	Haiderpur	220	WJC Canal	218.37	
iv)	Nangloi	40	-Do-	44.42	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	22.35	
vi)	Dwarka		WJC Canal	52.38	
vii)	Bawana		WJC Canal	20.04	

**GANGA WATER**

viii)	Bhagirathi	100	Upper Ganga Canal	108.78	
ix)	Sonia Vihar	144	-Do-	140.40	
1)	Production of Water Treatment Plants			<b>804.47</b>	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.21	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.00	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	1.66	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			<b>27.87</b>	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells		95.00	
	Total	(1+2+3)	<b>927.34</b>	

**5. MAJOR UGRs' LEVELS IN METERS.**

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	4.14
Greater Kailash (N)	4.80	3.04
Deer Park	4.50	3.90
Janak Puri	3.00	3.40
Kalka Ji	3.65	4.26

## 6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e..25.08.21 -----927.34 MGD

Member (WS)

Copy to: -

57. Pr. Secretary to Lt. Governor
58. P.S. to Chief Minister, Delhi
59. P.S. to Chief Secretary, Delhi
60. Principal Secretary (UD) Govt., of NCT of Delhi
61. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
62. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
  - a. Hudson Lane, Civil Lines ,Delhi-110009
63. CE(WW)
64. CE (East)

**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/  
**WATER PRODUCTION REPORT**

Date: 27.08.21

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/666.00	1600	4'	160
Western Jamuna Canal Level at Haiderpur		<b>NORMAL (Ft.)</b>		<b>ACTUAL (Ft.)</b>
		710.0		6

**PRODUCTION DETAILS** **TOTAL PRODUCTION : 940.08 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	94.62	
ii)	Wazirabad	124	-Do-	123.89	
iii)	Haiderpur	220	WJC Canal	215.63	
iv)	Nangloi	40	-Do-	44.50	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	21.87	
vi)	Dwarka		WJC Canal	51.10	
vii)	Bawana		WJC Canal	20.01	

**GANGA WATER**

viii)	Bhagirathi	100	Upper Ganga Canal	103.74	
ix)	Sonia Vihar	144	-Do-	140.14	
1)	Production of Water Treatment Plants			<b>815.50</b>	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.21	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.30	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	3.07	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			<b>29.58</b>	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells		<b>95.00</b>	
	Total	(1+2+3)	<b>940.08</b>	

**5. MAJOR UGRs' LEVELS IN METERS.**

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	4.14
Greater Kailash (N)	4.80	3.35
Deer Park	4.50	3.90
Janak Puri	3.00	3.40
Kalka Ji	3.65	4.54

**m6. TRANSMISSION MAIN**

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Afected

**Note :- Total supply of water in last 24 hours i.e. 26.08.21 -----940.08 MGD**

**Member (WS)**

**Copy to: -**

- 97. Pr. Secretary to Lt. Governor**
- 98. P.S. to Chief Minister, Delhi**
- 99. P.S. to Chief Secretary, Delhi**
- 100. Principal Secretary (UD) Govt., of NCT of Delhi**
- 101. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi**
- 102. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,**
- 103. Hudson Lane, Civil Lines ,Delhi-110009**
- 104. CE(WW)**
- 105. CE (East)**
- 106. Dir F & A**
- 107. E.E. (EDP) for uploading on Website**
- 108. Office copy**

**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/  
**WATER PRODUCTION REPORT**

Date: 28.08.21

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/666.40	2000	5'	155
Western Jamuna Canal Level at Haiderpur		<b>NORMAL (Ft.)</b>		<b>ACTUAL (Ft.)</b>
		710.0		6.0,4.6

**PRODUCTION DETAILS**

**TOTAL PRODUCTION : 949.09 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	94.50	
ii)	Wazirabad	124	-Do-	123.85	
iii)	Haiderpur	220	WJC Canal	219.06	
iv)	Nangloi	40	-Do-	44.32	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	22.95	
vi)	Dwarka		WJC Canal	52.41	
vii)	Bawana		WJC Canal	20.01	

**GANGA WATER**

viii)	Bhagirathi	100	Upper Ganga Canal	108.42	
ix)	Sonia Vihar	144	-Do-	139.90	
1)	Production of Water Treatment Plants			<b>823.42</b>	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.30	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.40	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	3.97	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			<b>30.67</b>	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells		95.00	
	Total	(1+2+3)	949.09	

**5. MAJOR UGRs' LEVELS IN METERS.**

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	3.84
Greater Kailash (N)	4.80	3.35
Deer Park	4.50	4.10
Janak Puri	3.00	3.40
Kalka Ji	3.65	4.54

**m6. TRANSMISSION MAIN**

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Afected

**Note :- Total supply of water in last 24 hours i.e. 27.08.21 -----949.09 MGD**

**Member (WS)**

**Copy to: -**

- 109. Pr. Secretary to Lt. Governor**
- 110. P.S. to Chief Minister, Delhi**
- 111. P.S. to Chief Secretary, Delhi**
- 112. Principal Secretary (UD) Govt., of NCT of Delhi**
- 113. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi**
- 114. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,**
- 115. Hudson Lane, Civil Lines ,Delhi-110009**
- 116. CE(WW)**
- 117. CE (East)**
- 118. Dir F & A**
- 119. E.E. (EDP) for uploading on Website**
- 120. Office copy**

**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/

Date: 29.08.21

**WATER PRODUCTION REPORT**

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/666.40	2000	5'	152
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		5.5

**PRODUCTION DETAILS**

**TOTAL PRODUCTION : 951.09 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	94.71	
ii)	Wazirabad	124	-Do-	123.89	
iii)	Haiderpur	220	WJC Canal	219.36	
iv)	Nangloi	40	-Do-	45.11	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	22.20	
vi)	Dwarka		WJC Canal	52.43	
vii)	Bawana		WJC Canal	20.03	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	108.49	
viii)	Sonia Vihar	144	-Do-	139.82	
1)	Production of Water Treatment Plants			826.04	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.31	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.10	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	3.64	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			30.05	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells			95.00	
	Total	(1+2+3)		951.09	

**5. MAJOR UGRs' LEVELS IN METERS.**

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	3.84
Greater Kailash (N)	4.80	3.35
Deer Park	4.50	4.00
Janak Puri	3.00	3.40
Kalka Ji	3.65	4.54

## 6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e..28.08.21 -----951.09 MGD

Member (WS)

Copy to: -

65. Pr. Secretary to Lt. Governor
66. P.S. to Chief Minister, Delhi
67. P.S. to Chief Secretary, Delhi
68. Principal Secretary (UD) Govt., of NCT of Delhi
69. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
70. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
  - a. Hudson Lane, Civil Lines ,Delhi-110009
71. CE(WW)
72. CE (East)



**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/  
**WATER PRODUCTION REPORT**

Date: 30.08.21

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/667.60	6400	16'	234
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		6.7

**PRODUCTION DETAILS**

**TOTAL PRODUCTION : 950.43 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	94.99	
ii)	Wazirabad	124	-Do-	123.90	
iii)	Haiderpur	220	WJC Canal	219.46	
iv)	Nangloi	40	-Do-	44.26	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	22.05	
vi)	Dwarka		WJC Canal	52.38	
vii)	Bawana		WJC Canal	20.01	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	108.49	
viii)	Sonia Vihar	144	-Do-	139.57	
1)	Production of Water Treatment Plants			825.11	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.34	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.00	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	3.98	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			30.32	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells			95.00	
	Total	(1+2+3)		950.43	

**5. MAJOR UGRs' LEVELS IN METERS.**

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	4.14
Greater Kailash (N)	4.80	3.04
Deer Park	4.50	4.10
Janak Puri	3.00	3.40

Kalka Ji	3.65	3.65
----------	------	------

**m6. TRANSMISSION MAIN**

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

**Note :- Total supply of water in last 24 hours i.e. 29.08.21 -----950.43 MGD**

**Member (WS)**

**Copy to: -**

- 121. Pr. Secretary to Lt. Governor
- 122. P.S. to Chief Minister, Delhi
- 123. P.S. to Chief Secretary, Delhi
- 124. Principal Secretary (UD) Govt., of NCT of Delhi
- 125. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
- 126. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
- 127. Hudson Lane, Civil Lines ,Delhi-110009
- 128. CE(WW)
- 129. CE (East)
- 130. Dir F & A
- 131. E.E. (EDP) for uploading on Website
- 132. Office copy

**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/  
**WATER PRODUCTION REPORT**

Date: 31.08.21

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/666.80	3200	8'	3400
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		6.2

**PRODUCTION DETAILS** **TOTAL PRODUCTION : 926.04 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	94.87	
ii)	Wazirabad	124	-Do-	123.90	
iii)	Haiderpur	220	WJC Canal	207.11	
iv)	Nangloi	40	-Do-	34.05	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	21.73	
vi)	Dwarka		WJC Canal	51.48	
vii)	Bawana		WJC Canal	20.03	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	108.54	
viii)	Sonia Vihar	144	-Do-	139.47	
1)	Production of Water Treatment Plants			801.18	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.31	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	15.70	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	3.85	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			29.86	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells			95.00	
	Total	(1+2+3)		926.04	

**5. MAJOR UGRs' LEVELS IN METERS.**

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	4.14
Greater Kailash (N)	4.80	3.35
Deer Park	4.50	4.00
Janak Puri	3.00	3.30

Kalka Ji	3.65	4.54
----------	------	------

**m6. TRANSMISSION MAIN**

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

**Note :- Total supply of water in last 24 hours i.e. 30.08.21 -----926.04 MGD**

**Member (WS)**

**Copy to: -**

- 133. Pr. Secretary to Lt. Governor
- 134. P.S. to Chief Minister, Delhi
- 135. P.S. to Chief Secretary, Delhi
- 136. Principal Secretary (UD) Govt., of NCT of Delhi
- 137. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
- 138. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
- 139. Hudson Lane, Civil Lines ,Delhi-110009
- 140. CE(WW)
- 141. CE (East)
- 142. Dir F & A
- 143. E.E. (EDP) for uploading on Website
- 144. Office copy