



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD: DELHI-110054

SURVEILLANCE OF WATER QUALITY ON Dtd. 07.05.2019

S. NO.	ZONAL LAB	TOTAL NOS OF SAMPLES COLLECTION	SATISFACTORY	TOTAL NOS OF UNSATISFACTORY	DETAILS OF UNSATISFACTORY WATER SAMPLES		
					Address	Clarity	R/Cl ₂
1	Wazirabad	103	103	Nil	--	--	--
2	Haiderpur	66	63	03	H. No. V-1/56A, Y-1/60, X-1/57, Phase – I, Budh Vihar	Hazy	Nil
3	Bhagirathi / TYR	60	55	05	H. No. 328, 2599, 227, 260, 327, Gali No. 6, West Kanti Nagar	Turbid	Nil
4	Greater Kailash	76	76	Nil	--	--	--
5	Okhla	87	87	Nil	--	--	--
6	Nangloi	125	125	Nil	--	--	--
7	Dwarka	42	42	Nil	--	--	--
8	Bawana	38	38	Nil	--	--	--
	Total	597	589	08			

% of Unsatisfactory Samples – 1.3

Note: The samples have been declared bacteriologically / chemically unsatisfactory for the reason above.

Director (T&QC)