



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	Parameters of STPs of Delhi as on					12.03.2019		
		DPPC limits	Parameter						
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		5.5-9.0	50	30	250	10	50	5	
Okhla	12 MGD	Inlet	7.4	274	240	464	1	44	2.4
		outlet	7.6	49	29	104	1	42	1.5
	45 MGD	Inlet	7.4	244	235	464	2	42	2.4
		outlet	7.6	31	22	72	1	40	1.2
	37 MGD	Inlet	7.4	244	235	464	2	42	2.4
		outlet	7.6	32	23	72	1	40	1.2
16 MGD	Inlet	7.4	244	235	464	2	42	2.4	
	outlet	7.7	22	16	56	Nil	36	1	
Kondli	25 MGD Phase-II	Inlet	7.3	378	196	328	22.5	39	6.7
		outlet	7.6	10	9	24	3.5	21	3.3
	45 MGD Phase-IV	Inlet	7.3	326	206	304	24.8	40	6.9
		outlet	7.5	34	19	66	6.5	33	2.9
Chilla	9 MGD	Inlet	7.1	452	187	437	17	40	6.8
		outlet	7.6	10	5	21	2.4	0.27	4.6
CWG Village	1 MGD	Inlet	7.2	128	113	162	28	26	4.9
		outlet	7.7	1	0.38	Bdl	Bdl	0.18	1.4
Yamuna Vihar	10 MGD Phase-I	Inlet	6.9	340	227	811	-	55	8
		outlet	7.3	50	31	133	-	25	3.5
	Phase-II	Inlet	7.1	372	232	877	-	50	7.5
		outlet	7.5	32	20	99	-	35	4
	25 MGD Phase-III	Inlet	7	460	256	1153	-	50	8.5
		outlet	7.4	30	20	106	-	30	4.5
Rithala	40 MGD	Inlet	7.2	280	-	450	24	31	1
		outlet	7.8	26	-	60	12	19	0.6
	40 MGD	Inlet	7.2	280	-	450	24	31	1
		Outlet	7.6	17	-	50	5	12	0.3
Keshopur	12 MGD	Inlet	7.3	308	240	-	-	27	3.4
		outlet	7.5	14	8	-	-	4	1.8
	40 MGD	Inlet	7.2	528	305	-	-	30	3.3
		outlet	7.5	120	83	-	-	29	2.6
	20 MGD	Inlet	7.2	528	305	-	-	30	3.3
		outlet	7.4	248	209	-	-	28	3.1
Nilothi	40 MGD Phase-I	Inlet	7.3	348	187	-	7.4	26	3.7
		outlet	7.3	66	33	-	1.2	22	3
	20 MGD Phase-II	Inlet	7.4	328	216	-	-	28	3.3
		outlet	7.4	8	5	-	-	2	1.9
Corronation pillar	20 MGD Phase-I & II	Inlet	7.1	218	203	488	8	40	2.6
		outlet	7.5	47	27	82	3.4	22	1.5
	10 MGD Phase-III	Inlet	7	450	330	512	7.8	48	2.3
		outlet	7.4	73	38	144	2.9	34	1.4

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	12.03.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
		DPPC limits	50	30
Okhla	12 MGD	49	29	104
	45 MGD	31	22	72
	37 MGD	32	23	72
	16 MGD	22	16	56
Kondli	25 MGD Pahse-II	10	9	24
	45 MGD Phase-IV	34	19	66
Chilla	9 MGD	10	5	21
CWG Village	1 MGD	1	0.38	Bdl
Yamuna Vihar	10 MGD Phase-I	50	31	133
	Phase-II	32	20	99
	25 MGD Phase-III	30	20	106
Rithala	40 MGD Phase-I	26	-	60
	40 MGD Phase-II	17	-	50
Keshopur	12 MGD	14	8	-
	40 MGD	120	83	-
	20 MGD	248	209	-
Nilothi	40 MGD Pahse-I	66	33	-
	20 MGD Phase-II	8	5	-
Corronation pillar	20 MGD Pahse-I & II	47	27	82
	10 MGD Pahse-III	73	38	144



**OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054**



		Parameters of STPs of Delhi as on					13.03.2019			
Name of the Plant	Capacity (in MGD)	Parameter								
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4	
		DPCCLimits	5.5-9.0	50	30	250	10	50	5	
Okhla	12 MGD	Inlet	7.3	246	190	456	3	42	3	
		outlet	7.6	25	19	72	1	42	1.4	
	45 MGD	Inlet	7.4	286	205	472	4	42	2.5	
		outlet	7.6	23	19	72	1	40	1	
	37 MGD	Inlet	7.4	286	205	472	4	42	2.5	
		outlet	7.6	23	18	72	1	40	1	
	16 MGD	Inlet	7.4	286	205	472	4	42	2.5	
		outlet	7.6	21	17	64	1	35	0.5	
Kondli	25 MGD Phase-II	Inlet	7.3	340	262	320	20	39	6.9	
		outlet	7.6	16	11	38	3.4	23	3.4	
	45 MGD Phase-IV	Inlet	7.2	282	222	256	25	39	6.8	
		outlet	7.5	28	19	58	4.8	31	3.1	
Chilla	9 MGD	Inlet	7.1	260	143	216	18	42	6.8	
		outlet	7.6	6	3	14	2.6	0.22	4.7	
CWG Village	1 MGD	Inlet	7.2	860	447	244	32	23	4.5	
		outlet	7.7	Bdl	0.76	Bdl	Bdl	0.16	1.4	
Yamuna Vihar	10 MGD Phase-I	Inlet	7.3	312	212	751	52.4	60	7	
		outlet	7.5	49	28	140	28.8	35	3	
	Phase-II	Inlet	7.1	304	207	715	70	45	6.5	
		outlet	7.6	21	14	74	25.6	30	3.5	
	25 MGD Phase-III	Inlet	7.2	556	287	1220	76.8	50	7.5	
		outlet	7.6	26	17	105	20.4	25	4.5	
Rithala	40 MGD	Inlet	7.1	264	-	410	-	35	1.8	
		outlet	7.8	27	-	70	-	21	1.1	
	40 MGD	Inlet	7.1	264	-	410	-	35	1.8	
		Outlet	7.7	16	-	50	-	14	0.7	
	Keshopur	12 MGD	Inlet	7.2	424	243	720	21.8	25	3.1
			outlet	7.5	15	9	40	Nil	2	1.4
40 MGD		Inlet	7.2	492	291	827	18.2	28	3.2	
		outlet	7.4	130	72	192	2.8	26	2.4	
20 MGD	Inlet	7.2	492	291	827	18.2	28	3.2		
	outlet	7.4	212	189	347	10.4	28	2.7		
Nilothi	40 MGD Phase-I	Inlet	7.1	360	118	396	8.9	29	3	
		outlet	7.3	46	33	102	1.2	19	2.5	
Nazafgarh	5 MGD	Inlet	7.3	298	228	-	-	28	2.8	
		outlet	7.5	16	11	-	-	8	1.2	
Pappankalan	20 MGD Phase-I	Inlet	7.3	377	330	-	-	34	2.8	
		outlet	7.5	47	43	-	-	28	0.8	
	20 MGD Phase-II	Inlet	7.3	377	330	-	-	34	2.8	
		outlet	7.5	8	8	-	-	6	1	
Corronation pillar	20 MGD Phase-I & II	Inlet	7.3	186	163	386	-	41	1.2	
		outlet	7.6	14	28	78	-	24	0.8	
	10 MGD Phase-III	Inlet	7.3	310	280	482	-	58	2	
		outlet	7.7	82	40	152	-	40	1.1	

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	13.03.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
		50	30	250
Okhla	12 MGD	25	19	72
	45 MGD	23	19	72
	37 MGD	23	18	72
	16 MGD	21	17	64
Kondli	25 MGD Pahse-II	16	11	38
	45 MGD Phase-IV	28	19	58
Chilla	9 MGD	6	3	14
CWG Village	1 MGD	Bdl	0.76	Bdl
Yamuna Vihar	10 MGD Phase-I	49	28	140
	Phase-II	21	14	74
	25 MGD Phase-III	26	17	105
Rithala	40 MGD Phase-I	27	-	70
	40 MGD Phase-II	16	-	50
Keshopur	12 MGD	15	9	40
	40 MGD	130	72	192
	20 MGD	212	189	347
Nilothi	40 MGD Pahse-I	46	33	102
Nazafgarh	5 MGD	16	11	-
PappanKalan	20 MGD Phase-I	47	43	-
	20 MGD Phase-II	8	8	-
Corronation pillar	20 MGD Pahse-I & II	14	28	78
	10 MGD Pahse-III	82	40	152



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



		Parameters of STPs of Delhi as on					14.03.2019		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Okhla	12 MGD	Inlet	7.4	274	183	424	3	42	2.6
		outlet	7.6	36	24	72	1	40	0.9
	45 MGD	Inlet	7.3	264	175	424	2	43	2
		outlet	7.6	22	15	56	1	40	1.8
	37 MGD	Inlet	7.3	264	175	424	2	43	2
		outlet	7.7	25	17	64	1	39	0.7
	16 MGD	Inlet	7.3	264	175	424	2	43	2
		outlet	7.6	20	15	48	Nil	41	1.5
	New 30 MGD	Inlet	7.3	306	200	424	3	42	2.5
		Outlet	7.9	4	4	16	Nil	35	1.8
Kondli	25 MGD Phase-II	Inlet	7.3	256	196	272	18.5	40	6.7
		outlet	7.6	19	11	38	4	21	3.2
	45 MGD Phase-IV	Inlet	7.3	262	212	238	26.5	39	6.6
		outlet	7.6	27	18	67	5	33	3.4
Yamuna Vihar	10 MGD Phase-I	Inlet	7.2	368	249	874	-	55	6
		outlet	7.5	47	29	136	-	30	3.5
	Phase-II	Inlet	7.2	260	199	655	-	45	5
		outlet	7.6	37	24	109	-	35	2.5
	25 MGD Phase-III	Inlet	7.1	592	252	1288	-	50	7
		outlet	7.5	28	21	86	-	20	4
Rithala	40 MGD	Inlet	7.2	252	-	380	-	32	1.4
		outlet	7.7	29	-	80	-	24	1.2
	40 MGD	Inlet	7.2	252	-	380	-	32	1.4
		Outlet	7.8	20	-	60	-	16	0.8
Keshopur	12 MGD	Inlet	7.3	444	283	-	-	28	3.2
		outlet	7.5	12	8	-	-	3	1.6
	40 MGD	Inlet	7.3	460	286	-	-	28	3.2
		outlet	7.4	110	94	-	-	30	2.9
	20 MGD	Inlet	7.3	460	286	-	-	28	3.2
		outlet	7.4	224	240	-	-	26	3
Nilothi	40 MGD Phase-I	Inlet	7.1	336	119	-	-	30	3
		outlet	7.3	42	34	-	-	22	2.6
Nazafgarh	5 MGD	Inlet	7.2	150	147	-	-	24	2.8
		outlet	7.7	15	13	-	-	8	1.2
PappanKalan	20 MGD Phase-I	Inlet	7.3	468	286	490	8	36	2.8
		outlet	7.8	56	46	120	Nil	28	0.8
	20 MGD Phase-II	Inlet	7.3	468	286	490	8	36	2.8
		outlet	7.7	5	5	24	Nil	6	1
Corronation pillar	20 MGD Phase-I & II	Inlet	7.2	156	153	348	7.6	42	1.3
		outlet	7.5	42	28	68	2.4	26	0.6
	10 MGD Phase-III	Inlet	7.2	295	275	416	7.5	55	2.2
		outlet	7.6	58	34	99	2.6	34	1.2

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	14.03.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
		50	30	250
Okhla	12 MGD	36	24	72
	45 MGD	22	15	56
	37 MGD	25	17	64
	16 MGD	20	15	48
	New 30 MGD	4	4	16
Kondli	25 MGD Pahse-II	19	11	38
	45 MGD Phase-IV	27	18	67
Yamuna Vihar	10 MGD Phase-I	47	29	136
	Phase-II	37	24	109
	25 MGD Phase-III	28	21	86
Rithala	40 MGD Phase-I	29	-	80
	40 MGD Phase-II	20	-	60
Keshopur	12 MGD	12	8	-
	40 MGD	110	94	-
	20 MGD	224	240	-
Nilothi	40 MGD Pahse-I	42	34	-
Nazafgarh	5 MGD	15	13	-
PappanKalan	20 MGD Phase-I	56	46	120
	20 MGD Phase-II	5	5	24
Corronation pillar	20 MGD Pahse-I & II	42	28	68
	10 MGD Pahse-III	58	34	99



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



		Parameters of STPs of Delhi as on					15.03.2019		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Okhla	12 MGD	Inlet	7.4	288	248	448	4	44	1.7
		outlet	7.7	29	17	64	1	38	0.8
	45 MGD	Inlet	7.3	260	243	440	4	43	1.8
		outlet	7.7	32	19	72	1	37	0.7
	37 MGD	Inlet	7.3	260	243	440	4	43	1.8
		outlet	7.6	48	28	112	2	36	1.1
16 MGD	Inlet	7.3	260	243	440	4	43	1.8	
	outlet	7.6	24	15	56	1	32	0.5	
Molarband	0.66 MGD	Inlet	7.2	1300	1080	2592	7	55	6
		outlet	7.6	20	15	56	3	20	4.8
Kondli	25 MGD Phase-II	Inlet	7.2	352	219	403	25	37	7.1
		outlet	7.6	15	10	32	4	20	3.4
	45 MGD Phase-IV	Inlet	7.2	252	193	325	26	39	6.9
		outlet	7.5	28	19	60	6	33	3.8
Chilla	9 MGD	Inlet	7.1	216	126	222	16	41	7.1
		outlet	7.6	9	3	20	2	0.28	4.8
CWG Village	1 MGD	Inlet	7.2	988	462	784	28	23	4.6
		outlet	7.7	1	0.54	Bdl	Bdl	0.12	1.7
Delhi Gate Nallah	2.2 MGD	Inlet	7.4	180	218	392	2	37	1.5
		outlet	7.7	7	6	24	Nil	5	0.6
	15 MGD	Inlet	7.3	220	283	456	3	38	1.8
		outlet	7.8	6	4	16	Nil	5	0.6
Sen Nursing Home	2.2 MGD	Inlet	7.4	288	258	488	3	40	1.8
		outlet	7.7	7	5	24	Nil	4	0.6
Yamuna Vihar	10 MGD Phase-I	Inlet	7.2	332	251	-	-	55	7
		outlet	7.5	50	32	-	-	25	3.5
	Phase-II	Inlet	7.2	280	222	-	-	50	6
		outlet	7.5	38	25	-	-	30	3
	25 MGD Phase-III	Inlet	7.3	380	261	-	-	45	7
		outlet	7.5	30	22	-	-	25	4
Rithala	40 MGD	Inlet	7.2	292	157	410	-	36	1.5
		outlet	7.9	26	18	80	-	22	0.7
	40 MGD	Inlet	7.2	292	157	410	-	36	1.5
		Outlet	7.8	16	10	50	-	17	0.4
Keshopur	12 MGD	Inlet	7.2	528	241	-	-	23	3.3
		outlet	7.5	14	9	-	-	3	1.7
	40 MGD	Inlet	7.2	520	262	-	-	31	3.2
		outlet	7.4	130	93	-	-	30	2.8
	20 MGD	Inlet	7.2	520	262	-	-	31	3.2
		outlet	7.4	224	179	-	-	28	3
Nilothi	40 MGD Phase-I	Inlet	7.2	280	126	410	-	27	3.4
		outlet	7.3	68	36	108	-	20	3
Nazafgarh	5 MGD	Inlet	7.3	292	170	-	-	-	2.8
		outlet	7.5	10	10	-	-	8	1.2
PappanKalan	20 MGD Phase-I	Inlet	7.3	340	210	-	-	36	2.8
		outlet	7.5	23	15	-	-	22	0.8
	20 MGD Phase-II	Inlet	7.3	340	210	-	-	36	2.8
		outlet	7.5	7	3	-	-	6	1
Corronation pillar	20 MGD Phase-I & II	Inlet	7.3	360	280	488	-	44	2
		outlet	7.6	66	34	102	-	28	1
	10 MGD Phase-III	Inlet	7.4	418	353	688	-	58	2.4
		outlet	7.7	76	35	142	-	31	1.3

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	15.03.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
		50	30	250
Okhla	12 MGD	29	17	64
	45 MGD	32	19	72
	37 MGD	48	28	112
	16 MGD	24	15	56
Molarband	0.66 MGD	20	15	56
Kondli	25 MGD Pahse-II	15	10	32
	45 MGD Phase-IV	28	19	60
Chilla	9 MGD	9	3	20
CWG Village	1 MGD	1	0.54	Bdl
Delhi Gate Nallah	2.2 MGD Pahse-I	7	6	24
	15 MGD Pahse-II	6	4	16
Sen Nursing Home	2.2 MGD	7	5	24
Yamuna Vihar	10 MGD Phase-I	50	32	-
	Phase-II	38	25	-
	25 MGD Phase-III	30	22	-
Rithala	40 MGD Phase-I	26	18	80
	40 MGD Phase-II	16	10	50
Keshopur	12 MGD	14	9	-
	40 MGD	130	93	-
	20 MGD	224	179	-
Nilothi	40 MGD Pahse-I	68	36	108
Nazafgarh	5 MGD	10	10	-
PappanKalan	20 MGD Phase-I	23	15	-
	20 MGD Phase-II	7	3	-
Corronation pillar	20 MGD Pahse-I & II	66	34	102
	10 MGD Pahse-III	76	35	142



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	Parameters of STPs of Delhi as on					16.03.2019		
		DPCCLimits	pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
Okhla	12 MGD	Inlet	7.3	230	253	432	3	44	1.8
		outlet	7.7	38	22	88	1	40	0.8
	45 MGD	Inlet	7.4	224	228	424	3	44	2
		outlet	7.6	33	17	72	1	40	1
	37 MGD	Inlet	7.4	224	228	424	3	44	2
		outlet	7.7	37	20	80	2	40	1
	16 MGD	Inlet	7.4	224	228	424	3	44	2
		outlet	7.7	26	17	64	1	38	0.8
Kondli	25 MGD Phase-II	Inlet	7.2	360	231	389	23	40	6.9
		outlet	7.6	16	11	46	3	18	3.1
	45 MGD Phase-IV	Inlet	7.2	308	198	361	25	39	6.8
		outlet	7.5	30	18	74	6	34	3.3
Chilla	9 MGD	Inlet	7.1	336	161	260	17	40	6.8
		outlet	7.6	8	4	18	3	0.3	4.5
CWG Village	1 MGD	Inlet	7.2	740	458	796	29	26	4.8
		outlet	7.7	Bdl	0.56	Bdl	Bdl	0.18	2.1
Yamuna Vihar	10 MGD Phase-I	Inlet	7.2	468	298	895	-	70	8.5
		outlet	7.5	48	27	144	-	45	5
	Phase-II	Inlet	7.2	264	202	673	-	50	7
		outlet	7.3	23	15	77	-	25	4
	25 MGD Phase-III	Inlet	7.1	320	225	928	-	55	7.5
		outlet	7.6	29	19	91	-	30	4
Rithala	40 MGD	Inlet	7	252	161	380	-	29	1.3
		outlet	7.8	27	19	70	-	16	0.8
	40 MGD	Inlet	7	252	161	380	-	29	1.3
		Outlet	7.9	16	11	60	-	13	0.5
Keshopur	12 MGD	Inlet	7.4	488	206	647	18.2	30	3.2
		outlet	7.6	16	8	36	Nil	2	1.6
	40 MGD	Inlet	7.3	416	193	596	14	31	3.4
		outlet	7.5	112	78	192	2.2	29	2.9
	20 MGD	Inlet	7.3	416	193	596	14	31	3.4
		outlet	7.4	244	176	502	6.7	26	3.1
Nilothi	40 MGD Phase-I	Inlet	7.2	260	117	-	6.3	28	3.4
		outlet	7.4	60	33	-	1.2	21	2.8
Nazafgarh	5 MGD	Inlet	7.3	332	202	380	5	26	2.8
		outlet	7.7	25	12	60	Nil	8	1.4
PappanKalan	20 MGD Phase-I	Inlet	7.3	342	222	540	6	34	3
		outlet	7.6	37	21	28	Nil	26	1
	20 MGD Phase-II	Inlet	7.3	342	222	540	6	34	3
		outlet	7.6	9	4	28	Nil	9	1
Corronation pillar	20 MGD Phase-I & II	Inlet	7.2	358	278	416	8	41	2.3
		outlet	7.5	62	37	98	3.2	25	1.2
	10 MGD Phase-III	Inlet	7.3	380	330	508	7.9	50	2.5
		outlet	7.6	64	34	128	2.8	31	2.1

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	16.03.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
		50	30	250
Okhla	12 MGD	38	22	88
	45 MGD	33	17	72
	37 MGD	37	20	80
	16 MGD	26	17	64
Kondli	25 MGD Pahse-II	16	11	46
	45 MGD Phase-IV	30	18	74
Chilla	9 MGD	8	4	18
CWG Village	1 MGD	Bdl	0.56	Bdl
Yamuna Vihar	10 MGD Phase-I	48	27	144
	Phase-II	23	15	77
	25 MGD Phase-III	29	19	91
Rithala	40 MGD Phase-I	27	19	70
	40 MGD Phase-II	16	11	60
Keshopur	12 MGD	16	8	36
	40 MGD	112	78	192
	20 MGD	244	176	502
Nilothi	40 MGD Pahse-I	60	33	-
Nazafgarh	5 MGD	25	12	60
PappanKalan	20 MGD Phase-I	37	21	28
	20 MGD Phase-II	9	4	28
Corronation pillar	20 MGD Pahse-I & II	62	37	98
	10 MGD Pahse-III	64	34	128