

DELHI JAL BOARD
OFFICE OF MEMBER (WATER SUPPLY)
VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI

No. DJB/M (WS)/A-97/2017/
WATER PRODUCTION REPORT

Date: 16.07.21

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/668.30	9200	23''	2700
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		6.1

PRODUCTION DETAILS **TOTAL PRODUCTION : 891.46 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

YAMUNA WATER

i)	Chandrawal	98	Wazirabad Pond	87.27	
ii)	Wazirabad	124	-Do-	102.01	
iii)	Haiderpur	220	WJC Canal	198.60	
iv)	Nangloi	40	-Do-	42.13	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	20.85	
vi)	Dwarka		WJC Canal	50.92	
vii)	Bawana		WJC Canal	20.01	

GANGA WATER

vii)	Bhagirathi	100	Upper Ganga Canal	109.95	
viii)	Sonia Vihar	144	-Do-	133.77	
1)	Production of Water Treatment Plants			765.51	

RECYCLING /PROCESS WASTE WATER PLANTS

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.23	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.10	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.62	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			30.95	

GROUND WATER SOURCES

3)	Production from Ranney wells & Tube wells			95.00	
	Total	(1+2+3)		891.46	

5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	3.96
Greater Kailash (N)	4.80	3.65
Deer Park	4.50	3.90
Janak Puri	3.00	3.35
Kalka Ji	3.65	4.14

6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected
	Sonia Vihar south delhi pumping low due to panel repair work	10.17 am to 5.49 pm , 9.33 pm to 11.40 pm	

Note :- Total supply of water in last 24 hours i.e..15.07.21 -----891.46 MGD

Member (WS)

Copy to: -

1. Pr. Secretary to Lt. Governor
2. P.S. to Chief Minister, Delhi
3. P.S. to Chief Secretary, Delhi
4. Principal Secretary (UD) Govt., of NCT of Delhi
5. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
6. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
 - a. Hudson Lane, Civil Lines ,Delhi-110009
7. CE(WW)
8. CE (East)

DELHI JAL BOARD
OFFICE OF MEMBER (WATER SUPPLY)
VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI

No. DJB/M (WS)/A-97/2017/
WATER PRODUCTION REPORT

Date: 17.07.21

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/667.30	5200	13''	2200
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		6.4,4.5

PRODUCTION DETAILS

TOTAL PRODUCTION : 944.12 MGD

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

YAMUNA WATER

i)	Chandrawal	98	Wazirabad Pond	90.65	
ii)	Wazirabad	124	-Do-	123.94	
iii)	Haiderpur	220	WJC Canal	218.47	
iv)	Nangloi	40	-Do-	42.13	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	20.89	
vi)	Dwarka		WJC Canal	52.05	
vii)	Bawana		WJC Canal	20.01	

GANGA WATER

vii)	Bhagirathi	100	Upper Ganga Canal	109.20	
viii)	Sonia Vihar	144	-Do-	141.18	
1)	Production of Water Treatment Plants			818.52	

RECYCLING /PROCESS WASTE WATER PLANTS

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.24	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.10	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.26	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			30.60	

GROUND WATER SOURCES

3)	Production from Ranney wells & Tube wells		95.00	
	Total	(1+2+3)	944.12	

5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	3.96
Greater Kailash (N)	4.80	3.35

Deer Park	4.50	3.40
Janak Puri	3.00	3.40
Kalka Ji	3.65	3.96

6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e. 16.07.2021 -----944.12 MGD

Member (WS)

Copy to: -

1. Pr. Secretary to Lt. Governor
2. P.S. to Chief Minister, Delhi
3. P.S. to Chief Secretary, Delhi
4. Principal Secretary (UD) Govt., of NCT of Delhi
5. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
6. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
 - a. Hudson Lane, Civil Lines ,Delhi-110009
7. CE(WW)
8. CE (East)
9. Dir F & A
10. E.E. (EDP) for uploading on Website
11. Office copy

DELHI JAL BOARD
OFFICE OF MEMBER (WATER SUPPLY)
VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI

No. DJB/M (WS)/A-97/2017/
WATER PRODUCTION REPORT

Date: 18.07.21

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/666.90	3600	9"	550
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		5.6

PRODUCTION DETAILS **TOTAL PRODUCTION : 954.58 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

YAMUNA WATER

i)	Chandrawal	98	Wazirabad Pond	95.75	
ii)	Wazirabad	124	-Do-	123.94	
iii)	Haiderpur	220	WJC Canal	219.25	
iv)	Nangloi	40	-Do-	43.61	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	22.16	
vi)	Dwarka		WJC Canal	50.48	
vii)	Bawana		WJC Canal	20.00	

GANGA WATER

vii)	Bhagirathi	100	Upper Ganga Canal	109.62	
viii)	Sonia Vihar	144	-Do-	141.68	
1)	Production of Water Treatment Plants			828.49	

RECYCLING /PROCESS WASTE WATER PLANTS

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.29	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.20	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.60	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			31.09	

GROUND WATER SOURCES

3)	Production from Ranney wells & Tube wells			95.00	
	Total	(1+2+3)		954.58	

5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	4.20
Greater Kailash (N)	4.80	3.35
Deer Park	4.50	4.00
Janak Puri	3.00	3.40
Kalka Ji	3.65	4.26

6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e..17.07.21 -----954.58 MGD

Member (WS)

Copy to: -

9. Pr. Secretary to Lt. Governor
10. P.S. to Chief Minister, Delhi
11. P.S. to Chief Secretary, Delhi
12. Principal Secretary (UD) Govt., of NCT of Delhi
13. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
14. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
 - a. Hudson Lane, Civil Lines ,Delhi-110009
15. CE(WW)
16. CE (East)

DELHI JAL BOARD
OFFICE OF MEMBER (WATER SUPPLY)
VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI

No. DJB/M (WS)/A-97/2017/
WATER PRODUCTION REPORT

Date: 19.07.21

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/666.80	3200	3"	450
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		6.7

PRODUCTION DETAILS **TOTAL PRODUCTION : 949.17 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

YAMUNA WATER

i)	Chandrawal	98	Wazirabad Pond	93.91	
ii)	Wazirabad	124	-Do-	123.85	
iii)	Haiderpur	220	WJC Canal	219.25	
iv)	Nangloi	40	-Do-	42.04	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	21.93	
vi)	Dwarka		WJC Canal	52.46	
vii)	Bawana		WJC Canal	20.00	

GANGA WATER

vii)	Bhagirathi	100	Upper Ganga Canal	112.17	
viii)	Sonia Vihar	144	-Do-	140.80	
1)	Production of Water Treatment Plants			826.41	

RECYCLING /PROCESS WASTE WATER PLANTS

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.27	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.20	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	1.29	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			27.76	

GROUND WATER SOURCES

3)	Production from Ranney wells & Tube wells			95.00	
	Total	(1+2+3)		949.17	

5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	3.96
Greater Kailash (N)	4.80	3.04
Deer Park	4.50	4.00
Janak Puri	3.00	3.40
Kalka Ji	3.65	4.54

m6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Afected

Note :- Total supply of water in last 24 hours i.e. 18.07.21 -----949.17 MGD

Member (WS)

Copy to: -

- 1. Pr. Secretary to Lt. Governor**
- 2. P.S. to Chief Minister, Delhi**
- 3. P.S. to Chief Secretary, Delhi**
- 4. Principal Secretary (UD) Govt., of NCT of Delhi**
- 5. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi**
- 6. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,**
- 7. Hudson Lane, Civil Lines ,Delhi-110009**
- 8. CE(WW)**
- 9. CE (East)**
- 10. Dir F & A**
- 11. E.E. (EDP) for uploading on Website**
- 12. Office copy**

DELHI JAL BOARD
OFFICE OF MEMBER (WATER SUPPLY)
VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI

No. DJB/M (WS)/A-97/2017/
WATER PRODUCTION REPORT

Date: 20.07.21

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/667.20	4800	12"	860
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		6.4,4.6

PRODUCTION DETAILS **TOTAL PRODUCTION : 933.35 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

YAMUNA WATER

i)	Chandrawal	98	Wazirabad Pond	88.34	
ii)	Wazirabad	124	-Do-	118.15	
iii)	Haiderpur	220	WJC Canal	219.04	
iv)	Nangloi	40	-Do-	42.87	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	18.71	
vi)	Dwarka		WJC Canal	52.47	
vii)	Bawana		WJC Canal	18.33	

GANGA WATER

vii)	Bhagirathi	100	Upper Ganga Canal	109.74	
viii)	Sonia Vihar	144	-Do-	139.63	
1)	Production of Water Treatment Plants			807.28	

RECYCLING /PROCESS WASTE WATER PLANTS

i)	Wazirabad	11	Recycled process waste at Wzd. Plant	10.28	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.20	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.59	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			31.07	

GROUND WATER SOURCES

3)	Production from Ranney wells & Tube wells			95.00	
	Total	(1+2+3)		933.35	

5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	4.14
Greater Kailash (N)	4.80	3.04
Deer Park	4.50	4.00
Janak Puri	3.00	3.40

Kalka Ji	3.65	4.26
----------	------	------

6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e. 19.07.2021 -----933.36 MGD

Member (WS)

Copy to: -

1. Pr. Secretary to Lt. Governor
2. P.S. to Chief Minister, Delhi
3. P.S. to Chief Secretary, Delhi
4. Principal Secretary (UD) Govt., of NCT of Delhi
5. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
6. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
a. Hudson Lane, Civil Lines ,Delhi-110009
7. CE(WW)
8. CE (East)
9. Dir F & A
10. E.E. (EDP) for uploading on Website
11. Office copy

DELHI JAL BOARD
OFFICE OF MEMBER (WATER SUPPLY)
VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI

No. DJB/M (WS)/A-97/2017/
WATER PRODUCTION REPORT

Date: 21.07.21

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/666.60	2500	6-3"	720
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		8

PRODUCTION DETAILS **TOTAL PRODUCTION : 874.51 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

YAMUNA WATER

i)	Chandrawal	98	Wazirabad Pond	81.87	
ii)	Wazirabad	124	-Do-	89.95	
iii)	Haiderpur	220	WJC Canal	201.89	
iv)	Nangloi	40	-Do-	43.09	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	15.72	
vi)	Dwarka		WJC Canal	52.44	
vii)	Bawana		WJC Canal	20.02	

GANGA WATER

vii)	Bhagirathi	100	Upper Ganga Canal	109.80	
viii)	Sonia Vihar	144	-Do-	133.82	
1)	Production of Water Treatment Plants			748.60	

RECYCLING /PROCESS WASTE WATER PLANTS

i)	Wazirabad	11	Recycled process waste at Wzd. Plant	10.28	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.10	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.53	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			30.91	

GROUND WATER SOURCES

3)	Production from Ranney wells & Tube wells			95.00	
	Total	(1+2+3)		874.51	

5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	3.96
Greater Kailash (N)	4.80	3.35
Deer Park	4.50	4.00
Janak Puri	3.00	3.25

Kalka Ji	3.65	4.45
----------	------	------

m6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e. 20.07.21-----874.51 MGD

Member (WS)

Copy to: -

1. Pr. Secretary to Lt. Governor
2. P.S. to Chief Minister, Delhi
3. P.S. to Chief Secretary, Delhi
4. Principal Secretary (UD) Govt., of NCT of Delhi
5. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
6. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
a. Hudson Lane, Civil Lines ,Delhi-110009
7. CE(WW)
8. CE (East)
9. Dir F & A
10. E.E. (EDP) for uploading on Website
11. Office copy

No. DJB/M (WS)/A-97/2017/
WATER PRODUCTION REPORT

Date: 22.07.21

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/666.60	2400	6''	520
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		5.4

PRODUCTION DETAILS**TOTAL PRODUCTION : 919.75 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

YAMUNA WATER

i)	Chandrawal	98	Wazirabad Pond	88.23	
ii)	Wazirabad	124	-Do-	116.18	
iii)	Haiderpur	220	WJC Canal	205.72	
iv)	Nangloi	40	-Do-	42.33	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	19.51	
vi)	Dwarka		WJC Canal	50.42	
vii)	Bawana		WJC Canal	20.00	

GANGA WATER

vii)	Bhagirathi	100	Upper Ganga Canal	108.91	
viii)	Sonia Vihar	144	-Do-	140.53	
1)	Production of Water Treatment Plants			793.83	

RECYCLING /PROCESS WASTE WATER PLANTS

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.30	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.20	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.42	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			30.92	

GROUND WATER SOURCES

3)	Production from Ranney wells & Tube wells			95.00	
	Total	(1+2+3)		919.75	

5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	3.96
Greater Kailash (N)	4.80	3.04
Deer Park	4.50	4.00
Janak Puri	3.00	3.40
Kalka Ji	3.65	4.54

6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e..21.07.21 -----919.75 MGD

Member (WS)

Copy to: -

1. Pr. Secretary to Lt. Governor
2. P.S. to Chief Minister, Delhi
3. P.S. to Chief Secretary, Delhi
4. Principal Secretary (UD) Govt., of NCT of Delhi
5. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
6. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
 - a. Hudson Lane, Civil Lines ,Delhi-110009
7. CE(WW)
8. CE (East)

DELHI JAL BOARD
OFFICE OF MEMBER (WATER SUPPLY)
VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI

No. DJB/M (WS)/A-97/2017/
WATER PRODUCTION REPORT

Date: 23.07.21

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/668.30	9200	23''	2700
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		6.1

PRODUCTION DETAILS **TOTAL PRODUCTION : 925.36 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

YAMUNA WATER

i)	Chandrawal	98	Wazirabad Pond	87.27	
ii)	Wazirabad	124	-Do-	102.01	
iii)	Haiderpur	220	WJC Canal	198.60	
iv)	Nangloi	40	-Do-	42.13	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	20.85	
vi)	Dwarka		WJC Canal	50.92	
vii)	Bawana		WJC Canal	20.01	

GANGA WATER

vii)	Bhagirathi	100	Upper Ganga Canal	109.95	
viii)	Sonia Vihar	144	-Do-	133.77	
1)	Production of Water Treatment Plants			765.51	

RECYCLING /PROCESS WASTE WATER PLANTS

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.23	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.10	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.62	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			30.95	

GROUND WATER SOURCES

3)	Production from Ranney wells & Tube wells			95.00	
	Total	(1+2+3)		925.36	

5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	3.96
Greater Kailash (N)	4.80	3.65
Deer Park	4.50	3.90
Janak Puri	3.00	3.35
Kalka Ji	3.65	4.14

6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e..22.07.21 -----925.36 MGD

Member (WS)

Copy to: -

1. Pr. Secretary to Lt. Governor
2. P.S. to Chief Minister, Delhi
3. P.S. to Chief Secretary, Delhi
4. Principal Secretary (UD) Govt., of NCT of Delhi
5. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
6. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
 - a. Hudson Lane, Civil Lines ,Delhi-110009
7. CE(WW)
8. CE (East)

DELHI JAL BOARD
OFFICE OF MEMBER (WATER SUPPLY)
VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI

No. DJB/M (WS)/A-97/2017/
WATER PRODUCTION REPORT

Date: 24.07.21

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/669.20	13600	34''	1120
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		6

PRODUCTION DETAILS

TOTAL PRODUCTION : 938.22 MGD

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

YAMUNA WATER

i)	Chandrawal	98	Wazirabad Pond	92.81	
ii)	Wazirabad	124	-Do-	120.67	
iii)	Haiderpur	220	WJC Canal	219.36	
iv)	Nangloi	40	-Do-	42.32	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	22.04	
vi)	Dwarka		WJC Canal	52.43	
vii)	Bawana		WJC Canal	20.01	

GANGA WATER

vii)	Bhagirathi	100	Upper Ganga Canal	106.98	
viii)	Sonia Vihar	144	-Do-	136.04	
1)	Production of Water Treatment Plants			812.66	

RECYCLING /PROCESS WASTE WATER PLANTS

i)	Wazirabad	11	Recycled process waste at Wzd. Plant	10.29	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.10	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.17	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			30.56	

GROUND WATER SOURCES

3)	Production from Ranney wells & Tube wells			95.00	
	Total	(1+2+3)		938.22	

5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters) at 6.00 am	3.04
Jhandewalan	4.11	4.14

Greater Kailash (O)	5.12	3.13
Greater Kailash (N)	4.80	3.04
Deer Park	4.50	4.20
Janak Puri	3.00	3.40
Kalka Ji	3.65	4.54

6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e. 23.07.2021 -----938.22 MGD

Member (WS)

Copy to: -

1. Pr. Secretary to Lt. Governor
2. P.S. to Chief Minister, Delhi
3. P.S. to Chief Secretary, Delhi
4. Principal Secretary (UD) Govt., of NCT of Delhi
5. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
6. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
a. Hudson Lane, Civil Lines ,Delhi-110009
7. CE(WW)
8. CE (East)
9. Dir F & A
10. E.E. (EDP) for uploading on Website
11. Office copy

DELHI JAL BOARD
OFFICE OF MEMBER (WATER SUPPLY)
VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI

No. DJB/M (WS)/A-97/2017/
WATER PRODUCTION REPORT

Date: 25.07.21

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/669.70	17600	44''	800
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		6.2

PRODUCTION DETAILS **TOTAL PRODUCTION : 949.56 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

YAMUNA WATER

i)	Chandrawal	98	Wazirabad Pond	95.61	
ii)	Wazirabad	124	-Do-	123.90	
iii)	Haiderpur	220	WJC Canal	219.25	
iv)	Nangloi	40	-Do-	43.50	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	21.98	
vi)	Dwarka		WJC Canal	52.44	
vii)	Bawana		WJC Canal	20.02	

GANGA WATER

vii)	Bhagirathi	100	Upper Ganga Canal	108.57	
viii)	Sonia Vihar	144	-Do-	138.31	
1)	Production of Water Treatment Plants			823.58	

RECYCLING /PROCESS WASTE WATER PLANTS

i)	Wazirabad	11	Recycled process waste at Wzd. Plant	10.31	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.20	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.47	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			30.98	

GROUND WATER SOURCES

3)	Production from Ranney wells & Tube wells			95.00	
	Total	(1+2+3)		949.56	

5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	3.13
Greater Kailash (N)	4.80	2.89
Deer Park	4.50	4.00
Janak Puri	3.00	3.40

Kalka Ji	3.65	4.26
----------	------	------

6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e..24.07.21 -----949.56 MGD

Member (WS)

Copy to: -

- 9. Pr. Secretary to Lt. Governor
- 10. P.S. to Chief Minister, Delhi
- 11. P.S. to Chief Secretary, Delhi
- 12. Principal Secretary (UD) Govt., of NCT of Delhi
- 13. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
- 14. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
 - a. Hudson Lane, Civil Lines ,Delhi-110009
- 15. CE(WW)
- 16. CE (East)

DELHI JAL BOARD
OFFICE OF MEMBER (WATER SUPPLY)
VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI

No. DJB/M (WS)/A-97/2017/
WATER PRODUCTION REPORT

Date: 26.07.21

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/669.70	13600	34''	600
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		2.5

PRODUCTION DETAILS **TOTAL PRODUCTION : 951.80 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

YAMUNA WATER

i)	Chandrawal	98	Wazirabad Pond	95.77	
ii)	Wazirabad	124	-Do-	123.88	
iii)	Haiderpur	220	WJC Canal	219.03	
iv)	Nangloi	40	-Do-	42.74	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	22.41	
vi)	Dwarka		WJC Canal	52.42	
vii)	Bawana		WJC Canal	20.02	

GANGA WATER

vii)	Bhagirathi	100	Upper Ganga Canal	108.95	
viii)	Sonia Vihar	144	-Do-	140.71	
1)	Production of Water Treatment Plants			825.93	

RECYCLING /PROCESS WASTE WATER PLANTS

i)	Wazirabad	11	Recycled process waste at Wzd. Plant	10.28	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.20	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.39	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			30.87	

GROUND WATER SOURCES

3)	Production from Ranney wells & Tube wells			95.00	
	Total	(1+2+3)		951.80	

5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	4.14
Greater Kailash (N)	4.80	3.04
Deer Park	4.50	4.00

Janak Puri	3.00	3.40
Kalka Ji	3.65	4.14

m6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Afected

Note :- Total supply of water in last 24 hours i.e. 25.07.21 -----951.80 MGD

Member (WS)

Copy to: -

1. Pr. Secretary to Lt. Governor
2. P.S. to Chief Minister, Delhi
3. P.S. to Chief Secretary, Delhi
4. Principal Secretary (UD) Govt., of NCT of Delhi
5. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
6. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
7. Hudson Lane, Civil Lines ,Delhi-110009
8. CE(WW)
9. CE (East)
10. Dir F & A
11. E.E. (EDP) for uploading on Website
12. Office copy

DELHI JAL BOARD
OFFICE OF MEMBER (WATER SUPPLY)
VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI

No. DJB/M (WS)/A-97/2017/
WATER PRODUCTION REPORT

Date: 27.07.21

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/669.70	10800	27"	980
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		6.1

PRODUCTION DETAILS

TOTAL PRODUCTION : 949.56 MGD

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

YAMUNA WATER

i)	Chandrawal	98	Wazirabad Pond	94.35	
ii)	Wazirabad	124	-Do-	122.16	
iii)	Haiderpur	220	WJC Canal	219.26	
iv)	Nangloi	40	-Do-	43.07	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	22.51	
vi)	Dwarka		WJC Canal	52.46	
vii)	Bawana		WJC Canal	20.00	

GANGA WATER

vii)	Bhagirathi	100	Upper Ganga Canal	109.12	
viii)	Sonia Vihar	144	-Do-	140.80	
1)	Production of Water Treatment Plants			823.73	

RECYCLING /PROCESS WASTE WATER PLANTS

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.28	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.20	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.35	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			30.83	

GROUND WATER SOURCES

3)	Production from Ranney wells & Tube wells			95.00	
	Total	(1+2+3)		949.56	

5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	4.14

Greater Kailash (N)	4.80	3.04
Deer Park	4.50	4.00
Janak Puri	3.00	3.40
Kalka Ji	3.65	4.26

6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e. 26.07.2021 -----949.56 MGD

Member (WS)

Copy to: -

1. Pr. Secretary to Lt. Governor
2. P.S. to Chief Minister, Delhi
3. P.S. to Chief Secretary, Delhi
4. Principal Secretary (UD) Govt., of NCT of Delhi
5. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
6. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
 - a. Hudson Lane, Civil Lines ,Delhi-110009
7. CE(WW)
8. CE (East)
9. Dir F & A
10. E.E. (EDP) for uploading on Website
11. Office copy