

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/666.70	2800	7"	110
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		7.2,4.2

## PRODUCTION DETAILS TOTAL PRODUCTION : 926.50 MGD

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

## YAMUNA WATER

i)	Chandrawal	98	Wazirabad Pond	94.60	
ii)	Wazirabad	124	-Do-	123.86	
iii)	Haiderpur	220	WJC Canal	207.40	
iv)	Nangloi	40	-Do-	43.57	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	21.13	
vi)	Dwarka		WJC Canal	44.23	
vii)	Bawana		WJC Canal	20.00	

## GANGA WATER

vii)	Bhagirathi	100	Upper Ganga Canal	106.52	
viii)	Sonia Vihar	144	-Do-	140.64	
1)	Production of Water Treatment Plants			801.95	

## RECYCLING /PROCESS WASTE WATER PLANTS

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.20	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.30	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	3.05	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			29.55	

## GROUND WATER SOURCES

3)	Production from Ranney wells & Tube wells			95.00	
	Total	(1+2+3)		926.50	

## 5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	4.45
Greater Kailash (N)	4.80	3.65
Deer Park	4.50	4.10
Janak Puri	3.00	3.40
Kalka Ji	3.65	3.96

**6. TRANSMISSION MAIN**

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected
	Haiderpur short production due to repair work in west delhi 1500mm line	9.05am to 6.15pm	

**Note :- Total supply of water in last 24 hours i.e.19.1.2022 -----926.50MGD**

**Member (WS)**

**Copy to: -**

1. Pr. Secretary to Lt. Governor
2. P.S. to Chief Minister, Delhi
3. P.S. to Chief Secretary, Delhi
4. Principal Secretary (UD) Govt., of NCT of Delhi
5. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
6. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
  - a. Hudson Lane, Civil Lines ,Delhi-110009
7. CE(WW)
8. CE (East)

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/666.70	2400	6''	118
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		7

## PRODUCTION DETAILS TOTAL PRODUCTION : 944.10 MGD

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

## YAMUNA WATER

i)	Chandrawal	98	Wazirabad Pond	94.48	
ii)	Wazirabad	124	-Do-	123.85	
iii)	Haiderpur	220	WJC Canal	219.06	
iv)	Nangloi	40	-Do-	44.14	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	21.16	
vi)	Dwarka		WJC Canal	50.35	
vii)	Bawana		WJC Canal	18.81	

## GANGA WATER

vii)	Bhagirathi	100	Upper Ganga Canal	105.92	
viii)	Sonia Vihar	144	-Do-	140.58	
1)	Production of Water Treatment Plants			818.35	

## RECYCLING /PROCESS WASTE WATER PLANTS

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.21	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.40	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.14	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			30.75	

## GROUND WATER SOURCES

3)	Production from Ranney wells & Tube wells			95.00	
	Total	(1+2+3)		944.10	

## 5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	4.45
Greater Kailash (N)	4.80	3.35
Deer Park	4.50	4.20
Janak Puri	3.00	3.10
Kalka Ji	3.65	3.96

## 6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e.20.1.2022 -----944.10MGD

Member (WS)

### Copy to: -

1. Pr. Secretary to Lt. Governor
2. P.S. to Chief Minister, Delhi
3. P.S. to Chief Secretary, Delhi
4. Principal Secretary (UD) Govt., of NCT of Delhi
5. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
6. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
  - a. Hudson Lane, Civil Lines ,Delhi-110009
7. CE(WW)
8. CE (East)

OFFICE OF MEMBER (WATER SUPPLY)  
VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI

No. DJB/M (WS)/A-97/2017/  
WATER PRODUCTION REPORT

Date: 22.1.2022

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/666.70	2800	7"	120
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		7.8,5.2

PRODUCTION DETAILS

TOTAL PRODUCTION : 941.35 MGD

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

YAMUNA WATER

i)	Chandrawal	98	Wazirabad Pond	94.99	
ii)	Wazirabad	124	-Do-	123.86	
iii)	Haiderpur	220	WJC Canal	219.26	
iv)	Nangloi	40	-Do-	43.93	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	21.32	
vi)	Dwarka		WJC Canal	50.42	
vii)	Bawana		WJC Canal	20.00	

GANGA WATER

vii)	Bhagirathi	100	Upper Ganga Canal	101.82	
viii)	Sonia Vihar	144	-Do-	140.35	
1)	Production of Water Treatment Plants			815.94	

RECYCLING /PROCESS WASTE WATER PLANTS

i)	Wazirabad	11	Recycled process waste at Wzd. Plant	10.09	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.20	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.12	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			30.41	

GROUND WATER SOURCES

3)	Production from Ranney wells & Tube wells			95.00	
	Total	(1+2+3)		941.35	

5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	4.45
Greater Kailash (N)	4.80	3.35
Deer Park	4.50	4.10
Janak Puri	3.00	3.10
Kalka Ji	3.65	4.14

## 6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e.21.1.2022 -----941.35 MGD

Member (WS)

Copy to: -

1. Pr. Secretary to Lt. Governor
2. P.S. to Chief Minister, Delhi
3. P.S. to Chief Secretary, Delhi
4. Principal Secretary (UD) Govt., of NCT of Delhi
5. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
6. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
  - a. Hudson Lane, Civil Lines ,Delhi-110009
7. CE(WW)
8. CE (East)

