

**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/

Date: 23.07.20

**WATER PRODUCTION REPORT**

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/665.00	600	1.6'	88
Western Jamuna Canal Level at Haiderpur		<b>NORMAL (Ft.)</b>		<b>ACTUAL (Ft.)</b>
		710.0		7.4,2.4

**PRODUCTION DETAILS**

**TOTAL PRODUCTION : 931.55 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	93.92	
ii)	Wazirabad	124	-Do-	123.92	
iii)	Haiderpur	220	WJC Canal	213.47	
iv)	Nangloi	40	-Do-	43.39	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	21.7	
vi)	Dwarka		WJC Canal	50.39	
vii)	Bawana		WJC Canal	19.57	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	110.84	
viii)	Sonia Vihar	144	-Do-	139.01	
1)	Production of Water Treatment Plants			<b>816.21</b>	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazirabad	11	Recycled process waste at Wzd. Plant	10.19	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.2	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.95	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			<b>31.34</b>	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells		90	
	Total	(1+2+3)	937.55	

## 5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	3.96
Greater Kailash (O)	5.12	3.99
Greater Kailash (N)	4.80	3.65
Deer Park	4.50	4.20
Janak Puri	3.00	3.30
Kalka Ji	3.65	4.29

## 6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected
1.	Sonia Vihar pump closed at 1.40pm to 2.545 pm		
2.	Bhagirathi two pump closed at 11.30 am to 1.55 pm due to fault in panel		

Note :- Total supply of water in last 24 hours i.e. 22.07.2020 -----937.55 MGD

Member (WS)

Copy to: -

1. Pr. Secretary to Lt. Governor
2. P.S. to Chief Minister, Delhi
3. P.S. to Chief Secretary, Delhi
4. Principal Secretary (UD) Govt., of NCT of Delhi
5. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
6. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,  
a. Hudson Lane, Civil Lines ,Delhi-110009
7. CE(WW)
8. CE (East)
9. Dir F & A
10. E.E. (EDP) for uploading on Website
11. Office copy

**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/  
 24.07.2020

Date:

**WATER PRODUCTION REPORT**

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/665.60	1200	3'	130
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		7.8,2.4

**PRODUCTION DETAILS**

**TOTAL PRODUCTION : 925.82 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	92.98	
ii)	Wazirabad	124	-Do-	114.98	
iii)	Haiderpur	220	WJC Canal	213.22	
iv)	Nangloi	40	-Do-	43.37	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	19.47	
vi)	Dwarka		WJC Canal	50.38	
vii)	Bawana		WJC Canal	19.57	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	110.57	
viii)	Sonia Vihar	144	-Do-	140.14	
1)	Production of Water Treatment Plants			804.68	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazirabad	11	Recycled process waste at Wzd. Plant	10.11	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.1	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.93	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			31.14	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells		90	
	Total	(1+2+3)	925.82	

**5. MAJOR UGRs' LEVELS IN METERS.**

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	3.96
Greater Kailash (O)	5.12	3.99
Greater Kailash (N)	4.80	N/R
Deer Park	4.50	3.90
Janak Puri	3.00	3.00
Kalka Ji	3.65	4.29

**6. TRANSMISSION MAIN**

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

**Note :- Total supply of water in last 24 hours i.e..23.07.2020 -----925.82 MGD**

**Member (WS)**

**Copy to: -**

1. Pr. Secretary to Lt. Governor
2. P.S. to Chief Minister, Delhi
3. P.S. to Chief Secretary, Delhi
4. Principal Secretary (UD) Govt., of NCT of Delhi
5. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
6. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
  - a. Hudson Lane, Civil Lines ,Delhi-110009
7. CE(WW)
8. CE (East)

**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/

Date: 25.07.20

**WATER PRODUCTION REPORT**

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/665.20	800	2'	90
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		6.5

**PRODUCTION DETAILS**

**TOTAL PRODUCTION : 907.58 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	78.49	Increase in ammonia level
ii)	Wazirabad	124	-Do-	111.34	Increase in ammonia level
iii)	Haiderpur	220	WJC Canal	213.57	
iv)	Nangloi	40	-Do-	42.94	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	19.32	
vi)	Dwarka		WJC Canal	50.39	
vii)	Bawana		WJC Canal	19.56	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	110.98	
viii)	Sonia Vihar	144	-Do-	139.87	
1)	Production of Water Treatment Plants			786.46	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazirabad	11	Recycled process waste at Wzd. Plant	10.10	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.1	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.92	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			31.27	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells		90	
	Total	(1+2+3)	907.58	

## 5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	3.96
Greater Kailash (O)	5.12	3.99
Greater Kailash (N)	4.80	3.65
Deer Park	4.50	3.90
Janak Puri	3.00	3.30
Kalka Ji	3.65	4.29

## 6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e. 24.07.2020 -----907.58 MGD

Member (WS)

Copy to: -

12. Pr. Secretary to Lt. Governor
13. P.S. to Chief Minister, Delhi
14. P.S. to Chief Secretary, Delhi
15. Principal Secretary (UD) Govt., of NCT of Delhi
16. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
17. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
  - a. Hudson Lane, Civil Lines ,Delhi-110009
18. CE(WW)
19. CE (East)
20. Dir F & A
21. E.E. (EDP) for uploading on Website
22. Office copy

**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/

Date: 26.07.20

**WATER PRODUCTION REPORT**

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/664.00	1600	4'	80
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		6

**PRODUCTION DETAILS**

**TOTAL PRODUCTION : 937.88 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	93.87	
ii)	Wazirabad	124	-Do-	123.51	
iii)	Haiderpur	220	WJC Canal	213.47	
iv)	Nangloi	40	-Do-	43.35	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	21.78	
vi)	Dwarka		WJC Canal	50.40	
vii)	Bawana		WJC Canal	19.60	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	110.93	
viii)	Sonia Vihar	144	-Do-	139.69	
1)	Production of Water Treatment Plants			816.60	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazirabad	11	Recycled process waste at Wzd. Plant	10.12	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.2	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.96	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			31.28	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells		90	
	Total	(1+2+3)	937.88	

## 5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	3.96
Greater Kailash (O)	5.12	3.99
Greater Kailash (N)	4.80	3.65
Deer Park	4.50	4.00
Janak Puri	3.00	3.30
Kalka Ji	3.65	4.29

## 6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e. 25.07.2020 -----937.88 MGD

Member (WS)

Copy to: -

23. Pr. Secretary to Lt. Governor
24. P.S. to Chief Minister, Delhi
25. P.S. to Chief Secretary, Delhi
26. Principal Secretary (UD) Govt., of NCT of Delhi
27. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
28. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,
  - a. Hudson Lane, Civil Lines ,Delhi-110009
29. CE(WW)
30. CE (East)
31. Dir F & A
32. E.E. (EDP) for uploading on Website
33. Office copy

**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/  
 27.07.2020

Date:

**WATER PRODUCTION REPORT**

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/666.60	2500	6.3'	85
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		6.6,3.3

**PRODUCTION DETAILS**

**TOTAL PRODUCTION : 934.04 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
-----------------------	--------------------------------	------------------	--------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	88.85	Increase in ammonia level
ii)	Wazirabad	124	-Do-	123.90	Increase in ammonia level
iii)	Haiderpur	220	WJC Canal	213.47	
iv)	Nangloi	40	-Do-	44.06	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	21.62	
vi)	Dwarka		WJC Canal	50.38	
vii)	Bawana		WJC Canal	19.56	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	110.89	
viii)	Sonia Vihar	144	-Do-	140.02	
1)	Production of Water Treatment Plants			812.75	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazirabad	11	Recycled process waste at Wzd. Plant	10.14	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16.2	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	4.95	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			31.29	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells		90	
	Total	(1+2+3)	934.04	

**5. MAJOR UGRs' LEVELS IN METERS.**

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	3.96
Greater Kailash (O)	5.12	3.99
Greater Kailash (N)	4.80	3.65
Deer Park	4.50	4.20
Janak Puri	3.00	3.30
Kalka Ji	3.65	4.29

**6. TRANSMISSION MAIN**

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected
	Chandrawal I,II & Wazirabad production low due to Increase in ammonia level		

**Note :- Total supply of water in last 24 hours i.e..26.07.2020 -----934.04 MGD**

**Member (WS)**

**Copy to: -**

9. Pr. Secretary to Lt. Governor
10. P.S. to Chief Minister, Delhi
11. P.S. to Chief Secretary, Delhi
12. Principal Secretary (UD) Govt., of NCT of Delhi
13. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
14. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,  
a. Hudson Lane, Civil Lines ,Delhi-110009
15. CE(WW)
16. CE (East)