



**OFFICE OF THE DIRECTOR (T&QC)**  
**DELHI JAL BOARD: GOVT. OF NCT OF DELHI**  
**WATER WORKS WAZIRABAD:DELHI-110054**



		Parameters of STPs of Delhi as on					24.03.2019			
Name of the Plant	Capacity (in MGD)	Parameter								
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4	
		DPCC limits	5.5-9.0	50	30	250	10	50	5	
Okhla	12 MGD	Inlet	7.5	254	190	448	3	40	1.6	
		outlet	7.7	24	18	56	Nil	37	0.7	
	45 MGD	Inlet	7.4	264	185	456	3	43	1.7	
		outlet	7.8	28	21	72	1	36	0.7	
	37 MGD	Inlet	7.4	264	185	456	3	43	1.7	
		outlet	7.7	26	19	64	1	34	0.6	
	16 MGD	Inlet	7.4	264	185	456	3	43	1.7	
		outlet	7.7	25	17	56	1	35	0.5	
Kondli	25 MGD Phase-II	Inlet	7.3	444	273	396	19	40	7.3	
		outlet	7.6	15	9	32	3	22	3.4	
	45 MGD Phase-IV	Inlet	7.2	460	247	432	25	40	7	
		outlet	7.5	20	12	54	5	34	3.5	
Yamuna Vihar	10 MGD Phase-I	Inlet	7.2	320	217	-	-	45	7	
		outlet	7.6	42	24	-	-	30	3.5	
	Phase-II	Inlet	7.1	448	257	-	-	55	7.5	
		outlet	7.5	39	25	-	-	30	3.5	
	25 MGD Phase-III	Inlet	7.2	544	282	-	-	60	8.5	
		outlet	7.5	33	22	-	-	35	4	
Rithala	40 MGD	Inlet	7.1	268	185	380	-	35	1.6	
		outlet	7.7	32	22	80	-	22	0.8	
	40 MGD	Inlet	7.1	268	185	380	-	35	1.6	
		Outlet	7.6	17	13	60	-	16	0.5	
	Keshopur	12 MGD	Inlet	7.3	396	228	-	-	32	3.4
			outlet	7.6	12	8	-	-	3	2
40 MGD		Inlet	7.2	416	221	-	-	33	3.2	
		outlet	7.5	78	42	-	-	29	2.6	
20 MGD	Inlet	7.2	416	221	-	-	33	3.2		
	outlet	7.3	144	109	-	-	30	3.1		
Nilothi	40 MGD Phase-I	Inlet	7.3	268	127	-	4.2	25	2.9	
		outlet	7.5	46	28	-	0.8	21	2.5	
PappanKalan	20 MGD Phase-I	Inlet	7.3	368	283	-	-	32	2	
		outlet	7.5	42	34	-	-	18	0.8	
	20 MGD Phase-II	Inlet	7.3	368	283	-	-	32	2	
		outlet	7.6	7	5	-	-	6	1	
Corronation pillar	20 MGD Phase-I & II	Inlet	7.2	174	163	316	5.8	38	2.1	
		outlet	7.6	48	29	96	2.9	25	1.2	
	10 MGD Phase-III	Inlet	7.4	316	295	436	-	52	2.3	
		outlet	7.6	47	28	95	-	30	1.2	

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)  
DELHI JAL BOARD: GOVT. OF NCT OF DELHI  
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	24.03.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
		50	30	250
Okhla	12 MGD	24	18	56
	45 MGD	28	21	72
	37 MGD	26	19	64
	16 MGD	25	17	56
Kondli	25 MGD Pahse-II	15	9	32
	45 MGD Phase-IV	20	12	54
Yamuna Vihar	10 MGD Phase-I	42	24	-
	Phase-II	39	25	-
	25 MGD Phase-III	33	22	-
Rithala	40 MGD Phase-I	32	22	80
	40 MGD Phase-II	17	13	60
Keshopur	12 MGD	12	8	-
	40 MGD	78	42	-
	20 MGD	144	109	-
Nilothi	40 MGD Pahse-I	46	28	-
PappanKalan	20 MGD Phase-I	42	34	-
	20 MGD Phase-II	7	5	-
Corronation pillar	20 MGD Pahse-I & II	48	29	96
	10 MGD Pahse-III	47	28	95



**OFFICE OF THE DIRECTOR (T&QC)**  
**DELHI JAL BOARD: GOVT. OF NCT OF DELHI**  
**WATER WORKS WAZIRABAD:DELHI-110054**



		Parameters of STPs of Delhi as on					25.03.2019		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPPC limits	5.5-9.0	50	30	250	10	50	5
Okhla	12 MGD	Inlet	7.4	308	185	432	4	38	2.8
		outlet	7.5	48	21	112	2	35	2.5
	45 MGD	Inlet	7.4	362	200	480	3	42	2.8
		outlet	7.5	29	20	80	Nil	38	1.5
	37 MGD	Inlet	7.4	362	200	480	3	42	2.8
		outlet	7.6	37	23	88	Nil	42	0.8
	16 MGD	Inlet	7.4	362	200	480	3	42	2.8
		outlet	7.6	30	20	80	Nil	40	1
	New 30 MGD	Inlet	7.4	336	189	448	-	40	2.5
		Outlet	7.7	9	8	32	-	10	1.8
Molarband	0.66 MGD	Inlet	7.2	1920	626	2240	1.3	58	3.6
		outlet	7.8	29	21	80	2	40	3
Kondli	25 MGD Phase-II	Inlet	7.2	348	232	354	-	41	6.8
		outlet	7.6	23	12	45	-	22	3.3
	45 MGD Phase-IV	Inlet	7.2	374	204	366	-	40	6.9
		outlet	7.5	30	15	72	-	33	4.9
Chilla	9 MGD	Inlet	7.1	350	176	386	-	41	6.7
		outlet	7.6	8	4	19	-	0.27	4.9
CWG Village	1 MGD	Inlet	7.2	500	269	522	-	23	5.1
		outlet	7.6	1	0.36	Bdl	-	0.16	1.5
Delhi Gate Nallah	2.2 MGD	Inlet	7.1	296	170	424	8	45	2.2
		outlet	7.5	10	10	40	Nil	5	0.5
	15 MGD	Inlet	7.2	254	163	2240	5	40	3
		outlet	7.5	6	6	24	1	1.5	0.8
Yamuna Vihar	10 MGD Phase-I	Inlet	7.3	326	216	-	-	55	6
		outlet	7.5	46	28	-	-	35	3
	Phase-II	Inlet	7.1	470	285	-	-	35	5
		outlet	7.5	40	25	-	-	25	3
	25 MGD Phase-III	Inlet	7.2	680	326	-	-	60	6.5
		outlet	7.4	28	20	-	-	45	4
Rithala	40 MGD	Inlet	7.2	356	183	430	26	33	1.2
		outlet	7.8	30	21	90	7	19	0.9
	40 MGD	Inlet	7.2	356	183	430	26	33	1.2
		Outlet	7.7	18	14	60	4	14	0.7
Keshopur	12 MGD	Inlet	7.2	420	298	-	-	39	3.6
		outlet	7.4	11	28	-	-	4	2.2
	40 MGD	Inlet	7.2	548	290	-	-	40	3.4
		outlet	7.4	76	69	-	-	34	3
	20 MGD	Inlet	7.2	548	290	-	-	40	3.4
		outlet	7.3	160	157	-	-	36	3.2
Nilothi	40 MGD Phase-I	Inlet	7.3	304	126	490	-	27	3
		outlet	7.4	34	25	90	-	21	2.4
	20 MGD Phase-II	Inlet	7.2	320	164	570	-	30	3.8
		outlet	7.2	10	6	26	-	7	1.6
Nazafgarh	5 MGD	Inlet	7.3	321	220	380	5	-	-
		outlet	7.5	13	7	60	Nil	-	-
PappanKalan	20 MGD Phase-I	Inlet	7.3	361	255	580	6	32	3
		outlet	7.5	28	23	80	Nil	24	1.2
	20 MGD Phase-II	Inlet	7.3	361	255	580	6	32	3
		outlet	7.5	7	7	30	Nil	14	2.2
Corronation pillar	20 MGD Phase-I & II	Inlet	7.3	168	155	376	-	40	2.4
		outlet	7.6	54	32	102	-	29	1.3
	10 MGD Phase-III	Inlet	7.2	298	275	452	8.1	50	2.5
		outlet	7.5	46	27	90	3.2	32	1.4
Narela	10 MGD	Inlet	7.3	162	165	314	7.9	48	2.6
		outlet	7.7	55	35	210	3.6	35	1.4

Dir.(T&QC)



**OFFICE OF THE DIRECTOR (T&QC)**  
**DELHI JAL BOARD: GOVT. OF NCT OF DELHI**  
**WATER WORKS WAZIRABAD:DELHI-110054**



Name of the Plant	Capacity (in MGD)	25.03.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
		50	30	250
Okhla	12 MGD	48	21	112
	45 MGD	29	20	80
	37 MGD	37	23	88
	16 MGD	30	20	80
	New 30 MGD	9	8	32
Molarband	0.66 MGD	29	21	80
Kondli	25 MGD Pahse-II	23	12	45
	45 MGD Phase-IV	30	15	72
Chilla	9 MGD	8	4	19
CWG Village	1 MGD	1	0.36	Bdl
Delhi Gate Nallah	2.2 MGD Pahse-I	10	10	40
	15 MGD Pahse-II	6	6	24
Yamuna Vihar	10 MGD Phase-I	46	28	-
	Phase-II	40	25	-
	25 MGD Phase-III	28	20	-
Rithala	40 MGD Phase-I	30	21	90
	40 MGD Phase-II	18	14	60
Keshopur	12 MGD	11	28	-
	40 MGD	76	69	-
	20 MGD	160	157	-
Nilothi	40 MGD Pahse-I	34	25	90
	20 MGD Phase-II	10	6	26
Nazafgarh	5 MGD	13	7	60
PappanKalan	20 MGD Phase-I	28	23	80
	20 MGD Phase-II	7	7	30
Corronation pillar	20 MGD Pahse-I & II	54	32	102
	10 MGD Pahse-III	46	27	90
Narela	10 MGD	55	35	210



**OFFICE OF THE DIRECTOR (T&QC)**  
**DELHI JAL BOARD: GOVT. OF NCT OF DELHI**  
**WATER WORKS WAZIRABAD:DELHI-110054**



		Parameters of STPs of Delhi as on					26.03.2019		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPPC limits	5.5-9.0	50	30	250	10	50	5
Okhla	12 MGD	Inlet	7.4	374	238	448	4	45	2.2
		outlet	7.7	31	22	80	1	43	0.8
	45 MGD	Inlet	7.4	322	263	448	4	45	2
		outlet	7.6	30	22	80	3	43	Nil
	37 MGD	Inlet	7.4	322	263	448	4	45	2
		outlet	7.6	24	16	64	2	30	0.5
16 MGD	Inlet	7.4	322	263	448	4	45	2	
	outlet	7.6	23	17	64	3	40	1	
Kondli	25 MGD Phase-II	Inlet	7.2	370	241	344	18.5	40	7
		outlet	7.6	22	9	46	3	24	3.4
	45 MGD Phase-IV	Inlet	7.2	420	258	378	24.5	39	6.8
		outlet	7.5	28	18	58	4.5	31	2.9
Chilla	9 MGD	Inlet	7.1	308	116	310	16.2	41	6.8
		outlet	7.6	8	3.9	18	2.4	0.25	4.7
CWG Village	1 MGD	Inlet	7.2	236	270	224	305	23	5
		outlet	7.7	1	Bdl	Bdl	Bdl	0.14	1.4
Yamuna Vihar	10 MGD Phase-I	Inlet	7.6	256	177	766	64.8	50	6.5
		outlet	7.3	39	23	114	26.4	35	3.5
	Phase-II	Inlet	7.2	244	168	655	-	45	5.5
		outlet	7.6	18	12	60	-	15	2.5
	25 MGD Phase-III	Inlet	7.2	400	277	1099	87.6	70	8.5
		outlet	7.5	35	22	103	32.4	45	5
Rithala	40 MGD	Inlet	7.1	312	153	460	-	29	0.9
		outlet	7.9	29	19	80	-	17	0.6
	40 MGD	Inlet	7.1	312	153	460	-	29	0.9
		Outlet	7.8	16	10	50	-	12	0.4
Keshopur	12 MGD	Inlet	7.3	468	271	720	-	38	3.7
		outlet	7.5	6	5	30	-	3	3.4
	40 MGD	Inlet	7.2	448	310	776	-	39	4.4
		outlet	7.4	114	97	240	-	36	3.2
	20 MGD	Inlet	7.2	448	310	776	-	39	4.4
		outlet	7.3	154	158	380	-	36	3.1
Nilothi	40 MGD Phase-I	Inlet	7.3	220	123	-	4.6	26	2.8
		outlet	7.4	28	25	-	0.8	20	2
Nazafgarh	5 MGD	Inlet	7.3	178	156	-	-	-	-
		outlet	7.5	15	9	-	-	-	-
PappanKalan	20 MGD Phase-I	Inlet	7.3	474	275	-	-	32	3
		outlet	7.5	30	24	-	-	22	1.2
	20 MGD Phase-II	Inlet	7.3	474	275	-	-	32	3
		outlet	7.5	11	7	-	-	16	2.2
Corronation pillar	20 MGD Phase-I & II	Inlet	7.4	320	260	436	6.8	38	2.3
		outlet	7.7	46	29	84	3	24	1.2
	10 MGD Phase-III	Inlet	7.3	326	305	462	-	48	2.3
		outlet	7.6	52	31	106	-	34	1.3

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)  
DELHI JAL BOARD: GOVT. OF NCT OF DELHI  
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	26.03.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
		50	30	250
Okhla	12 MGD	31	22	80
	45 MGD	30	22	80
	37 MGD	24	16	64
	16 MGD	23	17	64
Kondli	25 MGD Pahse-II	22	9	46
	45 MGD Phase-IV	28	18	58
Chilla	9 MGD	8	3.9	18
CWG Village	1 MGD	1	Bdl	Bdl
Yamuna Vihar	10 MGD Phase-I	39	23	114
	Phase-II	18	12	60
	25 MGD Phase-III	35	22	103
Rithala	40 MGD Phase-I	29	19	80
	40 MGD Phase-II	16	10	50
Keshopur	12 MGD	6	5	30
	40 MGD	114	97	240
	20 MGD	154	158	380
Nilothi	40 MGD Pahse-I	28	25	-
Nazafgarh	5 MGD	15	9	-
PappanKalan	20 MGD Phase-I	30	24	-
	20 MGD Phase-II	11	7	-
Corronation pillar	20 MGD Pahse-I & II	46	29	84
	10 MGD Pahse-III	52	31	106



**OFFICE OF THE DIRECTOR (T&QC)**  
**DELHI JAL BOARD: GOVT. OF NCT OF DELHI**  
**WATER WORKS WAZIRABAD:DELHI-110054**



		Parameters of STPs of Delhi as on					27.03.2019		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Okhla	12 MGD	Inlet	7.3	524	258	504	3	42	1.5
		outlet	7.8	26	18	72	1	40	Nil
	45 MGD	Inlet	7.4	440	235	-	4	42	2.5
		outlet	7.8	41	26	-	2	40	0.5
	37 MGD	Inlet	7.4	440	235	-	4	42	2.5
		outlet	7.8	26	19	-	1	43	0.8
	16 MGD	Inlet	7.4	440	235	-	4	42	2.5
		outlet	7.9	27	21	-	Nil	42	1.8
Kondli	25 MGD Phase-II	Inlet	7.2	246	186	216	27	37	6.9
		outlet	7.6	13	8	27	4	21	3.2
	45 MGD Phase-IV	Inlet	7.2	274	213	210	25	38	7.1
		outlet	7.5	30	19	62	5	30	3.8
Yamuna Vihar	10 MGD Phase-I	Inlet	7.3	316	209	792	-	50	6.5
		outlet	7.6	32	20	100	-	30	3.5
	Phase-II	Inlet	7.2	252	176	679	-	50	7
		outlet	7.6	21	14	68	-	15	2.5
	25 MGD Phase-III	Inlet	7.2	320	190	895	-	60	8
		outlet	7.6	60	32	180	-	40	3
Rithala	40 MGD	Inlet	7.2	268	158	390	-	39	1.9
		outlet	7.6	28	17	70	-	21	1.2
	40 MGD	Inlet	7.2	268	158	390	-	39	1.9
		Outlet	7.7	17	11	60	-	16	0.8
Keshopur	12 MGD	Inlet	7.3	364	226	-	-	36	3.2
		outlet	7.6	8	6	-	-	3	3
	40 MGD	Inlet	7.2	644	267	-	-	37	3.6
		outlet	7.5	120	78	-	-	34	3.2
	20 MGD	Inlet	7.2	644	267	-	-	37	3.6
		outlet	7.4	124	116	-	-	32	3.4
Nilothi	40 MGD Phase-I	Inlet	7.3	260	127	-	5.4	25	2.4
		outlet	7.5	40	25	-	0.9	20	1.8
Nazafgarh	5 MGD	Inlet	7.3	210	165	-	-	-	-
		outlet	7.5	18	10	-	-	-	-
PappanKalan	20 MGD Phase-I	Inlet	7.3	522	330	-	-	32	3
		outlet	7.5	29	27	-	-	27	1.2
	20 MGD Phase-II	Inlet	7.3	522	330	-	-	32	3
		outlet	7.5	16	12	-	-	26	2.4
Corronation pillar	20 MGD Phase-I & II	Inlet	7	212	195	348	5.8	37	2.2
		outlet	7.5	48	28	98	2.9	26	1.2
	10 MGD Phase-III	Inlet	7.2	334	310	482	7.2	54	2
		outlet	7.5	64	36	126	2.8	31	1

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)  
DELHI JAL BOARD: GOVT. OF NCT OF DELHI  
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	27.03.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
		50	30	250
Okhla	12 MGD	26	18	72
	45 MGD	41	26	-
	37 MGD	26	19	-
	16 MGD	27	21	-
Kondli	25 MGD Pahse-II	13	8	27
	45 MGD Phase-IV	30	19	62
Yamuna Vihar	10 MGD Phase-I	32	20	100
	Phase-II	21	14	68
	25 MGD Phase-III	60	32	180
Rithala	40 MGD Phase-I	28	17	70
	40 MGD Phase-II	17	11	60
Keshopur	12 MGD	8	6	-
	40 MGD	120	78	-
	20 MGD	124	116	-
Nilothi	40 MGD Pahse-I	40	25	-
Nazafgarh	5 MGD	18	10	-
PappanKalan	20 MGD Phase-I	29	27	-
	20 MGD Phase-II	16	12	-
Corronation pillar	20 MGD Pahse-I & II	48	28	98
	10 MGD Pahse-III	64	36	126





**OFFICE OF THE DIRECTOR (T&QC)**  
**DELHI JAL BOARD: GOVT. OF NCT OF DELHI**  
**WATER WORKS WAZIRABAD:DELHI-110054**



		Parameters of STPs of Delhi as on					28.03.2019		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Okhla	12 MGD	Inlet	7.3	354	235	-	7	43	2.5
		outlet	7.7	30	18	-	3	42	0.8
	45 MGD	Inlet	7.4	282	195	-	4	42	2.2
		outlet	7.8	39	24	-	3	40	0.5
	37 MGD	Inlet	7.4	282	195	-	4	42	2.2
		outlet	7.8	27	18	-	2	38	1
	16 MGD	Inlet	7.4	282	195	-	4	42	2.2
		outlet	7.9	46	28	-	1	42	1.5
	New 30 MGD	Inlet	7.4	548	310	524	5	43	2.4
		Outlet	7.8	6	5	24	Nil	10	1
Kondli	25 MGD Phase-II	Inlet	7.2	288	232	330	25	40	6.8
		outlet	7.6	17	14	38	2	18	2.9
	45 MGD Phase-IV	Inlet	7.1	358	233	344	25	39	6.5
		outlet	7.5	48	28	98	4.5	30	3
Chilla	9 MGD	Inlet	7	252	111	240	18	41	6.8
		outlet	7.2	7	3.3	18	3	0.23	4.5
CWG Village	1 MGD	Inlet	7.1	620	424	584	28	25	4.9
		outlet	7.7	Bdl	0.55	Bdl	Bdl	0.13	1.5
Yamuna Vihar	10 MGD Phase-I	Inlet	7.1	416	205	820	172.4	55	6.5
		outlet	7.5	45	32	132	29.6	35	3
	Phase-II	Inlet	7.2	308	214	829	63.4	45	6
		outlet	7.5	31	19	96	18	15	4.5
	25 MGD Phase-III	Inlet	7.2	752	296	1480	193.6	65	8.5
		outlet	7.6	42	31	126	42.4	45	4.5
Rithala	40 MGD	Inlet	7	272	176	370	18	36	1.5
		outlet	7.7	29	19	80	4	24	1.3
	40 MGD	Inlet	7	272	176	370	18	36	1.5
		Outlet	7.6	16	13	60	2	14	0.6
Keshopur	12 MGD	Inlet	7.4	400	251	747	18.6	30	3.7
		outlet	7.7	8	6	32	Nil	2	3.5
	40 MGD	Inlet	7.3	512	239	740	14	29	4.4
		outlet	7.6	102	81	232	2	24	3.3
	20 MGD	Inlet	7.3	512	239	740	14	29	4.4
		outlet	7.4	136	119	352	8.2	30	3.8
Nilothi	40 MGD Phase-I	Inlet	7.3	300	121	-	5	27	2.7
		outlet	7.4	38	26	-	0.8	19	2
Nazafgarh	5 MGD	Inlet	7.3	230	195	-	-	30	4.4
		outlet	7.5	18	10	-	-	4	2.6
Pappankalan	20 MGD Phase-I	Inlet	7.3	563	305	-	-	22	3.6
		outlet	7.5	26	22	-	-	32	0.8
	20 MGD Phase-II	Inlet	7.3	563	305	-	-	22	3.6
		outlet	7.5	14	8	-	-	24	2.4
Corronation pillar	20 MGD Phase-I & II	Inlet	7.2	290	215	388	8.6	40	2
		outlet	7.5	55	33	122	3.5	28	1
	10 MGD Phase-III	Inlet	7.3	320	305	510	-	50	2.3
		outlet	7.6	78	36	146	-	36	1.5
Narela	10 MGD	Inlet	7.2	180	168	338	8.1	50	2.2
		outlet	7.6	48	28	87	3.1	34	1.2

Dir.(T&QC)



**OFFICE OF THE DIRECTOR (T&QC)**  
**DELHI JAL BOARD: GOVT. OF NCT OF DELHI**  
**WATER WORKS WAZIRABAD:DELHI-110054**



Name of the Plant	Capacity (in MGD)	28.03.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
		50	30	250
Okhla	12 MGD	30	18	-
	45 MGD	39	24	-
	37 MGD	27	18	-
	16 MGD	46	28	-
	New 30 MGD	6	5	24
Kondli	25 MGD Pahse-II	17	14	38
	45 MGD Phase-IV	48	28	98
Chilla	9 MGD	7	3.3	18
CWG Village	1 MGD	Bdl	0.55	Bdl
Yamuna Vihar	10 MGD Phase-I	45	32	132
	Phase-II	31	19	96
	25 MGD Phase-III	42	31	126
Rithala	40 MGD Phase-I	29	19	80
	40 MGD Phase-II	16	13	60
Keshopur	12 MGD	8	6	32
	40 MGD	102	81	232
	20 MGD	136	119	352
Nilothi	40 MGD Pahse-I	38	26	-
Nazafgarh	5 MGD	18	10	-
PappanKalan	20 MGD Phase-I	26	22	-
	20 MGD Phase-II	14	8	-
Corronation pillar	20 MGD Pahse-I & II	55	33	122
	10 MGD Pahse-III	78	36	146
Narela	10 MGD	48	28	87

