



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Parameters of STPs of Delhi as on							01.03.2019		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Okhla	12 MGD	Inlet	7.4	278	185	-	2	40	2
		outlet	7.6	30	20	-	1	40	1
	45 MGD	Inlet	7.3	372	225	-	3	42	1.8
		outlet	7.6	28	16	-	1	40	0.8
	37 MGD	Inlet	7.3	372	225	-	3	42	1.8
		outlet	7.6	34	19	-	1	40	0.6
	16 MGD	Inlet	7.3	372	225	-	3	42	1.8
		outlet	7.6	35	21	-	1	42	0.8
Kondli	25 MGD Phase-II	Inlet	7.2	344	192	320	18	41	6.9
		outlet	7.6	16	9	34	3	25	3.2
	45 MGD Phase-IV	Inlet	7.2	286	178	208	29	40	6.7
		outlet	7.5	28	18	58	5.5	31	3.3
Chilla	9 MGD	Inlet	7.1	304	132	296	19	42	7.1
		outlet	7.6	9	3.7	22	2.5	0.27	4.9
CWG Village	1 MGD	Inlet	7.2	660	389	608	30	24	5.1
		outlet	7.7	1	Bdl	Bdl	Bdl	0.19	1.7
Rithala	40 MGD	Inlet	7.1	256	157	340	-	31	1.1
		outlet	7.6	30	20	80	-	24	0.9
	40 MGD	Inlet	7.1	256	157	340	-	31	1.1
		Outlet	7.6	18	12	60	-	12	0.4
Keshopur	12 MGD	Inlet	7.3	492	226	620	-	29	3.3
		outlet	7.4	11	6	32	-	2	2
	40 MGD	Inlet	7.2	408	233	647	-	30	3.2
		outlet	7.5	74	62	176	-	28	2.9
	20 MGD	Inlet	7.2	408	233	647	-	30	3.2
		outlet	7.3	220	186	510	-	26	2.9
Nilothi	40 MGD Phase-I	Inlet	7.4	130	70	-	-	24	3.8
		outlet	7.7	60	33	-	-	24	2.5
	20 MGD Phase-II	Inlet	7.3	296	153	-	-	26	3.4
		outlet	7.4	8	4	-	-	2	2
Nazafgarh	5 MGD	Inlet	7.3	220	200	-	-	28	3
		outlet	7.5	27	20	-	-	14	2.2
PappanKalan	20 MGD Phase-I	Inlet	7.3	339	220	-	-	34	2.8
		outlet	7.5	34	46	-	-	30	1
	20 MGD Phase-II	Inlet	7.3	339	220	-	-	34	2.8
		outlet	7.5	5	4	-	-	1.4	1.8
Corronation pillar	20 MGD Phase-I & II	Inlet	7.1	185	165	368	-	42	1.9
		outlet	7.4	48	28	86	-	24	1
	10 MGD Phase-III	Inlet	7	293	275	386	-	44	2.2
		outlet	7.4	41	25	80	-	28	1.2

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	01.03.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC limits	50	30	250
Okhla	12 MGD	30	20	-
	45 MGD	28	16	-
	37 MGD	34	19	-
	16 MGD	35	21	-
Kondli	25 MGD Pahse-II	16	9	34
	45 MGD Phase-IV	28	18	58
Chilla	9 MGD	9	3.7	22
CWG Village	1 MGD	1	Bdl	Bdl
Rithala	40 MGD Phase-I	30	20	80
	40 MGD Phase-II	18	12	60
Keshopur	12 MGD	11	6	32
	40 MGD	74	62	176
	20 MGD	220	186	510
Nilothe	40 MGD Pahse-I	60	33	-
	20 MGD Phase-II	8	4	-
Nazafgarh	5 MGD	27	20	-
Pappankalan	20 MGD Phase-I	34	46	-
	20 MGD Phase-II	5	4	-
Corronation pillar	20 MGD Pahse-I & II	48	28	86
	10 MGD Pahse-III	41	25	80



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Parameters of STPs of Delhi as on							02.03.2019		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Okhla	12 MGD	Inlet	7.5	216	157	408	1	42	1.2
		outlet	7.7	45	29	104	Nil	38	0.8
	45 MGD	Inlet	7.4	350	210	560	2	40	1
		outlet	7.6	35	25	96	1	38	0.4
	37 MGD	Inlet	7.4	350	210	560	2	40	1
		outlet	7.7	28	20	80	Nil	35	0.8
	16 MGD	Inlet	7.4	350	210	560	2	40	1
		outlet	7.6	40	27	112	1	39	0.7
Kondli	25 MGD Phase-II	Inlet	7.3	328	188	318	18	39	6.9
		outlet	7.6	17	12	38	4	27	3.3
	45 MGD Phase-IV	Inlet	7.2	336	197	214	26	42	6.8
		outlet	7.5	29	20	64	6	33	3.8
Chilla	9 MGD	Inlet	7.2	336	158	267	18	40	6.9
		outlet	7.6	6	3	19	3	0.3	4.5
CWG Village	1 MGD	Inlet	7.2	708	398	542	31	25	5.3
		outlet	7.7	1	Bdl	Bdl	Bdl	0.22	1.5
Yamuna Vihar	10 MGD Phase-I	Inlet	7	520	208	718	-	35	5
		outlet	7.4	48	29	96	-	20	2.5
	25 MGD Phase-III	Inlet	7.1	340	213	610	-	50	7.5
		outlet	7.5	35	24	106	-	35	3.5
Rithala	40 MGD	Inlet	7.2	248	168	370	-	35	1.6
		outlet	7.7	28	18	70	-	20	1.1
	40 MGD	Inlet	7.2	248	168	370	-	35	1.6
		Outlet	7.8	16	11	50	-	14	0.6
Keshopur	12 MGD	Inlet	7.3	380	162	498	12.2	28	3.1
		outlet	7.5	12	5	32	Nil	3	1.9
	40 MGD	Inlet	7.2	392	186	540	13	29	3
		outlet	7.5	65	57	180	2.1	28	2.6
	20 MGD	Inlet	7.2	392	186	540	13	29	3
		outlet	7.4	212	114	320	6.6	26	2.8
Corronation pillar	20 MGD Phase-I & II	Inlet	7	350	280	488	6.9	40	2.3
		outlet	7.5	92	43	148	2.8	25	1.2
	10 MGD Phase-III	Inlet	7.1	350	315	410	7.6	42	2.5
		outlet	7.4	38	24	86	2.4	30	1.3

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	02.03.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC limits	50	30	250
Okhla	12 MGD	45	29	104
	45 MGD	35	25	96
	37 MGD	28	20	80
	16 MGD	40	27	112
Kondli	25 MGD Pahse-II	17	12	38
	45 MGD Phase-IV	29	20	64
Chilla	9 MGD	6	3	19
CWG Village	1 MGD	1	Bdl	Bdl
Yamuna Vihar	10 MGD Phase-I	48	29	96
	25 MGD Phase-III	35	24	106
Rithala	40 MGD Phase-I	28	18	70
	40 MGD Phase-II	16	11	50
Keshopur	12 MGD	12	5	32
	40 MGD	65	57	180
	20 MGD	212	114	320
Corronation pillar	20 MGD Pahse-I & II	92	43	148
	10 MGD Pahse-III	38	24	86



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Parameters of STPs of Delhi as on							03.03.2019		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Okhla	12 MGD	Inlet	7.4	266	205	432	2	40	1.4
		outlet	7.6	30	21	64	1	35	0.4
	45 MGD	Inlet	7.5	278	220	464	2	39	1.3
		outlet	7.7	33	24	72	1	36	0.7
	37 MGD	Inlet	7.5	278	220	464	2	39	1.3
		outlet	7.8	31	22	64	Nil	34	0.6
	16 MGD	Inlet	7.5	278	220	464	2	39	1.3
		outlet	7.6	37	26	80	1	37	0.8
Kondli	25 MGD Phase-II	Inlet	7.3	354	191	336	19	39	6.8
		outlet	7.6	18	13	43	4	26	3.4
	45 MGD Phase-IV	Inlet	7.3	334	217	222	27	41	6.6
		outlet	7.5	30	20	72	6	32	3.9
Yamuna Vihar	10 MGD Phase-I	Inlet	7.4	526	201	-	-	40	5.5
		outlet	7.6	42	25	-	-	20	2.5
	Phase-II	Inlet	7.4	370	207	-	-	45	7
		outlet	7.6	27	14	-	-	25	3.5
	25 MGD Phase-III	Inlet	7.1	420	202	-	-	50	5.5
		outlet	7.6	34	22	-	-	25	3
Rithala	40 MGD	Inlet	7.1	248	163	330	-	30	1.4
		outlet	7.7	29	19	80	-	20	0.8
	40 MGD	Inlet	7.1	248	163	330	-	30	1.4
		Outlet	7.6	18	12	60	-	16	0.5
Keshopur	12 MGD	Inlet	7.3	344	146	-	-	28	3
		outlet	7.6	10	9	-	-	3	1.8
	40 MGD	Inlet	7.3	324	177	-	-	26	3.3
		outlet	7.5	62	38	-	-	28	2.8
	20 MGD	Inlet	7.3	324	177	-	-	26	3.3
		outlet	7.3	186	68	-	-	26	2.8
PappanKalan	20 MGD Phase-I	Inlet	7.2	378	245	-	-	34	2.8
		outlet	7.5	35	31	-	-	30	1
	20 MGD Phase-II	Inlet	7.2	378	245	-	-	34	2.8
		outlet	7.5	5	2	-	-	1.2	1.8
Corronation pillar	20 MGD Phase-I & II	Inlet	7.1	195	173	356	-	35	2.2
		outlet	7.5	46	28	82	-	22	1.1
	10 MGD Phase-III	Inlet	7.2	290	270	398	-	38	2.1
		outlet	7.6	36	23	78	-	28	1.2

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	03.03.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC limits	50	30	250
Okhla	12 MGD	30	21	64
	45 MGD	33	24	72
	37 MGD	31	22	64
	16 MGD	37	26	80
Kondli	25 MGD Pahse-II	18	13	43
	45 MGD Phase-IV	30	20	72
Yamuna Vihar	10 MGD Phase-I	42	25	-
	Phase-II	370	207	-
	25 MGD Phase-III	34	22	-
Rithala	40 MGD Phase-I	29	19	80
	40 MGD Phase-II	18	12	60
Keshopur	12 MGD	10	9	-
	40 MGD	62	38	-
	20 MGD	186	68	-
PappanKalan	20 MGD Phase-I	35	31	-
	20 MGD Phase-II	5	2	-
Corronation pillar	20 MGD Pahse-I & II	46	28	82
	10 MGD Pahse-III	36	23	78



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Parameters of STPs of Delhi as on							26.02.2019		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Okhla	12 MGD	Inlet	7.3	350	248	496	3	42	2.1
		outlet	7.7	36	24	80	1	35	1
	45 MGD	Inlet	7.4	350	220	496	3	43	1.8
		outlet	7.6	29	19	64	1	36	0.9
	37 MGD	Inlet	7.4	350	220	496	3	43	1.8
		outlet	7.7	38	22	88	1	37	0.8
	16 MGD	Inlet	7.4	350	220	496	3	43	1.8
		outlet	7.6	34	24	72	2	36	0.7
Kondli	25 MGD Phase-II	Inlet	7.2	420	213	392	18	39	7.2
		outlet	7.6	14	8	32	4	25	3.3
	45 MGD Phase-IV	Inlet	7.2	374	232	320	23	38	6.8
		outlet	7.5	30	18	62	5	30	3.5
Chilla	9 MGD	Inlet	7.1	300	127	280	15	40	7
		outlet	7.5	6	3	14	1	0.29	4.9
CWG Village	1 MGD	Inlet	7.1	860	450	576	29	21	5.4
		outlet	7.7	1	Bdl	Bdl	Bdl	0.08	1.2
Yamuna Vihar	10 MGD Phase-I	Inlet	7.1	268	187	586	-	40	5.5
		outlet	7.5	47	28	111	-	10	2.5
	25 MGD Phase-III	Inlet	7.2	384	250	694	-	50	6.5
		outlet	7.6	28	19	84	-	25	3
Rithala	40 MGD	Inlet	7.1	264	159	390	-	31	0.9
		outlet	7.8	28	17	80	-	22	0.8
	40 MGD	Inlet	7.1	264	159	390	-	31	0.9
		Outlet	7.6	17	12	60	-	16	0.5
Keshopur	12 MGD	Inlet	7.3	556	214	-	-	27	3
		outlet	7.5	14	8	-	-	2	1.8
	40 MGD	Inlet	7.2	612	210	-	-	29	3.2
		outlet	7.5	58	47	-	-	28	2.6
	20 MGD	Inlet	7.2	612	210	-	-	29	3.2
		outlet	7.4	216	191	-	-	26	2.7
Nazafgarh	5 MGD	Inlet	7.3	280	210	-	-	22	3
		outlet	7.5	40	28	-	-	14	2.2
PappanKalan	20 MGD Phase-I	Inlet	7.3	416	217	560	-	34	2.8
		outlet	7.5	26	19	120	-	32	1
	20 MGD Phase-II	Inlet	7.3	416	217	560	-	34	2.8
		outlet	7.4	4	2	20	-	0.5	1.4
Corronation pillar	20 MGD Phase-I & II	Inlet	6.9	290	230	428	8	38	2.1
		outlet	7.4	61	33	110	3.3	22	0.9
	10 MGD Phase-III	Inlet	7	318	305	428	7	44	2.1
		outlet	7.4	57	34	126	2.3	25	1

Dir. (T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	26.02.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC limits	50	30	250
Okhla	12 MGD	36	24	80
	45 MGD	29	19	64
	37 MGD	38	22	88
	16 MGD	34	24	72
Kondli	25 MGD Pahse-II	14	8	32
	45 MGD Phase-IV	30	18	62
Chilla	9 MGD	6	3	14
CWG Village	1 MGD	1	Bdl	Bdl
Yamuna Vihar	10 MGD Phase-I	47	28	111
	25 MGD Phase-III	28	19	84
Rithala	40 MGD Phase-I	28	17	80
	40 MGD Phase-II	17	12	60
Keshopur	12 MGD	14	8	-
	40 MGD	58	47	-
	20 MGD	216	191	-
Nazafgarh	5 MGD	40	28	-
PappanKalan	20 MGD Phase-I	26	19	120
	20 MGD Phase-II	4	2	20
Corronation pillar	20 MGD Pahse-I & II	61	33	110
	10 MGD Pahse-III	57	34	126



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Parameters of STPs of Delhi as on							27.02.2019		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Okhla	12 MGD	Inlet	7.4	272	203	432	3	42	1.8
		outlet	7.7	26	21	80	Nil	40	1.2
	45 MGD	Inlet	7.4	260	225	440	2	43	2.2
		outlet	7.7	46	27	104	1	41	1.1
	37 MGD	Inlet	7.4	260	225	440	2	43	2.2
		outlet	7.8	45	26	104	1	38	0.8
	16 MGD	Inlet	7.4	260	225	440	2	43	2.2
		outlet	7.7	34	22	80	Nil	40	1.4
Kondli	25 MGD Phase-II	Inlet	7.3	402	221	336	19	40	7
		outlet	7.6	16	11	34	3	24	3.3
	45 MGD Phase-IV	Inlet	7.2	304	198	296	28	38	6.8
		outlet	7.5	29	20	58	6	31	3.6
Chilla	9 MGD	Inlet	7.2	244	110	211	18	40	6.8
		outlet	7.6	8	3.2	18	2.3	0.31	4.8
CWG Village	1 MGD	Inlet	7.2	664	347	592	26	22	4.9
		outlet	7.7	1	Bdl	Bdl	Bdl	0.1	1.3
Yamuna Vihar	10 MGD Phase-I	Inlet	7	252	192	549	64.4	50	7
		outlet	7.4	43	23	86	22	20	3.5
	25 MGD Phase-III	Inlet	7.2	288	181	608	74	55	7.5
		outlet	7.5	26	16	73	26.4	35	3.5
Rithala	40 MGD	Inlet	7.2	272	155	400	29	28	0.8
		outlet	7.7	30	20	70	7	17	0.6
	40 MGD	Inlet	7.2	272	155	400	29	28	0.8
		Outlet	7.7	18	13	70	5	14	0.4
Keshopur	12 MGD	Inlet	7.3	356	222	647	12.2	31	2.9
		outlet	7.6	11	5	30	Nil	3	1.7
	40 MGD	Inlet	7.2	336	230	660	13	32	3
		outlet	7.5	58	64	180	1.8	30	2.7
	20 MGD	Inlet	7.2	336	230	660	13	32	3
		outlet	7.4	216	179	512	6.8	29	2.6
PappanKalan	20 MGD Phase-I	Inlet	7.2	378	203	-	-	34	2.8
		outlet	7.5	38	30	-	-	32	1
	20 MGD Phase-II	Inlet	7.2	378	203	-	-	34	2.8
		outlet	7.4	4	3	-	-	0.7	1.4
Corronation pillar	20 MGD Phase-I & II	Inlet	7.2	280	210	398	-	40	1.9
		outlet	7.5	60	35	104	-	24	1
	10 MGD Phase-III	Inlet	6.9	460	330	446	-	53	2.4
		outlet	7.3	55	40	114	-	23	1.4
Narela	10 MGD	Inlet	7.2	160	153	360	7.2	49	2.1
		outlet	7.5	52	32	94	3	33	1.4

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	27.02.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC limits	50	30	250
Okhla	12 MGD	26	21	80
	45 MGD	46	27	104
	37 MGD	45	26	104
	16 MGD	34	22	80
Kondli	25 MGD Pahse-II	16	11	34
	45 MGD Phase-IV	29	20	58
Chilla	9 MGD	8	3.2	18
CWG Village	1 MGD	1	Bdl	Bdl
Yamuna Vihar	10 MGD Phase-I	43	23	86
	25 MGD Phase-III	26	16	73
Rithala	40 MGD Phase-I	30	20	70
	40 MGD Phase-II	18	13	70
Keshopur	12 MGD	11	5	30
	40 MGD	58	64	180
	20 MGD	216	179	512
PappanKalan	20 MGD Phase-I	38	30	-
	20 MGD Phase-II	4	3	-
Corronation pillar	20 MGD Pahse-I & II	60	35	104
	10 MGD Pahse-III	55	40	114
Narela	10 MGD	52	32	94



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Parameters of STPs of Delhi as on							28.02.2019		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Okhla	12 MGD	Inlet	7.4	212	145	416	3	40	2
		outlet	7.7	28	18	72	Nil	39	1
	45 MGD	Inlet	7.3	184	132	400	3	42	2.2
		outlet	7.7	37	25	88	2	40	1
	37 MGD	Inlet	7.3	184	132	400	3	42	2.2
		outlet	7.8	37	26	96	2	40	0.8
	16 MGD	Inlet	7.3	184	132	400	3	42	2.2
		outlet	7.6	38	27	88	2	38	0.8
	New 30 MGD	Inlet	7.4	324	215	464	3	44	1.8
		Outlet	7.8	8	6	24	Nil	2	0.2
Kondli	25 MGD Phase-II	Inlet	7.3	330	220	326	20	39	6.8
		outlet	7.6	18	10	40	3.5	23	2.9
	45 MGD Phase-IV	Inlet	7.2	380	202	323	30	41	6.6
		outlet	7.5	29	19	62	6.3	33	3.1
Chilla	9 MGD	Inlet	7.2	232	180	208	16	43	6.7
		outlet	7.6	7	2.7	16	2	0.32	4.5
CWG Village	1 MGD	Inlet	7.2	628	335	595	28	22	4.7
		outlet	7.7	Bdl	0.24	Bdl	Bdl	0.16	1.2
Yamuna Vihar	10 MGD Phase-I	Inlet	7	272	191	592	-	45	5.5
		outlet	7.5	45	22	89	-	10	2.5
	25 MGD Phase-III	Inlet	7.2	340	196	629	-	55	6.5
		outlet	7.5	25	16	68	-	25	4
Rithala	40 MGD	Inlet	7	268	163	390	-	30	1
		outlet	7.9	29	18	70	-	22	0.9
	40 MGD	Inlet	7	268	163	390	-	30	1
		Outlet	7.6	16	12	50	-	12	0.3
Keshopur	12 MGD	Inlet	7.3	544	198	680	-	30	3.1
		outlet	7.5	9	6	30	-	2	1.9
	40 MGD	Inlet	7.2	712	237	720	-	29	3
		outlet	7.4	60	62	176	-	29	2.8
	20 MGD	Inlet	7.2	712	237	720	-	29	3
		outlet	7.4	196	173	480	-	27	2.8
Nazafgarh	5 MGD	Inlet	7.4	170	173	-	-	24	3
		outlet	7.5	14	9	-	-	12	2.2
PappanKalan	20 MGD Phase-I	Inlet	7.3	336	243	580	-	28	2.8
		outlet	7.5	30	28	160	-	26	1
	20 MGD Phase-II	Inlet	7.3	336	243	580	-	28	2.8
		outlet	7.5	4	2	30	-	1.4	1.8
Corronation pillar	20 MGD Phase-I & II	Inlet	7.2	210	198	394	5.8	38	1.8
		outlet	7.5	56	33	99	2.9	25	1.1
	10 MGD Phase-III	Inlet	7.2	364	320	424	8	45	2.1
		outlet	7.5	48	27	96	2.5	29	1.3

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	28.02.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC limits	50	30	250
Okhla	12 MGD	28	18	72
	45 MGD	37	25	88
	37 MGD	37	26	96
	16 MGD	38	27	88
	New 30 MGD	8	6	24
Kondli	25 MGD Pahse-II	18	10	40
	45 MGD Phase-IV	29	19	62
Chilla	9 MGD	7	2.7	16
CWG Village	1 MGD	Bdl	0.24	Bdl
Yamuna Vihar	10 MGD Phase-I	45	22	89
	25 MGD Phase-III	25	16	68
Rithala	40 MGD Phase-I	29	18	70
	40 MGD Phase-II	16	12	50
Keshopur	12 MGD	9	6	30
	40 MGD	60	62	176
	20 MGD	196	173	480
Nazafgarh	5 MGD	14	9	-
PappanKalan	20 MGD Phase-I	30	28	160
	20 MGD Phase-II	4	2	30
Corronation pillar	20 MGD Pahse-I & II	56	33	99
	10 MGD Pahse-III	48	27	96