



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD: DELHI-110054

SURVEILLANCE OF WATER QUALITY ON Dtd. 28.05.2019

S. NO.	ZONAL LAB	TOTAL NOS OF SAMPLES COLLECTION	SATISFACTORY	TOTAL NOS OF UNSATISFACTORY	DETAILS OF UNSATISFACTORY WATER SAMPLES		
					Address	Clarity	R/Cl ₂
1	Wazirabad	105	88	17	H. No. B-324, 75 Ist Floor, 321, 332, 274, Sangam Park H. No. 1148, 1180, 1174, 1124, 1163, 1150, 1147, 1177, Gali No. 11, Sadar Bazar H. No. 1119, 1114, 1119, 1250, Gali No. 11, Sadar Bazar	Clear	Nil
2	Haiderpur	66	66	Nil	--	--	--
3	Bhagirathi / TYR	98	85	13	H. No. 1/177, 1/225, 1/230, 1/231, 1/176, 1/174, 1/173, 1/175, 1/233, 1/234, 1/224, 1/222, 1/227, Trilokpuri	Turbid	Nil
4	Greater Kailash	96	96	Nil	--	--	--
5	Okhla	87	87	Nil	--	--	--
6	Nangloi	84	84	Nil	--	--	--
7	Dwarka	44	44	Nil	--	--	--
	Bawana	32	32	Nil	--	--	--
	Total	612	582	30			

% of Unsatisfactory Samples – 4.9

Note: The samples have been declared bacteriologically / chemically unsatisfactory for the reason above.

Director (T&QC)