



**OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD: DELHI-110054**

SURVEILLANCE OF WATER QUALITY ON Dtd. 28.03.2019

S. NO.	ZONAL LAB	TOTAL NOS OF SAMPLES COLLECTION	SATISFACTORY	TOTAL NOS OF UNSATISFACTORY	DETAILS OF UNSATISFACTORY WATER SAMPLES		
					Address	Clarity	R/Cl ₂
1	Wazirabad	105	105	Nil	--	--	--
2	Haiderpur	65	61	04	H. No. B-48, 46, 50 GF & Ist Floor, Tilak Nagar	Clear	Nil
3	Bhagirathi / TYR	87	74	13	H. No. D-5A, 4, 31, 34, 2, Balaji Dharamshala Wali Gali, Shakerpur, Main Market H. No. A-11, 11A, 14, Ganesh Nagar Pandav Nagar H. No. 76, H-78, K-237, H-75, K-237A, West Karawal Nagar PMC Factory	Turbid Clear Turbid	Nil
4	Greater Kailash	77	77	Nil	--	--	--
5	Okhla	74	74	Nil	--	--	--
6	Nangloi	97	93	04	H. No. RZ-89/90, /71, /92, /74, Jain Colony Part – 3, Uttam Nagar	Turbid	Nil
7	Dwarka	41	41	Nil	--	--	--
8	Bawana	42	42	Nil	--	--	--
	Total	588	567	21			

% of Unsatisfactory Samples – 3.5

Note: The samples have been declared bacteriologically / chemically unsatisfactory for the reason above.

Director (T&QC)