

**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/

Date: 28.10.2019

**WATER PRODUCTION REPORT**

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/664.60	200	0.6'	
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		

**PRODUCTION DETAILS**

**TOTAL PRODUCTION : 926.50 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
--------------------------	-----------------------------------	------------------	-----------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	95	
ii)	Wazirabad	124	-Do-	124	
iii)	Haiderpur	220	WJC Canal	213.50	
iv)	Nangloi	40	-Do-	43	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	21.5	
vi)	Dwarka		WJC Canal	50.5	
vii)	Bawana		WJC Canal	19.5	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	102.5	
viii)	Sonia Vihar	144	-Do-	141.5	
1)	Production of Water Treatment Plants			811.00	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.5	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	3	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			29.5	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells		86	
	Total	(1+2+3)	926.50	

## 5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	3.74
Greater Kailash (N)	4.80	3.65
Deer Park	4.50	4.00
Janak Puri	3.00	3.35
Kalka Ji	3.65	3.96

## 6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Affected

Note :- Total supply of water in last 24 hours i.e..28.10.19 -----926.50 MGD

Member (WS)

Copy to: -

1. Pr. Secretary to Lt. Governor
2. P.S. to Chief Minister, Delhi
3. P.S. to Chief Secretary, Delhi
4. Principal Secretary (UD) Govt., of NCT of Delhi
5. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
6. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,  
a. Hudson Lane, Civil Lines ,Delhi-110009
7. CE(WW)
8. CE (East)
9. Dir F & A
10. E.E. (EDP) for uploading on Website
11. Office copy

**DELHI JAL BOARD**  
**OFFICE OF MEMBER (WATER SUPPLY)**  
**VARUNALAYA PHASE-II. KAROL BAGH, NEW DELHI**

No. DJB/M (WS)/A-97/2017/

Date: 30.10.2019

**WATER PRODUCTION REPORT**

Normal Up Stream Pond Level At Wazirabad	Today's Figure of U/S and D/S Wazirabad Pond Level (in Feet)	Discharge (Cusec.)	Gate Opening (Feet)	Raw Water Turbidity (NTU)
674.50 Feet	674.50/664.4			40
Western Jamuna Canal Level at Haiderpur		NORMAL (Ft.)		ACTUAL (Ft.)
		710.0		7.1,4.3

**PRODUCTION DETAILS**

**TOTAL PRODUCTION : 926.00 MGD**

Water Treatment Plant	Peak Production Capacity (MGD)	Raw Water Source	Today's Production	Remarks
--------------------------	-----------------------------------	------------------	-----------------------	---------

**YAMUNA WATER**

i)	Chandrawal	98	Wazirabad Pond	95	
ii)	Wazirabad	124	-Do-	123	
iii)	Haiderpur	220	WJC Canal	213.5	
iv)	Nangloi	40	-Do-	43	
v)	Okhla	20	Recycled Process waste from Chandrawal & R. W.	20.5	
vi)	Dwarka		WJC Canal	50.5	
vii)	Bawana		WJC Canal	19.5	

**GANGA WATER**

vii)	Bhagirathi	100	Upper Ganga Canal	103.00	
viii)	Sonia Vihar	144	-Do-	142.5	
1)	Production of Water Treatment Plants			810.50	

**RECYCLING /PROCESS WASTE WATER PLANTS**

i)	Wazir\bad	11	Recycled process waste at Wzd. Plant	10.5	
ii)	Haiderpur	16	Recycled process waste at Wzd. Plant	16	
iii)	Bhagirathi	10	Recycled process waste at Wzd. Plant	3	
iv)	Chandrawal	08	Recycled process waste at Wz. Plant		
2)	Production from Recycling Plants			29.5	

**GROUND WATER SOURCES**

3)	Production from Ranney wells & Tube wells		86	
	Total	(1+2+3)	926.00	

## 5. MAJOR UGRs' LEVELS IN METERS.

Location	Normal Level (in Meters ) at 6.00 am	Today's Level
Jeetgarh	Normal Level (in Meters ) at 6.00 am	3.04
Jhandewalan	4.11	4.14
Greater Kailash (O)	5.12	3.74
Greater Kailash (N)	4.80	3.65
Deer Park	4.50	4.00
Janak Puri	3.00	3.35
Kalka Ji	3.65	3.96

## 6. TRANSMISSION MAIN

S. No.	Shut Down/Pipe Burst	Duration of Closure	Areas Afected

Note :- Total supply of water in last 24 hours i.e..29.10.2019 -----926.00 MGD

Member (WS)

Copy to: -

1. Pr. Secretary to Lt. Governor
2. P.S. to Chief Minister, Delhi
3. P.S. to Chief Secretary, Delhi
4. Principal Secretary (UD) Govt., of NCT of Delhi
5. C.E.O. BSES, Shakti Sadan, Nehru Place, N Delhi
6. Sr. General Manager, Tata Power Ltd., North and North West Distribution Company,  
a. Hudson Lane, Civil Lines ,Delhi-110009
7. CE(WW)
8. CE (East)