



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD: DELHI-110054

SURVEILLANCE OF WATER QUALITY ON Dtd. 05.05.2019

S. NO.	ZONAL LAB	TOTAL NOS OF SAMPLES COLLECTION	SATISFACTORY	TOTAL NOS OF UNSATISFACTORY	DETAILS OF UNSATISFACTORY WATER SAMPLES		
					Address	Clarity	R/Cl ₂
1	Wazirabad	137	137	Nil	--	--	--
2	Haiderpur	66	66	Nil	--	--	--
3	Bhagirathi / TYR	60	60	Nil	--	--	--
4	Greater Kailash	79	79	Nil	--	--	--
5	Okhla	47	47	Nil	--	--	--
6	Nangloi	89	89	Nil	--	--	--
7	Dwarka	36	36	Nil	--	--	--
8	Bawana	04	04	Nil	--	--	--
	Total	518	518	Nil			

% of Unsatisfactory Samples – 0

Note: The samples have been declared bacteriologically / chemically unsatisfactory for the reason above.

Director (T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD: DELHI-110054

SURVEILLANCE OF WATER QUALITY ON Dtd. 04.05.2019

S. NO.	ZONAL LAB	TOTAL NOS OF SAMPLES COLLECTION	SATISFACTORY	TOTAL NOS OF UNSATISFACTORY	DETAILS OF UNSATISFACTORY WATER SAMPLES		
					Address	Clarity	R/Cl ₂
1	Wazirabad	93	93	Nil	--	--	--
2	Haiderpur	97	97	Nil	--	--	--
3	Bhagirathi / TYR	87	83	04	H. No. F-90, F/40, F/36, F/93, Block Jagatpuri Near Tikkona Park, Jagatpuri	Clear	Nil
4	Greater Kailash	92	92	Nil	--	--	--
5	Okhla	50	50	Nil	--	--	--
6	Nangloi	104	98	06	H. No. RZ-74, 71, 72, Part-II, Jain Colony Uttam Nagar H. No. RZ-15, 71B, 71, Part-III, Jain Colony Uttam Nagar	Smell	Nil
7	Dwarka	57	57	Nil	--	--	--
8	Bawana	04	04	Nil	--	--	--
	Total	584	574	10			

% of Unsatisfactory Samples – 1.7

Note: The samples have been declared bacteriologically / chemically unsatisfactory for the reason above.

Director (T&QC)



SURVEILLANCE OF WATER QUALITY ON Dtd. 03.05.2019

S. NO.	ZONAL LAB	TOTAL NOS OF SAMPLES COLLECTION	SATISFACTORY	TOTAL NOS OF UNSATISFACTORY	DETAILS OF UNSATISFACTORY WATER SAMPLES		
					Address	Clarity	R/Cl ₂
1	Wazirabad	103	103	Nil	--	--	--
2	Haiderpur	65	65	Nil	--	--	--
3	Bhagirathi / TYR	87	87	Nil	--	--	--
4	Greater Kailash	68	68	Nil	--	--	--
5	Okhla	51	51	Nil	--	--	--
6	Nangloi	87	83	04	H. No. C-140, 141, 142B, 142A, Mohan Garden Uttam Nagar	Sewage	Nil
7	Dwarka	38	34	04	H. No. RZ-15B, 19, 19C, 7A, Gali No. 7E, Puran Nagar, Palam Colony	Turbid	Nil
8	Bawana	39	39	Nil	--	--	--
	Total	538	530	08			

% of Unsatisfactory Samples – 1.4

Note: The samples have been declared bacteriologically / chemically unsatisfactory for the reason above.

Director (T&QC)