



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD: DELHI-110054

SURVEILLANCE OF WATER QUALITY ON Dtd. 23.09.2019

S. NO.	ZONAL LAB	TOTAL NOS OF SAMPLES COLLECTION	SATISFACTORY	TOTAL NOS OF UNSATISFACTORY	DETAILS OF UNSATISFACTORY WATER SAMPLES		
					Address	Clarity	R/Cl ₂
1	Wazirabad	110	106	04	H. No. 2518/193A, 2524/193B, 2571.193C, 2522/193A Onkar Nagar	Turbid	Nil
2	Haiderpur	90	87	03	UGR/BPS & H. No. 203, 207, Rajouri Apartment Rajouri Garden	Clear	Nil
3	Bhagirathi / TYR	69	69	Nil	--	--	--
4	Greater Kailash	80	80	Nil	--	--	--
5	Okhla	40	40	Nil	--	--	--
6	Nangloi	99	99	Nil	--	--	--
7	Dwarka	43	43	Nil	--	--	--
8.	Bawana	39	39	Nil	--	--	--
	Total	570	563	07			

% of Unsatisfactory Samples – 1.2

Note: The samples have been declared bacteriologically / chemically unsatisfactory for the reason above.

Director (T&QC)

[Type text]



SURVEILLANCE OF WATER QUALITY ON Dtd. 22.09.2019

S. NO.	ZONAL LAB	TOTAL NOS OF SAMPLES COLLECTION	SATISFACTORY	TOTAL NOS OF UNSATISFACTORY	DETAILS OF UNSATISFACTORY WATER SAMPLES		
					Address	Clarity	R/Cl ₂
1	Wazirabad	110	104	06	H. No. 15/28 3 rd Floor, 18/28 GF, 22/7, 15/31, 15/24, 15/28 4 th Floor, West Patel Nagar	Clear	Nil
2	Haiderpur	77	75	02	H. No. D-298A, 297, Rajeev Nagar, Begumpur	Hazy	Nil
3	Bhagirathi / TYR	56	56	Nil	--	--	--
4	Greater Kailash	85	85	Nil	--	--	--
5	Okhla	50	46	04	H. No. 46A, FC-40 Ist Floor, FC-45 GF, South Extension , Part – I H. No. C-2, South Extension , Part – II	Clear	Nil
6	Nangloi	61	61	Nil	--	--	--
7	Dwarka	35	35	Nil	--	--	--
8.	Bawana	04	04	Nil	--	--	--
	Total	478	466	12			

% of Unsatisfactory Samples – 2.5

Note: The samples have been declared bacteriologically / chemically unsatisfactory for the reason above.

Director (T&QC)

[Type text]



SURVEILLANCE OF WATER QUALITY ON Dtd. 21.09.2019

S. NO.	ZONAL LAB	TOTAL NOS OF SAMPLES COLLECTION	SATISFACTORY	TOTAL NOS OF UNSATISFACTORY	DETAILS OF UNSATISFACTORY WATER SAMPLES		
					Address	Clarity	R/Cl ₂
1	Wazirabad	110	103	07	H. No. A-94, D-74, E-108, Old Gupta Colony H. No. 373, 171 L, 378, 382B, Gali No. 8, Dheerpur	Clear / Smelly	Nil
2	Haiderpur	106	106	Nil	--	--	--
3	Bhagirathi / TYR	92	92	Nil	--	--	--
4	Greater Kailash	91	91	Nil	--	--	--
5	Okhla	59	59	Nil	--	--	--
6	Nangloi	58	55	03	H. No. 83A, 47, L-2A, Block, Mohan Garden, Uttam Nagar	Clear	Nil
7	Dwarka	35	35	Nil	--	--	--
8.	Bawana	39	39	Nil	--	--	--
	Total	590	580	10			

% of Unsatisfactory Samples – 1.6

Note: The samples have been declared bacteriologically / chemically unsatisfactory for the reason above.

Director (T&QC)

[Type text]



SURVEILLANCE OF WATER QUALITY ON Dtd. 20.09.2019

S. NO.	ZONAL LAB	TOTAL NOS OF SAMPLES COLLECTION	SATISFACTORY	TOTAL NOS OF UNSATISFACTORY	DETAILS OF UNSATISFACTORY WATER SAMPLES		
					Address	Clarity	R/Cl ₂
1	Wazirabad	77	77	Nil	--	--	--
2	Haiderpur	94	91	03	H. No. 283/260, 259, 237A, Maddi Wali Gali, Vishnu Garden	Hazy	Nil
3	Bhagirathi / TYR	56	51	05	H. No. 4774/A, IX-4766, Gali No. 1, School Wali Gali, Old Seelumpur H. No. C-18, C-09, C-11, Gali No. 11, East Nathu Colony	Clear	Nil
4	Greater Kailash	87	87	Nil	--	--	--
5	Okhla	66	66	Nil	--	--	--
6	Nangloi	109	109	Nil	--	--	--
7	Dwarka	46	42	04	H. No. RZ-6, 7A/2, Gali No.8, Indra Park, Palam Colony H. No. RZ-26P/190, 26P/79, Indra Park, Extension Palam Colony	Sewage	Nil
8.	Bawana	38	38	Nil	--	--	--
	Total	573	561	12			

% of Unsatisfactory Samples – 2.0

Note: The samples have been declared bacteriologically / chemically unsatisfactory for the reason above.

Director (T&QC)

[Type text]