

" STOP CORONA – WEAR MASK, FOLLOW PHYSICAL DISTANCING & MAINTAIN HYGIENE "



रतन
शर्मा
The Joint Director of JWS

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD: DELHI-110054

SURVEILLANCE OF WATER QUALITY ON Dtd. 31.10.2021

S. NO.	ZONAL LAB	TOTAL NOS OF SAMPLES COLLECTION	SATISFACTORY	TOTAL NOS OF UNSATISFACTORY	DETAILS OF UNSATISFACTORY WATER SAMPLES		
					Address	Clarity	R/Cl ₂
1	Wazirabad	44	44	Nil	--	--	--
2	Haiderpur	61	61	Nil	--	--	--
3	Bhagirathi / TYR	81	81	Nil	--	--	--
4	Greater Kailash	36	36	Nil	--	--	--
5	Okhla	30	30	Nil	--	--	--
6	Nangloi	136	136	Nil	--	--	--
7	Dwarka	47	47	Nil	--	--	--
8.	Bawana	04	04	Nil	--	--	--
Total		439	439	Nil	--	--	--

% of Unsatisfactory Samples – 0

ASHUTOSH KAUSHIK
Director (T&QC)

[Type text]



"STOP CORONA – WEAR MASK, FOLLOW PHYSICAL DISTANCING & MAINTAIN HYGIENE "

आदेश
आदेश
आदेश

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD: DELHI-110054

SURVEILLANCE OF WATER QUALITY ON Dtd. 30.10.2021

S. NO.	ZONAL LAB	TOTAL NOS OF SAMPLES COLLECTION	SATISFACTORY	TOTAL NOS OF UNSATISFACTORY	DETAILS OF UNSATISFACTORY WATER SAMPLES		
					Address	Clarity	R/Cl ₂
1	Wazirabad	100	100	Nil	---	--	--
2	Haiderpur	94	94	Nil	---	--	--
3	Bhagirathi / TYR	59	59	Nil	---	--	--
4	Greater Kailash	40	40	Nil	---	--	--
5	Okhla	67	67	Nil	---	--	--
6	Nangloi	135	135	Nil	---	--	--
7	Dwaraka	47	47	Nil	---	--	--
8.	Bawana	36	36	Nil	---	--	--
Total		578	578	Nil			

% of Unsatisfactory Samples – 0

ASHUTOSH KAUSHIK
Director (T&QC)

[Type text]



"STOP CORONA - WEAR MASK, FOLLOW PHYSICAL DISTANCING & MAINTAIN HYGIENE"

सिद्धि
सिद्धि

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD: DELHI-110054

SURVEILLANCE OF WATER QUALITY ON Dtd. 29.10.2021

S. NO.	ZONAL LAB	TOTAL NOS OF SAMPLES COLLECTION	SATISFACTORY	TOTAL NOS OF UNSATISFACTORY	DETAILS OF UNSATISFACTORY WATER SAMPLES		
					Address	Clarity	R/Cl ₂
1	Wazirabad	102	102	Nil	--	--	--
2	Haiderpur	64	64	Nil	--	--	--
3	Bhagirathi / TYR	87	83	04	H. No. A-13, A-28, A-25, A-27, Preet Vihar	--	--
4	Greater Kailash	33	33	Nil	--	Clear	Nil
5	Okhla	61	61	Nil	--	--	--
6	Nangloi	134	134	Nil	--	--	--
7	Dwarka	50	50	Nil	--	--	--
8.	Bawana	36	36	Nil	--	--	--
Total		567	563	04		--	--

% of Unsatisfactory Samples - 0.70

ASHUTOSH KAUSHIK
Director (T&QC)

[Type text]



STOP CORONA – WEAR MASK, FOLLOW PHYSICAL DISTANCING & MAINTAIN HYGIENE "

आदेश
आदेश

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD: DELHI-110054

SURVEILLANCE OF WATER QUALITY ON Dtd. 28.10.2021

S. NO.	ZONAL LAB	TOTAL NOS OF SAMPLES COLLECTION	SATISFACTORY	TOTAL NOS OF UNSATISFACTORY	DETAILS OF UNSATISFACTORY WATER SAMPLES		
					Address	Clarity	R/Cl ₂
1	Wazirabad	103	103	Nil	--	--	--
2	Haiderpur	90	90	Nil	--	--	--
3	Bhagirathi / TYR	86	82	04	H. No. J-10, J-8, J-24, 8A, Gali No. 1, East Vinod Nagar	--	--
4	Greater Kailash	44	44	Nil	--	Turbid	Nil
5	Okhla	21	21	Nil	--	--	--
6	Nangloi	136	136	Nil	--	--	--
7	Dwarka	48	48	Nil	--	--	--
8	Bawana	35	35	Nil	--	--	--
Total		563	559	04		--	--

% of Unsatisfactory Samples – 0.71

ASHUTOSH KAUSHIK
Director (T&QC)

[Type text]



STOP CORONA – WEAR MASK, FOLLOW PHYSICAL DISTANCING & MAINTAIN HYGIENE "



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD: DELHI-110054

SURVEILLANCE OF WATER QUALITY ON Dtd. 27.10.2021

S. NO.	ZONAL LAB	TOTAL NOS OF SAMPLES COLLECTION	SATISFACTORY	TOTAL NOS OF UNSATISFACTORY	DETAILS OF UNSATISFACTORY WATER SAMPLES		
					Address	Clarity	R/Cl ₂
1	Wazirabad	105	105	Nil	--	--	--
2	Haiderpur	96	96	Nil	--	--	--
3	Bhagirathi / TYR	87	87	Nil	--	--	--
4	Greater Kailash	39	39	Nil	--	--	--
5	Okhla	48	48	Nil	--	--	--
6	Nangloi	151	151	Nil	--	--	--
7	Dwarka	47	47	Nil	--	--	--
8	Bawana	37	37	Nil	--	--	--
Total		610	610	Nil			

% of Unsatisfactory Samples – 0

ASHUTOSH KAUSHIK
Director (T&QC)

[Type text]



STOP CORONA – WEAR MASK, FOLLOW PHYSICAL DISTANCING & MAINTAIN HYGIENE "



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD: DELHI-110054

SURVEILLANCE OF WATER QUALITY ON Dtd. 26.10.2021

S. NO.	ZONAL LAB	TOTAL NOS OF SAMPLES COLLECTION	SATISFACTORY	TOTAL NOS OF UNSATISFACTORY	DETAILS OF UNSATISFACTORY WATER SAMPLES		
					Address	Clarity	R/Cl ₂
1	Wazirabad	103	103	Nil	--	--	--
2	Haiderpur	60	60	Nil	--	--	--
3	Bhagirathi / TYR	85	85	Nil	--	--	--
4	Greater Kailash	39	39	Nil	--	--	--
5	Okhla	33	33	Nil	--	--	--
6	Nangloi	113	113	Nil	--	--	--
7	Dwarka	45	45	Nil	--	--	--
8.	Bawana	36	36	Nil	--	--	--
Total		514	514	Nil			


% of Unsatisfactory Samples – 0

ASHUTOSH KAUSHIK
Director (T&QC)

[Type text]



STOP CORONA – WEAR MASK, FOLLOW PHYSICAL DISTANCING & MAINTAIN HYGIENE "



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD: DELHI-110054

SURVEILLANCE OF WATER QUALITY ON Dtd. 25.10.2021

S. NO.	ZONAL LAB	TOTAL NOS OF SAMPLES COLLECTION	SATISFACTORY	TOTAL NOS OF UNSATISFACTORY	DETAILS OF UNSATISFACTORY WATER SAMPLES		
					Address	Clarity	R/Cl ₂
1	Wazirabad	103	103	Nil	--	--	--
2	Haiderpur	63	63	Nil	--	--	--
3	Bhagirathi / TYR	85	85	Nil	--	--	--
4	Greater Kailash	35	35	Nil	--	--	--
5	Okhla	69	69	Nil	--	--	--
6	Nangloi	162	162	Nil	--	--	--
7	Dwarka	52	50	02	H. No. RZF-762/35, 763/42, Gali No. 5, Raj Nagar – II, Palam Colony	Hazy	Nil
8.	Bawana	36	36	Nil	--	--	--
Total		605	603	02			

% of Unsatisfactory Samples – 0.33

ASHUTOSH KAUSHIK
Director (T&QC)

[Type text]



STOP CORONA – WEAR MASK, FOLLOW PHYSICAL DISTANCING & MAINTAIN HYGIENE "

संलग्न
सहित
प्र. सं. ११११/२१

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD: DELHI-110054

SURVEILLANCE OF WATER QUALITY ON Dtd. 24.10.2021

S. NO.	ZONAL LAB	TOTAL NOS OF SAMPLES COLLECTION	SATISFACTORY	TOTAL NOS OF UNSATISFACTORY	DETAILS OF UNSATISFACTORY WATER SAMPLES		
					Address	Clarity	R/C ₂
1	Wazirabad	68	68	Nil	--	--	--
2	Haiderpur	64	64	Nil	--	--	--
3	Bhagirathi / TYR	53	53	Nil	--	--	--
4	Greater Kailash	34	34	Nil	--	--	--
5	Okhla	66	66	Nil	--	--	--
6	Nangloi	124	124	Nil	--	--	--
7	Dwarka	50	50	Nil	--	--	--
8.	Bawana	04	04	Nil	--	--	--
Total		463	463	Nil			


% of Unsatisfactory Samples – 0

ASHUTOSH KAUSHIK
Director (T&QC)

[Type text]



STOP CORONA – WEAR MASK, FOLLOW PHYSICAL DISTANCING & MAINTAIN HYGIENE "



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD: DELHI-110054

SURVEILLANCE OF WATER QUALITY ON Dtd. 23.10.2021

S. NO.	ZONAL LAB	TOTAL NOS OF SAMPLES COLLECTION	SATISFACTORY	TOTAL NOS OF UNSATISFACTORY	DETAILS OF UNSATISFACTORY WATER SAMPLES		
					Address	Clarity	R/Cl ₂
1	Wazirabad	97	97	Nil	--	--	--
2	Haiderpur	92	92	Nil	--	--	--
3	Bhagirathi / TYR	60	60	Nil	--	--	--
4	Greater Kailash	35	35	Nil	--	--	--
5	Okhla	16	16	Nil	--	--	--
6	Nangloi	147	147	Nil	--	--	--
7	Dwarka	48	47	01	H. No. RZF-763/38A, Gali No. 5, KV Apptt, Raj Nagar – II, Palam	--	--
8	Bawana	32	32	Nil	--	Clear	Nil
Total		527	526	01		--	--

% of Unsatisfactory Samples – 0.18

ASHUTOSH KAUSHIK
Director (T&QC)

[Type text]



"STOP CORONA – WEAR MASK, FOLLOW PHYSICAL DISTANCING & MAINTAIN HYGIENE"

आदेश
आदेश
आदेश

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD: DELHI-110054

SURVEILLANCE OF WATER QUALITY ON Dtd. 22.10.2021

S. NO.	ZONAL LAB	TOTAL NOS OF SAMPLES COLLECTION	SATISFACTORY	TOTAL NOS OF UNSATISFACTORY	DETAILS OF UNSATISFACTORY WATER SAMPLES		
					Address	Clarity	R/Cl ₂
1	Wazirabad	103	103	Nil	--	--	--
2	Haiderpur	66	65	01	UGR/BPS at Sanjay Gandhi Transport Nagar	Clear	Nil
3	Bhagirathi / TYR	85	85	Nil	--	--	--
4	Greater Kailash	42	42	Nil	--	--	--
5	Okhla	64	64	Nil	--	--	--
6	Nangloi	155	155	Nil	--	--	--
7	Dwarka	51	48	03	H. No. B-21A, B-46, B-25, Patel Garden, Dwarka Mod, Delhi - 110059	Hazy	Nil
8.	Bawana	38	38	Nil	--	--	--
Total		604	600	04			

% of Unsatisfactory Samples – 0.66

ASHUTOSH KAUSHIK
Director (T&QC)

[Type text]