



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD: DELHI-110054

SURVEILLANCE OF WATER QUALITY ON Dtd. 10.07.2019

S. NO.	ZONAL LAB	TOTAL NOS OF SAMPLES COLLECTION	SATISFACTORY	TOTAL NOS OF UNSATISFACTORY	DETAILS OF UNSATISFACTORY WATER SAMPLES		
					Address	Clarity	R/Cl ₂
1	Wazirabad	108	108	Nil	--	--	--
2	Haiderpur	94	94	Nil	--	--	--
3	Bhagirathi / TYR	92	82	10	H. No. 1/177, 1/175, 1/225, 1/178, 1/228, 1/231, 1/229, 1/222, 1/176, 1/174, Trilokpuri	Turbid	Nil
4	Greater Kailash	102	102	Nil	--	--	--
5	Okhla	95	85	10	H. No. C-81, D-39, D-40, D-104, D-31, D-19/2, D-19, Jasola Village H. No. B-4/176, B4/187, B4/177, S. J. Enclave	Clear	Nil
6	Nangloi	78	78	Nil	--	--	--
7	Dwarka	25	25	Nil	--	--	--
8.	Bawana	37	37	Nil	--	--	--
	Total	631	611	20			

% of Unsatisfactory Samples – 3.1

Note: The samples have been declared bacteriologically / chemically unsatisfactory for the reason above.

Director (T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD: DELHI-110054

SURVEILLANCE OF WATER QUALITY ON Dtd. 09.07.2019

S. NO.	ZONAL LAB	TOTAL NOS OF SAMPLES COLLECTION	SATISFACTORY	TOTAL NOS OF UNSATISFACTORY	DETAILS OF UNSATISFACTORY WATER SAMPLES		
					Address	Clarity	R/Cl ₂
1	Wazirabad	81	81	Nil	--	--	--
2	Haiderpur	65	65	Nil	--	--	--
3	Bhagirathi / TYR	57	57	Nil	--	--	--
4	Greater Kailash	94	94	Nil	--	--	--
5	Okhla	78	74	04	H. No. D3, D4, D5, D6, Maharani Bagh	Clear	Nil
6	Nangloi	85	85	Nil	--	--	--
7	Dwarka	48	48	Nil	--	--	--
8.	Bawana	38	38	Nil	--	--	--
	Total	546	542	04			

% of Unsatisfactory Samples – 0.7

Note: The samples have been declared bacteriologically / chemically unsatisfactory for the reason above.

Director (T&QC)