



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD: DELHI-110054

SURVEILLANCE OF WATER QUALITY ON Dtd. 17.06.2019

S. NO.	ZONAL LAB	TOTAL NOS OF SAMPLES COLLECTION	SATISFACTORY	TOTAL NOS OF UNSATISFACTORY	DETAILS OF UNSATISFACTORY WATER SAMPLES		
					Address	Clarity	R/Cl ₂
1	Wazirabad	90	80	10	H. No. 19/311, 19/310, 19/311, 19/309, 95/89, 95/104, 95/101, 95/18, 95/107, 95/15, Daya Basti, Shahzada Bagh	Turbid	Nil
2	Haiderpur	68	68	Nil	--	--	--
3	Bhagirathi / TYR	81	81	Nil	--	--	--
4	Greater Kailash	94	94	Nil	--	--	--
5	Okhla	49	49	Nil	--	--	--
6	Nangloi	151	151	Nil	--	--	--
7	Dwarka	43	43	Nil	--	--	--
	Bawana	37	37	Nil	--	--	--
	Total	613	603	10			

% of Unsatisfactory Samples – 1.6

Note: The samples have been declared bacteriologically / chemically unsatisfactory for the reason above.

Director (T&QC)