



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD: DELHI-110054

SURVEILLANCE OF WATER QUALITY ON Dtd. 20.06.2019

S. NO.	ZONAL LAB	TOTAL NOS OF SAMPLES COLLECTION	SATISFACTORY	TOTAL NOS OF UNSATISFACTORY	DETAILS OF UNSATISFACTORY WATER SAMPLES		
					Address	Clarity	R/Cl ₂
1	Wazirabad	104	104	Nil	--	--	--
2	Haiderpur	109	105	04	H. No. 68, 66, 66B, 70D, Phase – II, Vijay Vihar	Clear	Nil
3	Bhagirathi / TYR	112	99	13	H. No. D-4, D-5, D-7, D-19, D-81, D-82, D-80, D-77, D-63, D-26, D-63, D-26, D-28, Preet Vihar	Turbid	Nil
4	Greater Kailash	98	98	Nil	--	--	--
5	Okhla	81	81	Nil	--	--	--
6	Nangloi	127	127	Nil	--	--	--
7	Dwarka	37	37	Nil	--	--	--
8.	Bawana	36	36	Nil	--	--	--
	Total	704	687	17			

% of Unsatisfactory Samples – 2.4

Note: The samples have been declared bacteriologically / chemically unsatisfactory for the reason above.

Director (T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD: DELHI-110054

SURVEILLANCE OF WATER QUALITY ON Dtd. 19.06.2019

S. NO.	ZONAL LAB	TOTAL NOS OF SAMPLES COLLECTION	SATISFACTORY	TOTAL NOS OF UNSATISFACTORY	DETAILS OF UNSATISFACTORY WATER SAMPLES		
					Address	Clarity	R/Cl ₂
1	Wazirabad	100	95	05	H. No. 131 2 nd Floor, 135 2 nd Floor, 132 3 rd Floor, 125 Ground Floor, 126 1 st Floor, Delhi Govt. Flats, Timarpur	Clear	Nil
2	Haiderpur	93	93	Nil	--	--	--
3	Bhagirathi / TYR	88	84	04	H. No. 1/4786 3 rd Floor, 1/4786 2 nd Floor, 1/4786 4th Floor, 1/4797, Gali No. 10, Balbeer Nagar Extension	Clear	Nil
4	Greater Kailash	95	95	Nil	--	--	--
5	Okhla	73	73	Nil	--	--	--
6	Nangloi	74	74	Nil	--	--	--
7	Dwarka	41	41	Nil	--	--	--
	Bawana	37	37	Nil	--	--	--
	Total	601	592	09			

% of Unsatisfactory Samples – 1.4

Note: The samples have been declared bacteriologically / chemically unsatisfactory for the reason above.

Director (T&QC)