

**DELHI JAL BOARD****DAILY ANALYSIS REPORT OF ALL SEWAGE TREATMENT PLANT****DATE OF ANALYSIS : 01.01.2026**

S.No.	Lab	Sewage Treatment Plant (Operator) Technology	Capacity	DPCC Parameter (mg/l) (TSS:10,BOD:10, COD:50, NH4-N:5,PO4-P:2, Oil& grease : 10, f.coliform: 230 MPN/100ml)	pH		TSS		BOD (3 DAYS at 27 0 C)		COD		Ammonical nitrogen		Dissolve phosphate		Oil & Grease		Fecal Coliform (72 hrs)		Remarks
					INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	
			(MGD)	Parameter Limits	-	-	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	MPN/100ml	MPN/100ml	
1	Keshopur	Keshopur Ph-I (VA-TECH WABAG LTD.) ASP	12	As per plant design TSS:30/BOD:20/COD:250/NH4-N:50/PO4:5/ f.C:230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
2		Keshopur Ph-II (Ayaappa Pvt.Ltd) ASP(IFAS)	20	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
3		Keshopur Ph-III (Ayaappa Pvt.Ltd) ASP	60	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
4		Kapashera (Triveni Pvt. Ltd) SBR	5	As per plant design TSS:10/BOD:10/f.C:1000/100ml	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
5	Kondli	Kondli Ph-I (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	7.1	7.5	270	8	148	5	464	22	35	0.5	3.2	0.8	11.4	ND	290 X 10^11	73	
6		Kondli Ph-II (Triveni Pvt. Ltd) ASP	25	As per DPCC limits	7.1	7.6	270	9	148	7	464	25	35	2.2	3.2	1.8	11.4	ND	290 X 10^11	36	
7		Kondli Ph-III (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	7.1	7.6	270	9	148	7	464	25	35	2.2	3.2	1.8	11.4	ND	290 X 10^11	36	
8		Kondli Ph-IV (Ayaappa Pvt.Ltd) ASP(IFAS)	45	As per DPCC limits	7	7.5	262	9	150	6	480	21	35	3.5	3.5	1.5	10.2	ND	210 X 10^11	210	
9		Chilla (HNB Engineers) C-ISBR	9	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
10		CWG (M/s Toshiba Water Soluti on Pvt. Ltd.) MBR	1	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
11	N.S.T.P.C Pillar	Coronation Pillar Ph-II (DRA Infracom Pvt.Ltd.) ASP(IFAS)	20	As per plant design TSS:30/BOD:20/COD:250/NH4-N:50/PO4:5/ f.C:230	7	7.5	162	08	103	04	198	18	24	0.4	1.4	0.5			-	-	
12		Coronation Pillar Ph-III (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits	6.9	7.4	174	08	114	05	202	20	22	0.5	1.8	0.4			-	-	
13		Coronation New (L&T Construction and PASSAVANT (JV)) ASP	70	As per DPCC limits	7	7.5	210	16	137	10	284	39	26	1	1.9	1.2	2.5	0.5	-	-	
14		Narela (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits	7	7.4	184	10	120	05	212	26	24	0.6	1.6	0.9	2	0.2	-	-	
15	Nilothi	Nilothi Ph-I (SUBHASH INFRA PVT. LTD) ASP(IFAS)	60	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
16		Nilothi Ph-II (VEOLIA INDIA) ASP	20	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
17	Okhla	Okhla Ph-V (DIB) ASP	16	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
18		Okhla Ph-VI (SUEZ India Pvt. Ltd.) ASP	30	As per DPCC limits	7.2	7.4	258	9	200	6	(-)	(-)	30	0.1	2.6	1.1	3	ND	46X10^12	75	
19		Okhla New (SUEZ India Pvt. Ltd.) ASP	124	As per DPCC limits	7.2	7.5	338	7	245	4	(-)	(-)	25	0.3	2.8	0.9	3	ND	24x10^13	210	
20		Mehrauli (DIB) E.A	5	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
21		Molar band (DIB)	0.66	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
22	Okhla	Ghitorini (DIB) ASP	5	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
23		Vasant Kunj Ph-I (DIB) E.A	2.2	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
24		Vasant Kunj Ph-II (DIB) E.A	3	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
25		Delhi Gate Ph-I (Degramont) B & D	2.2	As per DPCC limits	7.2	7.4	210	3	180	2	(-)	(-)	15	10	1	0.3	4	ND	24x10^13	75x10^12	

[illegible]



DAILY ANALYSIS REPORT OF ALL SEWAGE TREATMENT PLANT

DATE OF ANALYSIS : 02 01 2026

[illegible]

[illegible]



DAILY ANALYSIS REPORT OF ALL SEWAGE TREATMENT PLANT

DATE OF ANALYSIS : 03.01.2026

S.No.	Lab	Sewage Treatment Plant (Operator) Technology	Capacity	DPCC Parameter (mg/l) (TSS:10,BOD:10, COD:50, NH4-N:5,PO4-P:2, Oil& grease : 10, f.coliform: 230 MPN/100ml)	pH		TSS		BOD (3 DAYS at 27 0 C)		COD		Ammonical nitrogen		Dissolve phosphate		Oil & Grease		Fecal Coliform (72 hrs)		Remarks
					INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	
			(MGD)	Parameter Limits	-	-	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	MPN/100ml	
1	Keshopur	Keshopur Ph-I (VA-TECH WABAG LTD.) ASP	12	As per plant design TSS:30/BOD:20/COD:250/NH4-N:50/PO4:5/ f.C:230	7.18	7.44	279	9	150	4	486	17	18	1.2	4	2	20.14	Nil	24*10^13	210	
2		Keshopur Ph-II (Ayaappa Pvt.Ltd) ASP(IFAS)	20	As per DPCC limits	7.23	7.53	278	4	170	8	492	25	24	2.8	3.5	1	-	-	24*10^13	160	
3		Keshopur Ph-III (Ayaappa Pvt.Ltd) ASP	60	As per DPCC limits	7.38	7.61	243	6	175	8	512	28	22	4	4.5	0.5	-	-	24*10^13	210	
4		Kapashera (Triveni Pvt. Ltd) SBR	5	As per plant design TSS:10/BOD:10/f.C:1000/100ml	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
5	Kondli	Kondli Ph-I (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	7	7.5	238	6	148	5	423	16	30	1.5	3.8	0.8			210*10^11	73	
6		Kondli Ph-II (Triveni Pvt. Ltd) ASP	25	As per DPCC limits	7	7.6	238	8	148	6	423	21	30	1	3.8	0.5			210*10^11	36	
7		Kondli Ph-III (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	7	7.6	238	8	148	6	423	21	30	1	3.8	0.5			210*10^11	36	
8		Kondli Ph-IV (Ayaappa Pvt.Ltd) ASP(IFAS)	45	As per DPCC limits	6.9	7.5	296	7	153	6	444	23	32	2.5	3.5	0.8			290*10^11	73	
9		Chilla (HNB Engineers) C-ISBR	9	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
10		CWG (M/s Toshiba Water Soluti on Pvt. Ltd.) MBR	1	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
11	N.S.T.P.C.Pillar	Coronation Pillar Ph-II (DRA Infracom Pvt.Ltd.) ASP(IFAS)	20	As per plant design TSS:30/BOD:20/COD:250/NH4-N:50/PO4:5/ f.C:230	6.9	7.4	196	08	111	05	204	21	20	0.5	1.7	0.7			15x10^7	150	
12		Coronation Pillar Ph-III (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits	6.9	7.5	182	07	106	04	403	19	24	0.5	1.5	0.6			75x10^6	210	
13		Coronation New (I&T Construction and PASSAVANT (JV)) ASP	70	As per DPCC limits	7	7.5	198	18	117	14	256	29	27	0.6	2.1	0.9			43x10^9	15000	
14		Narela (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits	7.1	7.5	162	06	98	03	166	15	30	0.5	2	0.8			43x10^10	210	
15	Nilothi	Nilothi Ph-I (SUBHASH INFRA PVT. LTD) ASP(IFAS)	60	As per DPCC limits	7.54	7.63	310	7	178	8	-	-	26.2	4.1	2.7	0.4			11x10^8	11x10^4	
16		Nilothi Ph-II (VEOLIA INDIA) ASP	20	As per DPCC limits	7.6	7.69	244	6	150	4	-	-	22.5	3.4	2.4	0.2			15x10^7	210	
17	Okhla	Okhla Ph-V (DIB) ASP	16	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
18		Okhla Ph-VI (SUEZ India Pvt. Ltd.) ASP	30	As per DPCC limits	7.4	7.7	172	10	300	7.6	560	26	25	ND	2.5	1	4	ND	46X10^12	<1.8	
19		Okhla New (SUEZ India Pvt. Ltd.) ASP	124	As per DPCC limits	7.4	7.6	194	10	178	8.1	430	22	25	1.5	2.3	1	3	ND	43X10^12	93	
20		Mehrauli (DIB) E.A	5	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	7.2	7.5	308	10	238	14.3	1420	35	55	25	4	0.5	5	1	46X10^12	24x10^5	

[illegible]

[illegible]

[illegible]

DELHI JAL BOARD

DAILY ANALYSIS REPORT OF ALL SEWAGE TREATMENT PLANT									
---	--	--	--	--	--	--	--	--	--

DATE OF ANALYSIS : 05.01.2026

[illegible]

[illegible]



DAILY NON COMPLIANCE REPORT OF ALL SEWAGE TREATMENT PLANT

DATE OF ANALYSIS : 06.01.2026

		S.No.	Lab	Sewage Treatment Plant (Operator) Technology	Capacity (MGD)	DPCC Parameter (mg/l) (TSS:10,BOD:10, COD:50, NH4-N:5,PO4-P:2, Oil& grease : 10, f.coliform: 230 MPN/100ml)	pH		TSS		BOD (3 DAYS at 27 0 C)		COD		Ammonical nitrogen		Dissolve phosphate		Oil & Grease		Fecal Coliform (72 hrs)		Remarks		
							INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET		INLET	OUTLET
									mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l		mg/l	MPN/100ml
	1	Keshapur	Keshapur Ph-I (VA-TECH WABAG LTD.) ASP	12	As per plant design TSS:30/BOD:20/COD:250/NH4-N:50/PO4:5/ f.c:230	7.32	7.61	277	10	170	7	492	23	18	2.5	5	2	-	-	24*10^14	150				
	2		Keshapur Ph-II (Ayaappa Pvt.Ltd) ASP(IFAS)	20	As per DPCC limits	7.28	7.58	338	10	165	8	480	26	22	4.9	4	0.5	16.34	Nil	24*10^14	160				
	3		Keshapur Ph-III (Ayaappa Pvt.Ltd) ASP	60	As per DPCC limits	7.21	7.52	286	6	160	6	466	20	24	5	3.5	0.4	-	-	24*10^14	210				
	4		Kapashera (Triveni Pvt. Ltd) SBR	5	As per plant design TSS:10/BOD:10/f.C:1000/100ml	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-				
	5	Kondli	Kondli Ph-I (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	7.1	7.5	248	6	138	4	460	18	32	1.5	3.5	1			290×10^11	110				
	6		Kondli Ph-II (Triveni Pvt. Ltd) ASP	25	As per DPCC limits	7.1	7.4	248	8	138	5	460	24	32	2.5	3.5	1.2			290×10^11	36				
	7		Kondli Ph-III (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	7.1	7.4	248	8	138	5	460	24	32	2.5	3.5	1.2			290×10^11	36				
	8		Kondli Ph-IV (Ayaappa Pvt.Ltd) ASP(IFAS)	45	As per DPCC limits	7	7.6	260	9	145	8	482	22	35	3	3.8	1.0			210×10^11	72				
	9		Chilla (HNB Engineers) C-ISBR	9	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-				
	10		CWG (W/s Toshiba Water Soluti on Pvt. Ltd.) MBR	1	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-				
	11	N.S.T.P.C.Pillar	Coronation Pillar Ph-II (DRA Infracom Pvt.Ltd.) ASP(IFAS)	20	As per plant design TSS:30/BOD:20/COD:250/NH4-N:50/PO4:5/ f.C:230	6.9	7.4	220	9	137	5	648	19	21	0.5	1.7	0.7	-	-	-	-				
	12		Coronation Pillar Ph-III (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits	7	7.5	150	7	80	3	284	17	24	0.5	1.5	0.8	-	-	-	-				
	13		Coronation New (L&T Construction and PASSAVANT (JV)) ASP	70	As per DPCC limits	7	7.4	214	19	123	10	501	28	28	0.5	2.5	0.9			-	-				
	14		Narela (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-				
	15	Nilothi	Nilothi Ph-I (SUBHASH INFRA PVT. LTD) ASP(IFAS)	60	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-				
	16		Nilothi Ph-II (VEOLIA INDIA) ASP	20	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-				
	17	Okhla	Okhla Ph-V (DIB) ASP	16	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-				
	18		Okhla Ph-VI (SUEZ India Pvt. Ltd.) ASP	30	As per DPCC limits	7.2	7.6	216	4	(-)	(-)	258	2.9	35	ND	3	1.2	4	ND	21 X 10^1	20				
	19		Okhla New (SUEZ India Pvt. Ltd.) ASP	124	As per DPCC limits	7.4	7.8	190	5	(-)	(-)	145	5.3	40	0.2	3.2	2.5	3	ND	93 X 10^1	<1.8				
	20		Mehrauli (DIB) E.A	5	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-				
	21		Mofar band (DIB)	0.66	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-				
	22		Ghitorini (DIB) ASP	5	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-				
	23		Vasant Kunj Ph-I (DIB) E.A	2.2	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-				
	24		Vasant Kunj Ph-II (DIB) E.A	3	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-				
	25	Delhi Gate Ph-I (Degramont) B & D	2.2	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-				
	26	Delhi Gate Ph-II (Degramont) B & D	15	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-				

[illegible]



DAILY ANALYSIS REPORT OF ALL SEWAGE TREATMENT PLANT

DATE OF ANALYSIS : 08.01.2026

DATE OF ANALYSIS: 05/05/2020																						
S.No.	Lab	Sewage Treatment Plant (Operator) Technology	Capacity	DPCC Parameter (mg/l) (TSS:10,BOD:10, COD:50, NH4-N:5,PO4-P:2, Oil& grease : 10, f.coliform: 230 MPN/100ml)	pH		TSS		BOD (3 DAYS at 27 0 C)		COD		Ammonical nitrogen		Dissolve phosphate		Oil & Grease		Fecal Coliform (72 hrs)		Remarks	
					INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET		INLET
			(MGD)	Parameter Limits	-	-	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l		mg/l
	1	Keshopur	Keshopur Ph-I (VA-TECH WABAG LTD.) ASP	12	As per plant design TSS:30/BOD:20/COD:250/NH4-N:50/PO4:5/ f.C:230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
	2		Keshopur Ph-II (Ayaappa Pvt.Ltd) ASP(IFAS)	20	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
	3		Keshopur Ph-III (Ayaappa Pvt.Ltd) ASP	60	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
	4		Kapashera (Triveni Pvt. Ltd) SBR	5	As per plant design TSS:10/BOD:10/f.C:1000/100ml	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
	5	Kondli	Kondli Ph-I (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	7	7.5	292	7	153	4	490	22	30	0.5	3.5	1			210×10^11	36	
	6		Kondli Ph-II (Triveni Pvt. Ltd) ASP	25	As per DPCC limits	7	7.4	292	8	153	6	490	20	30	2	3.5	1.5			210×10^11	73	
	7		Kondli Ph-III (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	7	7.4	292	8	153	6	490	20	30	2	3.5	1.5			210×10^11	73	
	8		Kondli Ph-IV (Ayaappa Pvt.Ltd) ASP(IFAS)	45	As per DPCC limits	6.9	7.4	302	7	152	5	510	23	32	3.2	3.8	1.2			290×10^11	91	
	9		Chilla (HNB Engineers) C-ISBR	9	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
	10		CWG (M/s Toshiba Water Soluti on Pvt. Ltd.) MBR	1	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
	11	N.5,T.P.C.Pillar	Coronation Pillar Ph-II (DRA Infracom Pvt.Ltd.) ASP(IFAS)	20	As per plant design TSS:30/BOD:20/COD:250/NH4-N:50/PO4:5/ f.C:230	7	7.4	194	8	106	4	228	14	21	0.5	2.1	0.7	2	bdl	-	-	
	12		Coronation Pillar Ph-III (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits	6.9	7.5	212	6	113	3	223	12	24	0.7	1.9	0.6	2.4	bdl	-	-	
	13		Coronation New (L&T Construction and PASSAVANT (JV)) ASP	70	As per DPCC limits	7	7.4	226	10	132	7	308	17	27	0.6	2.8	0.9	2.6	0.2	-	-	
	14		Narela (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits															-	-	
	15	Nilothi	Nilothi Ph-I (SUBHASH INFRA PVT. LTD) ASP(IFAS)	60	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
	16		Nilothi Ph-II (VEOLIA INDIA) ASP	20	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
	17	Okhla	Okhla Ph-V (DJB) ASP	16	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	Plant closed due to power failure	
	18		Okhla Ph-VI (SUEZ India Pvt. Ltd.) ASP	30	As per DPCC limits	7.58	7.99	544	9	215	6	(-)	(-)	35	ND	2.6	1.5	5	ND			
	19		Okhla New (SUEZ India Pvt. Ltd.) ASP	124	As per DPCC limits	7.44	7.36	196	15	225	12	(-)	(-)	20	0.6	2.7	2.5	3	ND			
	20		Mehrauli (DJB) E.A	5	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
	21		Molar band (DJB)	0.66	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
	22		Ghitorini (DJB) ASP	5	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
	23		Vasant Kunj Ph-I (DJB) E.A	2.2	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
	24		Vasant Kunj Ph-II (DJB) E.A	3	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
	25		Delhi Gate Ph-I (Degramont) B & D	2.2	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
	26		Delhi Gate Ph-II (Degramont) B & D	15	As per DPCC limits	7.47	7.54	220	29	230	13	520	68	60	13	2.3	1.5	3	ND			

ASP	Activated Sludge Process
ASP(IFAS)	Activated Sludge Process with Integrated Fixed-film Activated Sludge
E.A	Extended Aeration
FAB	Fluidized Aerobic Bed
B & D	Biofor and dansadeg
C-ISBR	Combitreat-ISBR
W	Waiting
ND	Not Detectable
BDL	Bellow Detection Limit



DAILY ANALYSIS REPORT OF ALL SEWAGE TREATMENT PLANT

DATE OF ANALYSIS : 10.01.2026

DATE OF ANALYSIS : 10.01.2020																						
S.No.	Lab	Sewage Treatment Plant (Operator) Technology	Capacity	DPCC Parameter (mg/l) (TSS:10,BOD:10, COD:50, NH4-N:5,PO4-P:2, Oil& grease : 10, f.coliform: 230 MPN/100ml)	pH		TSS		BOD (3 DAYS at 27 0 C)		COD		Ammonical nitrogen		Dissolve phosphate		Oil & Grease		Fecal Coliform (72 hrs)		Remarks	
					INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET		INLET
			(MGD)	Parameter Limits	-	-	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	MPN/100ml	MPN/100ml	
1	Keshapur	Keshapur Ph-I (VA-TECH WABAG LTD.) ASP	12	As per plant design TSS:30/BOD:20/COD:250/NH4-N:50/PO4:5/ f.C:230	7.28	7.58	344	04	140	04	390	18	18	2	4	1.8	-	-	24*10^14	150		
2		Keshapur Ph-II (Ayaappa Pvt.Ltd) ASP(IFAS)	20	As per DPCC limits	7.22	7.62	265	06	160	05	440	26	22	4.8	3.8	0.8	19.84	Nil	24*10^14	210		
3		Keshapur Ph-III (Ayaappa Pvt.Ltd) ASP	60	As per DPCC limits	7.29	7.64	270	08	145	05	400	28	24	4.5	4.2	0.2	-	-	24*10^14	210		
4		Kapashera (Triveni Pvt. Ltd) SBR	5	As per plant design TSS:10/BOD:10/f.C:1000/100ml	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
5	Kondli	Kondli Ph-I (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	7	7.6	232	7	135	5	461	16	30	0.5	2.8	0.8			290x10^11	36		
6		Kondli Ph-II (Triveni Pvt. Ltd) ASP	25	As per DPCC limits	7	7.5	232	8	135	7	461	21	30	1.5	2.8	1.0			290x10^11	73		
7		Kondli Ph-III (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	7	7.5	232	8	135	7	461	21	30	1.5	2.8	1.0			290x10^11	73		
8		Kondli Ph-IV (Ayaappa Pvt.Ltd) ASP(IFAS)	45	As per DPCC limits	6.9	7.5	266	6	145	6	498	19	32	2	3	0.8			210x10^11	73		
9		Chilla (HNB Engineers) C-ISBR	9	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
10		CWG (M/s Toshiba Water Soluti on Pvt. Ltd.) MBR	1	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
11	N.S.T.P.C.Pillar	Coronation Pillar Ph-II (DRA Infracom Pvt.Ltd.) ASP(IFAS)	20	As per plant design TSS:30/BOD:20/COD:250/NH4-N:50/PO4:5/ f.C:230	6.9	7.6	190	9	103	4	211	15	23	0.5	1.9	0.9	2	bdl	15x10^10	210		
12		Coronation Pillar Ph-III (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits	7.1	7.5	206	10	110	5	348	17	27	0.7	1.7	0.6	2.2	bdl	-	-		
13		Coronation New (L&T Construction and PASSAVANT (JV)) ASP	70	As per DPCC limits	7	7.4	200	10	119	6	507	27	29	0.8	3	0.7	-	-	-	-		
14		Narela (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits															-	-		
15	Nilothi	Nilothi Ph-I (SUBHASH INFRA PVT. LTD) ASP(IFAS)	60	As per DPCC limits	7.49	7.6	260	5	145	7	-	-	21.2	6.4	2.7	0.5			21x10^7	24x10^4		
16		Nilothi Ph-II (VEOLIA INDIA) ASP	20	As per DPCC limits	7.47	7.63	286	6	160	5	-	-	20	4	2.8	0.4			15x10^7	43		
17	Okhla	Okhla Ph-V (DIB) ASP	16	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	7.42	7.64	296	15	228	12.6	500	50	30	2.5	2.5	2	3	ND	46x10^10	24x10^4		
18		Okhla Ph-VI (SUEZ India Pvt. Ltd.) ASP	30	As per DPCC limits	7.47	7.79	260	6	173	2.9	200	40	35	ND	3	1.2	4	ND	24x10^12	15		
19		Okhla New (SUEZ India Pvt. Ltd.) ASP	124	As per DPCC limits	7.2	7.6	312	10	135	3.8	300	25	34	1.1	2.8	0.7	4	ND	93x10^12	93		
20		Mehrauli (DIB) E.A	5	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	7.4	7.6	392	3	195	7.9	430	40	60	0.5	3.8	1	3					

ASP	Activated Sludge Process
ASP(IFAS)	Activated Sludge Process with Integrated Fixed-film Activated Sludge
E.A	Extended Aeration
FAB	Fluidized Aerobic Bed
B & D	Biofor and dansadeg
C-ISBR	Combitreat-ISBR
W	Waiting
ND	Not Detectable
BDL	Bellow Detection Limit



DAILY ANALYSIS REPORT OF ALL SEWAGE TREATMENT PLANT

DATE OF ANALYSIS : 11.01.2026

[illegible]

[illegible]



DAILY ANALYSIS REPORT OF ALL SEWAGE TREATMENT PLANT

DATE OF ANALYSIS : 12.01.2026

DATE OF ANALYSIS : 12.01.2020																					
S.No.	Lab	Sewage Treatment Plant (Operator) Technology	Capacity	DPCC Parameter (mg/l) (TSS:10,BOD:10, COD:50, NH4-N:5,PO4-P:2, Oil& grease : 10, f.coliform: 230 MPN/100ml)	pH		TSS		BOD (3 DAYS at 27 0 C)		COD		Ammonical nitrogen		Dissolve phosphate		Oil & Grease		Fecal Coliform (72 hrs)		Remarks
					INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	
			(MGD)	Parameter Limits	-	-	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	MPN/100ml	MPN/100ml
1	Keshapur	Keshapur Ph-I (VA-TECH WABAG LTD.) ASP	12	As per plant design TSS:30/BOD:20/COD:250/NH4-N:50/PO4:5/ f.C:230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
2		Keshapur Ph-II (Ayaappa Pvt.Ltd) ASP(IFAS)	20	As per DPCC limits	7.48	7.62	420	10	150	8	463	26	26	4.8	4.8	0.4	24,64	Nil	24*10^14	160	
3		Keshapur Ph-III (Ayaappa Pvt.Ltd) ASP	60	As per DPCC limits	7.45	7.71	399	9	155	10	482	32	24	5	4.2	0.5	-	-	24*10^14	210	
4		Kapashera (Triveni Pvt. Ltd) SBR	5	As per plant design TSS:10/BOD:10/f.C:1000/100ml	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
5	Kondli	Kondli Ph-I (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	7	7.6	284	07	138	06	486	20	35	1	3.8	1.2			-	-	
6		Kondli Ph-II (Triveni Pvt. Ltd) ASP	25	As per DPCC limits	7	7.5	284	08	138	07	486	24	35	3	3.8	1.5			-	-	
7		Kondli Ph-III (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	7	7.5	284	08	138	07	486	24	35	3	3.8	1.5			-	-	
8		Kondli Ph-IV (Ayaappa Pvt.Ltd) ASP(IFAS)	45	As per DPCC limits	6.9	7.5	310	06	148	06	502	18	35	3	3.5	1.8			-	-	
9		Chilla (HNB Engineers) C-ISBR	9	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
10		CWG (M/s Toshiba Water Soluti on Pvt. Ltd.) MBR	1	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
11	N.S.T.P.C.Pillar	Coronation Pillar Ph-II (DRA Infracom Pvt.Ltd.) ASP(IFAS)	20	As per plant design TSS:30/BOD:20/COD:250/NH4-N:50/PO4:5/ f.C:230	7	7.6	194	07	117	04	272	14	20	0.5	1.9	0.7			-	-	
12		Coronation Pillar Ph-III (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits	7.1	7.5	200	06	127	04	213	17	23	0.7	1.6	0.8			-	-	
13		Coronation New (L&T Construction and PASSAVANT (JV)) ASP	70	As per DPCC limits	7.1	7.6	208	09	130	07	347	20	29	0.8	3	0.9			-	-	
14		Narela (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
15	Nilothi	Nilothi Ph-I (SUBHASH INFRA PVT. LTD) ASP(IFAS)	60	As per DPCC limits	7.48	7.59	334	8	188	8	-	-	20	7.5	2.8	0.2			-	-	
16		Nilothi Ph-II (VEOLIA INDIA) ASP	20	As per DPCC limits	7.49	7.55	296	7	165	6	-	-	20	4.5	2.4	0.4			-	-	
17	Okhla	Okhla Ph-V (DIB) ASP	16	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	7.39	7.51	344	14	140	13.3	-	-	30	4.3	3.4	1.8	3	ND	93x10^11	24x10^3	
18		Okhla Ph-VI (SUEZ India Pvt. Ltd.) ASP	30	As per DPCC limits	7.38	7.77	152	13	240	3.3	-	-	5.5	0.1	1.6	3.2	4	ND	15x10^12	93	
19		Okhla New (SUEZ India Pvt. Ltd.) ASP	124	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
20		Mehrauli (DIB) E.A	5	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
21		Molar band (DIB)	0.66	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
22		Ghitorini (DIB) ASP	5																		

[illegible]



DATE OF ANALYSIS : 13.01.2026

460

[illegible]

 DELHI JAL BOARD		DAILY ANALYSIS REPORT OF ALL SEWAGE TREATMENT PLANT																					
		DATE OF ANALYSIS : 14.01.2026																					
S.No.	Lab	Sewage Treatment Plant (Operator) Technology	Capacity	DPCC Parameter (mg/l) (TSS:10,BOD:10, COD:50, NH4-N:5,PO4-P:2, Oil&grease : 10, f.coliform: 230 MPN/100ml)	pH		TSS		BOD (3 DAYS at 27 0 C)		COD		Ammonical nitrogen		Dissolve phosphate		Oil & Grease		Fecal Coliform (72 hrs)		Remarks		
					INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET		INLET	OUTLET
			(MGD)	Parameter Limits	-	-	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	MPN/100ml	MPN/100ml		
1	Keshopur	Keshopur Ph-I (VA-TECH WABAG LTD.) ASP	12	As per plant design TSS:30/BOD:20/COD:250/NH4-N:50/PO4:5/ f.C:230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
2		Keshopur Ph-II (Ayaappa Pvt.Ltd) ASP(IFAS)	20	As per DPCC limits	7.23	7.58	217	7	140	6	380	20	26	4.3	3.8	0.5	18.64	Nil	24*10^14	150			
3		Keshopur Ph-III (Ayaappa Pvt.Ltd) ASP	60	As per DPCC limits	7.18	7.62	224	8	155	7	419	22	24	4.5	4	0.5	-	-	24*10^14	210			
4		Kapashera (Triveni Pvt. Ltd) SBR	5	As per plant design TSS:10/BOD:10/f.C:1000/100ml	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
5	Kondli	Kondli Ph-I (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	7.1	7.5	286	8	150	6	504	27	32	0.5	3.5	1.8			210*10^11	30			
6		Kondli Ph-II (Triveni Pvt. Ltd) ASP	25	As per DPCC limits	7.1	7.6	286	9	150	7	504	25	32	1.5	3.5	1.2			210*10^11	73			
7		Kondli Ph-III (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	7.1	7.6	286	9	150	7	504	25	32	1.5	3.5	1.2			210*10^11	73			
8		Kondli Ph-IV (Ayaappa Pvt.Ltd) ASP(IFAS)	45	As per DPCC limits	7	7.5	304	8	157	5	510	24	35	2	3.5	1.0			1100*10^11	73			
9		Chilla (HNB Engineers) C-ISBR	9	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
10		CWG (M/s Toshiba Water Soluti on Pvt. Ltd.) MBR	1	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
11	N.S.T.P.C.Pillar	Coronation Pillar Ph-II (DRA Infracom Pvt.Ltd.) ASP(IFAS)	20	As per plant design TSS:30/BOD:20/COD:250/NH4-N:50/PO4:5/ f.C:230	6.9	7.6	148	07	67	03	287	15	15	0.5	2	0.9			-	-			
12		Coronation Pillar Ph-III (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits	7	7.6	285	10	142	06	340	20	14	0.7	1.7	1			-	-			
13		Coronation New (L&T Construction and PASSAVANT (JV)) ASP	70	As per DPCC limits	7	7.7	154	10	122	06	317	17	29	0.8	2.5	1.7			-	-			
14		Narela (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
15	Nilothi	Nilothi Ph-I (SUBHASH INFRA PVT. LTD) ASP(IFAS)	60	As per DPCC limits	7.45	7.57	346	6	195	4	-	-	27.5	6	3	0.4			21x10^8	24x10^4			
16		Nilothi Ph-II (VEOLIA INDIA) ASP	20	As per DPCC limits	7.5	7.55	254	4	140	3	-	-	25	3.9	2.8	0.2			15x10^8	43			
17	Okhla	Okhla Ph-V (DJB) ASP	16	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	7.41	7.41	148	10	128	7.1	-	-	30	3.2	3.5	1.8	5	ND	75X10^9	21X10^3			
18		Okhla Ph-VI (SUEZ India Pvt. Ltd.) ASP	30	As per DPCC limits	7.31	7.48	346	8	198	3.4	-	-	38	0.1	3.8	1.9	4	ND	24X10^12	3.6			
19		Okhla New (SUEZ India Pvt. Ltd.) ASP	124	As per DPCC limits	7.38	7.18	612	8	138	5.4	-	-	32	0.1	3.8	2.4	5	ND	21X10^12	15			
20		Mehrauli (DJB) E.A	5	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
21		Molar band (DJB)	0.66	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
22		Ghitorini (DJB) ASP	5	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
23		Vasant Kunj Ph-I (DJB) E.A	2.2	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
24		Vasant Kunj Ph-II (DJB) E.A	3	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
25	Delhi Gate	Delhi Gate Ph-I (Degramont) B & D	2.2	As per DPCC limits	7.49	7.63	70	7	106	2.2	-	-	10	0.5	1.5	0.3	6	1	24X10^13	75X10^3			
26		Delhi Gate Ph-II (Degramont) B & D	15	As per DPCC limits	7.65	7.68	150	16	86.5	3.2	-	-	20	15	1.3	0.3	5	1	43X10^11	15			
27		SNH drain (Degramont) B & D	2.2	As per DPCC limits	7.25	7.55	362	10	203	5.2	-	-	20	6	1	0.2	7	2	24X10^13	24X10^4			
28	Pappankalan	Phappankalan Ph-I (SUBHASH INFRA PVT. LTD) ASP	20	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
29		Phappankalan Ph-II (VA-TECH WABAG LTD.) ASP	20	As per plant design TSS:10/BOD:10/NH4-N:2/PO4:6/ f.C:2500/100ml	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
30		Najafgarh (Ayaappa Pvt.Ltd.) ASP	5	As per DPCC limits	7.28	7.51	335	6	170	5	460	26	44	1	4	0.5	-	-	-	-			

[illegible]



DAILY ANALYSIS REPORT OF ALL SEWAGE TREATMENT PLANT

DATE OF ANALYSIS : 15.01.2026

DATE OF ANALYSIS : 15.01.2026																							
S.No.	Lab	Sewage Treatment Plant (Operator) Technology	Capacity	DPCC Parameter (mg/l) (TSS:10,800:10, COD:50, NH4-N:5, PO4-P:2, Oil& grease : 10, f.coliform: 230 MPN/100ml)	pH		TSS		BOD (3 DAYS at 27 0 C)		COD		Ammonical nitrogen		Dissolve phosphate		Oil & Grease		Fecal Coliform (72 hrs)		Remarks		
					INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET		INLET	OUTLET
					(MGD)	Parameter Limits	-	-	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l		mg/l	MPN/100ml
1	Keshopur	Keshopur Ph-I (VA-TECH WABAG LTD.) ASP	12	As per plant design TSS:30/BOD:20/COD:250/NH4-N:50/PO4-5/ f.C:230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	lab closed on sunday		
2		Keshopur Ph-II (Ayaappa Pvt.Ltd) ASP(IFAS)	20	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	lab closed on sunday		
3		Keshopur Ph-III (Ayaappa Pvt.Ltd) ASP	60	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	lab closed on sunday		
4		Kapashera (Triveni Pvt. Ltd) SBR	5	As per plant design TSS:10/BOD:10/f.C:1000/100ml	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	lab closed on sunday		
5	Kondli	Kondli Ph-I (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	7.1	7.5	254	07	142	5	482	24	30	0.5	3	0.8			210 x 10^11	73			
6		Kondli Ph-II (Triveni Pvt. Ltd) ASP	25	As per DPCC limits	7.1	7.5	254	08	142	7	482	20	30	0.8	3	1.0			210 x 10^11	91			
7		Kondli Ph-III (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	7.1	7.5	254	8	142	7	482	20	30	0.8	3	1.0			210 x 10^11	91			
8		Kondli Ph-IV (Ayaappa Pvt.Ltd) ASP(IFAS)	45	As per DPCC limits	7.1	7.5	260	6	148	5	478	26	32	3.5	3	1.5			210 x 10^11	91			
9		Chilla (HNB Engineers) C-ISBR	9	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
10		CWG (M/s Toshiba Water Soluti on Pvt. Ltd.) MBR	1	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
11	N.S.T.P.C.Pillar	Coronation Pillar Ph-II (DRA Infracom Pvt.Ltd.) ASP(IFAS)	20	As per plant design TSS:30/BOD:20/COD:250/NH4-N:50/PO4-5/ f.C:230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
12		Coronation Pillar Ph-III (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
13		Coronation New (L&T Construction and PASSAVANT (JV)) ASP	70	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
14		Narela (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
15	Nilothi	Nilothi Ph-I (SUBHASH INFRA PVT. LTD) ASP(IFAS)	60	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
16		Nilothi Ph-II (VEOLIA INDIA) ASP	20	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
17	Okhla	Okhla Ph-V (DIB) ASP	16	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4-5	7.4	7.5	252	14	205	8	(-)	(-)	30	3.5	2.6	1.2	4	ND					
18		Okhla Ph-VI (SUEZ India Pvt. Ltd.) ASP	30	As per DPCC limits	7.3	7.6	274	6	200	4	(-)	(-)	15	0.1	2.6	1.1	5	ND					
19		Okhla New (SUEZ India Pvt. Ltd.) ASP	124	As per DPCC limits	7.3	7.8	174	9	150	5	(-)	(-)	30	0.2	2.9	0.8	4	ND					
20		Mehrauli (DIB) E.A	5	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4-5	7.29	8.24	274	19	300	24	(-)	(-)	50	20	5.5	1.4	3	1					
21		Molar band (DIB)	0.66	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4-5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
22		Ghitorini (DIB) ASP	5	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4-5	8.12	8.2	606	47	345	25	(-)	(-)	50	45	4	3	4	1					

[illegible]



DAILY ANALYSIS REPORT OF ALL SEWAGE TREATMENT PLANT

DATE OF ANALYSIS : 16.01.2026

DATE OF ANALYSIS : 16.07.2026																							
S.No.	Lab	Sewage Treatment Plant (Operator) Technology	Capacity	DPCC Parameter (mg/l) (TSS:10,BOD:10, COD:50, NH4-N:5,PO4-P:2, Oil& grease : 10, f.coliform: 230 MPN/100ml)	pH		TSS		BOD (3 DAYS at 27 O C)		COD		Ammonical nitrogen		Dissolve phosphate		Oil & Grease		Fecal Coliform (72 hrs)		Remarks		
					Inlet	Outlet	Inlet	Outlet	Inlet	Outlet	Inlet	Outlet	Inlet	Outlet	Inlet	Outlet	Inlet	Outlet	Inlet	Outlet		Inlet	Outlet
					(MGD)	Parameter Limits	-	-	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l		mg/l	MPN/100ml
1	Keshopur	Keshopur Ph-I (VA-TECH WABAG LTD.) ASP	12	As per plant design TSS:30/BOD:20/COD:250/NH4-N:50/PO4-S/ f.C:230	7.31	7.58	344	10	180	06	495	21	18	3	4.2	2	16.34	Nil	24*10^13	93			
2		Keshopur Ph-II (Ayaappa Pvt.Ltd) ASP(IFAS)	20	As per DPCC limits	7.3	7.68	265	07	165	06	420	24	22	4.8	5	1	----	-----	24*10^13	150			
3		Keshopur Ph-III (Ayaappa Pvt.Ltd) ASP	60	As per DPCC limits	7.28	7.82	270	06	170	05	470	24	20	5	4.8	0.5	-----	-----	24*10^13	210			
4		Kapashera (Triveni Pvt. Ltd) SBR	5	As per plant design TSS:10/BOD:10/f.C:1000/100ml	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
5	Kondli	Kondli Ph-I (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	7.2	7.5	260	6	145	5	490	22	35	1	3.5	0.8			210 X 10^11	73			
6		Kondli Ph-II (Triveni Pvt. Ltd) ASP	25	As per DPCC limits	7.2	7.4	260	7	145	6	490	24	35	3.5	3.5	1.0			210 X 10^11	91			
7		Kondli Ph-III (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	7.2	7.4	260	7	145	6	490	24	35	3.5	3.5	1.0			210 X 10^11	91			
8		Kondli Ph-IV (Ayaappa Pvt.Ltd) ASP(IFAS)	45	As per DPCC limits	7.1	7.4	274	5	163	7	494	18	38	4.5	3.5	1.0			1100 X 10^11	3.6			
9		Chilla (HNB Engineers) C-ISBR	9	As per DPCC limits	7.2	7.4	320	8	158	6	524	35	35	0.5	4	Nil			1100 X 10^11	73			
10		CWG (M/s Toshiba Water Soluti on Pvt. Ltd.) MBR	1	As per DPCC limits	7.1	7.5	460	6	160	4	680	25	32	0.5	4.2	Nil			480 X 10^11	36			
11	N.S.T.P.C Pillar	Coronation Pillar Ph-II (DRA Infracom Pvt.Ltd.) ASP(IFAS)	20	As per plant design TSS:30/BOD:20/COD:250/NH4-N:50/PO4-S/ f.C:230	7	7.6	132	10	77	5	177	14	15	0.9	1.7	0.7	1.8	Bdl	-	-			
12		Coronation Pillar Ph-III (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits	7	7.6	176	8	90	4	195	15	20	0.8	1.5	0.9	1.9	Bdl	-	-			
13		Coronation New (L&T Construction and PASSAVANT (JV)) ASP	70	As per DPCC limits	7	7.7	206	10	111	6	316	19	28	0.7	2.5	1.2			-	-			
14		Narela (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits															-	-			
15	Nilothi	Nilothi Ph-I (SUBHASH INFRA PVT. LTD) ASP(IFAS)	60	As per DPCC limits	7.45	7.63	454	4	240	5	-	-	26.2	6.2	3.1	0.3			11x10^9	24x10^4			
16		Nilothi Ph-II (VEOLIA INDIA) ASP	20	As per DPCC limits	7.44	7.48	316	5	175	4	-	-	23.7	4	2.9	0.3			46x10^8	75			
17	Okhla	Okhla Ph-V (DJB) ASP	16	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4-S	7.53	7.66	202	20	170	10.1	(-)	(-)	30	3.5	3.2	0.5	3	ND	24x10^10	43x10^2			
18		Okhla Ph-VI (SUEZ India Pvt. Ltd.) ASP	30	As per DPCC limits	7.32	7.74	248	10	255	6.2	(-)	(-)	35	1	2.8	1.6	4	ND	75x10^11	7.3			
19		Okhla New (SUEZ India Pvt. Ltd.) ASP	124	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
20		Mehrauli (DJB) E.A	5	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4-S	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
21		Molar band (DJB)	0.66	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4-S	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
22		Ghitorini (DJB) ASP	5	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4-S	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
23	Vasant Kunj Ph-I (DJB) E.A	2.2	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4-S	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-				
24	Vasant Kunj Ph-II (DJB) E.A	3	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4-S	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-				
25	Delhi Gate Ph-I (Degramont) B & D	2.2	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
26	Delhi Gate Ph-II (Degramont) B & D	15	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			

[illegible]



DAILY ANALYSIS REPORT OF ALL SEWAGE TREATMENT PLANT

DATE OF ANALYSIS : 17 01 2026

[illegible]

[illegible]



DAILY ANALYSIS REPORT OF ALL SEWAGE TREATMENT PLANT

DATE OF ANALYSIS - 18.01.2026

DATE OF ANALYSIS : 16.01.2026																							
S.No.	Lab	Sewage Treatment Plant (Operator) Technology	Capacity	DPCC Parameter (mg/l) (TSS:10,BOD:10, COD:50, NH4-N:5, PO4-P:2, Oil& grease : 10, f.coliform: 230 MPN/100ml)	pH		TSS		BOD (3 DAYS at 27 0 C)		COD		Ammonical nitrogen		Dissolve phosphate		Oil & Grease		Fecal Coliform (72 hrs)		Remarks		
					INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET		INLET	OUTLET
					(MGD)	Parameter Limits	-	-	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l		mg/l	MPN/100ml
1	Keshopur	Keshopur Ph-I (VA-TECH WABAG LTD.) ASP	12	As per plant design TSS:30/BOD:20/COD:250/NH4-N:50/PO4:5/ f.C:230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	lab closed on sunday		
2		Keshopur Ph-II (Ayaappa Pvt.Ltd) ASP(IFAS)	20	As per DPCC limits	ASP	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	lab closed on sunday		
3		Keshopur Ph-III (Ayaappa Pvt.Ltd) ASP	60	As per DPCC limits	ASP	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	lab closed on sunday		
4		Kapashera (Triveni Pvt. Ltd) SBR	5	As per plant design TSS:10/BOD:10/f.C:1000/100ml	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	lab closed on sunday		
5	Kondli	Kondli Ph-I (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	7	7.5	262	6	138	5	498	20	35	1.2	3.8	1			-	-			
6		Kondli Ph-II (Triveni Pvt. Ltd) ASP	25	As per DPCC limits	7	7.6	262	8	138	7	498	24	35	3.5	3.8	2.0			-	-			
7		Kondli Ph-III (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	7	7.6	262	8	138	7	498	24	35	3.5	3.8	2.0			-	-			
8		Kondli Ph-IV (Ayaappa Pvt.Ltd) ASP(IFAS)	45	As per DPCC limits	6.9	7.5	286	5	155	6	485	26	32	3	3.5	1.0			-	-			
9		Chilla (HNB Engineers) C-ISBR	9	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	Sample collected twice in week		
10		CWG (M/s Toshiba Water Soluti on Pvt. Ltd.) MBR	1	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	Sample collected twice in week		
11	N.S.T.P.C.Pillar	Coronation Pillar Ph-II (DRA Infracom Pvt.Ltd.) ASP(IFAS)	20	As per plant design TSS:30/BOD:20/COD:250/NH4-N:50/PO4:5/ f.C:230	7	7.6	172	9	96	4	292	25	15	0.5	1.7	0.7			-	-			
12		Coronation Pillar Ph-III (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits	7.1	7.5	148	7	74	3	230	21	22	0.7	1.9	0.9			-	-			
13		Coronation New (L&T Construction and PASSAVANT (JV)) ASP	70	As per DPCC limits	7.1	7.6	210	8	141	5	342	19	25	0.8	2	1			-	-			
14		Narela (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits															-	-			
15	Nilothi	Nilothi Ph-I (SUBHASH INFRA PVT. LTD) ASP(IFAS)	60	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
16		Nilothi Ph-II (VEOLIA INDIA) ASP	20	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
17	Okhla	Okhla Ph-V (DIB) ASP	16	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	7.2	7.5	278	12	240	13.7	(-)	(-)	38	3.5	2.4	1.1	5	ND	46x10^10	24x10^4			
18		Okhla Ph-VI (SUEZ India Pvt. Ltd.) ASP	30	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
19		Okhla New (SUEZ India Pvt. Ltd.) ASP	124	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
20		Mehrauli (DIB) E.A	5	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
21		Molar band (DIB)	0.66	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
22		Ghitorini (DIB) ASP	5	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
23		Vasant Kunj Ph-I (DIB) E.A	2.2																				

[illegible]



DAILY ANALYSIS REPORT OF ALL SEWAGE TREATMENT PLANT

DATE OF ANALYSIS - 19.01.2026

DATE OF ANALYSIS : 15.01.2026																							
S.No.	Lab	Sewage Treatment Plant (Operator) Technology	Capacity	DPCC Parameter (mg/l) (TSS:10,800:10, COD:50, NH4-N:5, PO4-P:2, Oil& grease : 10, f.coliform: 230 MPN/100ml)	pH		TSS		BOD (3 DAYS at 27 0 C)		COD		Ammonical nitrogen		Dissolve phosphate		Oil & Grease		Fecal Coliform (72 hrs)		Remarks		
					INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET		INLET	OUTLET
					(MGD)	Parameter Limits	-	-	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l		mg/l	MPN/100ml
1	Keshopur	Keshopur Ph-I (VA-TECH WABAG LTD.) ASP	12	As per plant design TSS:30/BOD:20/COD:250/NH4-N:50/PO4:5/ f.C:230	7.18	7.44	262	7	155	4	452	15	18	5	4	2	20.64	Nil	-	-			
2		Keshopur Ph-II (Ayaappa Pvt.Ltd) ASP(IFAS)	20	As per DPCC limits	7.23	7.54	312	5	160	5	486	18	22	4.8	5	0.8	-	-	-	-			
3		Keshopur Ph-III (Ayaappa Pvt.Ltd) ASP	60	As per DPCC limits	7.38	7.62	150	9	175	8	512	27	26	5	6.5	0.6	-	-	-	-			
4		Kapashera (Triveni Pvt. Ltd) SBR	5	As per plant design TSS:10/BOD:10/f.C:1000/100ml	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
5	Kondli	Kondli Ph-I (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	7	7.5	284	7	143	6	425	25	32	1	3.8	0.8			210*10^11	73			
6		Kondli Ph-II (Triveni Pvt. Ltd) ASP	25	As per DPCC limits	7	7.6	284	7	143	6	425	21	32	4.5	3.8	1.0			210*10^11	72			
7		Kondli Ph-III (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	7	7.6	284	7	143	6	425	21	32	4.5	3.8	1.0			210*10^11	72			
8		Kondli Ph-IV (Ayaappa Pvt.Ltd) ASP(IFAS)	45	As per DPCC limits	7.1	7.5	290	6	152	5	420	23	35	3	3.8	1.0			210*10^11	36			
9		Chilla (HNB Engineers) C-ISBR	9	As per DPCC limits	7.1	7.5	236	08	165	06	412	18	38	ND	4	Nil	12.4	Nil	210*10^11	72			
10		CWG (M/s Toshiba Water Soluti on Pvt. Ltd.) MBR	1	As per DPCC limits	7.2	7.4	396	5	185	4	544	14	32	ND	3.8	Nil	10.8	Nil	290*10^11	36			
11	N.S.T.P.C.Pillar	Coronation Pillar Ph-II (DRA Infracom Pvt.Ltd.) ASP(IFAS)	20	As per plant design TSS:30/BOD:20/COD:250/NH4-N:50/PO4:5/ f.C:230	7	7.6	184	8	100	4	272	14	18	0.6	1.5	0.7	1.8	bdl	-	-			
12		Coronation Pillar Ph-III (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits	7.1	7.5	160	6	81	3	270	18	21	0.5	1.8	0.8	1.9	bdl	-	-			
13		Coronation New (L&T Construction and PASSAVANT (JV)) ASP	70	As per DPCC limits	7.1	7.6	200	10	114	6	307	17	28	0.7	2.6	1.2			-	-			
14		Narela (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits															-	-			
15	Nilothi	Nilothi Ph-I (SUBHASH INFRA PVT. LTD) ASP(IFAS)	60	As per DPCC limits	7.45	7.59	520	6	285	8	-	-	30	5.8	3	0.2			-	-			
16		Nilothi Ph-II (VEOLIA INDIA) ASP	20	As per DPCC limits	7.37	7.78	218	8	218	6	-	-	26.2	4.6	2.7	0.3			-	-			
17	Okhla	Okhla Ph-V (DIB) ASP	16	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	7.56	7.88	264	10	140	12.1	340	39	20	2.5	2	1.8	4	ND	93X10^9	24X10^4			
18		Okhla Ph-VI (SUEZ India Pvt. Ltd.) ASP	30	As per DPCC limits	7.43	7.76	220	6	140	2.1	430	13	20	ND	3	0.5	3	ND	75X10^11	3.6			
19		Okhla New (SUEZ India Pvt. Ltd.) ASP	124	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
20		Mehrauli (DIB) E.A	5	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
21		Molar band (DIB)	0.66	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
22		Ghitorini (DIB) ASP	5	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
23		Vasant Kunj Ph-I (DIB) E.A	2.2	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-				
24		Vasant Kunj Ph-II (DIB) E.A	3	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-				
25		Delhi Gate Ph-I (Degramont) B & D	2.2	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
26		Delhi Gate Ph-II (Degramont) B & D	15	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			

	ASP	Activated Sludge Process
	ASP(IFAS)	Activated Sludge Process with Integrated Fixed-film Activated Sludge
	E.A	Extended Aeration
	FAB	Fluidized Aerobic Bed
	B & D	Biofor and dansadeg
	C-ISBR	Combitreat-ISBR
	W	Waiting
	ND	Not Detectable
	BDL	Bellow Detection Limit



DAILY ANALYSIS REPORT OF ALL SEWAGE TREATMENT PLANT

DATE OF ANALYSIS : 20.01.2026

DATE OF ANALYSIS : 20.07.2026																								
	S.No.	Lab	Sewage Treatment Plant (Operator) Technology	Capacity	DPCC Parameter (mg/l) (TSS:10,BOD:10, COD:50, NH4-N:5,PO4-P:2, Oil& grease : 10, f.coliform: 230 MPN/100ml)	pH		TSS		BOD (3 DAYS at 27 o C)		COD		Ammonical nitrogen		Dissolve phosphate		Oil & Grease		Fecal Coliform (72 hrs)		Remarks		
						INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET		INLET	OUTLET
	1	Keshopur	Keshopur Ph-I (VA-TECH WABAG LTD.) ASP	12	As per plant design TSS:30/BOD:20/COD:250/NH4-N:50/PO4-5/ f.c:230	7.15	7.36	276	5	160	7	384	24	26	4	4	2	-	-	24*10^10	93			
	2		Keshopur Ph-II (Ayaappa Pvt.Ltd) ASP(IFAS)	20	As per DPCC limits	7.22	7.48	157	10	165	8	416	29	28	7	5	0.3	21.26	Nil	24*10^10	150			
	3		Keshopur Ph-III (Ayaappa Pvt.Ltd) ASP	60	As per DPCC limits	7.24	7.51	455	8	160	8	492	26	30	9	4.8	0.4	-	-	24*10^10	210			
	4		Kapashera (Triveni Pvt. Ltd) SBR	5	As per plant design TSS:10/BOD:10/f.C:1000/100ml	7.38	8.02	608	10	165	7	484	25	60	18	19	3	-	-	24*10^10	2400+			
	5	Kondli	Kondli Ph-I (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	7.1	7.5	260	8	135	7	442	24	32	0.8	3.5	0.5	11.6	0.6	290*10^11	73			
	6		Kondli Ph-II (Triveni Pvt. Ltd) ASP	25	As per DPCC limits	7.1	7.5	260	6	135	7	442	22	32	4.5	3.5	0.8	11.6	Nil	290*10^11	73			
	7		Kondli Ph-III (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	7.1	7.5	260	6	135	7	442	22	32	4.5	3.5	0.8	11.6	Nil	290*10^11	73			
	8		Kondli Ph-IV (Ayaappa Pvt.Ltd) ASP(IFAS)	45	As per DPCC limits	7.2	7.5	270	6	147	6	438	25	32	3.5	3.5	0.5	12.2	Nil	210*10^11	72			
	9		Chilla (HNB Engineers) C-ISBR	9	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	10		CWG (M/s Toshiba Water Soluti on Pvt. Ltd.) MBR	1	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	11	N.S.T.P.C Pillar	Coronation Pillar Ph-II (DRA Infracom Pvt.Ltd.) ASP(IFAS)	20	As per plant design TSS:30/BOD:20/COD:250/NH4-N:50/PO4-5/ f.c:230	7	7.6	174	08	133	04	281	15	17	0.5	1.7	0.6			43X10^7	210			
	12		Coronation Pillar Ph-III (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits	7.1	7.5	266	10	173	05	396	16	18	0.7	1.5	0.9			15X10^7	93			
	13		Coronation New (L&T Construction and PASSAVANT (JV)) ASP	70	As per DPCC limits	7.1	7.6	154	10	107	07	308	17	24	0.6	1.9	0.8			75X10^8	150			
	14		Narela (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits	7	7.5	166	09	120	05	224	14	26	0.5	2	0.7			15X10^7	210			
	15	Nilothi	Nilothi Ph-I (SUBHASH INFRA PVT. LTD) ASP(IFAS)	60	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-				
	16		Nilothi Ph-II (VEOLIA INDIA) ASP	20	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	17	Okhla	Okhla Ph-V (DJB) ASP	16	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4-5	7.5	7.8	256	7	153	11.9	600	65	30	1.5	2.8	1.8	4	ND	15X10^10	11X10^4			
	18		Okhla Ph-VI (SUEZ India Pvt. Ltd.) ASP	30	As per DPCC limits	7.5	7.7	292	10	198	4.9	520	55	25	ND	2.5	1.2	3	ND	75X10^11	<1.8			
	19		Okhla New (SUEZ India Pvt. Ltd.) ASP	124	As per DPCC limits	7.4	7.8	328	10	228	4.1	(-)	(-)	30	0.1	2.2	1.3	3	ND	24X10^13	75			
	20		Mehrauli (DJB) E.A	5	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4-5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	21		Molar band (DJB)	0.66	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4-5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	22		Ghitorini (DJB) ASP	5	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4-5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	23		Vasant Kunj Ph-I (DJB) E.A	2.2	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4-5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	24		Vasant Kunj Ph-II (DJB) E.A	3	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4-5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	25	Delhi Gate	Ph-I (Degramont) B & D	2.2	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-				
	26		Ph-II (Degramont) B & D	15	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			

[illegible]

ASP	Activated Sludge Process
ASP(IFAS)	Activated Sludge Process with Integrated Fixed-film Activated Sludge
E.A	Extended Aeration
FAB	Fluidized Aerobic Bed
B & D	Biofor and dansadeg
C-ISBR	Combitreat-ISBR
W	Waiting
ND	Not Detectable
BDL	Bellow Detection Limit



DAILY ANALYSIS REPORT OF ALL SEWAGE TREATMENT PLANT

DATE OF ANALYSIS : 23.01.2026

DATE OF ANALYSIS : 23.01.2026																							
S.No.	Lab	Sewage Treatment Plant (Operator) Technology	Capacity	DPCC Parameter (mg/l) (TSS:10,800:10, COD:50, NH4-N:5, PO4-P:2, Oil& grease : 10, f.coliform: 230 MPN/100ml)	pH		TSS		BOD (3 DAYS at 27 0 C)		COD		Ammonical nitrogen		Dissolve phosphate		Oil & Grease		Fecal Coliform (72 hrs)		Remarks		
					INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET		INLET	OUTLET
					(MGD)	Parameter Limits	-	-	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l		mg/l	MPN/100ml
1	Keshopur	Keshopur Ph-I (VA-TECH WABAG LTD.) ASP	12	As per plant design TSS:30/BOD:20/COD:250/NH4-N:50/PO4:5/ f.C:230	7.13	7.38	224	6	160	5	489	19	24	24	2.8	5.8	1.9	-	-	24*10^11	93		
2		Keshopur Ph-II (Ayaappa Pvt.Ltd) ASP(IFAS)	20	As per DPCC limits	7.24	7.47	338	9	165	8	480	24	22	22	5	5	0.2	19.48	Nil	24*10^11	1100		
3		Keshopur Ph-III (Ayaappa Pvt.Ltd) ASP	60	As per DPCC limits	7.19	7.57	342	9	175	8	512	27	22	22	4.9	4.8	0.4	-	-	24*10^11	150		
4		Kapashera (Triveni Pvt. Ltd) SBR	5	As per plant design TSS:10/BOD:10/f.C:1000/100ml	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
5	Kondli	Kondli Ph-I (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	7.1	7.4	282	06	150	06	436	18	30	30	0.8	3.2	1.2			210 X 10^11	30		
6		Kondli Ph-II (Triveni Pvt. Ltd) ASP	25	As per DPCC limits	7.1	7.6	282	08	150	07	436	25	30	30	3	3.2	1.5			210 X 10^11	73		
7		Kondli Ph-III (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	7.1	7.6	282	08	150	07	436	25	30	30	3	3.2	1.5			210 X 10^11	73		
8		Kondli Ph-IV (Ayaappa Pvt.Ltd) ASP(IFAS)	45	As per DPCC limits	7	7.5	264	08	157	05	478	24	30	30	2.5	3	0.8			1100 X 10^11	73		
9		Chilla (HNB Engineers) C-ISBR	9	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
10		CWG (M/s Toshiba Water Soluti on Pvt. Ltd.) MBR	1	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
11	N.S.T.P.C.Pillar	Coronation Pillar Ph-II (DRA Infracom Pvt.Ltd.) ASP(IFAS)	20	As per plant design TSS:30/BOD:20/COD:250/NH4-N:50/PO4:5/ f.C:230	7	7.6	220	7	132	3	497	16	15	15	0.5	1.9	0.8			-	-		
12		Coronation Pillar Ph-III (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits	7	7.6	192	8	103	4	445	16	20	20	0.6	2.1	0.9			-	-		
13		Coronation New (L&T Construction and PASSAVANT (JV)) ASP	70	As per DPCC limits	7	7.7	200	8	121	3	223	14	19	19	0.5	2.4	0.6			-	-		
14		Narela (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits																-	-		
15	Nilothi	Nilothi Ph-I (SUBHASH INFRA PVT. LTD) ASP(IFAS)	60	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
16		Nilothi Ph-II (VEOLIA INDIA) ASP	20	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
17	Okhla	Okhla Ph-V (DIB) ASP	16	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	7.24	7.8	276	5	153	10.4				30	2	3.5	1.8	4	ND	24X10^11	28X10^2		
18		Okhla Ph-VI (SUEZ India Pvt. Ltd.) ASP	30	As per DPCC limits	7.3	7.4	202	4	350	5.7				35	0.5	3	0.7	3	ND	46X10^12	7.3		
19		Okhla New (SUEZ India Pvt. Ltd.) ASP	124	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
20		Mehrauli (DIB) E.A	5	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
21		Molar band (DIB)	0.66	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:																			

[illegible]



DATE OF ANALYSIS : 24 01 2026

DATE OF ANALYSIS : 24 01 2026

DATE OF ANALYSIS : 24.01.2026																							
S.No.	Lab	Sewage Treatment Plant (Operator) Technology	Capacity	DPCC Parameter (mg/l) (TSS:10,BOD:10, COD:50, NH4-N:5,PO4-P:2, Oil& grease :10, f.coliform: 230 MPN/100ml)	pH		TSS		BOD (3 DAYS at 27 0 C)		COD		Ammonical nitrogen		Dissolve phosphate		Oil & Grease		Fecal Coliform (72 hrs)		Remarks		
					INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET		INLET	OUTLET
					(MGD)	Parameter Limits	-	-	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l		mg/l	MPN/100ml
1	Keshopur	Keshopur Ph-I (VA-TECH WABAG LTD.) ASP	12	As per plant design TSS:30/BOD:20/COD:250/NH4-N:50/PO4:5/ f.C:230	7.18	7.28	232	6	180	5	456	18	18	1	7	2	-	-	24*10^12	75			
2		Keshopur Ph-II (Ayaappa Pvt.Ltd) ASP(IFAS)	20	As per DPCC limits	7.22	7.43	340	6	170	4	448	16	20	5	6.5	0.2	-	-	24*10^12	160			
3		Keshopur Ph-III (Ayaappa Pvt.Ltd) ASP	60	As per DPCC limits	7.29	7.58	346	6	170	5	463	20	12	4.8	5	0.1	20.64	Nil	24*10^12	210			
4		Kapashera (Triveni Pvt. Ltd) SBR	5	As per plant design TSS:10/BOD:10/f.C:1000/100ml	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
5	Kondli	Kondli Ph-I (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	7	7.5	278	8	155	5	502	23	35	1	3	1			210*10^11	36			
6		Kondli Ph-II (Triveni Pvt. Ltd) ASP	25	As per DPCC limits	7	7.5	278	9	155	6	502	27	35	2.5	3	1.2			210*10^11	91			
7		Kondli Ph-III (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	7	7.5	278	9	155	6	502	27	35	2.5	3	1.2			210*10^11	91			
8		Kondli Ph-IV (Ayaappa Pvt.Ltd) ASP(IFAS)	45	As per DPCC limits	7.1	7.6	290	7	162	4	482	19	32	3	3	0.6			1100*10^11	72			
9		Chilla (HNB Engineers) C-ISBR	9	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
10		CWG (M/s Toshiba Water Soluti on Pvt. Ltd.) MBR	1	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
11	N.S.T.P.C Pillar	Coronation Pillar Ph-II (DRA Infracom Pvt.Ltd.) ASP(IFAS)	20	As per plant design TSS:30/BOD:20/COD:250/NH4-N:50/PO4:5/ f.C:230	7.2	7.3	200	10	107	7	410	14	10	0.5	2	0.7			75x10^6	210			
12		Coronation Pillar Ph-III (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits	7.2	7.3	142	10	82	6	301	15	15	0.6	1.7	0.6			21x10^10	150			
13		Coronation New (L&T Construction and PASSAVANT (JV)) ASP	70	As per DPCC limits	7.3	7.4	238	10	124	7	492	17	20	0.5	1.5	0.9	1.8	bdl	43x10^6	460			
14		Narela (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits	7.7	7.1	180	10	101	5	367	15	24	0.5	1	0.9	1.6	BDL	93x10^6	210			
15	Nilothi	Nilothi Ph-I (SUBHASH INFRA PVT. LTD) ASP(IFAS)	60	As per DPCC limits	7.54	7.65	552	5	270	5	-	-	24.5	5.4	2.7	0.4			29x10^8	11x10^4			
16		Nilothi Ph-II (VEOLIA INDIA) ASP	20	As per DPCC limits	7.46	7.66	448	8	210	7	-	-	23.7	3.8	2.5	2			46x10^8	75			
17	Okhla	Okhla Ph-V (DJB) ASP	16	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	7.2	7.5	330	10	278	13.9	(-)	(-)	30	2.5	3	1	6	1	24X10^11	21X10^3			
18		Okhla Ph-VI (SUEZ India Pvt. Ltd.) ASP	30	As per DPCC limits	7.3	7.4	360	6	210	4.8	(-)	(-)	20	0.4	2	1.7	7	ND	15X10^12	11			
19		Okhla New (SUEZ India Pvt. Ltd.) ASP	124	As per DPCC limits	7.31	7.65	344	8	195	5.2	(-)	(-)	28	0.1	1.2	0.9	3	ND	24X10^12	15			
20		Mehrauli (DJB) E.A	5	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	7.44	8.06	224	26	265	22.5	660	80											

[illegible]

DELHI JAL BOARD

DAILY ANALYSIS REPORT OF ALL SEWAGE TREATMENT PLANT

DATE OF ANALYSIS : 25.01.2026

DATE OF ANALYSIS : 29.01.2020																							
S.No.	Lab	Sewage Treatment Plant (Operator) Technology	Capacity	DPCC Parameter (mg/l) (TSS:10,BOD:10, COD:50, NH4-N:5,PO4-P:2, Oil& grease :10, f.coliform: 230 MPN/100ml)	pH		TSS		BOD (3 DAYS at 27 0 C)		COD		Ammonical nitrogen		Dissolve phosphate		Oil & Grease		Fecal Coliform (72 hrs)		Remarks		
					INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET		INLET	OUTLET
					(MGD)	Parameter Limits		-	-	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l		mg/l	mg/l
1	Keshapur	Keshopur Ph-I (VA-TECH WABAG LTD.) ASP	12	As per plant design TSS:30/BOD:20/COD:250/NH4-N:50/PO4:5 /f.C:230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
2		Keshopur Ph-II (Ayaappa Pvt.Ltd) ASP(IFAS)	20	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
3		Keshopur Ph-III (Ayaappa Pvt.Ltd) ASP	60	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
4		Kapashera (Triveni Pvt. Ltd) SBR	5	As per plant design TSS:10/BOD:10/f.C:1000/100ml	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
5	Kondli	Kondli Ph-I (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	7	7.5	282	6	152	7	425	25	32	0.8	3.2	0.8			-	-			
6		Kondli Ph-II (Triveni Pvt. Ltd) ASP	25	As per DPCC limits	7	7.5	282	7	152	5	425	21	32	3	3.2	1.0			-	-			
7		Kondli Ph-III (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	7	7.5	282	7	152	5	425	21	32	3	3.2	1.0			-	-			
8		Kondli Ph-IV (Ayaappa Pvt.Ltd) ASP(IFAS)	45	As per DPCC limits	7.1	7.5	292	7	160	6	430	20	35	2.8	3.5	1.0			-	-			
9		Chilla (HNB Engineers) C-ISBR	9	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
10		CWG (M/s Toshiba Water Soluti on Pvt. Ltd.) MBR	1	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
11	N.S.T.P.C.Pillar	Coronation Pillar Ph-II (DRA Infracom Pvt.Ltd.) ASP(IFAS)	20	As per plant design TSS:30/BOD:20/COD:250/NH4-N:50/PO4:5 /f.C:230	7	7.6	210	9	114	4	340	19	12	0.5	2	0.8			-	-			
12		Coronation Pillar Ph-III (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits	7.1	7.5	162	10	91	5	274	21	17	0.7	1.5	0.6			-	-			
13		Coronation New (L&T Construction and PASSAVANT (JV)) ASP	70	As per DPCC limits	7	7.6	240	10	122	6	362	22	24	0.5	1.7	0.9			-	-			
14		Narela (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits															-	-			
15	Nilothi	Nilothi Ph-I (SUBHASH INFRA PVT. LTD) ASP(IFAS)	60	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
16		Nilothi Ph-II (VEOLIA INDIA) ASP	20	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
17	Okhla	Okhla Ph-V (DJB) ASP	16	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	7.39	7.61	224	8	180	8.9	(-)	(-)	25	2	2	0.8	3	ND	21X10^10	15X10^3			
18		Okhla Ph-VI (SUEZ India Pvt. Ltd.) ASP	30	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
19		Okhla New (SUEZ India Pvt. Ltd.) ASP	124	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
20		Mehrauli (DJB) E.A	5	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
21		Molar band (DJB)	0.66	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
22		Ghitorini (DJB) ASP	5	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
23		Vasant Kunj Ph-I (DJB) E.A	2.2	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-															

26		Delhi Gate Ph-II (Degramont) B & D	15	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
27		SNH drain (Degramont) B & D	2.2	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
28	Pagankalan	Phappankalan Ph-I (SUBHASH INFRA PVT. LTD) ASP	20	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
29		Phappankalan Ph-II (VA-TECH WABAG LTD.) ASP	20	As per plant design TSS:10/BOD:10/NH4-N:2/PO4:6/ F.C.:2500/100ml	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
30		Najafgarh (Ayaappa Pvt.Ltd.) ASP	5	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
31	Rithala	Rithala Ph-I (Ms WA TECH BABAG LTD.) ASP	40	As per DPCC limits	7.26	7.4	272	8	168	7	401	33	25	0.8	3.2	1	-	2	_	_
32		Rithala Ph-II (SUEZ India Pvt. Ltd.) ASP	40	As per DPCC limits	7.29	7.52	288	7	175	6	413	29	27	4	3.6	0.6	-	2	_	_
33	Rohini Sec-25	Rohini (Ms Dinesh Chandra Rohini project pvt. Ltd .) ASP(IFAS)	25	As per DPCC limits	7.13	7.27	148	9	110	7	-	28	12	4	1.2	0.8	-	-	_	_
34	Yamuna Vihar	Yamuna Vihar Ph-I (DJB) ASP	10	As per plant design TSS:30/BOD:20/COD:250/NH4-N:50/PO4:5	7.2	7.3	396	13	250	08	572	28	34	22	4	1.4			-	-
35		Yamuna Vihar Ph-II (M/s SIPL-RKC JV) ASP(IFAS)	15	As per DPCC limits	7.4	7.3	260	07	174	05	408	18	30	04	3.5	0.5			-	-
36		Yamuna Vihar Ph-III (M/s Joly & joly) ASP	25	As per plant design TSS:30/BOD:20/COD:250/NH4-N:50/PO4:5	7.4	7.6	500	46	226	25	808	96	40	27	4.6	2.1			-	-
37		Sonia Vihar (Ayaappa Pvt.Ltd.) ASP	7	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Total Treatment			799.26																	
ASP			Activated Sludge Process																	
ASP(IFAS)			Activated Sludge Process with Integrated Fixed-film Activated Sludge																	
E.A			Extended Aeration																	
FAB			Fluidized Aerobic Bed																	
B & D			Biofor and dansadeg																	
C-ISBR			Combitreat-ISBR																	
W			Waiting																	
ND			Not Detectable																	
BDL			Below Detection Limit																	
No any non compliance																				



		DPCC Parameter (mg/l) (TSS:10,BOD:10, COD:50,	pH	TSS	BOD (3 DAYS at 27 0 C)	COD	Ammonical nitrogen	Dissolve phosphate	Oil & Grease	Fecal Coliform (72 hrs)	
--	--	--	----	-----	---------------------------	-----	-----------------------	-----------------------	--------------	----------------------------	--

DATE OF ANALYSIS : 27.07.2026																					
S.No.	Lab	Sewage Treatment Plant (Operator) Technology	Capacity	DPCC Parameter (mg/l) (TSS:10,BOD:10, COD:50, NH4-N:5,PO4-P:2, Oil& grease : 10, f.coliform: 230 MPN/100ml)	pH		TSS		BOD (3 DAYS at 27 O C)		COD		Ammonical nitrogen		Dissolve phosphate		Oil & Grease		Fecal Coliform (72 hrs)		Remarks
					INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	
			(MGD)	Parameter Limits	-	-	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	
1	Keshopur	Keshopur Ph-I (VA-TECH WABAG LTD.) ASP	12	As per plant design TSS:30/BOD:20/COD:250/NH4-N:50/PO4:5 /f.C:230	7.2	7.48	339	7	180	6	496	21	20	0.5	4.8	2	18.66	Nil	24*10^11+	95	
2		Keshopur Ph-II (Ayaappa Pvt.Ltd) ASP(IFAS)	20	As per DPCC limits	7.28	7.52	335	9	175	8	486	27	26	4.9	4.6	0.5	-	-	24*10^11+	150	
3		Keshopur Ph-III (Ayaappa Pvt.Ltd) ASP	60	As per DPCC limits	7.32	7.66	333	6	180	5	479	18	22	5	4.5	0.2	-	-	24*10^11+	150	
4		Kapashera (Triveni Pvt. Ltd) SBR	5	As per plant design TSS:10/BOD:10/f.C:1000/100ml	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
5	Kondli	Kondli Ph-I (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	7.1	7.5	264	06	152	05	490	22	35	0.5	3.5	0.8			1100*10^11	73	
6		Kondli Ph-II (Triveni Pvt. Ltd) ASP	25	As per DPCC limits	7.1	7.5	264	07	152	06	490	24	35	3.5	3.5	0.8			1100*10^11	91	
7		Kondli Ph-III (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	7.1	7.5	264	07	152	06	490	24	35	3.5	3.5	0.8			1100*10^11	91	
8		Kondli Ph-IV (Ayaappa Pvt.Ltd) ASP(IFAS)	45	As per DPCC limits	7.1	7.5	270	06	160	05	488	25	35	3	3.5	0.8			1100*10^11	72	
9		Chilla (HNB Engineers) C-ISBR	9	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
10		CWG (M/s Toshiba Water Soluti on Pvt. Ltd.) MBR	1	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
11	N.S.T.P.C Pillar	Coronation Pillar Ph-II (DRA Infracom Pvt.Ltd.) ASP(IFAS)	20	As per plant design TSS:30/BOD:20/COD:250/NH4-N:50/PO4:5 /f.C:230	7	7.5	116	08	83	04	184	17	16	0.7	1.7	0.9			-	23	
12		Coronation Pillar Ph-III (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits	7.1	7.5	218	09	119	05	299	18	19	0.8	2	0.9			-	75	
13		Coronation New (L&T Construction and PASSAVANT (JV)) ASP	70	As per DPCC limits	7	7.7	244	09	130	06	317	20	22	0.5	2.5	1.3	1	bdl	-	2400	
14		Narela (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits	7.1	7.7	132	07	91	04	390	20	29	1	3	1	1.1	bdl	-	210	
15	Nilothi	Nilothi Ph-I (SUBHASH INFRA PVT. LTD) ASP(IFAS)	60	As per DPCC limits	7.51	7.7	468	4	285	5	-	-	27.5	5.4	3.2	0.3			24x10^9	24x10^4	
16		Nilothi Ph-II (VEOLIA INDIA) ASP	20	As per DPCC limits	7.31	7.63	480	6	265	4	-	-	25	4.2	2.9	0.5			46x10^8	150	
17	Okhla	Okhla Ph-V (DJB) ASP	16	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	7.69	7.73	360	19	123	18.8	(-)	(-)	30	3	2.6	1.8	5	1	46^10^10	11x10^4	
18		Okhla Ph-VI (SUEZ India Pvt. Ltd.) ASP	30	As per DPCC limits	7.43	7.87	266	5	160	2.9	(-)	(-)	35	0.2	2.5	1	4	ND	93x10^11	<1.8	
19		Okhla New (SUEZ India Pvt. Ltd.) ASP	124	As per DPCC limits	7.5	7.53	248	8	210	4	(-)	(-)	35	0.2	2	1.5	4	ND	24x10^13	7.3	
20		Mehrauli (DJB) E.A	5	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
21		Molar band (DJB)	0.66	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
22		Ghitorini (DJB) ASP	5	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
23		Vasant Kunj Ph-I (DJB) E.A	2.2	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
24		Vasant Kunj Ph-II (DJB) E.A	3	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
25		Delhi Gate Ph-I (Degramont) B & D	2.2	As per DPCC limits	7.55	7.3	232	8	144	4	(-)	(-)	20	0.2	2	0.3	4	ND	75x10^11	43x10^3	

26		Delhi Gate Ph-II (Degramont) B & D	15	As per DPCC limits	7.51	7.16	228	10	185	10	(-)	(-)	20	12	2.2	0.5	3	ND	24x10^12	<1.8	
27		SNH drain (Degramont) B & D	2.2	As per DPCC limits	7.4	7.21	446	8	253	13.5	(-)	(-)	25	8	3.2	1.8	4	ND	24x10^13	11x10^3	
28	Pagankalan	Phappankalan Ph-I (SUBHASH INFRA PVT. LTD) ASP	20	As per DPCC limits	7.46	7.62	596	9	355	6	684	34	40	7	3.3	ND	-	-	24*10^13+	75	
29		Phappankalan Ph-II (VA-TECH WABAG LTD.) ASP	20	As per plant design TSS:10/BOD:10/NH4-N:2/PO4:6/ F.C.:2500/100ml	7.46	7.87	596	7	355	4	684	23	40	13	3.3	1.2	-	-	24*10^13+	210	
30		Najafgarh (Ayaappa Pvt.Ltd.) ASP	5	As per DPCC limits	7.24	7.47	262	5	170	4	453	13	38	0.4	3.2	0.8	-	-	24*10^11+	75	
31	Rithala	Rithala Ph-I (Ms WA TECH BABAG LTD.) ASP	40	As per DPCC limits	7.25	7.39	248	10	155	8	380	42	18	0.4	3	0.5	-	2	24x10^12	95	
32		Rithala Ph-II (SUEZ India Pvt. Ltd.) ASP	40	As per DPCC limits	7.32	7.54	336	9	195	7	472	38	18	2	3.2	0.4	-	2	24x10^12	93	
33	Rohini Sec-25	Rohini (Ms Dinesh Chandra Rohini project pvt. Ltd.) ASP(IFAS)	25	As per DPCC limits	6.82	7.23	336	10	202	8	-	32	38	1.5	6.5	0.5	-	-	24x10^11	210	
34	Yamuna Vihar	Yamuna Vihar Ph-I (DJB) ASP	10	As per plant design TSS:30/BOD:20/COD:250/NH4-N:50/PO4:5	7.4	7.5	376	16	237	13	587	33	32	23	3.8	1.6	5.2	2	-	-	
35		Yamuna Vihar Ph-II (M/s SIPL-RKC JV) ASP(IFAS)	15	As per DPCC limits	7.4	7.6	224	7	196	6	367	15	26	5	3.2	0.6	-	-	-	-	
36		Yamuna Vihar Ph-III (M/s Joly & joly) ASP	25	As per plant design TSS:30/BOD:20/COD:250/NH4-N:50/PO4:5	7.4	7.6	492	39	308	28	839	80	34	24	4	1.8	-	-	-	-	
37		Sonia Vihar (Ayaappa Pvt.Ltd.) ASP	7	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
Total Treatment			799.26																		
ASP			Activated Sludge Process																		
ASP(IFAS)			Activated Sludge Process with Integrated Fixed-film Activated Sludge																		
E.A			Extended Aeration																		
FAB			Fluidized Aerobic Bed																		
B & D			Biofor and dansadeg																		
C-ISBR			Combitreat-ISBR																		
W			Waiting																		
ND			Not Detectable																		
BDL			Bellow Detection Limit																		
No any non compliance																					

DELHI JAL BOARD

DAILY ANALYSIS REPORT OF ALL SEWAGE TREATMENT PLANT

DATE OF ANALYSIS : 29.01.2026

DATE OF ANALYSIS : 29.01.2026																							
S.No.	Lab	Sewage Treatment Plant (Operator) Technology	Capacity	DPCC Parameter (mg/l) (TSS:10,BOD:10,COD:50, NH4-N:5,P04-P:2, Oil& grease : 10, f.coliform: 230 MPN/100ml)	pH		TSS		BOD (3 DAYS at 27 0 C)		COD		Ammonical nitrogen		Dissolve phosphate		Oil & Grease		Fecal Coliform (72 hrs)		Remarks		
					INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET		INLET	OUTLET
					(MGD)	Parameter Limits	-	-	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l		mg/l	mg/l
1	Keshopur	Keshopur Ph-I (VA-TECH WABAG LTD.) ASP	12	As per plant design TSS:30/BOD:20/COD:250/NH4-N:50/P04:5 /f.C:230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
2		Keshopur Ph-II (Ayaappa Pvt.Ltd) ASP(IFAS)	20	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
3		Keshopur Ph-III (Ayaappa Pvt.Ltd) ASP	60	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
4		Kapashera (Triveni Pvt. Ltd) SBR	5	As per plant design TSS:10/BOD:10/f.C:1000/100ml	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
5	Kondli	Kondli Ph-I (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	7.1	7.5	262	06	155	05	464	19	35	0.8	3	0.5			210×10 ¹¹	36			
6		Kondli Ph-II (Triveni Pvt. Ltd) ASP	25	As per DPCC limits	7.1	7.6	262	08	155	07	464	22	35	2	3	0.5			210×10 ¹¹	73			
7		Kondli Ph-III (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	7.1	7.6	262	08	155	07	464	22	35	2	3	0.5			210×10 ¹¹	73			
8		Kondli Ph-IV (Ayaappa Pvt.Ltd) ASP(IFAS)	45	As per DPCC limits	7	7.5	278	08	165	07	516	27	38	2.5	3.2	0.8			290×10 ¹¹	36			
9		Chilla (HNB Engineers) C-ISBR	9	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
10		CWG (M/s Toshiba Water Soluti on Pvt. Ltd.) MBR	1	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
11	N.S.T.P.C Pillar	Coronation Pillar Ph-II (DRA Infracom Pvt.Ltd.) ASP(IFAS)	20	As per plant design TSS:30/BOD:20/COD:250/NH4-N:50/P04:5 /f.C:230	7	7.6	250	6	156	3	324	14	15	0.7	1.6	0.9	-	-	-	-			
12		Coronation Pillar Ph-III (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits	7.1	7.5	178	7	102	5	249	14	17	0.8	1.9	0.8			-	-			
13		Coronation New (L&T Construction and PASSAVANT (JV)) ASP	70	As per DPCC limits	7.1	7.6	202	8	122	4	301	17	24	0.6	2.4	1	1.8	bdl	-	-			
14		Narela (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits	7	7.6	204	10	128	6	434	15	30	0.9	3.5	0.9	1.8	0.3	-	-			
15	Nilothi	Nilothi Ph-I (SUBHASH INFRA PVT. LTD) ASP(IFAS)	60	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
16		Nilothi Ph-II (VEOLIA INDIA) ASP	20	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
17	Okhla	Okhla Ph-V (DJB) ASP	16	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/P04:5	7.2	7.8	206	17	250	8	(-)	(-)	25	0.6	1.5	2.5	4	ND					
18		Okhla Ph-VI (SUEZ India Pvt. Ltd.) ASP	30	As per DPCC limits	7.3	7.6	224	6	290	6	(-)	(-)	25	ND	2.2	1	5	ND					
19		Okhla New (SUEZ India Pvt. Ltd.) ASP	124	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
20		Mehrauli (DJB) E.A	5	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/P04:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
21		Molar band (DJB)	0.66	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/P04:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
22		Ghitorini (DJB) ASP	5	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/P04:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
23		Vasant Kunj Ph-I (DJB) E.A	2.2	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/P04:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
24		Vasant Kunj Ph-II (DJB) E.A	3	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/P04:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
25		Delhi Gate Ph-I (Degramont) B & D	2.2	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		

[illegible]