

DELHI JAL BOARD

DAILY ANALYSIS REPORT OF ALL SEWAGE TREATMENT PLANT

DATE OF ANALYSIS : 01.11.2025

Sl. No.	S.No.	Lab	Plant	Sewage Treatment Plant (Operator) Technology	Capacity	DPCC Parameter (mg/l) (TSS:10,BOD:10, COD:50, NH4-N:5,PO4-P:2, f.coliform: 230 MPN/100ml)	pH		TSS		BOD (3 DAYS at 27.0 C)		COD		Ammonical nitrogen		Dissolve phosphate		Oil & Grease		Fecal Coliform (72 hrs)		Remarks		
							INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET		INLET	OUTLET
							(MGD)	Parameter Limits					-	-	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l		mg/l	mg/l
	1	Keshapur	Keshapur Ph-I	Keshapur Ph-I (VA-TECH WABAG LTD.) ASP	12	As per plant design TSS:30/BOD:20/COD:250/NH4-N:50/PO4:5/ f.C:230	7.28	7.44	344	4	155	4	420	21	19	2	3.8	1.5	-	-	24*10^12	150			
	2		Keshapur Ph-II	Keshapur Ph-II (Ayaappa Pvt.Ltd) ASP(IFAS)	20	As per DPCC limits	7.27	7.53	265	3	150	3	408	26	22	4.5	3.1	1.6	-	-	-	-			
	3		Keshapur Ph-III	Keshapur Ph-III (Ayaappa Pvt.Ltd) ASP	60	As per DPCC limits	7.38	7.61	270	5	155	4	418	22	21	4.2	3.2	1.8	-	-	-	-			
	4		Kapashera	Kapashera (Triveni Pvt. Ltd) SBR	5	As per plant design TSS:10/BOD:10/f.C:1000/100ml	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	5	Kondli	Kondli Ph-I	Kondli Ph-I (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	7.1	7.6	212	8	135	6	331	14	30	0.6	2.8	0.8			-	-			
	6		Kondli Ph-II	Kondli Ph-II (Triveni Pvt. Ltd) ASP	25	As per DPCC limits	7.1	7.5	212	9	135	5	331	16	30	1	2.8	0.8			-	-			
	7		Kondli Ph-III	Kondli Ph-III (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	7.1	7.5	212	9	135	5	331	16	30	1	2.8	0.8			-	-			
	8		Kondli Ph-IV	Kondli Ph-IV (Ayaappa Pvt.Ltd) ASP(IFAS)	45	As per DPCC limits	7	7.5	256	8	148	7	340	14	32	0.8	2.8	0.5			-	-			
	9		Chilla	Chilla (HNB Engineers) C-ISBR	9	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	10		CWG	CWG (M/s Toshiba Water Soluti on Pvt. Ltd.) MBR	1	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	11	N.S.T.P.C.Pillar	Coronation Pillar Ph-II	Coronation Pillar Ph-II (DRA Infracom Pvt.Ltd.) ASP(IFAS)	20	As per plant design TSS:30/BOD:20/COD:250/NH4-N:50/PO4:5/ f.C:230	7.1	7.6	82	8	54	4	194	16	12	0.4	1.7	0.5	-	-	23x10^6	93			
	12		Coronation Pillar Ph-III	Coronation Pillar Ph-III (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits	7	7.5	88	7	57	4	189	19	20	0.6	1.9	0.7	-	-	91x10^6	75			
	13		Coronation New	Coronation New (L&T Construction and PASSAVANT (JV)) ASP	70	As per DPCC limits	6.9	7.5	272	10	198	5	408	17	27	0.5	3.3	0.9	1.5	bdl	23x10^7	23			
	14		Narela	Narela (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits	7.2	7.6	62	7	40	4	170	15	29	0.5	3.7	1	1	bdl	36x10^5	23			
	15	Nilothi	Nilothi Ph-I	Nilothi Ph-I (SUBHASH INFRA PVT. LTD) ASP(IFAS)	60	As per DPCC limits	7.55	7.59	340	4	183	3	-	-	18.7	8	3	0.5			-	-			
	16		Nilothi Ph-II	Nilothi Ph-II (VEOLIA INDIA) ASP	20	As per DPCC limits	7.41	7.46	268	5	150	4	-	-	17.5	4.8	3	1			-	-			
	17	Okhla	Okhla Ph-V	Okhla Ph-V (DJB) ASP	16	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	7.2	7.4	150	7	188	9	(-)	(-)	30	4.2	2.4	0.8	5	Nil	43X10^9	15x10^2			
	18		Okhla Ph-VI	Okhla Ph-VI (SUEZ India Pvt. Ltd.) ASP	30	As per DPCC limits	7.2	7.4	420	4	208	3.2	(-)	(-)	28	0.1	2.2	0.6	6	Nil	93x10^12	460			
	19		Okhla New	Okhla New (SUEZ India Pvt. Ltd.) ASP	124	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	20		Mehrauli	Mehrauli (DJB) E.A	5	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	21		Molar band	Molar band (DJB)	0.66	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	22		Ghitorini	Ghitorini (DJB) ASP	5	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	23		Vasant Kunj Ph-I	Vasant Kunj Ph-I (DJB) E.A	2.2	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	24		Vasant Kunj Ph-II	Vasant Kunj Ph-II (DJB) E.A	3	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	25		Delhi Gate Ph-I	Delhi Gate Ph-I (Degramont) B & D	2.2	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	26		Delhi Gate Ph-II	Delhi Gate Ph-II (Degramont) B & D	15	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	27		SNH drain	SNH drain (Degramont) B & D	2.2	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	28	Phappankalan Ph-I	Phappankalan Ph-I (SUBHASH INFRA PVT. LTD) ASP	20	As per DPCC limits	7.29	7.3	338	4	-	-	540	25	35	0.4	4.2	1	-	-	28*10^11	210				

[illegible]

DATE OF ANALYSIS : 02.11.2025

	S.No.	Lab	Plant	Sewage Treatment Plant (Operator) Technology	Capacity	DPCC Parameter (mg/l) (TSS:10,BOD:10, COD:50, NH4-N:5,PO4-P:2, Oil& grease : 10, f.coliform: 230 MPN/100ml)	pH		TSS		BOD (3 DAYS at 27 0 C)		COD		Ammonical nitrogen		Dissolve phosphate		Oil & Grease		Fecal Coliform (72 hrs)		Remarks		
							INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET		INLET	OUTLET
							(MGD)	Parameter Limits					-	-	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l		mg/l	mg/l
	1	Keshopur	Keshopur Ph-I	Keshopur Ph-I (VA-TECH WABAG LTD.) ASP	12	As per plant design TSS:30/BOD:20/COD:250/NH4-N:50/PO4:5/ f.C:230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	lab close on sunday		
	2		Keshopur Ph-II	Keshopur Ph-II (Ayaappa Pvt.Ltd) ASP(IFAS)	20	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	lab close on sunday		
	3		Keshopur Ph-III	Keshopur Ph-III (Ayaappa Pvt.Ltd) ASP	60	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	lab close on sunday		
	4		Kapashera	Kapashera (Triveni Pvt. Ltd) SBR	5	As per plant design TSS:10/BOD:10/f.C:1000/100ml	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	lab close on sunday		
	5	Kondli	Kondli Ph-I	Kondli Ph-I (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	7	7.5	223	8	140	7	354	12	30	0.5	2.8	1			-	-			
	6		Kondli Ph-II	Kondli Ph-II (Triveni Pvt. Ltd) ASP	25	As per DPCC limits	7	7.4	223	8	140	8	354	16	30	1.2	2.8	1.5			-	-			
	7		Kondli Ph-III	Kondli Ph-III (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	7	7.4	223	8	140	8	354	16	30	1.2	2.8	1.5			-	-			
	8		Kondli Ph-IV	Kondli Ph-IV (Ayaappa Pvt.Ltd) ASP(IFAS)	45	As per DPCC limits	6.9	7.5	256	7	145	6	402	15	32	1	2.8	1.2			-	-			
	9		Chilla	Chilla (HNB Engineers) C-ISBR	9	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	10		CWG	CWG (M/s Toshiba Water Soluti on Pvt. Ltd.) MBR	1	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	11	N.S.T.P.C.Rillar	Coronation Pillar Ph-II	Coronation Pillar Ph-II (DRA Infracom Pvt.Ltd.) ASP(IFAS)	20	As per plant design TSS:30/BOD:20/COD:250/NH4-N:50/PO4:5/ f.C:230	7	7.6	86	6	47	3	112	14	15	0.5	1.5	0.6	-	-	-	-			
	12		Coronation Pillar Ph-III	Coronation Pillar Ph-III (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits	6.9	7.5	112	8	53	5	180	17	21	0.5	1.8	0.7	-	-	-	-			
	13		Coronation New	Coronation New (L&T Construction and PASSAVANT (JV)) ASP	70	As per DPCC limits	6.9	7.6	270	8	131	5	390	19	28	0.5	3	0.9	-	-	-	-			
	14		Narela	Narela (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits													-	-	-	-	lab close on sunday		
	15	Nilothi	Nilothi Ph-I	Nilothi Ph-I (SUBHASH INFRA PVT. LTD) ASP(IFAS)	60	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	lab close on sunday			
	16		Nilothi Ph-II	Nilothi Ph-II (VEOLIA INDIA) ASP	20	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	lab close on sunday		
	17	Okhla	Okhla Ph-V	Okhla Ph-V (DJB) ASP	16	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	7.3	7.6	224	5	188	11.6			28	3.3	2.1	0.5	4	ND	93X10^9	15X10^3			
	18		Okhla Ph-VI	Okhla Ph-VI (SUEZ India Pvt. Ltd.) ASP	30	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	19		Okhla New	Okhla New (SUEZ India Pvt. Ltd.) ASP	124	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	20		Mehrauli	Mehraulil (DJB) E.A	5	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	21		Molar band	Molar band (DJB)	0.66	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	22		Ghitorini	Ghitorini (DJB) ASP	5	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	23		Vasant Kunj Ph-I	Vasant Kunj Ph-I (DJB) E.A	2.2	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	24		Vasant Kunj Ph-II	Vasant Kunj Ph-II (DJB) E.A	3	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	25		Delhi Gate Ph-I	Delhi Gate Ph-I (Degramont) B & D	2.2	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	26		Delhi Gate Ph-II	Delhi Gate Ph-II (Degramont) B & D	15	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	27		SNH drain	SNH drain (Degramont) B & D	2.2	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	28	Phappankalan Ph-I	Phappankalan Ph-I (SUBHASH INFRA PVT. LTD) ASP	20	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	lab close on sunday			

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]



DELHI JAL BOARD

DAILY ANALYSIS REPORT OF ALL SEWAGE TREATMENT PLANT

DATE OF ANALYSIS : 05.11.2025

S.No.	Lab	Plant	Sewage Treatment Plant (Operator) Technology	Capacity (MGD)	DPCC Parameter (mg/l) (TSS:10/BOD:10, COD:50, NH4-N:5,PO4-P:2, Oil & grease : 10, f.coliform: 230 MPN/100ml)	pH		TSS		BOD (3 DAYS at 27.0 C)		COD		Ammonical nitrogen		Dissolve phosphate		Oil & Grease		Fecal Coliform (72 hrs)		Remarks
						INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	
						-	-	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	MPN/100ml	MPN/100ml	
1	Keshopur	Keshopur Ph-I	Keshopur Ph-I (VA-TECH WABAG LTD.) ASP	12	As per plant design TSS:30/BOD:20/COD:250/NH4-N:50/PO4-S: f.C:230	7.28	7.68	261	2	165	2	448	21	22	1.2	3	0.8	-	-	24*10^11	210	
2		Keshopur Ph-II	Keshopur Ph-II (Ayaappa Pvt.Ltd) ASP(IFAS)	20	As per DPCC limits	7.42	7.88	446	4	190	3	515	24	23	4.8	4	2	-	-	-	-	
3		Keshopur Ph-III	Keshopur Ph-III (Ayaappa Pvt.Ltd) ASP	60	As per DPCC limits	7.36	7.98	469	7	195	6	530	26	21	4.6	2.5	1	-	-	-	-	
4		Kapashera	Kapashera (Triveni Pvt. Ltd) SBR	5	As per plant design TSS:10/BOD:10/f.C:1000/100ml	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
5	Kondli	Kondli Ph-I	Kondli Ph-I (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	290X10^11	36	
6		Kondli Ph-II	Kondli Ph-II (Triveni Pvt. Ltd) ASP	25	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	290X10^11	72	
7		Kondli Ph-III	Kondli Ph-III (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	290X10^11	72	
8		Kondli Ph-IV	Kondli Ph-IV (Ayaappa Pvt.Ltd) ASP(IFAS)	45	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	210X10^11	91	
9	N.S.T.C.Pillar	Chilla	Chilla (HNB Engineers) C-IBSR	9	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
10		CWG	CWG (M/s Toshiba Water Soluti on Pvt. Ltd.) MBR	1	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
11		Coronation Pillar Ph-II	Coronation Pillar Ph-II (DRA Infracom Pvt.Ltd.) ASP(IFAS)	20	As per plant design TSS:30/BOD:20/COD:250/NH4-N:50/PO4-S: f.C:230	7	7.5	114	6	50	3	127	14	26	0.5	2.8	1	1.2	bdl	-	-	
12		Coronation Pillar Ph-III	Coronation Pillar Ph-III (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits	7	7.6	86	4	42	2	102	11	17	0.5	2.3	1	1	bdl	-	-	
13	Nilothi	Coronation New	Coronation New (L&T Construction and PASSAVANT (JV)) ASP	70	As per DPCC limits	6.9	7.6	82	8	41	5	136	17	30	0.5	3.4	1.5	-	-	-	-	
14		Narela	Narela (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits															-	-	
15		Nilothi Ph-I	Nilothi Ph-I (SUBHASH INFRA PVT. LTD) ASP(IFAS)	60	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
16		Nilothi Ph-II	Nilothi Ph-II (VEOLIA INDIA) ASP	20	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
17	Okhla	Okhla Ph-V	Okhla Ph-V (DIB) ASP	16	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4-S:	7.2	7.4	470	9	90	3.4	725	63	38	2	2.5	1.8	5	ND	7.3X10^9	93X10^2	
18		Okhla Ph-VI	Okhla Ph-VI (SUEZ India Pvt. Ltd.) ASP	30	As per DPCC limits	7.2	7.4	238	6	83	5.7	356	51	38	4.4	2.6	2.4	4	ND	24X10^13	460	
19		Okhla New	Okhla New (SUEZ India Pvt. Ltd.) ASP	124	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
20		Mehrauli	Mehrauli (DIB) E.A	5	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4-S	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
21	Pappankalan	Molar band	Molar band (DIB) ASP	0.66	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4-S	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
22		Ghitorini	Ghitorini (DIB) ASP	5	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4-S	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
23		Vasant Kunj Ph-I	Vasant Kunj Ph-I (DIB) E.A	2.2	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4-S	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
24		Vasant Kunj Ph-II	Vasant Kunj Ph-II (DIB) E.A	3	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4-S	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
25	Rithala	Delhi Gate Ph-I	Delhi Gate Ph-I (Degramont) B & D	2.2	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
26		Delhi Gate Ph-II	Delhi Gate Ph-II (Degramont) B & D	15	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
27		SNH drain	SNH drain (Degramont) B & D	2.2	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
28		Phappankalan Ph-I	Phappankalan Ph-I (SUBHASH INFRA PVT. LTD) ASP	20	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
29	Najafgarh	Phappankalan Ph-II	Phappankalan Ph-II (VA-TECH WABAG LTD.) ASP	20	As per plant design TSS:10/BOD:10/NH4-N:2/PO4-S: f.C:2500/100ml	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
30		Najafgarh	Najafgarh (Ayaappa Pvt.Ltd.) ASP	5	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
31		Rithala Ph-I	Rithala Ph-I (Ms WA TECH BABAG LTD.) ASP	40	As per DPCC limits	7.43	7.67	252	8	160	7	392	32	21	2.9	3.6	1.1	-	1	24x10^12	93	
32		Rithala Ph-II	Rithala Ph-II (SUEZ India Pvt. Ltd.) ASP	40	As per DPCC limits	7.47	7.8	312	6	185	5	456	24	24	4	3.4	0.5	-	1	24x10^12	75	

[illegible]



DATE OF ANALYSIS : 06.11.2025

Sl. No.	S.No.	Lab	Plant	Sewage Treatment Plant (Operator) Technology	Capacity	DPPC Parameter (mg/l) (TSS:10,BOD:10, COD:50, NH4-N:5,PO4-P:2, Oil& grease : 10, f.coliform: 230 MPN/100ml)	pH		TSS		BOD (3 DAYS at 27 0 C)		COD		Ammonical nitrogen		Dissolve phosphate		Oil & Grease		Fecal Coliform (72 hrs)		Remarks		
							INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET		INLET	OUTLET
							(MGD)	Parameter Limits					-	-	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l		mg/l	mg/l
	1	Keshopur	Keshopur Ph-I	Keshopur Ph-I (VA-TECH WABAG LTD.) ASP	12	As per plant design TSS:30/BOD:20/COD:250/NH4-N:50/PO4-5/ f.C:230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	2		Keshopur Ph-II	Keshopur Ph-II (Ayaappa Pvt.Ltd) ASP(IFAS)	20	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	3		Keshopur Ph-III	Keshopur Ph-III (Ayaappa Pvt.Ltd) ASP	60	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	4		Kapashera	Kapashera (Triveni Pvt. Ltd) SBR	5	As per plant design TSS:10/BOD:10/f.C:1000/100ml	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
	5	Kondli	Kondli Ph-I	Kondli Ph-I (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	7.1	7.6	294	8	150	8	448	14	28	0.5	2.5	1			210 x 10^11	73			
	6		Kondli Ph-II	Kondli Ph-II (Triveni Pvt. Ltd) ASP	25	As per DPCC limits	7.1	7.6	294	8	150	7	448	17	28	0.5	2.5	1.2			210 x 10^11	36			
	7		Kondli Ph-III	Kondli Ph-III (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	7.1	7.6	294	8	150	7	448	17	28	0.5	2.5	1.2			210 x 10^11	36			
	8		Kondli Ph-IV	Kondli Ph-IV (Ayaappa Pvt.Ltd) ASP(IFAS)	45	As per DPCC limits	7	7.5	302	9	148	8	462	15	30	0.6	2.8	0.8			290 x 10^11	36			
	9		Chilla	Chilla (HNB Engineers) C-ISBR	9	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	10		CWG	CWG (M/s Toshiba Water Soluti on Pvt. Ltd.) MBR	1	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	11	N.S.T.P.C.Pillar	Coronation Pillar Ph-II	Coronation Pillar Ph-II (DRA Infracom Pvt.Ltd.) ASP(IFAS)	20	As per plant design TSS:30/BOD:20/COD:250/NH4-N:50/PO4-5/ f.C:230	7	7.5	118	6	61	4	130	12	21	0.5	2.5	1	-	-	-	-			
	12		Coronation Pillar Ph-III	Coronation Pillar Ph-III (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits	7.1	7.6	80	5	37	3	104	15	12	0.5	2.3	1	-	-	-	-			
	13		Coronation New	Coronation New (L&T Construction and PASSAVANT (JV)) ASP	70	As per DPCC limits	7	7.5	134	7	72	4	188	16	20	0.5	2.7	1.8	1.2	bdl	-	-			
	14		Narela	Narela (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits	7.1	7.6	64	5	36	3	326	20	23	0.5	2	0.8	1	bdl	-	-			
	15	Nilothi	Nilothi Ph-I	Nilothi Ph-I (SUBHASH INFRA PVT. LTD) ASP(IFAS)	60	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	16		Nilothi Ph-II	Nilothi Ph-II (VEOLIA INDIA) ASP	20	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	17	Okhla	Okhla Ph-V	Okhla Ph-V (DJB) ASP	16	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4-5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	18		Okhla Ph-VI	Okhla Ph-VI (SUEZ India Pvt. Ltd.) ASP	30	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	19		Okhla New	Okhla New (SUEZ India Pvt. Ltd.) ASP	124	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	20		Mehrauli	Mehrauli (DJB) E.A	5	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4-5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	21		Molar band	Molar band (DJB)	0.66	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4-5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	22		Ghitorini	Ghitorini (DJB) ASP	5	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4-5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	23		Vasant Kunj Ph-I	Vasant Kunj Ph-I (DJB) E.A	2.2	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4-5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	24		Vasant Kunj Ph-II	Vasant Kunj Ph-II (DJB) E.A	3	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4-5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	25		Delhi Gate Ph-I	Delhi Gate Ph-I (Degramont) B & D	2.2	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
	26		Delhi Gate Ph-II	Delhi Gate Ph-II (Degramont) B & D	15	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	27		SNH drain	SNH drain (Degramont) B & D	2.2	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
	28	Phappankalan Ph-I	Phappankalan Ph-I (SUBHASH INFRA PVT. LTD) ASP	20	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			

	ASP	Activated Sludge Process
	ASP(IFAS)	Activated Sludge Process with Integrated Fixed-film Activated Sludge
	E.A	Extended Aeration
	FAB	Fluidized Aerobic Bed
	B & D	Bioror and dansadeg
	C-ISBR	Combreat-ISBR
	W	Waiting
	ND	Not Detectable
	BDL	Bellow Detection Limit



	DPCC Parameter
--	----------------

S.No.	Lab	Plant	Sewage Treatment Plant (Operator) Technology	Capacity	DPC Parameter (mg/l) (TSS:10,BOD:10, COD:50, NH4-N:5,PO4-P:2, Oil& grease : 10, f.coliform: 230 MPN/100ml)	pH		TSS		BOD (3 DAYS at 27 0 C)		COD		Ammonical nitrogen		Dissolve phosphate		Oil & Grease		Fecal Coliform (72 hrs)		Remarks		
						INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET		INLET	OUTLET
						(MGD)	Parameter Limits	-	-	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l		mg/l	MPN/100ml
1	Keshopur	Keshopur Ph-I	Keshopur Ph-I (VA-TECH WABAG LTD.) ASP	12	As per plant design TSS:30/BOD:20/COD:250/NH4-N:50/PO4:5/ f.C:230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
2		Keshopur Ph-II	Keshopur Ph-II (Ayaappa Pvt.Ltd) ASP(IFAS)	20	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
3		Keshopur Ph-III	Keshopur Ph-III (Ayaappa Pvt.Ltd) ASP	60	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
4		Kapashera	Kapashera (Triveni Pvt. Ltd) SBR	5	As per plant design TSS:10/BOD:10/f.C:1000/100ml	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
5	Kondli	Kondli Ph-I	Kondli Ph-I (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	7	7.6	260	6	140	5	375	9	30	0.8	2.8	0.6			210X10^11	110			
6		Kondli Ph-II	Kondli Ph-II (Triveni Pvt. Ltd) ASP	25	As per DPCC limits	7	7.5	260	9	140	8	375	16	30	1	2.8	1.0			210X10^11	73			
7		Kondli Ph-III	Kondli Ph-III (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	7	7.5	260	9	140	8	375	16	30	1	2.8	1.0			210X10^11	73			
8		Kondli Ph-IV	Kondli Ph-IV (Ayaappa Pvt.Ltd) ASP(IFAS)	45	As per DPCC limits	7.1	7.5	278	8	155	6	402	18	32	0.6	2.8	0.8			210X10^11	200			
9		Chilla	Chilla (HNB Engineers) C-ISBR	9	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
10		CWG	CWG (M/s Toshiba Water Soluti on Pvt. Ltd.) MBR	1	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
11	N.S.T.P.C.Pillar	Coronation Pillar Ph-II	Coronation Pillar Ph-II (DRA Infracom Pvt.Ltd.) ASP(IFAS)	20	As per plant design TSS:30/BOD:20/COD:250/NH4-N:50/PO4:5/ f.C:230	7	7.6	204	8	118	5	218	15	23	0.5	2.7	1	1.98	bdl	-	-			
12		Coronation Pillar Ph-III	Coronation Pillar Ph-III (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits	7.1	7.6	176	8	77	4	204	17	15	0.6	2.5	1	1.04	bdl	-	-			
13		Coronation New	Coronation New (L&T Construction and PASSAVANT (JV)) ASP	70	As per DPCC limits	7	7.6	116	10	55	5	145	20	19	0.5	2.4	1.8			-	-			
14		Narela	Narela (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits															-	-			
15	Nilothi	Nilothi Ph-I	Nilothi Ph-I (SUBHASH INFRA PVT. LTD) ASP(IFAS)	60	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
16		Nilothi Ph-II	Nilothi Ph-II (VEOLIA INDIA) ASP	20	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
17	Okhla	Okhla Ph-V	Okhla Ph-V (DJB) ASP	16	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
18		Okhla Ph-VI	Okhla Ph-VI (SUEZ India Pvt. Ltd.) ASP	30	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
19		Okhla New	Okhla New (SUEZ India Pvt. Ltd.) ASP	124	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
20		Mehrauli	Mehrauli (DJB) E.A	5	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
21		Molar band	Molar band (DJB)	0.66	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
22		Ghitorini	Ghitorini (DJB) ASP	5	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
23		Vasant Kunj Ph-I	Vasant Kunj Ph-I (DJB) E.A	2.2	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
24		Vasant Kunj Ph-II	Vasant Kunj Ph-II (DJB) E.A	3	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
25		Delhi Gate Ph-I	Delhi Gate Ph-I (Degramont) B & D	2.2	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
26		Delhi Gate Ph-II	Delhi Gate Ph-II (Degramont) B & D	15	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
27	SNH drain	SNH drain (Degramont) B & D	2.2	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
28	Phappankalan Ph-I	Phappankalan Ph-I (SUBHASH INFRA PVT. LTD) ASP	20	As per DPCC limits	7.38	7.34	378	2	-	-	507	28	38	0.3	4.5	1	-	-	29×10^14	95				

[illegible]



DAILY ANALYSIS REPORT OF ALL SEWAGE TREATMENT PLANT

DATE OF ANALYSIS : 06.11.2025																									
	S.No.	Lab	Plant	Sewage Treatment Plant (Operator) Technology	Capacity	DPCC Parameter (mg/l) (TSS:10,BOD:10, COD:50, NH4-N:5,PO4-P:2, Oil& grease : 10, f.coliform: 230 MPN/100ml)	pH		TSS		BOD (3 DAYS at 27 0 C)		COD		Ammonical nitrogen		Dissolve phosphate		Oil & Grease		Fecal Coliform (72 hrs)		Remarks		
							INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET		INLET	OUTLET
							(MGD)	Parameter Limits					-	-	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l		mg/l	mg/l
	1	Keshopur	Keshopur Ph-I	Keshopur Ph-I (VA-TECH WABAG LTD.) ASP	12	As per plant design TSS:30/BOD:20/COD:250/NH4-N:50/PO4:5/ f.C:230	7.3	7.42	344	4	165	4	446	24	27	4.8	3.5	2	-	-	24*10^12	290			
	2		Keshopur Ph-II	Keshopur Ph-II (Ayaappa Pvt.Ltd) ASP(IFAS)	20	As per DPCC limits	7.28	7.41	265	3	155	3	420	21	25	5	3.3	1.8	-	-	-	-			
	3		Keshopur Ph-III	Keshopur Ph-III (Ayaappa Pvt.Ltd) ASP	60	As per DPCC limits	7.3	7.51	270	5	165	4	480	26	24	4.9	3.2	0.7	-	-	-	-			
	4		Kapashera	Kapashera (Triveni Pvt. Ltd) SBR	5	As per plant design TSS:10/BOD:10/f.C:1000/100ml	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	5	Kondli	Kondli Ph-I	Kondli Ph-I (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	7.1	7.5	302	8	143	6	496	13	32	0.5	3	0.8			150x10^11	36			
	6		Kondli Ph-II	Kondli Ph-II (Triveni Pvt. Ltd) ASP	25	As per DPCC limits	7.1	7.6	302	9	143	7	496	17	32	0.8	3	0.8			150x10^11	36			
	7		Kondli Ph-III	Kondli Ph-III (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	7.1	7.6	302	9	143	7	496	17	32	0.8	3	0.8			150x10^11	36			
	8		Kondli Ph-IV	Kondli Ph-IV (Ayaappa Pvt.Ltd) ASP(IFAS)	45	As per DPCC limits	7.1	7.6	310	9	153	8	502	18	36	0.5	3	0.8			210x10^11	93			
	9		Chilla	Chilla (HNB Engineers) C-ISBR	9	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	10		CWG	CWG (M/s Toshiba Water Soluti on Pvt. Ltd.) MBR	1	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	11	N.S.T.P.C Pillar	Coronation Pillar Ph-II	Coronation Pillar Ph-II (DRA Infracom Pvt.Ltd.) ASP(IFAS)	20	As per plant design TSS:30/BOD:20/COD:250/NH4-N:50/PO4:5/ f.C:230	7	7.5	200	7	123	3	272	16	22	0.5	2.6	1	-	-	46x10^6	210			
	12		Coronation Pillar Ph-III	Coronation Pillar Ph-III (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits	7.1	7.5	81	3	234	14	16	0.6	16	0.6	2.4	1	-	-	11x10^7	15			
	13		Coronation New	Coronation New (L&T Construction and PASSAVANT (JV)) ASP	70	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	24x10^6	210			
	14		Narela	Narela (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits	7.1	7.5	68	8	37	4	97	17	25	0.5	3	0.7	1	bdl	73x10^6	150			
	15	Nilothi	Nilothi Ph-I	Nilothi Ph-I (SUBHASH INFRA PVT. LTD) ASP(IFAS)	60	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	16		Nilothi Ph-II	Nilothi Ph-II (VEOLIA INDIA) ASP	20	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	17	Okhla	Okhla Ph-V	Okhla Ph-V (DJB) ASP	16	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	7.2	7.4	310	6	288	5.5	-	-	32.5	5	2.3	2	6	ND	11x10^11	93x10^2			
	18		Okhla Ph-VI	Okhla Ph-VI (SUEZ India Pvt. Ltd.) ASP	30	As per DPCC limits	7.2	7.4	270	6	245	2.9	-	-	30	0.5	2.5	1.8	5	ND	21x10^12	15			
	19		Okhla New	Okhla New (SUEZ India Pvt. Ltd.) ASP	124	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	20		Mehrauli	Mehrauli (DJB) E.A	5	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	21		Molar band	Molar band (DJB)	0.66	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	22		Ghitorini	Ghitorini (DJB) ASP	5	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	23		Vasant Kunj Ph-I	Vasant Kunj Ph-I (DJB) E.A	2.2	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	24		Vasant Kunj Ph-II	Vasant Kunj Ph-II (DJB) E.A	3	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	25		Delhi Gate Ph-I	Delhi Gate Ph-I (Degramont) B & D	2.2	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	26		Delhi Gate Ph-II	Delhi Gate Ph-II (Degramont) B & D	15	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	27		SNH drain	SNH drain (Degramont) B & D	2.2	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	28	Phappankalan Ph-I	Phappankalan Ph-I (SUBHASH INFRA PVT. LTD) ASP	20	As per DPCC limits	7.33	7.38	296	4	-	-	520	24	40	0.2	4.3	0.5	-	-	-	-				

[illegible]



DATE OF ANALYSIS : 09.11.2025		
-------------------------------	--	--

	S.No.	Lab	Plant	Sewage Treatment Plant (Operator) Technology	Capacity	DPPC Parameter (mg/l) (TSS-10,BOD-10, COD-50, NH4-N:5,P04-P:2, Oil& grease : 10, f.coliform: 230 MPN/100ml)	pH		TSS		BOD (3 DAYS at 27 0 C)		COD		Ammonical nitrogen		Dissolve phosphate		Oil & Grease		Fecal Coliform (72 hrs)		Remarks		
							INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET		INLET	OUTLET
							(MGD)	Parameter Limits					-	-	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l		mg/l	mg/l
	1	Keshapur	Keshapur Ph-I	Keshapur Ph-I (VA-TECH WABAG LTD.) ASP	12	As per plant design TSS:30/BOD:20/COD:250/NH4-N:50/PO4:5/ f.C:230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	Lab closed on sunday		
	2		Keshapur Ph-II	Keshapur Ph-II (Ayaappa Pvt.Ltd) ASP(IFAS)	20	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	Lab closed on sunday		
	3		Keshapur Ph-III	Keshapur Ph-III (Ayaappa Pvt.Ltd) ASP	60	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	Lab closed on sunday		
	4		Kapashera	Kapashera (Triveni Pvt. Ltd) SBR	5	As per plant design TSS:10/BOD:10/f.C:1000/100ml	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	Lab closed on sunday	
	5	Kondli	Kondli Ph-I	Kondli Ph-I (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	7	7.4	292	7	138	5	428	14	32	1.5	3.2	1			-	-			
	6		Kondli Ph-II	Kondli Ph-II (Triveni Pvt. Ltd) ASP	25	As per DPCC limits	7	7.5	292	8	138	7	428	16	32	2	3.2	1.5			-	-			
	7		Kondli Ph-III	Kondli Ph-III (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	7	7.5	292	8	138	7	428	16	32	2	3.2	1.5			-	-			
	8		Kondli Ph-IV	Kondli Ph-IV (Ayaappa Pvt.Ltd) ASP(IFAS)	45	As per DPCC limits	7.1	7.5	302	7	143	6	462	17	35	1.8	3.5	1.2			-	-			
	9		Chilla	Chilla (HNB Engineers) C-ISBR	9	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	10		CWG	CWG (M/s Toshiba Water Soluti on Pvt. Ltd.) MBR	1	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	11	N.S.T.P.C.Pillar	Coronation Pillar Ph-II	Coronation Pillar Ph-II (DRA Infracom Pvt.Ltd.) ASP(IFAS)	20	As per plant design TSS:30/BOD:20/COD:250/NH4-N:50/PO4:5/ f.C:230	7	7.5	208	6	127	3	272	14	24	0.5	2.6	0.9	-	-	-	-			
	12		Coronation Pillar Ph-III	Coronation Pillar Ph-III (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits	7	7.5	174	7	82	4	218	16	19	0.6	2.2	1	-	-	-	-			
	13		Coronation New	Coronation New (L&I Construction and PASSAVANT (JV)) ASP	70	As per DPCC limits	7.1	7.6	132	6	73	3	198	13	21	0.5	2.9	1.2	-	-	-	-			
	14		Narela	Narela (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits															-	-			
	15	Nilothi	Nilothi Ph-I	Nilothi Ph-I (SUBHASH INFRA PVT. LTD) ASP(IFAS)	60	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	Lab closed on sunday		
	16		Nilothi Ph-II	Nilothi Ph-II (VEOLIA INDIA) ASP	20	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	Lab closed on sunday		
	17	Okhla	Okhla Ph-V	Okhla Ph-V (DJIB) ASP	16	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	7.2	7.4	330	5	200	5.9	-	-	38	3.5	2.4	0.8	5	ND	75X10^9	93X10^2			
	18		Okhla Ph-VI	Okhla Ph-VI (SUEZ India Pvt. Ltd.) ASP	30	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	19		Okhla New	Okhla New (SUEZ India Pvt. Ltd.) ASP	124	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	20		MehraulI	MehraulI (DJIB) E.A	5	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	21		Molar band	Molar band (DJIB)	0.66	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	22		Ghitorini	Ghitorini (DJIB) ASP	5	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	23		Vasant Kunj Ph-I	Vasant Kunj Ph-I (DJIB) E.A	2.2	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	24		Vasant Kunj Ph-II	Vasant Kunj Ph-II (DJIB) E.A	3	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	25		Delhi Gate Ph-I	Delhi Gate Ph-I (Degramont) B & D	2.2	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
	26		Delhi Gate Ph-II	Delhi Gate Ph-II (Degramont) B & D	15	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
	27		SNH drain	SNH drain (Degramont) B & D	2.2	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
	28	Phappankalan Ph-I	Phappankalan Ph-I (SUBHASH INFRA PVT. LTD) ASP	20	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			

[illegible]



DELHI JAL BOARD

DAILY ANALYSIS REPORT OF ALL SEWAGE TREATMENT PLANT

DATE OF ANALYSIS : 10.11.2025

S.No.	Lab	Plant	Sewage Treatment Plant (Operator) Technology	Capacity (MGD)	DPCC Parameter (mg/l) (TSS:10/BOD:10, COD:50, NH4-N:5,PO4-P:2, Oil & grease : 10, f.coliform: 230 MPN/100ml)	pH		TSS		BOD (3 DAYS at 27.0 C)		COD		Ammonical nitrogen		Dissolve phosphate		Oil & Grease		Fecal Coliform (72 hrs)		Remarks
						INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	
						-	-	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	MPN/100ml	MPN/100ml	
1	Keshopur	Keshopur Ph-I	Keshopur Ph-I (VA-TECH WABAG LTD.) ASP	12	As per plant design TSS:30/BOD:20/COD:250/NH4-N:50/PO4-S: f.C:230	7.28	7.44	344	4	165	3	440	24	18	9	1.7	1.2	-	-	-	-	
2		Keshopur Ph-II	Keshopur Ph-II (Ayaappa Pvt.Ltd) ASP(IFAS)	20	As per DPCC limits	7.27	7.53	265	3	155	3	420	26	28	9	3.3	2	-	-	24x10^13+	460	
3		Keshopur Ph-III	Keshopur Ph-III (Ayaappa Pvt.Ltd) ASP	60	As per DPCC limits	7.38	7.61	270	5	160	4	432	24	30	8	3.5	1	-	-	-	-	
4		Kapashera	Kapashera (Triveni Pvt. Ltd) SBR	5	As per plant design TSS:10/BOD:10/f.C:1000/100ml	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
5	Kondli	Kondli Ph-I	Kondli Ph-I (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	7.1	7.6	306	8	143	7	454	17	30	1.5	2.8	0.8			290X10^11	73	
6		Kondli Ph-II	Kondli Ph-II (Triveni Pvt. Ltd) ASP	25	As per DPCC limits	7.1	7.5	306	9	143	5	454	20	30	2	2.8	1.2	9.1	Nil	290X10^11	91	
7		Kondli Ph-III	Kondli Ph-III (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	7.1	7.5	306	9	143	5	454	20	30	2	2.8	1.2	9.1	Nil	290X10^11	91	
8		Kondli Ph-IV	Kondli Ph-IV (Ayaappa Pvt.Ltd) ASP(IFAS)	45	As per DPCC limits	7	7.5	314	9	142	7	492	18	32	1.5	3	0.8	9.4	0.5	210X10^11	150	
9	N.S.T.C.Pillar	Chilla	Chilla (HNB Engineers) C-ISBR	9	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
10		CWG	CWG (M/s Toshiba Water Soluti on Pvt. Ltd.) MBR	1	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
11		Coronation Pillar Ph-II	Coronation Pillar Ph-II (DRA Infracom Pvt.Ltd.) ASP(IFAS)	20	As per plant design TSS:30/BOD:20/COD:250/NH4-N:50/PO4-S: f.C:230	7	7.5	118	8	63	4	230	19	24	0.6	2.8	0.8	1.5	bdl	-	-	
12		Coronation Pillar Ph-III	Coronation Pillar Ph-III (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits	7.1	7.5	80	8	40	4	138	17	18	0.5	2.5	0.9	1.2	bdl	-	-	
13	Nilethi	Coronation New	Coronation New (L&T Construction and PASSAVANT (JV)) ASP	70	As per DPCC limits	7.1	7.5	76	7	37	4	120	15	22	0.6	2.4	1.2			-	-	
14		Narela	Narela (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
15		Nilethi Ph-I	Nilethi Ph-I (SUBHASH INFRA PVT. LTD) ASP(IFAS)	60	As per DPCC limits	7.5	7.54	298	6	163	8	-	-	22.5	7.5	3	0.5			-	-	
16		Nilethi Ph-II	Nilethi Ph-II (VEOLIA INDIA) ASP	20	As per DPCC limits	7.42	7.71	226	9	130	4	-	-	18.7	4.7	2.5	0.6			-	-	
17	Okhla	Okhla Ph-V	Okhla Ph-V (DIB) ASP	16	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4-S:	7.2	7.5	274	6	223	4.8			34	1.5	2.8	1.8	5	ND	75x10^9	21x10^2	
18		Okhla Ph-VI	Okhla Ph-VI (SUEZ India Pvt. Ltd.) ASP	30	As per DPCC limits	7.1	7.6	208	4	180	1.5			38	0.2	2.6	2	4	ND	43x10^11	35	
19		Okhla New	Okhla New (SUEZ India Pvt. Ltd.) ASP	124	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
20		Mehrauli	Mehrauli (DIB) E.A	5	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4-S	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
21	Phappankalan	Molar band	Molar band (DIB) ASP	0.66	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4-S	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
22		Ghitorini	Ghitorini (DIB) ASP	5	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4-S	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
23		Vasant Kunj Ph-I	Vasant Kunj Ph-I (DIB) E.A	2.2	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4-S	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
24		Vasant Kunj Ph-II	Vasant Kunj Ph-II (DIB) E.A	3	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4-S	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
25	Rithala	Delhi Gate Ph-I	Delhi Gate Ph-I (Degramont) B & D	2.2	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
26		Delhi Gate Ph-II	Delhi Gate Ph-II (Degramont) B & D	15	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
27		SNH drain	SNH drain (Degramont) B & D	2.2	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
28		Phappankalan Ph-I	Phappankalan Ph-I (SUBHASH INFRA PVT. LTD) ASP	20	As per DPCC limits	7.32	7.45	493	3	-	-	520	22	35	0.2	3.2	0.8	-	-	-	-	
29	Najafgarh	Phappankalan Ph-II	Phappankalan Ph-II (VA-TECH WABAG LTD.) ASP	20	As per plant design TSS:10/BOD:10/NH4-N:2/PO4-S: f.C:2500/100ml	7.32	7.78	493	4	-	-	520	26	35	18	3.2	1	-	-	-	-	
30		Najafgarh	Najafgarh (Ayaappa Pvt.Ltd.) ASP	5	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
31		Rithala Ph-I	Rithala Ph-I (Ms WA TECH BABAG LTD.) ASP	40	As per DPCC limits	7.46	7.68	256	09	160	08	392	36	21	1.4	3	0.7	10	02	24x10^12	75	
32		Rithala Ph-II	Rithala Ph-II (SUEZ India Pvt. Ltd.) ASP	40	As per DPCC limits	7.51	7.86	380	05	202	04	512	20	26	4	3.4	0.3	9	1	24x10^12	95	

[illegible]

[illegible]

29	Phappankalan	Phappankalan Ph-II (VA-TECH WABAG LTD.) ASP	20	As per plant design TSS:10/BOD:10/NH4-N:2/PO4:6/ F.C.:2500/100ml	7.29	7.88	338	2	-	-	540	31	35	18	4.2	1	-	-	28*10^11	1600
30		Najafgarh (Ayaappa Pvt.Ltd.) ASP	5	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
31	Rithala	Rithala Ph-I (Ms WA TECH BABAG LTD.) ASP	40	As per DPCC limits	7.33	7.41	328	7	190	6	464	28	26	0.9	3.2	0.8	-	1	24x10^11	93
32		Rithala Ph-II (SUEZ India Pvt. Ltd.) ASP	40	As per DPCC limits	7.43	7.69	3420	6	187	5	456	24	27	0.5	3.4	0.6	-	1	24x10^11	120
33	Bahadurpur	Rohini (Ms Dinesh Chandra Rohini project pvt. Ltd.) ASP(IFAS)	25	As per DPCC limits	7.5	7.2	144	10	123	8	312	40	22	0.3	5	0.8	-	-	-	-
34	Yamuna Vihar	Yamuna Vihar Ph-I (DJB) ASP	10	As per plant design TSS:30/BOD:20/COD:250/NH4-N:50/PO4:5	7.7	7.8	324	12	205	09	524	25	38	20	4.8	0.8	-	-	14x10^8	35x10^5
35		Yamuna Vihar Ph-II (M/s SIPL-RKC JV) ASP(IFAS)	15	As per DPCC limits	7.6	7.3	260	06	159	03	428	14	35	04	3.8	0.4	-	-	42x10^8	27x10^2
36		Yamuna Vihar Ph-III (M/s Joly & joly) ASP	25	As per plant design TSS:30/BOD:20/COD:250/NH4-N:50/PO4:5	7.5	7.6	432	24	240	17	712	52	42	24	4	1.8	-	-	34x10^9	20x10^5
37		Sonia Vihar (Ayaappa Pvt.Ltd.) ASP	7	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Total Treatment			799.26																	
ASP			Activated Sludge Process																	
ASP(IFAS)			Activated Sludge Process with Integrated Fixed-film Activated Sludge																	
E.A			Extended Aeration																	
FAB			Fluidized Aerobic Bed																	
B & D			Biofor and dansadeg																	
C-ISBR			Combitreat-ISBR																	
W			Waiting																	
ND			Not Detectable																	
BDL			Below Detection Limit																	
No any non compliance																				

DELHI JAL BOARD

DAILY ANALYSIS REPORT OF ALL SEWAGE TREATMENT PLANT

DATE OF ANALYSIS : 12.11.2025

[illegible]

[illegible]



DATE OF ANALYSIS : 13.11.2025

				DATE OF ANALYSIS : 10/11/2020				DPPC Parameter (mg/l) (TSS:10,BOD:10, COD:50, NH4-N:5,PO4-P:2, Oil& grease : 10, f.coliform: 230 MPN/100ml)		pH		TSS		BOD (3 DAYS at 27 0 C)		COD		Ammonical nitrogen		Dissolve phosphate		Oil & Grease		Fecal Coliform (72 hrs)		Remarks	
	S.No.	Lab	Plant	Sewage Treatment Plant (Operator) Technology	Capacity				INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET		OUTLET
					(MGD)	Parameter Limits			-	-	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	MPN/100ml		MPN/100ml
	1	Keshapur	Keshapur Ph-I	Keshapur Ph-I (VA-TECH WABAG LTD.) ASP	12	As per plant design TSS:30/BOD:20/COD:250/NH4-N:50/PO4:5/ f.C:230			-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
	2		Keshapur Ph-II	Keshapur Ph-II (Ayaappa Pvt.Ltd) ASP(IFAS)	20	As per DPCC limits			-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
	3		Keshapur Ph-III	Keshapur Ph-III (Ayaappa Pvt.Ltd) ASP	60	As per DPCC limits			-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
	4		Kapashera	Kapashera (Triveni Pvt. Ltd) SBR	5	As per plant design TSS:10/BOD:10/f.C:1000/100ml			-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
	5	Kondli	Kondli Ph-I	Kondli Ph-I (Triveni Pvt. Ltd) ASP	10	As per DPCC limits			7	7.5	274	8	135	6	355	18	30	1.2	2.8	0.8					210×10^11	36	
	6		Kondli Ph-II	Kondli Ph-II (Triveni Pvt. Ltd) ASP	25	As per DPCC limits			7	7.6	274	8	135	7	355	19	30	1.8	2.8	1.2					210×10^11	73	
	7		Kondli Ph-III	Kondli Ph-III (Triveni Pvt. Ltd) ASP	10	As per DPCC limits			7	7.6	274	8	135	7	355	19	30	1.8	2.8	1.2					210×10^11	73	
	8		Kondli Ph-IV	Kondli Ph-IV (Ayaappa Pvt.Ltd) ASP(IFAS)	45	As per DPCC limits			7.1	7.6	288	9	148	8	402	18	35	1.2	3.2	1.0					1100×10^11	200	
	9		Chilla	Chilla (HNB Engineers) C-ISBR	9	As per DPCC limits			-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
	10		CWG	CWG (M/s Toshiba Water Soluti on Pvt. Ltd.) MBR	1	As per DPCC limits			-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
	11	N.S.T.P.C.Pillar	Coronation Pillar Ph-II	Coronation Pillar Ph-II (DRA Infracom Pvt.Ltd.) ASP(IFAS)	20	As per plant design TSS:30/BOD:20/COD:250/NH4-N:50/PO4:5/ f.C:230			-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
	12		Coronation Pillar Ph-III	Coronation Pillar Ph-III (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits			-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
	13		Coronation New	Coronation New (L&T Construction and PASSAVANT (JV)) ASP	70	As per DPCC limits			-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
	14		Narela	Narela (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits			-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
	15	Nilothi	Nilothi Ph-I	Nilothi Ph-I (SUBHASH INFRA PVT. LTD) ASP(IFAS)	60	As per DPCC limits			-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
	16		Nilothi Ph-II	Nilothi Ph-II (VEOLIA INDIA) ASP	20	As per DPCC limits			-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
	17	Okhla	Okhla Ph-V	Okhla Ph-V (DJB) ASP	16	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5			-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
	18		Okhla Ph-VI	Okhla Ph-VI (SUEZ India Pvt. Ltd.) ASP	30	As per DPCC limits			-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
	19		Okhla New	Okhla New (SUEZ India Pvt. Ltd.) ASP	124	As per DPCC limits			-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
	20		Mehrauli	Mehrauli (DJB) E.A	5	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5			-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
	21		Molar band	Molar band (DJB)	0.66	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5			-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
	22		Ghitorini	Ghitorini (DJB) ASP	5	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5			-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
	23		Vasant Kunj Ph-I	Vasant Kunj Ph-I (DJB) E.A	2.2	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5			-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
	24		Vasant Kunj Ph-II	Vasant Kunj Ph-II (DJB) E.A	3	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5			-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
	25		Delhi Gate Ph-I	Delhi Gate Ph-I (Degramont) B & D	2.2	As per DPCC limits			-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
	26		Delhi Gate Ph-II	Delhi Gate Ph-II (Degramont) B & D	15	As per DPCC limits			-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
	27	SNH drain	SNH drain (Degramont) B & D	2.2	As per DPCC limits			-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
	28	Phappankalan Ph-I	Phappankalan Ph-I (SUBHASH INFRA PVT. LTD) ASP	20	As per DPCC limits			-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		

[illegible]

DATE OF ANALYSIS : 14.11.2025

Sl. No.	S.No.	Lab	Plant	Sewage Treatment Plant (Operator) Technology	Capacity	DPCC Parameter (mg/l) (TSS:10,BOD:10, COD:50, NH4-N:5,PO4-P:2, Oil& grease : 10, f.coliform: 230 MPN/100ml)	pH		TSS		BOD (3 DAYS at 27 0 C)		COD		Ammonical nitrogen		Dissolve phosphate		Oil & Grease		Fecal Coliform (72 hrs)		Remarks		
							INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET		INLET	OUTLET
							(MGD)	Parameter Limits					-	-	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l		mg/l	mg/l
	1	Keshopur	Keshopur Ph-I	Keshopur Ph-I (VA-TECH WABAG LTD.) ASP	12	As per plant design TSS:30/BOD:20/COD:250/NH4-N:50/PO4:5/ f.C:230	7.2	7.4	282	5	165	3	448	22	19	2	3	2	-----	-----	-	-			
	2		Keshopur Ph-II	Keshopur Ph-II (Ayaappa Pvt.Ltd) ASP(IFAS)	20	As per DPCC limits	7.2	7.5	280	5	170	04	460	24	22	4.2	3.5	1	----	-----	-	-			
	3		Keshopur Ph-III	Keshopur Ph-III (Ayaappa Pvt.Ltd) ASP	60	As per DPCC limits	7.3	7.6	363	3	190	3	514	21	21	4	3.2	0.9	----	-----	11*10^13	210			
	4		Kapashera	Kapashera (Triveni Pvt. Ltd) SBR	5	As per plant design TSS:10/BOD:10/f.C:1000/100ml	7.24	8.23	276	10	270	4	620	19	50	0.1	5.5	ND	-	-	-	-			
	5	Kondli	Kondli Ph-I	Kondli Ph-I (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	7.1	7.6	298	7	145	5	386	13	32	0.8	3	0.8			201X10^11	73			
	6		Kondli Ph-II	Kondli Ph-II (Triveni Pvt. Ltd) ASP	25	As per DPCC limits	7.1	7.6	298	9	145	7	386	17	32	1.2	3	1.0			201X10^11	36			
	7		Kondli Ph-III	Kondli Ph-III (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	7.1	7.6	298	9	145	7	386	17	32	1.2	3	1.0			201X10^11	36			
	8		Kondli Ph-IV	Kondli Ph-IV (Ayaappa Pvt.Ltd) ASP(IFAS)	45	As per DPCC limits	7	7.5	310	8	152	6	414	18	35	1	2.8	0.6			201X10^11	73			
	9		Chilla	Chilla (HNB Engineers) C-ISBR	9	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	10		CWG	CWG (M/s Toshiba Water Soluti on Pvt. Ltd.) MBR	1	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	11	N.S.T.P.C.Pillar	Coronation Pillar Ph-II	Coronation Pillar Ph-II (DRA Infracom Pvt.Ltd.) ASP(IFAS)	20	As per plant design TSS:30/BOD:20/COD:250/NH4-N:50/PO4:5/ f.C:230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-				
	12		Coronation Pillar Ph-III	Coronation Pillar Ph-III (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	13		Coronation New	Coronation New (L&T Construction and PASSAVANT (JV)) ASP	70	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	14		Narela	Narela (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	15	Nilothi	Nilothi Ph-I	Nilothi Ph-I (SUBHASH INFRA PVT. LTD) ASP(IFAS)	60	As per DPCC limits	7.51	7.6	326	8	175	6	-	-	17	12	2.8	1			-	-			
	16		Nilothi Ph-II	Nilothi Ph-II (VEOLIA INDIA) ASP	20	As per DPCC limits	7.49	7.57	278	7	153	5	-	-	18	4.1	2.6	1.5			-	-			
	17	Okhla	Okhla Ph-V	Okhla Ph-V (DJB) ASP	16	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	7.1	7.6	140	9	218	8.6	411	16	28	8	3	2.3	4	ND	21X10^10	23X10^2			
	18		Okhla Ph-VI	Okhla Ph-VI (SUEZ India Pvt. Ltd.) ASP	30	As per DPCC limits	7.2	7.6	330	5	238	3.4	1300	23	45	0.35	3.3	2.2	5	ND	20X10^12	210			
	19		Okhla New	Okhla New (SUEZ India Pvt. Ltd.) ASP	124	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	20		Mehrauli	Mehrauli (DJB) E.A	5	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	21		Molar band	Molar band (DJB)	0.66	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	22		Ghitorini	Ghitorini (DJB) ASP	5	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	23		Vasant Kunj Ph-I	Vasant Kunj Ph-I (DJB) E.A	2.2	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	24		Vasant Kunj Ph-II	Vasant Kunj Ph-II (DJB) E.A	3	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	25		Delhi Gate Ph-I	Delhi Gate Ph-I (Degramont) B & D	2.2	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	26		Delhi Gate Ph-II	Delhi Gate Ph-II (Degramont) B & D	15	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	27		SNH drain	SNH drain (Degramont) B & D	2.2	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	28	Phappankalan Ph-I	Phappankalan Ph-I (SUBHASH INFRA PVT. LTD) ASP	20	As per DPCC limits	7.37	7.31	434	15	280	3	720	22	40	3.5	4.7	2.5	-	-	-	-				

[illegible]



DELHI JAL BOARD

DAILY ANALYSIS REPORT OF ALL SEWAGE TREATMENT PLANT

DATE OF ANALYSIS : 15.11.2025

S.No.	Lab	Plant	Sewage Treatment Plant (Operator) Technology	Capacity (MGD)	DPCC Parameter (mg/l) (TSS:10/BOD:10, COD:50, NH4-N:5,PO4-P:2, Oil & grease : 10, f.coliform: 230 MPN/100ml)	pH		TSS		BOD (3 DAYS at 27.0 C)		COD		Ammonical nitrogen		Dissolve phosphate		Oil & Grease		Fecal Coliform (72 hrs)		Remarks
						INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	
						-	-	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	MPN/100ml	MPN/100ml	
1	Keshopur	Keshopur Ph-I	Keshopur Ph-I (VA-TECH WABAG LTD.) ASP	12	As per plant design TSS:30/BOD:20/COD:250/NH4-N:50/PO4-S: f.C:230	7.3	7.6	282	5	170	4	460	24	20	2.5	3	2	----	----	24*10^13	290	
2		Keshopur Ph-II	Keshopur Ph-II (Ayaappa Pvt.Ltd) ASP(IFAS)	20	As per DPCC limits	7.4	7.8	381	6	180	5	490	26	22	3	4	1.5	----	----	-	-	
3		Keshopur Ph-III	Keshopur Ph-III (Ayaappa Pvt.Ltd) ASP	60	As per DPCC limits	7.3	7.9	450	5	195	4	535	28	24	5	4	1	----	----	-	-	
4		Kapashera	Kapashera (Triveni Pvt. Ltd) SBR	5	As per plant design TSS:10/BOD:10/f.C:1000/100ml	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
5	Kondli	Kondli Ph-I	Kondli Ph-I (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	7	7.6	314	8	140	7	408	15	30	1.2	2.6	0.8			210*10^11	73	
6		Kondli Ph-II	Kondli Ph-II (Triveni Pvt. Ltd) ASP	25	As per DPCC limits	7	7.6	314	9	140	6	408	20	30	1.5	2.6	1.0			210*10^11	73	
7		Kondli Ph-III	Kondli Ph-III (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	7	7.6	314	9	140	6	408	20	30	1.5	2.6	1.0			210*10^11	73	
8		Kondli Ph-IV	Kondli Ph-IV (Ayaappa Pvt.Ltd) ASP(IFAS)	45	As per DPCC limits	7.1	7.5	322	9	147	7	428	18	35	1.2	2.8	0.6			290*10^11	72	
9	Chilla	Chilla	Chilla (HNB Engineers) C-ISBR	9	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
10		CWG	CWG (M/s Toshiba Water Soluti on Pvt. Ltd.) MBR	1	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
11		Coronation Pillar Ph-II	Coronation Pillar Ph-II (DRA Infracom Pvt.Ltd.) ASP(IFAS)	20	As per plant design TSS:30/BOD:20/COD:250/NH4-N:50/PO4-S: f.C:230	7	7.5	100	07	51	04	200	14	21	0.6	1.7	0.7			-	15	
12	N.S.T.C.Pillar	Coronation Pillar Ph-III	Coronation Pillar Ph-III (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits	7	7.6	94	06	43	03	184	12	18	0.7	1.9	0.9			-	23	
13		Coronation New	Coronation New (L&T Construction and PASSAVANT (JV)) ASP	70	As per DPCC limits	6.9	7.6	88	06	37	03	179	15	23	0.9	1.7	1	1.06	BDL	-	23	
14		Narela	Narela (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits	6.9	7.6	164	07	71	04	304	19	30	0.5	1.9	0.9	1.89	BDL	-	43	
15	Nilothi	Nilothi Ph-I	Nilothi Ph-I (SUBHASH INFRA PVT. LTD) ASP(IFAS)	60	As per DPCC limits	7.52	7.58	310	3	170	4	-	-	20	6	3	0.4			21x10^8	2400+	
16		Nilothi Ph-II	Nilothi Ph-II (VEOLIA INDIA) ASP	20	As per DPCC limits	7.47	7.57	198	4	120	5	-	-	19	4	2.9	0.3			21x10^8	200	
17	Okhla	Okhla Ph-V	Okhla Ph-V (DIB) ASP	16	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4-S	7.41	7.64	146	8	198	9.8	(-)	(-)	35	7	2.2	1.9	5	ND	93x10^9	15x10^3	
18		Okhla Ph-VI	Okhla Ph-VI (SUEZ India Pvt. Ltd.) ASP	30	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
19		Okhla New	Okhla New (SUEZ India Pvt. Ltd.) ASP	124	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
20		Mehrauli	Mehrauli (DIB) E.A	5	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4-S	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
21		Molar band	Molar band (DIB)	0.66	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4-S	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
22		Ghitorini	Ghitorini (DIB) ASP	5	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4-S	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
23		Vasant Kunj Ph-I	Vasant Kunj Ph-I (DIB) E.A	2.2	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4-S	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
24	Pappankalan	Vasant Kunj Ph-II	Vasant Kunj Ph-II (DIB) E.A	3	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4-S	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
25		Delhi Gate Ph-I	Delhi Gate Ph-I (Degramont) B & D	2.2	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
26		Delhi Gate Ph-II	Delhi Gate Ph-II (Degramont) B & D	15	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
27		SNH drain	SNH drain (Degramont) B & D	2.2	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
28		Phappankalan Ph-I	Phappankalan Ph-I (SUBHASH INFRA PVT. LTD) ASP	20	As per DPCC limits	7.37	7.24	282	4	170	3	500	19	45	3	4	1.5	-	-	-	-	
29		Phappankalan Ph-II	Phappankalan Ph-II (VA-TECH WABAG LTD.) ASP	20	As per plant design TSS:10/BOD:10/NH4-N:2/PO4-S: f.C:2500/100ml	7.37	7.51	282	4	170	3	500	22	45	12	4	1	-	-	-	-	
30		Najafgarh	Najafgarh (Ayaappa Pvt.Ltd.) ASP	5	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
31	Rithala	Rithala Ph-I	Rithala Ph-I (Ms WA TECH BABAG LTD.) ASP	40	As per DPCC limits	7.43	7.65	204	10	145	9	344	40	21	0.6	3.2	0.8	-	1	11x10^12	95	
32		Rithala Ph-II	Rithala Ph-II (SUEZ India Pvt. Ltd.) ASP	40	As per DPCC limits	7.51	7.83	324	7	193	6	464	28	19	3	2.8	0.6	-	1	24x10^12	210	

[illegible]



DPCC Parameter

S.No.	Lab	Plant	Sewage Treatment Plant (Operator) Technology	Capacity	DPC Parameter (mg/l) (TSS:10,BOD:10, COD:50, NH4-N:5,PO4-P:2, Oil& grease : 10, f.coliform: 230 MPN/100ml)	pH		TSS		BOD (3 DAYS at 27 0 C)		COD		Ammonical nitrogen		Dissolve phosphate		Oil & Grease		Fecal Coliform (72 hrs)		Remarks		
						INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET		INLET	OUTLET
						(MGD)	Parameter Limits	-	-	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l		mg/l	MPN/100ml
1	Keshopur	Keshopur Ph-I	Keshopur Ph-I (VA-TECH WABAG LTD.) ASP	12	As per plant design TSS:30/BOD:20/COD:250/NH4-N:50/PO4:5/ f.C:230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
2		Keshopur Ph-II	Keshopur Ph-II (Ayaappa Pvt.Ltd) ASP(IFAS)	20	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
3		Keshopur Ph-III	Keshopur Ph-III (Ayaappa Pvt.Ltd) ASP	60	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
4		Kapashera	Kapashera (Triveni Pvt. Ltd) SBR	5	As per plant design TSS:10/BOD:10/f.C:1000/100ml	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
5	Kondli	Kondli Ph-I	Kondli Ph-I (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	7.2	7.5	282	9	132	8	390	15	32	1.5	3.5	0.8			210X10^11	91			
6		Kondli Ph-II	Kondli Ph-II (Triveni Pvt. Ltd) ASP	25	As per DPCC limits	7.2	7.6	282	8	132	6	390	19	32	1.8	3.5	1.5			210X10^11	36			
7		Kondli Ph-III	Kondli Ph-III (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	7.2	7.6	282	8	132	6	390	19	32	1.8	3.5	1.5			210X10^11	36			
8		Kondli Ph-IV	Kondli Ph-IV (Ayaappa Pvt.Ltd) ASP(IFAS)	45	As per DPCC limits	7.1	7.4	312	8	143	8	450	16	35	1.2	3.6	1.0			290X10^11	10			
9		Chilla	Chilla (HNB Engineers) C-ISBR	9	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
10		CWG	CWG (M/s Toshiba Water Soluti on Pvt. Ltd.) MBR	1	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
11	N.S.T.P.C.Pillar	Coronation Pillar Ph-II	Coronation Pillar Ph-II (DRA Infracom Pvt.Ltd.) ASP(IFAS)	20	As per plant design TSS:30/BOD:20/COD:250/NH4-N:50/PO4:5/ f.C:230	7	7.5	110	8	61	5	190	19	20	0.5	1.8	0.8			-	-			
12		Coronation Pillar Ph-III	Coronation Pillar Ph-III (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits	7.1	7.5	98	7	37	4	140	14	17	0.5	1.5	0.7			-	-			
13		Coronation New	Coronation New (L&T Construction and PASSAVANT (JV)) ASP	70	As per DPCC limits	6.9	7.5	150	7	70	4	240	16	24	0.5	2.1	1	1.46	Bdl	-	-			
14		Narela	Narela (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits															-	-			
15	Nilothi	Nilothi Ph-I	Nilothi Ph-I (SUBHASH INFRA PVT. LTD) ASP(IFAS)	60	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
16		Nilothi Ph-II	Nilothi Ph-II (VEOLIA INDIA) ASP	20	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
17	Okhla	Okhla Ph-V	Okhla Ph-V (DJB) ASP	16	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	7.44	7.68	144	8	138	12.2	-	-	35	12	2.3	1.6	6	ND	24x10^10	15x10^3			
18		Okhla Ph-VI	Okhla Ph-VI (SUEZ India Pvt. Ltd.) ASP	30	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
19		Okhla New	Okhla New (SUEZ India Pvt. Ltd.) ASP	124	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
20		Mehrauli	Mehrauli (DJB) E.A	5	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
21		Molar band	Molar band (DJB)	0.66	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
22		Ghitorini	Ghitorini (DJB) ASP	5	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
23		Vasant Kunj Ph-I	Vasant Kunj Ph-I (DJB) E.A	2.2	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
24		Vasant Kunj Ph-II	Vasant Kunj Ph-II (DJB) E.A	3	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
25		Delhi Gate Ph-I	Delhi Gate Ph-I (Degramont) B & D	2.2	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
26		Delhi Gate Ph-II	Delhi Gate Ph-II (Degramont) B & D	15	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
27		SNH drain	SNH drain (Degramont) B & D	2.2	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
28	Phappankalan Ph-I	Phappankalan Ph-I (SUBHASH INFRA PVT. LTD) ASP	20	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-				

[illegible]

		DELHI JAL BOARD																						
		DAILY ANALYSIS REPORT OF ALL SEWAGE TREATMENT PLANT																						
		DATE OF ANALYSIS : 17.11.2025																						
S.No.	Lab	Plant	Sewage Treatment Plant (Operator) Technology	Capacity	DPCC Parameter (mg/l) (TSS:10,BOD:10, COD:50, NH4-N:5,PO4-P:2, Oil& grease : 10, f.coliform: 230 MPN/100ml)	pH		TSS		BOD (3 DAYS at 27 0 C)		COD		Ammonical nitrogen		Dissolve phosphate		Oil & Grease		Fecal Coliform (72 hrs)		Remarks		
						INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET		INLET	OUTLET
						(MGD)	Parameter Limits	-	-	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l		mg/l	MPN/100ml
1	Keshopur	Keshopur Ph-I	Keshopur Ph-I (VA-TECH WABAG LTD.) ASP	12	As per plant design TSS:30/BOD:20/COD:250/NH4-N:50/PO4:5/ f.C:230	7.38	7.56	344	04	160	03	435	24	22	4	3.5	2	-	-	-	-			
2		Keshopur Ph-II	Keshopur Ph-II (Ayaappa Pvt.Ltd) ASP(IFAS)	20	As per DPCC limits	7.24	7.48	265	3	155	2	420	25	20	5	4.2	1	-	-	24*10^14	210			
3		Keshopur Ph-III	Keshopur Ph-III (Ayaappa Pvt.Ltd) ASP	60	As per DPCC limits	7.31	7.62	270	05	150	4	410	3	24	5	4	1	-	-	-	-			
4		Kapashera	Kapashera (Triveni Pvt. Ltd) SBR	5	As per plant design TSS:10/BOD:10/f.C:1000/100ml	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
5	Kondli	Kondli Ph-I	Kondli Ph-I (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	7	7.4	290	8	150	7	400	16	30	1	3	1.5			210X10^11	110			
6		Kondli Ph-II	Kondli Ph-II (Triveni Pvt. Ltd) ASP	25	As per DPCC limits	7	7.5	290	9	150	7	400	18	30	1.5	3	1.5			210X10^11	73			
7		Kondli Ph-III	Kondli Ph-III (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	7	7.5	290	7	150	7	400	18	30	1.5	3	1.5			210X10^11	73			
8		Kondli Ph-IV	Kondli Ph-IV (Ayaappa Pvt.Ltd) ASP(IFAS)	45	As per DPCC limits	7.1	7.5	320	7	147	6	415	15	32	1.2	3.5	1.0			210X10^11	36			
9		Chilla	Chilla (HNB Engineers) C-ISBR	9	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
10		CWG	CWG (M/s Toshiba Water Soluti on Pvt. Ltd.) MBR	1	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
11	N.S.T.P.C.Pillar	Coronation Pillar Ph-II	Coronation Pillar Ph-II (DRA Infracom Pvt.Ltd.) ASP(IFAS)	20	As per plant design TSS:30/BOD:20/COD:250/NH4-N:50/PO4:5/ f.C:230	7	7.5	110	8	57	5	190	17	20	0.5	1.7	0.6	1	Bdl	-	-			
12		Coronation Pillar Ph-III	Coronation Pillar Ph-III (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits	7.1	7.5	82	8	42	4	150	18	18	0.4	1.8	0.5	0.9	Bdl	-	-			
13		Coronation New	Coronation New (L&T Construction and PASSAVANT (JV)) ASP	70	As per DPCC limits	7	7.6	106	10	54	5	190	19	21	0.6	1.7	0.7			-	-			
14		Narela	Narela (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits															-	-			
15	Nilothi	Nilothi Ph-I	Nilothi Ph-I (SUBHASH INFRA PVT. LTD) ASP(IFAS)	60	As per DPCC limits	7.63	7.65	284	8	173	7	-	-	22.5	8	3.2	1			-	-			
16		Nilothi Ph-II	Nilothi Ph-II (VEOLIA INDIA) ASP	20	As per DPCC limits	7.53	7.57	292	2	185	2	-	-	23.75	4.3	2.9	0.4			-	-			
17	Okhla	Okhla Ph-V	Okhla Ph-V (DJB) ASP	16	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	7.48	7.62	324	19	390	8.4	980	30	45	8.5	2.8	2	6	ND	93x10^9	43x10^2			
18		Okhla Ph-VI	Okhla Ph-VI (SUEZ India Pvt. Ltd.) ASP	30	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
19		Okhla New	Okhla New (SUEZ India Pvt. Ltd.) ASP	124	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
20		Mehrauli	Mehrauli (DJB) E.A	5	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	7.72	8.25	158	18	85	10.3	299	67	45	20	3.2	0.12	ND	ND	46x10^13	24x10^5			
21		Molar band	Molar band (DJB)	0.66	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
22		Ghitorini	Ghitorini (DJB) ASP	5	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	7.46	8.28	324	57	263	31	963	112	55	47.5	4	2.6	2	ND	24x10^14	11x10^6			
23		Vasant Kunj Ph-I	Vasant Kunj Ph-I (DJB) E.A	2.2	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	7.51	8.38	318	21	133	2.4	817	26	24.5	1.5	3	0.02	12	ND	11x10^14	21x10^5			
24		Vasant Kunj Ph-II	Vasant Kunj Ph-II (DJB) E.A	3	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	7.53	7.74	336	4540	123	808	856	3600	35	3.5	2.9	2	ND	ND	21x10^13	24x10^4			
25		Delhi Gate Ph-I	Delhi Gate Ph-I (Degramont) B & D	2.2	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
26		Delhi Gate Ph-II	Delhi Gate Ph-II (Degramont) B & D	15	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
27		SNH drain	SNH drain (Degramont) B & D	2.2	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
28	Phappankalan Ph-I	Phappankalan Ph-I (SUBHASH INFRA PVT. LTD) ASP	20	As per DPCC limits	7.39	7.21	388	6	243	5	700	30	50	0.5	3.7	1	-	-	-	-				

NO ANY NON COMPLIANCE



DELHI JAL BOARD

DAILY ANALYSIS REPORT OF ALL SEWAGE TREATMENT PLANT

DATE OF ANALYSIS : 18.11.2025

S.No.	Lab	Plant	Sewage Treatment Plant (Operator) Technology	Capacity (MGD)	DPCC Parameter (mg/l) (TSS:10/BOD:10, COD:50, NH4-N:5,PO4-P:2, Oil & grease : 10, f.coliform: 230 MPN/100ml)	pH		TSS		BOD (3 DAYS at 27.0 C)		COD		Ammonical nitrogen		Dissolve phosphate		Oil & Grease		Fecal Coliform (72 hrs)		Remarks
						INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	
						-	-	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	MPN/100ml	MPN/100ml	
1	Keshopur	Keshopur Ph-I	Keshopur Ph-I (VA-TECH WABAG LTD.) ASP	12	As per plant design TSS:30/BOD:20/COD:250/NH4-N:50/PO4-S: f.C:230	7.3	7.5	261	3	170	3	460	24	18	7	3	2	-	-	-	-	
2		Keshopur Ph-II	Keshopur Ph-II (Ayaappa Pvt.Ltd) ASP(IFAS)	20	As per DPCC limits	7.2	7.38	279	4	185	3	500	24	22	9	4	2	-	-	-	-	
3		Keshopur Ph-III	Keshopur Ph-III (Ayaappa Pvt.Ltd) ASP	60	As per DPCC limits	7.3	7.62	292	10	190	7	513	26	24	9	4.5	1	-	-	24x10^11+	460	
4		Kapashera	Kapashera (Triveni Pvt. Ltd) SBR	5	As per plant design TSS:10/BOD:10/f.C:1000/100ml	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
5	Kondli	Kondli Ph-I	Kondli Ph-I (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	7.1	7.6	302	7	152	6	416	16	30	1.5	2.8	0.8			290x10^11	110	
6		Kondli Ph-II	Kondli Ph-II (Triveni Pvt. Ltd) ASP	25	As per DPCC limits	7.1	7.5	302	8	152	7	416	19	30	1.8	2.8	1.2			290x10^11	73	
7		Kondli Ph-III	Kondli Ph-III (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	7.1	7.5	302	8	152	7	416	19	30	1.8	2.8	1.2			290x10^11	73	
8		Kondli Ph-IV	Kondli Ph-IV (Ayaappa Pvt.Ltd) ASP(IFAS)	45	As per DPCC limits	7	7.5	292	8	145	7	430	15	35	1	2.8	0.8			210x10^11	91	
9	N.S.T.C.Pillar	Chilla	Chilla (HNB Engineers) C-ISBR	9	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
10		CWG	CWG (M/s Toshiba Water Soluti on Pvt. Ltd.) MBR	1	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
11		Coronation Pillar Ph-II	Coronation Pillar Ph-II (DRA Infracom Pvt.Ltd.) ASP(IFAS)	20	As per plant design TSS:30/BOD:20/COD:250/NH4-N:50/PO4-S: f.C:230	7	7.5	110	7	52	3	192	15	21	0.6	1.8	0.5			-	-	
12	Narela	Coronation Pillar Ph-III	Coronation Pillar Ph-III (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits	7.1	7.6	90	6	41	3	154	13	20	0.5	1.6	0.4			-	-	
13		Coronation New	Coronation New (L&T Construction and PASSAVANT (JV)) ASP	70	As per DPCC limits	7.1	7.5	120	8	62	5	198	19	32	0.5	1.7	0.6	1.2	BDI	-	-	
14		Narela	Narela (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits	7.2	7.5	162	08	84	04	234	18	22	0.5	1.9	0.6	1.9	BDL	-	-	
15	Nilothi	Nilothi Ph-I	Nilothi Ph-I (SUBHASH INFRA PVT. LTD) ASP(IFAS)	60	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
16		Nilothi Ph-II	Nilothi Ph-II (VEOLIA INDIA) ASP	20	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
17	Okhla	Okhla Ph-V	Okhla Ph-V (DIB) ASP	16	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4-S: f.C:230	7.59	7.1	280	10	163	9.4	(-)	(-)	45	3	3.2	1.6	7	ND	24X10^10	7.3X10^2	
18		Okhla Ph-VI	Okhla Ph-VI (SUEZ India Pvt. Ltd.) ASP	30	As per DPCC limits	7.76	7.67	248	6	160	1.9	649	25	30	0.1	3	2.3	5	ND	15X10^12	460	
19		Okhla New	Okhla New (SUEZ India Pvt. Ltd.) ASP	124	As per DPCC limits	7.61	7.51	196	6	165	12.4	635	41	20	3.2	2	0.5	6	ND	24X10^13	210	
20		Mehrauli	Mehrauli (DIB) E.A	5	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4-S: f.C:230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
21		Molar band	Molar band (DIB) E.A	0.66	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4-S: f.C:230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
22		Ghitorini	Ghitorini (DIB) ASP	5	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4-S: f.C:230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
23	Pappankalan	Vasant Kunj Ph-I	Vasant Kunj Ph-I (DIB) E.A	2.2	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4-S: f.C:230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
24		Vasant Kunj Ph-II	Vasant Kunj Ph-II (DIB) E.A	3	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4-S: f.C:230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
25		Delhi Gate Ph-I	Delhi Gate Ph-I (Degramont) B & D	2.2	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
26		Delhi Gate Ph-II	Delhi Gate Ph-II (Degramont) B & D	15	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
27		SNH drain	SNH drain (Degramont) B & D	2.2	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
28	Rithala	Phappankalan Ph-I	Phappankalan Ph-I (SUBHASH INFRA PVT. LTD) ASP	20	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
29		Phappankalan Ph-II	Phappankalan Ph-II (VA-TECH WABAG LTD.) ASP	20	As per plant design TSS:10/BOD:10/NH4-N:2/PO4-S: f.C:2500/100ml	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
30		Najafgarh	Najafgarh (Ayaappa Pvt.Ltd.) ASP	5	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
31	Rithala	Rithala Ph-I	Rithala Ph-I (Ms WA TECH BABAG LTD.) ASP	40	As per DPCC limits	7.45	7.53	236	7	155	6	376	28	20	0.7	3.6	0.8	-	1	11x10^12	95	
32		Rithala Ph-II	Rithala Ph-II (SUEZ India Pvt. Ltd.) ASP	40	As per DPCC limits	7.52	7.84	300	6	182	5	448	24	19	3	3.9	0.5	-	1	11x10^11	93	

NO ANY NON COMPLIANCE

		DELHI JAL BOARD																						
		DAILY ANALYSIS REPORT OF ALL SEWAGE TREATMENT PLANT																						
		DATE OF ANALYSIS : 19.11.2025																						
S.No.	Lab	Plant	Sewage Treatment Plant (Operator) Technology	Capacity	DPCC Parameter (mg/l) (TSS:10,BOD:10, COD:50, NH4-N:5,PO4-P:2, Oil& grease : 10, f.coliform: 230 MPN/100ml)	pH		TSS		BOD (3 DAYS at 27 0 C)		COD		Ammonical nitrogen		Dissolve phosphate		Oil & Grease		Fecal Coliform (72 hrs)		Remarks		
						INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET		INLET	OUTLET
						(MGD)	Parameter Limits	-	-	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l		mg/l	mg/l
1	Keshopur	Keshopur Ph-I	Keshopur Ph-I (VA-TECH WABAG LTD.) ASP	12	As per plant design TSS:30/BOD:20/COD:250/NH4-N:50/PO4:5/ f.C:230	7.48	7.62	352	5	180	4	489	24	18	5	3	2	-	-	-	-			
2		Keshopur Ph-II	Keshopur Ph-II (Ayaappa Pvt.Ltd) ASP(IFAS)	20	As per DPCC limits	7.33	7.52	236	5	160	3	438	22	24	5	3	1.8	-	-	-	-			
3		Keshopur Ph-III	Keshopur Ph-III (Ayaappa Pvt.Ltd) ASP	60	As per DPCC limits	7.28	7.63	185	10	140	6	380	26	21	9	3.5	1	-	-	-	-			
4		Kapashera	Kapashera (Triveni Pvt. Ltd) SBR	5	As per plant design TSS:10/BOD:10/f.C:1000/100ml	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
5	Kondli	Kondli Ph-I	Kondli Ph-I (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	7	7.5	288	6	137	4	395	13	32	1.2	3	0.8			1100×10^11	91			
6		Kondli Ph-II	Kondli Ph-II (Triveni Pvt. Ltd) ASP	25	As per DPCC limits	7	7.6	288	8	137	6	395	15	32	1.8	3	1.0			1100×10^11	110			
7		Kondli Ph-III	Kondli Ph-III (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	7	7.6	288	8	137	6	395	15	32	1.8	3	1.0			1100×10^11	110			
8		Kondli Ph-IV	Kondli Ph-IV (Ayaappa Pvt.Ltd) ASP(IFAS)	45	As per DPCC limits	7.1	7.5	306	9	155	7	412	15	35	1.2	2.8	1.0			210×10^11	110			
9		Chilla	Chilla (HNB Engineers) C-ISBR	9	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
10		CWG	CWG (M/s Toshiba Water Soluti on Pvt. Ltd.) MBR	1	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
11	N.S.T.P.C.Pillar	Coronation Pillar Ph-II	Coronation Pillar Ph-II (DRA Infracom Pvt.Ltd.) ASP(IFAS)	20	As per plant design TSS:30/BOD:20/COD:250/NH4-N:50/PO4:5/ f.C:230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
12		Coronation Pillar Ph-III	Coronation Pillar Ph-III (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
13		Coronation New	Coronation New (L&T Construction and PASSAVANT (JV)) ASP	70	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
14		Narela	Narela (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
15	Nilothi	Nilothi Ph-I	Nilothi Ph-I (SUBHASH INFRA PVT. LTD) ASP(IFAS)	60	As per DPCC limits	7.51	7.56	294	5	160	4	-	-	17.5	5	3	0.4			12x10^8	15x10^3			
16		Nilothi Ph-II	Nilothi Ph-II (VEOLIA INDIA) ASP	20	As per DPCC limits	7.65	7.68	178	2	110	3	-	-	18	4.2	3.1	0.3			12x10^8	210			
17	Okhla	Okhla Ph-V	Okhla Ph-V (DJB) ASP	16	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	7.2	7.4	294	9	188	13	1443	28	45	8	3	1.8	5	ND	24x10^11	43x10^2			
18		Okhla Ph-VI	Okhla Ph-VI (SUEZ India Pvt. Ltd.) ASP	30	As per DPCC limits	7.2	7.5	348	5	460	3.4	1221	50	27.5	0.15	3.1	2	6	ND	93x10^11	150			
19		Okhla New	Okhla New (SUEZ India Pvt. Ltd.) ASP	124	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
20		Mehrauli	Mehrauli (DJB) E.A	5	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
21		Molar band	Molar band (DJB)	0.66	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
22		Ghitorini	Ghitorini (DJB) ASP	5	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
23		Vasant Kunj Ph-I	Vasant Kunj Ph-I (DJB) E.A	2.2	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
24		Vasant Kunj Ph-II	Vasant Kunj Ph-II (DJB) E.A	3	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
25		Delhi Gate Ph-I	Delhi Gate Ph-I (Degramont) B & D	2.2	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
26		Delhi Gate Ph-II	Delhi Gate Ph-II (Degramont) B & D	15	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
27		SNH drain	SNH drain (Degramont) B & D	2.2	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
28		Phappankalan Ph-I	Phappankalan Ph-I (SUBHASH INFRA PVT. LTD) ASP	20	As per DPCC limits	7.34	7.27	424	5	308	2	680	26	45	8	3.5	0.5	-	-	53*10^7+	75			

[illegible]

[illegible]

DATE OF ANALYSIS : 21.11.2025

	S.No.	Lab	Plant	Sewage Treatment Plant (Operator) Technology	Capacity	DPPC Parameter (mg/l) (TSS:10,BOD:10, COD:50, NH4-N:5,PO4-P:2, Oil& grease : 10, f.coliform: 230 MPN/100ml)	pH		TSS		BOD (3 DAYS at 27 0 C)		COD		Ammonical nitrogen		Dissolve phosphate		Oil & Grease		Fecal Coliform (72 hrs)		Remarks		
							INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET		INLET	OUTLET
							(MGD)	Parameter Limits					-	-	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l		mg/l	mg/l
	1	Keshapur	Keshapur Ph-I	Keshapur Ph-I (VA-TECH WABAG LTD.) ASP	12	As per plant design TSS:30/BOD:20/COD:250/NH4-N:50/PO4:5/ f.C:230	7.1	7.4	228	7	170	04	465	25	21	2	2.5	1.8	----	----	24*10^11	210			
	2		Keshapur Ph-II	Keshapur Ph-II (Ayaappa Pvt.Ltd) ASP(IFAS)	20	As per DPCC limits	7.3	7.4	324	03	180	05	485	28	22	05	3.2	1	-----	-----	-	-			
	3		Keshapur Ph-III	Keshapur Ph-III (Ayaappa Pvt.Ltd) ASP	60	As per DPCC limits	7.4	7.5	314	8.5	195	04	530	26	18	4.5	2.8	0.9	---	---	-	-			
	4		Kapashera	Kapashera (Triveni Pvt. Ltd) SBR	5	As per plant design TSS:10/BOD:10/f.C:1000/100ml	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
	5	Kondli	Kondli Ph-I	Kondli Ph-I (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	7	7.5	282	7	150	5	364	12	32	1.2	2.8	1	7.9	Nil	290X10^11	73			
	6		Kondli Ph-II	Kondli Ph-II (Triveni Pvt. Ltd) ASP	25	As per DPCC limits	7	7.6	282	8	150	6	364	15	32	1.2	2.8	0.8	7.9	Nil	290X10^11	72			
	7		Kondli Ph-III	Kondli Ph-III (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	7	7.6	282	8	150	06	364	15	32	1.2	2.8	0.8	7.9	Nil	290X10^11	72			
	8		Kondli Ph-IV	Kondli Ph-IV (Ayaappa Pvt.Ltd) ASP(IFAS)	45	As per DPCC limits	7.1	7.6	298	8	147	5	382	17	35	1	3	0.8	8.4	Nil	1100X10^11	110			
	9		Chilla	Chilla (HNB Engineers) C-ISBR	9	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
	10		CWG	CWG (M/s Toshiba Water Soluti on Pvt. Ltd.) MBR	1	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
	11	N.S.T.P.C Pillar	Coronation Pillar Ph-II	Coronation Pillar Ph-II (DRA Infracom Pvt.Ltd.) ASP(IFAS)	20	As per plant design TSS:30/BOD:20/COD:250/NH4-N:50/PO4:5/ f.C:230	6.9	7.6	122	7	62	4	239	16	20	0.5	1.9	0.8	1.5	Bdl	-	-			
	12		Coronation Pillar Ph-III	Coronation Pillar Ph-III (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits	7	7.7	100	8	57	4	196	19	17	0.5	1.8	0.6	1.2	Bdl	-	-			
	13		Coronation New	Coronation New (L&T Construction and PASSAVANT (JV)) ASP	70	As per DPCC limits	7.1	7.7	106	6	50	3	311	13	20	0.6	2	1			-	-			
	14		Narela	Narela (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits															-	-			
	15	Nilothi	Nilothi Ph-I	Nilothi Ph-I (SUBHASH INFRA PVT. LTD) ASP(IFAS)	60	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	16		Nilothi Ph-II	Nilothi Ph-II (VEOLIA INDIA) ASP	20	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
	17	Okhla	Okhla Ph-V	Okhla Ph-V (DJB) ASP	16	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	7.65	7.7	254	9	218	8.4	1237	54	32.5	6	2.5	1.5	6	ND	24x10^10	93x10^2			
	18		Okhla Ph-VI	Okhla Ph-VI (SUEZ India Pvt. Ltd.) ASP	30	As per DPCC limits	7.83	7.86	312	6	160	3.7	652	37	55	0.2	2.7	2.6	4	ND	24x10^12	93			
	19		Okhla New	Okhla New (SUEZ India Pvt. Ltd.) ASP	124	As per DPCC limits	7.64	7.4	188	5	110	9.6	448	31	25	4.7	2.3	1	5	ND	11x10^13	43			
	20		Mehrauli	Mehrauli (DJB) E.A	5	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
	21		Molar band	Molar band (DJB)	0.66	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
	22		Ghitorini	Ghitorini (DJB) ASP	5	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
	23		Vasant Kunj Ph-I	Vasant Kunj Ph-I (DJB) E.A	2.2	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
	24		Vasant Kunj Ph-II	Vasant Kunj Ph-II (DJB) E.A	3	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
	25		Delhi Gate Ph-I	Delhi Gate Ph-I (Degramont) B & D	2.2	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
	26		Delhi Gate Ph-II	Delhi Gate Ph-II (Degramont) B & D	15	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
	27		SNH drain	SNH drain (Degramont) B & D	2.2	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
	28	Phappankalan Ph-I	Phappankalan Ph-I (SUBHASH INFRA PVT. LTD) ASP	20	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		

NO ANY NON COMPLIANCE

DATE OF ANALYSIS : 22.11.2025

Sl. No.	S.No.	Lab	Plant	Sewage Treatment Plant (Operator) Technology	Capacity	DPCC Parameter (mg/l) (TSS:10,BOD:10, COD:50, NH4-N:5,PO4-P:2, f.coliform: 230 MPN/100ml)	pH		TSS		BOD (3 DAYS at 27 0 C)		COD		Ammonical nitrogen		Dissolve phosphate		Oil & Grease		Fecal Coliform (72 hrs)		Remarks		
							INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET		INLET	OUTLET
							(MGD)	Parameter Limits					-	-	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l		mg/l	mg/l
	1	Keshapur	Keshapur Ph-I	Keshapur Ph-I (VA-TECH WABAG LTD.) ASP	12	As per plant design TSS:30/BOD:20/COD:250/NH4-N:50/PO4:5/ f.C:230	7.32	7.72	223	5	165	3	444	24	24	1	2.5	1.2	16.24	Nil	-	-			
	2		Keshapur Ph-II	Keshapur Ph-II (Ayaappa Pvt.Ltd) ASP(IFAS)	20	As per DPCC limits	7.28	7.68	345	4	170	4	462	26	22	4.5	3.5	0.7	-		24*10^12	160			
	3		Keshapur Ph-III	Keshapur Ph-III (Ayaappa Pvt.Ltd) ASP	60	As per DPCC limits	7.31	7.71	315	5	190	3	518	22	26	4.2	3.5	0.5	-	-	-	-			
	4		Kapashera	Kapashera (Triveni Pvt. Ltd) SBR	5	As per plant design TSS:10/BOD:10/f.C:1000/100ml	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
	5	Kondli	Kondli Ph-I	Kondli Ph-I (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	7	7.5	260	8	137	6	342	15	30	0.8	3	0.6			-	-			
	6		Kondli Ph-II	Kondli Ph-II (Triveni Pvt. Ltd) ASP	25	As per DPCC limits	7	7.6	260	9	137	6	342	20	30	1.2	3	1.0			-	-			
	7		Kondli Ph-III	Kondli Ph-III (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	7	7.6	260	9	137	6	342	20	30	1.2	3	1.0			-	-			
	8		Kondli Ph-IV	Kondli Ph-IV (Ayaappa Pvt.Ltd) ASP(IFAS)	45	As per DPCC limits	7.1	7.5	276	08	150	6	390	16	30	1	2.8	0.8			-	-			
	9		Chilla	Chilla (HNB Engineers) C-ISBR	9	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	10		CWG	CWG (M/s Toshiba Water Soluti on Pvt. Ltd.) MBR	1	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	11	N.S.T.P.C.Pillar	Coronation Pillar Ph-II	Coronation Pillar Ph-II (DRA Infracom Pvt.Ltd.) ASP(IFAS)	20	As per plant design TSS:30/BOD:20/COD:250/NH4-N:50/PO4:5/ f.C:230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	12		Coronation Pillar Ph-III	Coronation Pillar Ph-III (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	13		Coronation New	Coronation New (L&T Construction and PASSAVANT (JV)) ASP	70	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	14		Narela	Narela (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	15	Nilothi	Nilothi Ph-I	Nilothi Ph-I (SUBHASH INFRA PVT. LTD) ASP(IFAS)	60	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	16		Nilothi Ph-II	Nilothi Ph-II (VEOLIA INDIA) ASP	20	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	17	Okhla	Okhla Ph-V	Okhla Ph-V (DJB) ASP	16	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	7.77	7.72	272	7	158	8.8	(-)	(-)	45	6.5	4	2	6	ND	21x10^9	28x10^2			
	18		Okhla Ph-VI	Okhla Ph-VI (SUEZ India Pvt. Ltd.) ASP	30	As per DPCC limits	7.67	7.76	296	5	200	3.2	(-)	(-)	50	0.1	4	3.6	5	ND	24x10^12	150			
	19		Okhla New	Okhla New (SUEZ India Pvt. Ltd.) ASP	124	As per DPCC limits	7.66	7.37	212	4	105	9.8	(-)	(-)	25	6	2.1	0.8	4	ND	24x10^12	93			
	20		Mehrauli	Mehrauli (DJB) E.A	5	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	21		Molar band	Molar band (DJB)	0.66	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	22		Ghitorini	Ghitorini (DJB) ASP	5	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	23		Vasant Kunj Ph-I	Vasant Kunj Ph-I (DJB) E.A	2.2	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	24		Vasant Kunj Ph-II	Vasant Kunj Ph-II (DJB) E.A	3	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/PO4:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	25		Delhi Gate Ph-I	Delhi Gate Ph-I (Degramont) B & D	2.2	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
	26		Delhi Gate Ph-II	Delhi Gate Ph-II (Degramont) B & D	15	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
	27		SNH drain	SNH drain (Degramont) B & D	2.2	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
	28	Phappankalan Ph-I	Phappankalan Ph-I (SUBHASH INFRA PVT. LTD) ASP	20	As per DPCC limits	7.31	7.3	358	8	208	5	558	27	50	2.5	4	1	-	-	-	-				

[illegible]



S.No.	Lab	Plant	Sewage Treatment Plant (Operator) Technology	Capacity	DPCC Parameter (mg/l) (TSS:10,BOD:10, COD:50, NH4-N:5,P04-P:2, Oil& grease : 10, f.coliform: 230 MPN/100ml)	pH		TSS		BOD (3 DAYS at 27 0 C)		COD		Ammonical nitrogen		Dissolve phosphate		Oil & Grease		Fecal Coliform (72 hrs)		Remarks
						INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	
				(MGD)		Parameter Limits		-	-	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	
1	Keshopur	Keshopur Ph-I	Keshopur Ph-I (VA-TECH WABAG LTD.) ASP	12	As per plant design TSS:30/BOD:20/COD:250/NH4-N:50/P04:5/ f.C:230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	Lab closed on sunday	
2		Keshopur Ph-II	Keshopur Ph-II (Ayaappa Pvt.Ltd) ASP(IFAS)	20	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	Lab closed on sunday	
3		Keshopur Ph-III	Keshopur Ph-III (Ayaappa Pvt.Ltd) ASP	60	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	Lab closed on sunday	
4		Kapashera	Kapashera (Triveni Pvt. Ltd) SBR	5	As per plant design TSS:10/BOD:10/f.C:1000/100ml	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
5	Kondli	Kondli Ph-I	Kondli Ph-I (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	7	7.5	244	6	145	6	364	12	30	0.8	2.5	0.5			-	-	
6		Kondli Ph-II	Kondli Ph-II (Triveni Pvt. Ltd) ASP	25	As per DPCC limits	7	7.5	244	8	145	7	364	17	30	1	2.5	0.8			-	-	
7		Kondli Ph-III	Kondli Ph-III (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	7	7.5	244	8	145	7	364	17	30	1	2.5	0.8			-	-	
8		Kondli Ph-IV	Kondli Ph-IV (Ayaappa Pvt.Ltd) ASP(IFAS)	45	As per DPCC limits	7	7.4	256	7	140	6	392	15	32	1	3	0.8			-	-	
9		Chilla	Chilla (HNB Engineers) C-ISBR	9	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
10		CWG	CWG (M/s Toshiba Water Soluti on Pvt. Ltd.) MBR	1	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
11	N.S.T.P.C.Pillar	Coronation Pillar Ph-II	Coronation Pillar Ph-II (DRA Infracom Pvt.Ltd.) ASP(IFAS)	20	As per plant design TSS:30/BOD:20/COD:250/NH4-N:50/P04:5/ f.C:230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
12		Coronation Pillar Ph-III	Coronation Pillar Ph-III (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
13		Coronation New	Coronation New (L&T Construction and PASSAVANT (JV)) ASP	70	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
14		Narela	Narela (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
15	Nilothi	Nilothi Ph-I	Nilothi Ph-I (SUBHASH INFRA PVT. LTD) ASP(IFAS)	60	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
16		Nilothi Ph-II	Nilothi Ph-II (VEOLIA INDIA) ASP	20	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
17	Okhla	Okhla Ph-V	Okhla Ph-V (DJB) ASP	16	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/P04:5	7.2	7.4	278	7	160	9	(-)	(-)	42	3.4	2.8	1.4	4	NIL	24x10^10	93x10^2	
18		Okhla Ph-VI	Okhla Ph-VI (SUEZ India Pvt. Ltd.) ASP	30	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
19		Okhla New	Okhla New (SUEZ India Pvt. Ltd.) ASP	124	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
20		Mehrauli	Mehrauli (DJB) E.A	5	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/P04:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
21		Molar band	Molar band (DJB)	0.66	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/P04:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
22		Ghitorini	Ghitorini (DJB) ASP	5	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/P04:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
23		Vasant Kunj Ph-I	Vasant Kunj Ph-I (DJB) E.A	2.2	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/P04:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
24		Vasant Kunj Ph-II	Vasant Kunj Ph-II (DJB) E.A	3	As per plant design TSS:50/BOD:30/COD:250/NH4-N:50/P04:5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
25		Delhi Gate Ph-I	Delhi Gate Ph-I (Degramont) B & D	2.2	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
26		Delhi Gate Ph-II	Delhi Gate Ph-II (Degramont) B & D	15	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
27		SNH drain	SNH drain (Degramont) B & D	2.2	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
28	Phappankalan Ph-I	Phappankalan Ph-I (SUBHASH INFRA PVT. LTD) ASP	20	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	Lab closed on sunday	

[illegible]

[illegible]

[illegible]

