

[illegible]

[illegible]

DELHI JAL BOARD

DAILY ANALYSIS REPORT OF ALL SEWAGE TREATMENT PLANT

DATE OF ANALYSIS : 03.04.2026

DATE OF ANALYSIS : 05.04.2020																							
S.No.	Lab	Sewage Treatment Plant (Operator) Technology	Capacity	DPCC Parameter (mg/l) (TSS:10,BOD:10, COD:50, NH4-N:5,PO4-P:2, Oil& grease : 10, f.coliform: 230 MPN/100ml)	pH		TSS		BOD (3 DAYS at 27 0 C)		COD		Ammonical nitrogen		Dissolve phosphate		Oil & Grease		Fecal Coliform (72 hrs)		Remarks		
					INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET		INLET	OUTLET
					(MGD)	Parameter Limits		-	-	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l		mg/l	mg/l
1	Keshopur	Keshopur Ph-I (VA-TECH WABAG LTD.) ASP	12	As per plant design TSS:30/BOD:20/COD:50/NH4-N:5/PO4:2/O &G:1.2/f.c:2500 MPN/100ml	7.21	7.59	69	7	130	5	365	24	50	3	2.5	1.5	-	-	24*10^11+	75			
2		Keshopur Ph-II (Ayaappa Pvt.Ltd) ASP(IFAS)	20	As per DPCC limits	7.38	7.5	346	4	175	3	480	28	45	2.5	2.7	1.3	-	-	24*10^11+	120			
3		Keshopur Ph-III (Ayaappa Pvt.Ltd) ASP	60	As per DPCC limits	7.39	7.48	314	4	165	3	495	26	50	2	2.8	0.2	-	-	24*10^11+	150			
4		Kapashera (Triveni Pvt. Ltd) SBR	5	As per plant design TSS:10/BOD:10/COD:50/NH4: 5/O&G:1.2/PO4:1/f.c:1000/100ml	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
5	Kondli	Kondli Ph-I (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	7	7.5	260	6	147	6	490	18	35	0.5	3	0.6			1100X10^12	73			
6		Kondli Ph-II (Triveni Pvt. Ltd) ASP	25	As per DPCC limits	7	7.6	260	8	147	7	490	20	35	1.5	4	0.8			1100X10^12	36			
7		Kondli Ph-III (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	7	7.6	260	8	147	7	490	20	35	1.5	3	0.8			1100X10^12	36			
8		Kondli Ph-IV (Ayaappa Pvt.Ltd) ASP(IFAS)	45	As per DPCC limits	7	7.5	260	8	147	5	490	22	35	1	3	0.8			1100X10^12	30			
9		Chilla (HNB Engineers) C-ISBR	9	As per DPCC limits	7.2	7.5	310	8	150	6	464	16	35	ND	3	ND	11.8	ND	210X10^12	36			
10		CWG (M/s Toshiba Water Soluti on Pvt. Ltd.) MBR	1	As per DPCC limits	7.1	7.6	342	1	160	2	480	6	38	ND	3.2	ND	12.4	ND	290X10^12	3			
11	N.S.T.P.C.Pillar	Coronation Pillar Ph-II (DRA Infracom Pvt.Ltd.) ASP(IFAS)	20	As per plant design TSS:30/BOD:20/COD:50/NH4-N:5/PO4:1/O &G:1.2/f.c:230	7	7.4	124	10	65	6	274	14	18	0.6	1.6	0.7			75x10^11	93			
12		Coronation Pillar Ph-III (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	15x10^13	150			
13		Coronation New (L&T Construction and PASSAVANT (JV)) ASP	70	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	11x10^14	210			
14		Narela (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
15	Nilothi	Nilothi Ph-I (SUBHASH INFRA PVT. LTD) ASP(IFAS)	60	As per DPCC limits	7.83	7.86	572	3	320	6	-	-	26.2	2.3	2.9	0.5			35x10^7	150			
16		Nilothi Ph-II (VEOLIA INDIA) ASP	20	As per DPCC limits	7.81	7.84	334	5	185	8	-	-	25.5	6	2.6	0.6			15x10^8	93			
17	Okhla	Okhla Ph-V (DJB) ASP	16	As per plant design TSS:50/BOD:30/COD:50	7.34	7.56	316	15	120	13.8	(-)	(-)	42.5	20	4.1	2	3	ND	11x10^11	35x10^2			
18		Okhla Ph-VI (SUEZ India Pvt. Ltd.) ASP	30	As per DPCC limits	7.1	7.34	230	7	130	3.2	(-)	(-)	35	ND	3.6	1.7	2	ND	24x10^11	3.6			
19		Okhla New (SUEZ India Pvt. Ltd.) ASP	124	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
20		Mehrauli (DJB) E.A	5	As per plant design TSS:50/BOD:30/COD:50	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
21		Molar band (																					

ASP	Activated Sludge Process
ASP(IFAS)	Activated Sludge Process with Integrated Fixed-film Activated Sludge
E.A	Extended Aeration
FAB	Fluidized Aerobic Bed
B & D	Biofor and dansadeg
C-ISBR	Combitreat-ISBR
W	Waiting
ND	Not Detectable
BDL	Bellow Detection Limit



DATE OF ANALYSIS : 04.04.2026

DATE OF ANALYSIS : 04.04.2020																							
S.No.	Lab	Sewage Treatment Plant (Operator) Technology	Capacity	DPCC Parameter (mg/l) (TSS:10,BOD:10, COD:50, NH4-N:5,PO4-P:2, Oil& grease : 10, f.coliform: 230 MPN/100ml)	pH		TSS		BOD (3 DAYS at 27 0 C)		COD		Ammonical nitrogen		Dissolve phosphate		Oil & Grease		Fecal Coliform (72 hrs)		Remarks		
					INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET		INLET	OUTLET
					(MGD)	Parameter Limits	-	-	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l		mg/l	MPN/100ml
1	Keshapur	Keshapur Ph-I (VA-TECH WABAG LTD.) ASP	12	As per plant design TSS:30/BOD:20/COD:50/NH4-N:5/PO4:2/O &G:1.2/f.C:2500 MPN/100ml	7.3	7.66	100	8	138	6	296	21	50	2.5	3.5	1.5	-	-	24*10^11+	75			
2		Keshapur Ph-II (Ayaappa Pvt.Ltd) ASP(IFAS)	20	As per DPCC limits	7.46	7.66	304	6	155	5	423	19	60	4.5	3	0.8	0-	-	24*10^11+	150			
3		Keshapur Ph-III (Ayaappa Pvt.Ltd) ASP	60	As per DPCC limits	7.45	7.63	298	8	150	7	444	28	58	5	3.6	0.7	-	-	24*10^11+	160			
4		Kapashera (Triveni Pvt. Ltd) SBR	5	As per plant design TSS:10/BOD:10/COD:50/NH4: 5/O&G:1.2/PO4:1/f.C:1000/100ml	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
5	Kondli	Kondli Ph-I (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	7.1	7.5	278	07	150	06	464	16	35	0.5	3.2	0.6			290X10^12	36			
6		Kondli Ph-II (Triveni Pvt. Ltd) ASP	25	As per DPCC limits	7.1	7.6	278	09	150	08	464	22	35	2	3.2	0.8			290X10^12	91			
7		Kondli Ph-III (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	7.1	7.6	278	09	150	08	464	22	35	2	3.2	0.8			290X10^12	91			
8		Kondli Ph-IV (Ayaappa Pvt.Ltd) ASP(IFAS)	45	As per DPCC limits	7.1	7.6	278	07	150	06	464	20	35	1.2	3.2	0.5			290X10^12	93			
9		Chilla (HNB Engineers) C-ISBR	9	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
10		CWG (M/s Toshiba Water Soluti on Pvt. Ltd.) MBR	1	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
11	N.S.T.P.C Pillar	Coronation Pillar Ph-II (DRA Infracom Pvt.Ltd.) ASP(IFAS)	20	As per plant design TSS:30/BOD:20/COD:50/NH4-N:5/PO4:1/O &G:1.2/f.C:230	6.9	7.4	110	8	73	4	346	16	20	0.7	1.8	0.9			-	-			
12		Coronation Pillar Ph-III (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits	7.1	7.4	130	8	80	4	211	19	24	0.8/	2.2	0.7			-	-			
13		Coronation New (L&T Construction and PASSAVANT (JV)) ASP	70	As per DPCC limits	7.2	7.6	276	10	136	6	480	16	32	1.2	2.6	1.3	3	bdI	-	-			
14		Narela (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits	7.1	7.5	438	10	157	6	620	18	38	0.9	2.9	0.8	3.4	bdI	-	-			
15	Nilothi	Nilothi Ph-I (SUBHASH INFRA PVT. LTD) ASP(IFAS)	60	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	21x10^8	75			
16		Nilothi Ph-II (VEOLIA INDIA) ASP	20	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	28x10^7	120			
17	Okhla	Okhla Ph-V (DJB) ASP	16	As per plant design TSS:50/BOD:30/COD:50	7.2	7.66	160	10	124	12.8	(-)	(-)	50	25	3.9	2.3	3	ND	24x10^11	46x10^3			
18		Okhla Ph-VI (SUEZ India Pvt. Ltd.) ASP	30	As per DPCC limits	7.46	7.63	268	9	142	3.8	(-)	(-)	35	0.2	3.5	1.9	3	ND	21x10^11	3.6			
19		Okhla New (SUEZ India Pvt. Ltd.) ASP	124	As per DPCC limits	7.75	8.25	280	8	120	2.4	(-)	(-)	20	0.1	3.4	3.4	3	ND	75x10^10	35			
20		Mehrauli (DJB) E.A	5	As per plant design TSS:50/BOD:30/COD:50	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
21		Molar band (DJB)																					

[illegible]



[illegible]

[illegible]



[illegible]

[illegible]

[illegible]

DATE OF ANALYSIS : 07-09-2020																								
	S.No.	Lab	Sewage Treatment Plant (Operator) Technology	Capacity	DPCC Parameter (mg/l) (TSS:10/BOD:10, COD:50, NH4-N:5, PO4-P:2, Oil& grease : 10, f.coliform: 230 MPN/100ml)	pH		TSS		BOD (3 DAYS at 27 0 C)		COD		Ammonical nitrogen		Dissolve phosphate		Oil & Grease		Fecal Coliform (72 hrs)		Remarks		
						INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET		INLET	OUTLET
						(MGD)	Parameter Limits				-	-	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l		mg/l	mg/l
	1	Keshapur	Keshopur Ph-I (VA-TECH WABAG LTD.) ASP	12	As per plant design TSS:30/BOD:20/COD:50/NH4-N:5/PO4:2/O &G:1.2/f.c:2500 MPN/100ml	7.21	7.54	90	7	140	6	390	20	39	0.1	3.2	1.8	-	-	24*10^11+	75			
	2		Keshopur Ph-II (Ayaappa Pvt.Ltd) ASP(IFAS)	20	As per DPCC limits	7.28	7.46	330	6	170	6	459	19	38	3	3.6	0.6	-	-	24*10^11+	93			
	3		Keshopur Ph-III (Ayaappa Pvt.Ltd) ASP	60	As per DPCC limits	7.26	7.5	302	6	165	5	423	17	31	1.5	2.8	1	-	-	24*10^11+	160			
	4		Kapashera (Triveni Pvt. Ltd) SBR	5	As per plant design TSS:10/BOD:10/COD:50/NH4: 5/O&G:1.2/PO4:1/f.C:1000/100ml	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	5	Kondli	Kondli Ph-I (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	7.2	7.6	264	6	140	5	460	18	35	Nil	3.8	0.8	11.2	Nil	1100X10^12	3			
	6		Kondli Ph-II (Triveni Pvt. Ltd) ASP	25	As per DPCC limits	7.2	7.5	264	7	140	6	460	16	35	1.5	3.8	0.5	11.2	Nil	1100X10^12	7.3			
	7		Kondli Ph-III (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	7.2	7.5	264	7	140	6	460	16	35	1.5	3.8	0.5	11.2	Nil	1100X10^12	7.3			
	8		Kondli Ph-IV (Ayaappa Pvt.Ltd) ASP(IFAS)	45	As per DPCC limits	7.2	7.6	264	8	140	5	460	20	35	1	3.8	0.3	11.2	Nil	1100X10^12	7.2			
	9		Chilla (HNB Engineers) C-ISBR	9	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	10		CWG (M/s Toshiba Water Soluti on Pvt. Ltd.) MBR	1	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	11	N.S.T.P.C Pillar	Coronation Pillar Ph-II (DRA Infracom Pvt.Ltd.) ASP(IFAS)	20	As per plant design TSS:30/BOD:20/COD:50/NH4-N:5/PO4:1/O &G:1.2/f.c:230	7	7.6	138	7	72	3	402	14	24	0.5	2.1	0.7			-	-			
	12		Coronation Pillar Ph-III (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits	7.1	7.6	142	8	76	4	356	17	26	0.6	2.6	0.8			-	-			
	13		Coronation New (L&T Construction and PASSAVANT (JV)) ASP	70	As per DPCC limits	7	7.6	304	7	110	3	366	17	29	0.5	3	0.9	2.4	bdl	-	-			
	14		Narela (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits	7.1	7.5	372	10	165	6	442	19	38	0.9	2.9	0.8	2.8	bdl	-	-			
	15	Nilothi	Nilothi Ph-I (SUBHASH INFRA PVT. LTD) ASP(IFAS)	60	As per DPCC limits	7.64	7.7	390	5	213	5	-	-	24	4.2	2.9	0.1			29x10^8	75			
	16		Nilothi Ph-II (VEOLIA INDIA) ASP	20	As per DPCC limits	7.69	7.75	350	7	195	8	-	-	22.5	4.9	2.7	0.5			15x10^8	93			
	17	Okhla	Okhla Ph-V (DJB) ASP	16	As per plant design TSS:50/BOD:30/COD:50	7.1	7.5	138	10	128	12.7	(-)	(-)	30	20	2.3	3.4	2	ND	24x10^12	20			
	18		Okhla Ph-VI (SUEZ India Pvt. Ltd.) ASP	30	As per DPCC limits	7	7.4	264	7	210	2.5	(-)	(-)	35	ND	1.5	ND	3	ND	24X10^12	<1.8			
	19		Okhla New (SUEZ India Pvt. Ltd.) ASP	124	As per DPCC limits	7.1	7.5	214	7	106	4.3	(-)	(-)	30	0.2	1.8	1.7	3	ND	75X10^9	35X10^2			
	20		Mehrauli (DJB) E.A	5	As per plant design TSS:50/BOD:30/COD:50	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	21		Molar band (DJB)	0.66	As per plant design TSS:50/BOD:30/COD:50	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	22		Ghitorini (DJB) ASP	5	As per plant design TSS:50/BOD:30/COD:50	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	23		Vasant Kunj Ph-I (DJB) E.A	2.2	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	24		Vasant Kunj Ph-II (DJB) E.A	3	As per plant design TSS:50/BOD:30/COD:50	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	25		Delhi Gate Ph-I (Degramont) B & D	2.2	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			

ASP	Activated Sludge Process
ASP(IFAS)	Activated Sludge Process with Integrated Fixed-film Activated Sludge
E.A	Extended Aeration
FAB	Fluidized Aerobic Bed
B & D	Biofor and dansadeg
C-ISBR	Combitreat-ISBR
W	Waiting
ND	Not Detectable
BDL	Bellow Detection Limit

[illegible]

[illegible]

[illegible]



[illegible]

[illegible]



[illegible]

[illegible]



[illegible]

[illegible]



4/14/2028

[illegible]

ASP	Activated Sludge Process
ASP(IFAS)	Activated Sludge Process with Integrated Fixed-film Activated Sludge
E.A	Extended Aeration
FAB	Fluidized Aerobic Bed
B & D	Biofor and dansadeg
C-ISBR	Combitreat-ISBR
W	Waiting
ND	Not Detectable
BDL	Bellow Detection Limit

DELHI JAL BOARD

DAILY ANALYSIS REPORT OF ALL SEWAGE TREATMENT PLANT

DATE OF ANALYSIS : 15.04.2026

4/15/2020

[illegible]

[illegible]

DELHI JAL BOARD

DAILY ANALYSIS REPORT OF ALL SEWAGE TREATMENT PLANT

DATE OF ANALYSIS : 16.04.2026

4/16/2026

DATE OF ANALYSIS : 10-09-2020																					
S.No.	Lab	Sewage Treatment Plant (Operator) Technology	Capacity	DPCC Parameter (mg/l) (TSS:10,BOD:10, COD:50, NH4-N:5,PO4-P:2, Oil& grease : 10, f.coliform: 230 MPN/100ml)	pH		TSS		BOD (3 DAYS at 27 0 C)		COD		Ammonical nitrogen		Dissolve phosphate		Oil & Grease		Fecal Coliform (72 hrs)		Remarks
					INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	
			(MGD)	Parameter Limits	-	-	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	
1	Keshopur	Keshopur Ph-I (VA-TECH WABAG LTD.) ASP	12	As per plant design TSS:30/BOD:20/COD:50/NH4-N:5/PO4-2/O &G:1.2/f.c:2500 MPN/100ml	7.74	7.83	77	10	-	-	-	-	48	8	2.5	4.5	-	-	24*10^11+	460	
2		Keshopur Ph-II (Ayaappa Pvt.Ltd) ASP(IFAS)	20	As per DPCC limits	7.78	7.9	318	6	-	-	-	-	55	5.2	2.4	0.8	-	-	24*10^11+	290	
3		Keshopur Ph-III (Ayaappa Pvt.Ltd) ASP	60	As per DPCC limits	7.8	7.94	310	4	-	-	-	-	35	5.4	3	0.4	-	-	24*10^11+	460	
4		Kapashera (Triveni Pvt. Ltd) SBR	5	As per plant design TSS:10/BOD:10/COD:50/NH4: 5/O&G:1.2/PO4:1/f.C:1000/100ml	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
5	Kondli	Kondli Ph-I (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	7	7.5	264	8	142	6	482	15	35	ND	3.2	0.6	-	-	210 X 10^12	30	
6		Kondli Ph-II (Triveni Pvt. Ltd) ASP	25	As per DPCC limits	7	7.6	264	9	142	7	482	22	35	1	3.2	0.6	-	-	210 X 10^12	72	
7		Kondli Ph-III (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	7	7.6	264	9	142	7	482	22	35	1	3.2	0.6	-	-	210 X 10^12	72	
8		Kondli Ph-IV (Ayaappa Pvt.Ltd) ASP(IFAS)	45	As per DPCC limits	7	7.5	264	7	142	5	482	20	35	0.8	3.2	0.5	-	-	210 X 10^12	73	
9		Chilla (HNB Engineers) C-ISBR	9	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
10		CWG (M/s Toshiba Water Soluti on Pvt. Ltd.) MBR	1	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
11	N.S.T.P.C Pillar	Coronation Pillar Ph-II (DRA Infracom Pvt.Ltd.) ASP(IFAS)	20	As per plant design TSS:30/BOD:20/COD:50/NH4-N:5/PO4:1/O &G:1.2/f.c:230	7.46	7.38	220	10	148	6	334	19	25	0.8	2.6	0.9			43x10^9	21	
12		Coronation Pillar Ph-III (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits	7.5	7.64	210	8	140	4	320	17	20	0.7	2.2	0.8			93x10^8	20	
13		Coronation New (L&T Construction and PASSAVANT (JV)) ASP	70	As per DPCC limits	7.6	7.74	240	9	157	5	390	19	28	0.8	3	0.9	3	bdl	46x10^10	21	
14		Narela (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits	7.5	7.8	302	10	236	6	498	20	34	0.9	3.2	1	4	0.4	24x10^10	15	
15	Nilothi	Nilothi Ph-I (SUBHASH INFRA PVT. LTD) ASP(IFAS)	60	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
16		Nilothi Ph-II (VEOLIA INDIA) ASP	20	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
17	Okhla	Okhla Ph-V (DJB) ASP	16	As per plant design TSS:50/BOD:30/COD:50	7.78	8.04	358	5	315	6	-	-	35	10	3.2	0.9	5	ND	46x10^10	93x10^2	
18		Okhla Ph-VI (SUEZ India Pvt. Ltd.) ASP	30	As per DPCC limits	7.77	8.5	328	6	305	5	-	-	40	ND	2.8	0.1	4	ND	11x10^13	<1.8	
19		Okhla New (SUEZ India Pvt. Ltd.) ASP	124	As per DPCC limits	7.65	8.11	306	5	215	5	-	-	30	0.1	2.5	1.7	5	ND	24x10^12	75	
20		Mehrauli (DJB) E.A	5	As per plant design TSS:50/BOD:30/COD:50	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
21		Molar band (DJB)	0.66	As per plant design TSS:50/BOD:30/COD:50</																	

[illegible]



4/17/2026

Sl. No.	S.No.	Lab	Sewage Treatment Plant (Operator) Technology	Capacity	DPCC Parameter (mg/l) (TSS:10,BOD:10, COD:50, NH4-N:5,PO4-P:2, Oil& grease : 10, f.coliform: 230 MPN/100ml)	pH		TSS		BOD (3 DAYS at 27 0 C)		COD		Ammonical nitrogen		Dissolve phosphate		Oil & Grease		Fecal Coliform (72 hrs)		Remarks		
						INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET		INLET	OUTLET
						(MGD)	Parameter Limits				-	-	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l		mg/l	MPN/100ml
	1	Keshopur	Keshopur Ph-I (VA-TECH WABAG LTD.) ASP	12	As per plant design TSS:30/BOD:20/COD:50/NH4-N:5/PO4:2/O &G:1.2/f.C:2500 MPN/100ml	7.81	7.94	82	6	140	5	380	24	50	7	3	4	10.06	0	24*10^11+	2400			
	2		Keshopur Ph-II (Ayaappa Pvt.Ltd) ASP(IFAS)	20	As per DPCC limits	7.83	8.04	323	7	190	6	530	28	48	5	3.4	0.8	11.64	0	24*10^11+	150			
	3		Keshopur Ph-III (Ayaappa Pvt.Ltd) ASP	60	As per DPCC limits	7.78	7.97	302	5	180	4	490	25	40	5.8	3.5	1	11.98	0	24*10^11+	1100			
	4		Kapashera (Triveni Pvt. Ltd) SBR	5	As per plant design TSS:10/BOD:10/COD:50/NH4: 5/O&G:1.2/PO4:1/f.C:1000/100ml	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	5	Kondli	Kondli Ph-I (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	7	7.5	288	9	157	7	464	23	32	Nil	3	0.8			1100X10^12	36			
	6		Kondli Ph-II (Triveni Pvt. Ltd) ASP	25	As per DPCC limits	7	7.6	288	7	157	5	464	16	32	1	3	0.5			1100X10^12	110			
	7		Kondli Ph-III (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	7	7.6	288	7	157	5	464	16	32	1	3	0.5			1100X10^12	110			
	8		Kondli Ph-IV (Ayaappa Pvt.Ltd) ASP(IFAS)	45	As per DPCC limits	7	7.5	288	8	157	6	464	20	32	0.5	3	0.6			1100X10^12	91			
	9		Chilla (HNB Engineers) C-ISBR	9	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	10		CWG (M/s Toshiba Water Soluti on Pvt. Ltd.) MBR	1	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	11	N.S.T.P.C.Pillar	Coronation Pillar Ph-II (DRA Infracom Pvt.Ltd.) ASP(IFAS)	20	As per plant design TSS:30/BOD:20/COD:50/NH4-N:5/PO4:1/O &G:1.2/f.C:230	7.41	7.57	206	9	107	5	594	18	25	0.5	2	0.8	2.4	bdl	-	-			
	12		Coronation Pillar Ph-III (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits	7.47	7.56	200	8	103	4	245	13	30	0.5	2.5	0.9	2.2	bdl	-	-			
	13		Coronation New (L&T Construction and PASSAVANT (JV)) ASP	70	As per DPCC limits	7.53	7.68	230	9	122	5	512	14	32	0.7	3.2	1			-	-			
	14		Narela (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits															-	-			
	15	Nilothi	Nilothi Ph-I (SUBHASH INFRA PVT. LTD) ASP(IFAS)	60	As per DPCC limits	7.69	7.72	244	3	165	5	-	-	26.7	3.1	3.4	0.1			42x10^7	93			
	16		Nilothi Ph-II (VEOLIA INDIA) ASP	20	As per DPCC limits	7.64	7.7	408	3	228	6	-	-	26	3.5	2.9	1			15x10^8	120			
	17	Okhla	Okhla Ph-V (DJB) ASP	16	As per plant design TSS:50/BOD:30/COD:50	7.6	7.4	340	6	305	12	(-)	(-)	30	20	4	1.3	5	ND					
	18		Okhla Ph-VI (SUEZ India Pvt. Ltd.) ASP	30	As per DPCC limits	7.6	8.3	344	5	300	3	-	-	30	0.1	4.2	ND	4	ND					
	19		Okhla New (SUEZ India Pvt. Ltd.) ASP	124	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	20		Mehrauli (DJB) E.A	5	As per plant design TSS:50/BOD:30/COD:50	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	21		Molar band (DJB)	0.66	As per plant design TSS:50/BOD:30/COD:50	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	22		Ghitorini (DJB) ASP	5	As per plant design TSS:50/BOD:30/COD:50	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	23		Vasant Kunj Ph-I (DJB) E.A	2.2	As per plant design TSS:50/BOD:30/COD:50	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	24		Vasant Kunj Ph-II (DJB) E.A	3	As per plant design TSS:50/BOD:30/COD:50	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	25		Delhi Gate Ph-I (Degramont) B & D	2.2	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			

[illegible]

DELHI JAL BOARD

DAILY ANALYSIS REPORT OF ALL SEWAGE TREATMENT PLANT

DATE OF ANALYSIS : 18.04.2026

4/18/2008

DATE OF ANALYSIS : 16.04.2026																							
S.No.	Lab	Sewage Treatment Plant (Operator) Technology	Capacity	DPCC Parameter (mg/l) (TSS:10,BOD:10, COD:50, NH4-N:5,PO4-P:2, Oil& grease : 10, f.coliform: 230 MPN/100ml)	pH		TSS		BOD (3 DAYS at 27 0 C)		COD		Ammonical nitrogen		Dissolve phosphate		Oil & Grease		Fecal Coliform (72 hrs)		Remarks		
					INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET		INLET	OUTLET
					(MGD)	Parameter Limits	-	-	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l		mg/l	MPN/100ml
1	Keshopur	Keshopur Ph-I (VA-TECH WABAG LTD.) ASP	12	As per plant design TSS:30/BOD:20/COD:50/NH4-N:5/PO4:2/O &G:1.2/f.C:2500 MPN/100ml	7.48	7.62	215	11	160	3	440	20	30	5.8	1.5	3	11.12	Nil	24*10^12+	460			
2		Keshopur Ph-II (Ayaappa Pvt.Ltd) ASP(IFAS)	20	As per DPCC limits	7.49	7.69	280	8	175	7	480	24	40	3.5	2.5	0.5	12.36	Nil	24*10^12+	93			
3		Keshopur Ph-III (Ayaappa Pvt.Ltd) ASP	60	As per DPCC limits	7.46	7.72	395	4	185	3	510	26	35	4	2.7	0.8	10.41	Nil	24*10^12+	150			
4		Kapashera (Triveni Pvt. Ltd) SBR	5	As per plant design TSS:10/BOD:10/COD:50/NH4: 5/O&G:1.2/PO4:1/f.C:1000/100ml	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
5	Kondli	Kondli Ph-I (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	6.9	7.6	264	7	145	5	422	14	32	0.5	3.5	0.8			1100X10^14	30			
6		Kondli Ph-II (Triveni Pvt. Ltd) ASP	25	As per DPCC limits	6.9	7.5	264	8	145	6	422	19	32	1	3.5	0.5			1100X10^14	91			
7		Kondli Ph-III (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	6.9	7.5	264	8	145	6	422	19	32	1	3.5	0.5			1100X10^14	91			
8		Kondli Ph-IV (Ayaappa Pvt.Ltd) ASP(IFAS)	45	As per DPCC limits	6.9	7.6	264	9	145	6	422	16	32	1	3.5	0.8			1100X10^14	150			
9		Chilla (HNB Engineers) C-ISBR	9	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
10		CWG (M/s Toshiba Water Soluti on Pvt. Ltd.) MBR	1	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
11	N.S.T.P.C.Pillar	Coronation Pillar Ph-II (DRA Infracom Pvt.Ltd.) ASP(IFAS)	20	As per plant design TSS:30/BOD:20/COD:50/NH4-N:5/PO4:1/O &G:1.2/f.C:230	7.5	7.75	230	9	116	5	419	19	24	0.5	2.1	0.5			93x10^11	15			
12		Coronation Pillar Ph-III (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits	7.6	7.67	302	6	135	3	582	14	30	0.5	2.4	0.6			43x10^7	21			
13		Coronation New (L&T Construction and PASSAVANT (JV)) ASP	70	As per DPCC limits	7.7	7.94	174	8	103	4	628	16	34	0.5	3.4	0.5	2.2	bdI	23x10^7	75			
14		Narela (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits	7.57	7.92	478	10	172	6	897	19	44	0.8	4.8	0.9	3	bdI	28x10^10	15			
15	Nilothi	Nilothi Ph-I (SUBHASH INFRA PVT. LTD) ASP(IFAS)	60	As per DPCC limits	8.59	7.64	356	2	210	4	-	-	26.2	3.2	3.2	0.1			53x10^7	75			
16		Nilothi Ph-II (VEOLIA INDIA) ASP	20	As per DPCC limits	7.78	7.81	352	5	195	8	-	-	25.5	3.5	3	1.2			43x10^7	93			
17	Okhla	Okhla Ph-V (DJB) ASP	16	As per plant design TSS:50/BOD:30/COD:50	7.7	8.3	404	5	203	2.5	(-)	(-)	30	0.1	3.4	1.8	4	ND	21x10^11	<1.8			
18		Okhla Ph-VI (SUEZ India Pvt. Ltd.) ASP	30	As per DPCC limits	7.5	8.1	296	5	125	3.7	(-)	(-)	25	0.1	3.4	2.3	5	ND	24x10^12	2400			
19		Okhla New (SUEZ India Pvt. Ltd.) ASP	124	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
20		Mehrauli (DJB) E.A	5	As per plant design TSS:50/BOD:30/COD:50	8.23	8.36	326	40	305	26.5	536	83	60										

[illegible]



4/19/2026

DATE OF ANALYSIS : 15-09-2020																							
S.No.	Lab	Sewage Treatment Plant (Operator) Technology	Capacity	DPCC Parameter (mg/l) (TSS:10,BOD:10, COD:50, NH4-N:5,PO4-P:2, Oil& grease : 10, f.coliform: 230 MPN/100ml)	pH		TSS		BOD (3 DAYS at 27 O C)		COD		Ammonical nitrogen		Dissolve phosphate		Oil & Grease		Fecal Coliform (72 hrs)		Remarks		
					INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET		INLET	OUTLET
					(MGD)	Parameter Limits		-	-	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l		mg/l	mg/l
1	Keshopur	Keshopur Ph-I (VA-TECH WABAG LTD.) ASP	12	As per plant design TSS:30/BOD:20/COD:50/NH4-N:5/PO4:2/O &G:1.2/f.C:2500 MPN/100ml	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
2		Keshopur Ph-II (Ayaappa Pvt.Ltd) ASP(IFAS)	20	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
3		Keshopur Ph-III (Ayaappa Pvt.Ltd) ASP	60	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
4		Kapashera (Triveni Pvt. Ltd) SBR	5	As per plant design TSS:10/BOD:10/COD:50/NH4: 5/O&G:1.2/PO4:1/f.C:1000/100ml	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
5	Kondli	Kondli Ph-I (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	7.1	7.5	278	07	150	05	470	18	35	Nil	3.5	0.5			-	-			
6		Kondli Ph-II (Triveni Pvt. Ltd) ASP	25	As per DPCC limits	7.1	7.6	278	09	150	07	470	20	35	1	3.5	0.8			-	-			
7		Kondli Ph-III (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	7.1	7.6	278	09	150	07	470	20	35	1	3.5	0.8			-	-			
8		Kondli Ph-IV (Ayaappa Pvt.Ltd) ASP(IFAS)	45	As per DPCC limits	7.1	7.5	278	08	150	06	470	15	35	0.8	3.5	0.8			-	-			
9		Chilla (HNB Engineers) C-ISBR	9	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
10		CWG (M/s Toshiba Water Soluti on Pvt. Ltd.) MBR	1	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
11	N.S.T.P.C Pillar	Coronation Pillar Ph-II (DRA Infracom Pvt.Ltd.) ASP(IFAS)	20	As per plant design TSS:30/BOD:20/COD:50/NH4-N:5/PO4:1/O &G:1.2/f.C:230	7.4	7.7	254	8	147	4	380	17	25	0.6	2	0.7			-	-			
12		Coronation Pillar Ph-III (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits	7.6	7.68	284	7	163	4	396	18	29	0.5	2.5	0.6			-	-			
13		Coronation New (L&T Construction and PASSAVANT (JV)) ASP	70	As per DPCC limits	7.62	7.8	224	5	122	3	374	14	33	0.6	3.5	0.9			-	-			
14		Narela (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits															-	-			
15	Nilothi	Nilothi Ph-I (SUBHASH INFRA PVT. LTD) ASP(IFAS)	60	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
16		Nilothi Ph-II (VEOLIA INDIA) ASP	20	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
17	Okhla	Okhla Ph-V (DJB) ASP	16	As per plant design TSS:50/BOD:30/COD:50	7.5	7.4	214	16	205	15.9	(-)	(-)	42	20	2.2	1.2	4	ND	24x10^10	46x10^3			
18		Okhla Ph-VI (SUEZ India Pvt. Ltd.) ASP	30	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
19		Okhla New (SUEZ India Pvt. Ltd.) ASP	124	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
20		Mehrauli (DJB) E.A	5	As per plant design TSS:50/BOD:30/COD:50	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
21		Molar band (DJB)	0.66	As per plant design TSS:50/BOD:30/COD:50	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
22		Ghitorini (DJB) ASP	5	As per plant design TSS:50/BOD:30/COD:50	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
23		Vasant Kunj Ph-I (DJB) E.A	2.2	As per plant design TSS:50/BOD:30/COD:50	-	-	-	-															

[illegible]



4/20/2028

[illegible]

[illegible]

DELHI JAL BOARD

DAILY ANALYSIS REPORT OF ALL SEWAGE TREATMENT PLANT

DATE OF ANALYSIS : 21.04.2026

4210026

431(2018)																											
		S.No.	Lab	Sewage Treatment Plant (Operator) Technology	Capacity	DPCC Parameter (mg/l) (TSS:10,BOD:10, COD:50, NH4-N:5,PO4-P:2, Oil& grease : 10, f.coliform: 230 MPN/100ml)	pH		TSS		BOD (3 DAYS at 27 O C)		COD		Ammonical nitrogen		Dissolve phosphate		Oil & Grease		Fecal Coliform (72 hrs)		Remarks				
							INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET		INLET	OUTLET	INLET	OUTLET
							(MGD)	Parameter Limits		-	-	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l		mg/l	mg/l	MPN/100ml	MPN/100ml
		1	Keshopur	Keshopur Ph-I (VA-TECH WABAG LTD.) ASP	12	As per plant design TSS:30/BOD:20/COD:50/NH4-N:5/PO4:2/O &G:1.2/f.c:2500 MPN/100ml	7.28	7.5	71	9	145	7	327	24	35	5	3	4	7.89	Nil	24*10^11+	210					
		2		Keshopur Ph-II (Ayaappa Pvt.Ltd) ASP(IFAS)	20	As per DPCC limits	7.37	7.57	339	7	158	6	411	22	32	4.5	2.8	0.3	6.92	Nil	24*10^11+	150					
		3		Keshopur Ph-III (Ayaappa Pvt.Ltd) ASP	60	As per DPCC limits	7.4	7.59	321	5	160	4	452	19	30	4.8	2.5	0.2	7.11	Nil	24*10^11+	150					
		4		Kapashera (Triveni Pvt. Ltd) SBR	5	As per plant design TSS:10/BOD:10/COD:50/NH4: 5/O&G:1.2/PO4:1/LC:1000/100ml	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-					
		5	Kondli	Kondli Ph-I (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	7.1	7.5	270	7	152	5	480	10	35	0.5	3.2	0.5	11.9	Nil	1100X10^12	36					
		6		Kondli Ph-II (Triveni Pvt. Ltd) ASP	25	As per DPCC limits	7.1	7.6	270	7	152	5	480	15	35	1.5	3.2	0.5	11.9	Nil	1100X10^12	91					
		7		Kondli Ph-III (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	7.1	7.6	270	7	152	5	480	15	35	1.5	3.2	0.5	11.9	Nil	1100X10^12	91					
		8		Kondli Ph-IV (Ayaappa Pvt.Ltd) ASP(IFAS)	45	As per DPCC limits	7.1	7.5	270	9	152	7	480	20	35	1	3.2	0.6	11.9	Nil	1100X10^12	210					
		9		Chilla (HNB Engineers) C-ISBR	9	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-					
		10		CWG (M/s Toshiba Water Soluti on Pvt. Ltd.) MBR	1	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-					
		11	N.S.T.P.C Pillar	Coronation Pillar Ph-II (DRA Infracom Pvt.Ltd.) ASP(IFAS)	20	As per plant design TSS:30/BOD:20/COD:50/NH4-N:5/PO4:1/O &G:1.2/f.c:230	7.3	7.58	254	09	182	05	358	17	29	0.5	2.5	0.8			-	-					
		12		Coronation Pillar Ph-III (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits	7.39	7.59	188	05	112	03	290	16	26	0.5	2	0.7			-	-					
		13		Coronation New (L&T Construction and PASSAVANT (JV)) ASP	70	As per DPCC limits	7.48	7.63	276	07	198	05	390	15	32	0.6	3	0.9	2.6	bdl	-	-					
		14		Narela (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits	8.03	8.7	516	10	320	06	680	19	40	0.8	3.8	0.9	3.4	bdl	-	-					
		15	Nilothi	Niliothi Ph-I (SUBHASH INFRA PVT. LTD) ASP(IFAS)	60	As per DPCC limits	7.62	7.71	320	2	195	3	-	-	27	3	2.6	0.1			21x10^7	120					
		16		Niliothi Ph-II (VEOLIA INDIA) ASP	20	As per DPCC limits	7.41	7.49	280	4	160	5	-	-	26	3.2	2.4	1.2			14x10^7	150					
		17	Okhla	Okhla Ph-V (DJB) ASP	16	As per plant design TSS:50/BOD:30/COD:50	7.6	7.6	172	17	85.5	15.3	(-)	(-)	35	22.5	3.2	2.1	4	ND	75 x10^9	43x10^2					
		18		Okhla Ph-VI (SUEZ India Pvt. Ltd.) ASP	30	As per DPCC limits	7.4	8.3	286	5	175	3.4	(-)	(-)	30	0.15	3	ND	5	ND	24x10^11	<1.8					
		19		Okhla New (SUEZ India Pvt. Ltd.) ASP	124	As per DPCC limits	7.2	7.5	312	7	1																

[illegible]

DELHI JAL BOARD

DAILY ANALYSIS REPORT OF ALL SEWAGE TREATMENT PLANT

DATE OF ANALYSIS : 22.04.2026

4/22/2026

DATE OF ANALYSIS : 22-04-2024																					
S.No.	Lab	Sewage Treatment Plant (Operator) Technology	Capacity	DPCC Parameter (mg/l) (TSS:10,BOD:10, COD:50, NH4-N:5,PO4-P:2, Oil& grease : 10, f.coliform: 230 MPN/100ml)	pH		TSS		BOD (3 DAYS at 27 O C)		COD		Ammonical nitrogen		Dissolve phosphate		Oil & Grease		Fecal Coliform (72 hrs)		Remarks
					INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	
			(MGD)	Parameter Limits	-	-	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	
1	Keshopur	Keshopur Ph-I (VA-TECH WABAG LTD.) ASP	12	As per plant design TSS:30/BOD:20/COD:50/NH4-N:5/PO4:2/O &G:1.2/f.c:2500 MPN/100ml	7.35	7.59	78	10	155	3	410	18	40	6.6	3.2	4.2	-	-	24*10^11+	460	
2		Keshopur Ph-II (Ayaappa Pvt.Ltd) ASP(IFAS)	20	As per DPCC limits	7.5	7.6	307	9	185	5	510	24	30	3	3	0.9	-	-	24*10^11+	150	
3		Keshopur Ph-III (Ayaappa Pvt.Ltd) ASP	60	As per DPCC limits	7.37	7.55	276	9	175	7	473	28	32	3.5	2.8	0.7	-	-	24*10^11+	210	
4		Kapashera (Triveni Pvt. Ltd) SBR	5	As per plant design TSS:10/BOD:10/COD:50/NH4: 5/O&G:1.2/PO4:1/f.c:1000/100ml	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
5	Kondli	Kondli Ph-I (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	7.3	7.6	264	8	140	6	460	10	32	0.5	3.5	0.8			1100*10^11	36	
6		Kondli Ph-II (Triveni Pvt. Ltd) ASP	25	As per DPCC limits	7.3	7.5	264	8	140	5	460	20	32	1.8	3.5	0.5			1100*10^11	73	
7		Kondli Ph-III (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	7.3	7.5	264	8	140	5	460	20	32	1.8	3.5	0.5			1100*10^11	73	
8		Kondli Ph-IV (Ayaappa Pvt.Ltd) ASP(IFAS)	45	As per DPCC limits	7.3	7.6	264	7	140	6	460	15	32	1.5	3.5	0.8			1100*10^11	91	
9		Chilla (HNB Engineers) C-ISBR	9	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
10		CWG (M/s Toshiba Water Soluti on Pvt. Ltd.) MBR	1	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
11	N.S.T.P.C Pillar	Coronation Pillar Ph-II (DRA Infracom Pvt.Ltd.) ASP(IFAS)	20	As per plant design TSS:30/BOD:20/COD:50/NH4-N:5/PO4:1/O &G:1.2/f.c:230	7.32	7.48	206	9	123	4	317	17	28	0.6	2.4	0.8	3	bdl	-	-	
12		Coronation Pillar Ph-III (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits	7.49	7.57	180	7	116	3	268	15	26	0.6	2.1	0.4	2.6	bdl	-	-	
13		Coronation New (L&T Construction and PASSAVANT (JV)) ASP	70	As per DPCC limits	7.3	7.68	240	8	127	4	410	16	38	0.5	3.4	0.9			-	-	
14		Narela (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits															-	-	
15	Nilothi	Nilothi Ph-I (SUBHASH INFRA PVT. LTD) ASP(IFAS)	60	As per DPCC limits	7.41	7.54	324	6	183	5	-	-	29.2	3	3.8	0.1			93x10^7	75	
16		Nilothi Ph-II (VEOLIA INDIA) ASP	20	As per DPCC limits	7.55	7.64	332	8	205	7	-	-	26.5	2.9	2.9	1			42x10^7	120	
17	Okhla	Okhla Ph-V (DJB) ASP	16	As per plant design TSS:50/BOD:30/COD:50	7.5	7.7	154	12	218	13.6	(-)	(-)	35	20	2.7	1.5	4	ND	46 x10^10	21x10^3	
18		Okhla Ph-VI (SUEZ India Pvt. Ltd.) ASP	30	As per DPCC limits	7.6	8.4	278	5	188	3.6	(-)	(-)	35	0.2	2.8	0.01	4	ND	24x10^12	<1.8	
19		Okhla New (SUEZ India Pvt. Ltd.) ASP	124	As per DPCC limits	7.2	7.5	282	5	139	5.3	(-)	(-)	35	0.2	3.5	2	4	ND	46x10^12	21	
20		Mehrauli (DJB) E.A	5	As per plant design TSS:50/BOD:30/COD:50	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
21		Molar band (DJB)																			

[illegible]



DELHI JAL BOARD

DAILY ANALYSIS REPORT OF ALL SEWAGE TREATMENT PLANT

DATE OF ANALYSIS : 23.04.2026

403/2026

S.No.	Lab	Sewage Treatment Plant (Operator) Technology	Capacity (MGD)	DPCC Parameter (mg/l) (TSS:10,BOD:10, COD:50, NH4-N:5,PO4-P:2, Oil& grease : 10, f.coliform: 230 MPN/100ml)	pH		TSS		BOD (3 DAYS at 27 0 C)		COD		Ammonical nitrogen		Dissolve phosphate		Oil & Grease		Fecal Coliform (72 hrs)		Remarks
					INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	
					-	-	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	MPN/100ml	MPN/100ml	
1	Keshopur	Keshopur Ph-I (VA-TECH WABAG LTD.) ASP	12	As per plant design TSS:30/BOD:20/COD:50/NH4-N:5/PO4:2/O &G:1.2/f.C:2500 MPN/100ml	7.38	7.61	88	17	-	-	-	-	30	6	2.8	4.2	9.68	Nil	24*10^11+	1100	
2		Keshopur Ph-II (Ayaappa Pvt.Ltd) ASP(IFAS)	20	As per DPCC limits	7.52	7.63	323	16	-	-	-	-	32	3.8	2.5	0.8	9.12	Nil	24*10^11+	210	
3		Keshopur Ph-III (Ayaappa Pvt.Ltd) ASP	60	As per DPCC limits	7.4	7.58	276	9	-	-	-	-	28	3.9	2.8	0.9	10.04	Nil	24*10^11+	150	
4		Kapashera (Triveni Pvt. Ltd) SBR	5	As per plant design TSS:10/BOD:10/COD:50/NH4: 5/O&G:1.2/PO4:1/f.C:1000/100ml	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
5	Kondli	Kondli Ph-I (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	7.1	7.5	258	7	145	5	482	15	32	0.5	3.5	0.5			210X10^11	3	
6		Kondli Ph-II (Triveni Pvt. Ltd) ASP	25	As per DPCC limits	7.1	7.6	258	9	145	7	482	22	32	1.5	3.5	0.8			210X10^11	11	
7		Kondli Ph-III (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	7.1	7.6	258	9	145	7	482	22	32	1.5	3.5	0.8			210X10^11	11	
8		Kondli Ph-IV (Ayaappa Pvt.Ltd) ASP(IFAS)	45	As per DPCC limits	7.1	7.6	258	8	145	5	482	21	32	1.5	3.5	0.5			210X10^11	7.3	
9		Chilla (HNB Engineers) C-ISBR	9	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
10		CWG (M/s Toshiba Water Soluti on Pvt. Ltd.) MBR	1	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
11	N.S.I.P.C Pillar	Coronation Pillar Ph-II (DRA Infracom Pvt.Ltd.) ASP(IFAS)	20	As per plant design TSS:30/BOD:20/COD:50/NH4-N:5/PO4:1/O &G:1.2/f.C:230	7.34	7.6	202	8	117	5	392	17	24	0.6	2.2	0.7			-	9.1	
12		Coronation Pillar Ph-III (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits	7.34	7.56	178	5	97	3	286	14	20	0.5	2.1	0.8			-	21	
13		Coronation New (L&T Construction and PASSAVANT (JV)) ASP	70	As per DPCC limits	7.4	7.62	180	7	87	4	290	16	32	0.5	3	0.9	2.4	bdl	-	43	
14		Narela (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits	7.34	8.4	386	9	137	5	536	20	36	0.7	4.8	0.8	3.2	bdl	-	-	
15	Nilothi	Nilothi Ph-I (SUBHASH INFRA PVT. LTD) ASP(IFAS)	60	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
16		Nilothi Ph-II (VEOLIA INDIA) ASP	20	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
17	Okhla	Okhla Ph-V (DJB) ASP	16	As per plant design TSS:50/BOD:30/COD:50	7	7.7	352	14	240	6	1012	22	38	25	4	1	5	ND	43 x10^9	75 x10^2	
18		Okhla Ph-VI (SUEZ India Pvt. Ltd.) ASP	30	As per DPCC limits	7.4	8.5	330	6	270	5	632	39	30	0.1	4.6	0.05	4	ND	75x10^11	<1.8	
19		Okhla New (SUEZ India Pvt. Ltd.) ASP	124	As per DPCC limits	7.1	7.4	278	6	205	6	427	26	20	0.1	3.8	2	5	ND	15x10^12	93	
20		Mehrauli (DJB) E.A	5	As per plant design TSS:50/BOD:30/COD:50	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
21		Molar band (DJB)	0.66	As per plant design TSS:50/BOD:30/COD:50	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
22		Ghitorini (DJB) ASP	5	As per plant design TSS:50/BOD:30/COD:50	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
23		Vasant Kunj Ph-I (DJB) E.A	2.2	As per plant design TSS:50/BOD:30/COD:50	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
24		Vasant Kunj Ph-II (DJB) E.A	3	As per plant design TSS:50/BOD:30/COD:50	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
25		Delhi Gate Ph-I (Degramont) B & D	2.2	As per DPCC limits	7.56	7.74	156	5	240	3	598	33	22.5	3	4	2.3	4	ND	46x10^12	21x10^4	

[illegible]

DATE OF ANALYSIS : 24.04.2026

DATE OF ANALYSIS : 24-09-2020																						
S.No.	Lab	Sewage Treatment Plant (Operator) Technology	Capacity	DPCC Parameter (mg/l) (TSS:10,BOD:10, COD:50, NH4-N:5,PO4-P:2, Oil& grease : 10, f.coliform: 230 MPN/100ml)	pH		TSS		BOD (3 DAYS at 27 O C)		COD		Ammonical nitrogen		Dissolve phosphate		Oil & Grease		Fecal Coliform (72 hrs)		Remarks	
					INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET		INLET
			(MGD)	Parameter Limits	-	-	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l		mg/l
1	Keshopur	Keshopur Ph-I (VA-TECH WABAG LTD.) ASP	12	As per plant design TSS:30/BOD:20/COD:50/NH4-N:5/PO4:2/O &G:1.2/f.c:2500 MPN/100ml	7.32	7.57	60	7	135	6	370	22	35	6	2.5	3.5	9.16	Nil	24*10^11+	460		
2		Keshopur Ph-II (Ayaappa Pvt.Ltd) ASP(IFAS)	20	As per DPCC limits	7.49	7.62	305	5	155	4	440	26	30	1	1.5	0.4	8.73	Nil	24*10^11+	150		
3		Keshopur Ph-III (Ayaappa Pvt.Ltd) ASP	60	As per DPCC limits	7.44	7.56	290	3	165	3	460	24	32	1.2	1.4	0.5	8.42	Nil	24*10^11+	120		
4		Kapashera (Triveni Pvt. Ltd) SBR	5	As per plant design TSS:10/BOD:10/COD:50/NH4: 5/O&G:1.2/PO4:1/f.C:1000/100ml	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
5	Kondli	Kondli Ph-I (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	6.9	7.5	262	08	140	06	410	22	32	0.5	3	0.8			290X10^11	3.6		
6		Kondli Ph-II (Triveni Pvt. Ltd) ASP	25	As per DPCC limits	6.9	7.6	262	09	140	07	410	16	32	1.2	3	0.8			290X10^11	9.1		
7		Kondli Ph-III (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	6.9	7.6	262	09	140	07	410	16	32	1.2	3	0.8			290X10^11	9.1		
8		Kondli Ph-IV (Ayaappa Pvt.Ltd) ASP(IFAS)	45	As per DPCC limits	6.9	7.5	262	07	140	06	410	19	32	1	3	0.5			290X10^11	11		
9		Chilla (HNB Engineers) C-ISBR	9	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
10		CWG (M/s Toshiba Water Soluti on Pvt. Ltd.) MBR	1	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
11	N.S.T.P.C.Pillar	Coronation Pillar Ph-II (DRA Infracom Pvt.Ltd.) ASP(IFAS)	20	As per plant design TSS:30/BOD:20/COD:50/NH4-N:5/PO4:1/O &G:1.2/f.c:230	7.4	7.78	196	7	107	4	206	10	23	0.5	2.1	0.8	1.89	bdl	-	-		
12		Coronation Pillar Ph-III (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits	7.43	7.63	182	6	108	3	198	10	21	0.5	2.2	0.7	1.96	bdl	-	-		
13		Coronation New (L&T Construction and PASSAVANT (JV)) ASP	70	As per DPCC limits	7.52	7.69	204	8	116	4	251	12	33	0.5	2.9	0.9			-	-		
14		Narela (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits															-	-		
15	Nilothi	Nilothi Ph-I (SUBHASH INFRA PVT. LTD) ASP(IFAS)	60	As per DPCC limits	7.5	7.56	412	3	230	4	-	-	29.5	2.8	4	0.2			15x10^8	75		
16		Nilothi Ph-II (VEOLIA INDIA) ASP	20	As per DPCC limits	7.58	7.65	198	6	198	6	-	-	28	3.6	3.6	1.3			75x10^7	93		
17	Okhla	Okhla Ph-V (DJB) ASP	16	As per plant design TSS:50/BOD:30/COD:50	7.2	7.4	218	13	133	12.2			35	20	4	1.3	6	ND	75 x10^9	43 x10^2		
18		Okhla Ph-VI (SUEZ India Pvt. Ltd.) ASP	30	As per DPCC limits	7.3	8.1	212	5	190	5.2			30	0.1	3.8	0.35	4	ND	24x10^11	<1.8		
19		Okhla New (SUEZ India Pvt. Ltd.) ASP	124	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
20		Mehrauli (DJB) E.A	5	As per plant design TSS:50/BOD:30/COD:50	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
21		Molar band (DJB)	0.66	As per plant design TSS																		

[illegible]



4/25/2026

DATE OF ANALYSIS : 20/04/2020																						
S.No.	Lab	Sewage Treatment Plant (Operator) Technology	Capacity	DPCC Parameter (mg/l) (TSS:10,BOD:10, COD:50, NH4-N:5 PO4-P:2, Oil& grease : 10, f.coliform: 230 MPN/100ml)	pH		TSS		BOD (3 DAYS at 27 O C)		COD		Ammonical nitrogen		Dissolve phosphate		Oil & Grease		Fecal Coliform (72 hrs)		Remarks	
					INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET		INLET
			(MGD)	Parameter Limits	-	-	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l		mg/l
1	Keshopur	Keshopur Ph-I (VA-TECH WABAG LTD.) ASP	12	As per plant design TSS:30/BOD:20/COD:50/NH4-N:5/PO4:2/O &G:1.2/f.c:2500 MPN/100ml	7.33	7.45	71	6	130	3	355	21	40	5	2.5	4.5	8.35	Nil	24*10^11+	460		
2		Keshopur Ph-II (Ayaappa Pvt.Ltd) ASP(IFAS)	20	As per DPCC limits	7.34	7.54	298	4	160	8	445	24	40	3	2.6	1.2	9.46	Nil	24*10^11+	1100		
3		Keshopur Ph-III (Ayaappa Pvt.Ltd) ASP	60	As per DPCC limits	7.36	7.52	274	4	145	6	410	28	35	4.5	2.4	1.3	9.42	Nil	24*10^11+	2400		
4		Kapashera (Triveni Pvt. Ltd) SBR	5	As per plant design TSS:10/BOD:10/COD:50/NH4: 5/O&G:1.2/PO4:1/LC:1000/100ml	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
5	Kondli	Kondli Ph-I (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	7	7.5	264	08	147	04	462	15	35	Nil	3.5	0.5			210X10^11	7.2		
6		Kondli Ph-II (Triveni Pvt. Ltd) ASP	25	As per DPCC limits	7	7.5	264	08	147	05	462	20	35	1	3.5	0.8			210X10^11	7.3		
7		Kondli Ph-III (Triveni Pvt. Ltd) ASP	10	As per DPCC limits	7	7.6	264	08	147	05	462	20	35	1	3.5	0.8			210X10^11	7.3		
8		Kondli Ph-IV (Ayaappa Pvt.Ltd) ASP(IFAS)	45	As per DPCC limits	7	7.5	264	07	147	05	462	22	35	1	3.5	0.5			210X10^11	9.1		
9		Chilla (HNB Engineers) C-SBR	9	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
10		CWG (M/s Toshiba Water Soluti on Pvt. Ltd.) MBR	1	As per DPCC limits	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
11	N.S.T.P.C Pillar	Coronation Pillar Ph-II (DRA Infracom Pvt.Ltd.) ASP(IFAS)	20	As per plant design TSS:30/BOD:20/COD:50/NH4-N:5/PO4:1/O &G:1.2/f.c:230	7.4	7.6	128	5	77	3	241	18	23	0.7	2	0.6			-	-		
12		Coronation Pillar Ph-III (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits	7.34	7.53	190	9	103	5	328	19	20	0.6	2.2	0.8			-	-		
13		Coronation New (L&T Construction and PASSAVANT (JV)) ASP	70	As per DPCC limits	7.4	7.68	176	8	102	4	545	19	30	0.5	2.9	0.9	2.4	bdl	-	-		
14		Narela (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	As per DPCC limits	7.42	8.2	116	10	72	6	480	21	33	0.5	3.6	1	2.2	bdl	15x10^9	43		
15	Nilothi	Nilothi Ph-I (SUBHASH INFRA PVT. LTD) ASP(IFAS)	60	As per DPCC limits	7.54	7.69	478	2	265	3	-	-	27.2	2.3	3.9	0.5			29x10^7	93		
16		Nilothi Ph-II (VEOLIA INDIA) ASP	20	As per DPCC limits	7.62	7.7	440	6	243	8	-	-	27	3.5	3.5	1			28x10^7	120		
17	Okhla	Okhla Ph-V (DJB) ASP	16	As per plant design TSS:50/BOD:30/COD:50	7.2	7.4	218	13	133	12.2			35	20	4	1.3	6	ND	43 x10^9	35 x10^2		
18		Okhla Ph-VI (SUEZ India Pvt. Ltd.) ASP	30	As per DPCC limits	7.3	8.1	212	5	190	5.2			30	0.1	3.8	0.35	4	ND	24x10^13	<1.8		
19		Okhla New (SUEZ India Pvt. Ltd.) ASP	124	As per DPCC limits															24x10^12	210		
20		Mehrauli (DJB) E.A	5	As per plant design TSS:50/BOD:30/COD:50	7.27	7.68	282	27	218	16.8	861	58	48	42	3.8							

[illegible]