

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Parameters of STPs of Delhi as on							01.01.21			
Name of the Plant	Capacity (in MGD)	Parameter								
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4	Daily Flow (MGD)
		DPCC limits	5.5-9.0	50	30	250	10	50	5	
Yamuna Vihar	10 MGD Phase-I	Inlet	6.8	400	255			45	5.0	8.16
		outlet	7.4	45	28			30	2.0	
	Real Time Reading at Outlet									
	10 MGD Phase-II	Inlet	7.2	296	194			35	4.5	7.82
		outlet	7.5	31	19			15	2.0	
	Real Time Reading at Outlet									
	25 MGD Phase-III	Inlet	7.3	636	402			55	6.0	27.19
		outlet	7.5	41	24			20	3.0	
Real Time Reading at Outlet										
Rithala	40 MGD	Inlet	7.2	256	161	420		42	1.7	
		outlet	7.6	122	45	200		34	1.6	11.83
	Real Time Reading at Outlet		ND	ND	ND	ND		Nd		
	40 MGD	Inlet	7.2	256	161	420		42	1.7	
		Outlet	7.4	17	12	60		12	0.3	38.06
	Real Time Reading at Outlet		7.22	20.7	12.58	60.44		6.24		
Corronation Pillar	20 MGD Phase-I & II	Inlet	7	232	190	344	-	25	6.3	18.866
		outlet	7.3	90	63	246	-	21	5.2	-
	Real Time Reading at Outlet									
	10 MGD Phase-III	Inlet	6.9	348	295	480	8	47	10.4	5.9
		outlet	7.5	94	70	218	3.8	39	6.5	-
	Real Time Reading at Outlet									
Narela	10 MGD Phase-III	Inlet	7.1	146	205	312	3.6	38	7.6	1.75
		outlet	7.4	20	12	46	1	18	1.4	-
	Real Time Reading at Outlet									
Rohini	15 MGD	Inlet	7.2	332	175	595		50	6	6.5
		Outlet	7.5	27	14	48		15	3	
	Real Time Reading at Outlet									
Keshopur	12 MGD (PH-I)	Inlet	7.4	196	122	-	-	29	2.8	12.08
		Outlet	7.6	17	6	-	-	2	3.3	
	Real time reading at OUTLET(online)									
	20 MGD (PH-II)	Inlet	7.4	568	172	-	-	31	3.2	17.22
		Outlet	7.5	174	138	-	-	32	2.9	
	Real Time Reading at Outlet									
	40 MGD (PH-III)	Inlet	7.4	568	172	-	-	31	3.2	39.43
		Outlet	7.6	188	98	-	-	27	2.8	
	Real Time Reading at Outlet									
	20 MGD (PH-II)	Inlet	7.4	296	163	-	-	32	3.4	11.75
		Outlet	7.3	9	7	-	-	12	2	
	Real Time Reading at Outlet									
	12 MGD	Inlet	7.4	226	145	330	-	32	1.7	-

Okhla	12 MGD	outlet	7.6	29	14	50	-	28	0.9	6.02
	Real Time Reading at Outlet									
	45 MGD	Inlet	6.9	232	148	360	-	38	1.6	-
		outlet	7.1	30	18	60	-	30	0.8	38.49
	Real Time Reading at Outlet									
	37 MGD	Inlet	6.9	232	148	360	-	38	1.6	-
		outlet	7.3	31	19	70	-	32	0.6	29.11
	Real Time Reading at Outlet									
	16 MGD	Inlet	6.9	232	148	360	-	38	1.6	-
		outlet	7.1	15	7	30	-	27	0.5	14.56
	Real Time Reading at Outlet									
	New 30 MGD	Inlet	7.4	228	132	310	-	42	1.6	-
		Outlet	7.6	6	5	20	-	1	0.3	29.49
	Real Time Reading at Outlet									
Molarbund	0.66 MGD	Inlet	7.3	238	150	350	-	42	1.8	
		outlet	7.5	19	13	40	-	31	0.7	
	Real Time Reading at Outlet									
Delhi Gate-I	2.2 MGD	Inlet	7.3	230	130	310	-	37	1.8	
		outlet	7.5	7	5	20	-	3	NIL	
	Real Time Reading at Outlet									
Delhi Gate-II	15 MGD	Inlet	7.3	220	127	300	-	32	1.4	
		outlet	7.6	6	4	20	-	NIL	NIL	
	Real Time Reading at Outlet									
Sen Nursing Home	2.2 MGD	Inlet	7.2	226	132	310	-	34	1.3	
		outlet	7.2	8	4	20	-	NIL	NIL	
	Real Time Reading at Outlet									

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Name of the Plant	Capacity (in MGD)	01.01.21		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC Limit	50	30	250
Yamuna Vihar	10 MGD Phase-I	45	28	-
	10 MGD Phase-II	31	19	-
	25 MGD Phase-III	41	24	-
Rithala	40 MGD	122	45	200
	40 MGD	17	12	60
Corronation pillar	20 MGD Phase-I &II	90	63	246
	10 MGD Phase-III	94	70	218
Narela	10 MGD Phase-III	20	12	46
Rohini	15 MGD	27	14	48
Keshopur	12 MGD	17	6	-
	20 MGD	174	138	-
	40 MGD	188	98	-
	20 MGD	9	7	-
Okhla	12 MGD	29	14	50
	45 MGD	30	18	60
	37 MGD	31	19	70
	16 MGD	15	7	30
	New 30 MGD	6	5	20
Molarbund	0.66 MGD	19	13	40
Delhi Gate-I	2.2 MGD	7	5	20
Delhi Gate-II	15 MGD	6	4	20
Sen Nursing Home	2.2 MGD	8	4	20

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Parameters of STPs of Delhi as on							02.01.21			
Name of the Plant	Capacity (in MGD)	Parameter								
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4	Daily Flow (MGD)
		DPCC limits	5.5-9.0	50	30	250	10	50	5	
Yamuna Vihar	10 MGD Phase-I	Inlet	7.0	372	270	520	31.2	30	4.5	7.85
		outlet	7.4	23	14	65	13.2	20	2.5	
	Real Time Reading at Outlet									
	10 MGD Phase-II	Inlet	7.0	408	298	670	46.8	30	4.0	7.55
		outlet	7.5	22	12	59	14.8	15	2.0	
	Real Time Reading at Outlet									
	25 MGD Phase-III	Inlet	7.1	532	410	845	51.6	40	5.0	27.86
		outlet	7.5	30	22	78	8.8	25	2.5	
Real Time Reading at Outlet										
Rithala	40 MGD	Inlet	7.3	268	163	410	8	32	0.9	
		outlet	7.7	106	43	190	6	29	0.9	12.94
	Real Time Reading at Outlet		7	42.4	26.55	117.36		18.57		
	40 MGD	Inlet	7.3	268	163	410	8	32	0.9	
		Outlet	7.6	16	10	60	3	10	0.3	38.12
	Real Time Reading at Outlet		7.28	17.87	12.54	58.58		6.3		
Corronation Pillar	20 MGD Phase-I &II	Inlet	6.9	282	210	324	5.1	30	6.8	18.324
		outlet	7.2	84	58	232	3.4	24	4.7	-
	Real Time Reading at Outlet									
	10 MGD Phase-III	Inlet	7	300	265	426	-	42	7.2	6.26
		outlet	7.4	68	75	252	-	36	3.9	-
	Real Time Reading at Outlet									
Rohini	15 MGD	Inlet	7.1	248	118			39	6.5	7.23
		Outlet	7.6	29	16			13	2.5	
	Real Time Reading at Outlet									
Keshopur	12 MGD	Inlet	7.4	256	150	420	-	28	3.1	12.7
	(PH-I)	Outlet	7.6	15	10	30	-	1	3.4	
	Real time reading at OUTLET(online)									
	20 MGD (PH-II)	Inlet	7.3	496	179	640	-	29	3.2	16.92
		Outlet	7.5	156	113	340	-	27	2.9	
	Real Time Reading at Outlet									
	40 MGD (PH-III)	Inlet	7.3	496	179	640	-	29	3.2	35.64
		Outlet	7.5	154	129	347	-	26	2.7	
	Real Time Reading at Outlet									
	20 MGD (PH-II)	Inlet	7.4	220	148	-	-	28	2.9	9.5
		Outlet	7.4	14	9	-	-	6	1.8	
	Real Time Reading at Outlet									
	12 MGD	Inlet	7.2	216	140	310	-	41	2	-
		outlet	7.6	26	15	60	-	34	0.8	6
	Real Time Reading at Outlet									
	45 MGD	Inlet	7.2	236	143	340	-	40	1.9	-

Okhla	45 MGD	outlet	7.6	31	18	70	-	36	0.7	38.11
	Real Time Reading at Outlet									
	37 MGD	Inlet	7.2	236	143	340	-	40	1.9	-
		outlet	7.6	29	17	60	-	32	0.8	29.41
	Real Time Reading at Outlet									
	16 MGD	Inlet	7.2	236	143	340	-	40	1.9	-
		outlet	7.6	17	11	40	-	25	0.5	14.25
	Real Time Reading at Outlet									
	New 30 MGD	Inlet	7.3	232	145	360	-	41	1.6	-
Outlet		7.7	7	4	20	-	5	NIL	28.19	
Real Time Reading at Outlet										
Mehrauli	5 MGD	Inlet	7.4	272	157	390	-	39	1.9	
		outlet	7.6	20	11	40	-	32	0.8	
	Real Time Reading at Outlet									
Vasant Kunj	2.2 MGD	Inlet	7.2	224	152	320	-	40	2.2	
		outlet	7.7	26	14	50	-	31	1	
	Real Time Reading at Outlet									
	3 MGD	Inlet	7.3	204	135	320	-	38	1.5	
		outlet	7.6	19	10	40	-	25	0.6	
	Real Time Reading at Outlet									
Kapashera	5 MGD	Inlet	7.6	282	160	400	-	43	1.6	-
		outlet	7.7	8	4	4	-	4	0.3	3.97
	Real Time Reading at Outlet									

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Name of the Plant	Capacity (in MGD)	02.01.21		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC Limit	50	30	250
Yamuna Vihar	10 MGD Phase-I	23	14	65
	10 MGD Phase-II	22	12	59
	25 MGD Phase-III	30	22	78
Rithala	40 MGD	106	43	190
	40 MGD	16	10	60
Corronation pillar	20 MGD Phase-I &II	84	58	232
	10 MGD Phase-III	68	75	252
Rohini	15 MGD	29	16	-
Keshopur	12 MGD	15	10	30
	20 MGD	156	113	340
	40 MGD	154	129	347
	20 MGD	14	9	-
Okhla	12 MGD	26	15	60
	45 MGD	31	18	70
	37 MGD	29	17	60
	16 MGD	17	11	40
	New 30 MGD	7	4	20
Mehrauli	5 MGD	20	11	40
Vasant Kunj	2.2 MGD	26	14	50
	3 MGD	19	10	40
Kapashera	5 MGD	8	4	4

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Name of the Plant	Capacity (in MGD)	03.01.21		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC Limit	50	30	250
Yamuna Vihar	10 MGD Phase-I	26	15	-
	10 MGD Phase-II	30	17	-
	25 MGD Phase-III	43	25	-
Rithala	40 MGD	104	42	160
	40 MGD	16	11	40
Corronation pillar	20 MGD Phase-I &II	78	62	182
	10 MGD Phase-III	74	78	216
Rohini	15 MGD	28	21	38
Nilothi	20 MGD	12	8	-
Okhla	12 MGD	27	16	60
	45 MGD	30	17	60
	37 MGD	32	18	70
	16 MGD	15	8	30

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Parameters of STPs of Delhi as on							04.01.21			
Name of the Plant	Capacity (in MGD)	Parameter								
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4	Daily Flow (MGD)
		DPCC limits	5.5-9.0	50	30	250	10	50	5	
Yamuna Vihar	10 MGD Phase-I	Inlet	7.1	252	182	402	27.6	35	5.0	8.42
		outlet	7.4	22	12	60	9.6	20	2.5	
	Real Time Reading at Outlet									
	10 MGD Phase-II	Inlet	7.2	372	237	578	32.0	30	5.5	8.69
		outlet	7.5	25	19	65	10.8	20	3.0	
	Real Time Reading at Outlet									
	25 MGD Phase-III	Inlet	7.4	608	317	980	41.2	40	6.0	28.79
		outlet	7.5	34	22	78	11.2	25	2.5	
Real Time Reading at Outlet										
Rithala	40 MGD	Inlet	7.4	282	164	340		29	0.9	
		outlet	7.6	112	46	160		28	0.9	18.59
	Real Time Reading at Outlet		6.95	58.67	33.8	184.13		21.65		
	40 MGD	Inlet	7.4	282	164	340		29	0.9	
		Outlet	7.5	17	12	40		14	0.3	39.04
	Real Time Reading at Outlet		7.31	22.54	13.11	68.16		6.33		
Corronation Pillar	20 MGD Phase-I &II	Inlet	7	170	190	486	8.4	41	13	19.994
		outlet	7.3	72	65	194	4.2	27	9.7	-
	Real Time Reading at Outlet									
	10 MGD Phase-III	Inlet	7	256	245	456	-	52	15	6.19
		outlet	7.3	65	72	192	-	34	8.6	-
Real Time Reading at Outlet										
Narela	10 MGD Phase-III	Inlet	7	204	218	368	4.5	49	8.6	1.75
		outlet	7.5	18	14	48	3.5	14	4.2	-
	Real Time Reading at Outlet									
Rohini	15 MGD	Inlet	7.2	344	183			55	7.5	8.42
		Outlet	7.7	36	20			15	5	
	Real Time Reading at Outlet									
Nilothi	40 MGD (PH-I)	Inlet	7.4	284	127	-	-	27	3.1	27.12
		Outlet	7.6	98	48	-	-	21	3	
	Real Time Reading at Outlet									
	20 MGD (PH-II)	Inlet	7.4	224	132	-	-	29	3.2	18.62
		Outlet	7.5	13	7	-	-	8	3.4	
	Real Time Reading at Outlet									
Pappankalan	(20 MGD) PH-I	Inlet	7.4	260	234	720	22.8	32	3.3	20.43
		Outlet	7.7	126	41	168	-	27	2.7	
	Real Time Reading at Outlet									
	(20 MGD) PH-II	Inlet	7.4	260	234	720	22.8	32	3.3	20.8
		Outlet	7.6	6	5	32	-	20	3.2	
	Real Time Reading at Outlet									
	(05 MGD)	Inlet	7.5	504	215	800	16.2	38	3.6	5.12

Najafgarh	105 MGD	Outlet	7.7	32	25	96	1.6	18	3.1	
	Real Time Reading at Outlet									
Okhla	12 MGD	Inlet	7.4	232	143	360	-	42	1.9	-
		outlet	7.6	30	17	60	-	36	0.9	7.12
	Real Time Reading at Outlet									
	45 MGD	Inlet	7.2	224	148	360	-	40	2	-
		outlet	7.6	28	14	50	-	36	0.8	42.62
	Real Time Reading at Outlet									
	37 MGD	Inlet	7.2	224	148	360	-	40	2	-
		outlet	7.6	30	19	70	-	34	0.6	32.16
	Real Time Reading at Outlet									
	16 MGD	Inlet	7.2	224	148	360	-	40	2	-
		outlet	7.6	14	7	30	-	30	0.6	15.11
	Real Time Reading at Outlet									
	New 30 MGD	Inlet	7.4	240	133	310	-	41	2	-
		Outlet	7.6	7	5	20	-	NIL	NIL	26.52
	Real Time Reading at Outlet									

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Name of the Plant	Capacity (in MGD)	04.01.21		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC Limit	50	30	250
Yamuna Vihar	10 MGD Phase-I	22	12	60
	10 MGD Phase-II	25	19	65
	25 MGD Phase-III	34	22	78
Rithala	40 MGD	112	46	160
	40 MGD	17	12	40
Corronation pillar	20 MGD Phase-I &II	72	65	194
	10 MGD Phase-III	65	72	192
Narela	10 MGD Phase-III	18	14	48
Rohini	15 MGD	36	20	-
Nilothi	40 MGD	98	48	-
	20 MGD	13	7	-
Pappankalan	(20 MGD)	126	41	168
	(20 MGD)	6	5	32
Najafgarh	05 MGD	32	25	96
Okhla	12 MGD	30	17	60
	45 MGD	28	14	50
	37 MGD	30	19	70
	16 MGD	14	7	30
	New 30 MGD	7	5	20

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Parameters of STPs of Delhi as on							05.01.21			
Name of the Plant	Capacity (in MGD)	Parameter								
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4	Daily Flow (MGD)
		DPCC limits	5.5-9.0	50	30	250	10	50	5	
Yamuna Vihar	10 MGD Phase-I	Inlet	7.2	300	210			40	4.5	7.80
		outlet	7.4	24	17			25	2.0	
	Real Time Reading at Outlet		7.2	26	16	54		3		
	10 MGD Phase-II	Inlet	7.1	248	177			35	5.0	7.62
		outlet	7.5	22	14			15	2.5	
	Real Time Reading at Outlet									
	25 MGD Phase-III	Inlet	7.2	676	307			50	5.5	28.84
		outlet	7.5	33	21			25	3.0	
Real Time Reading at Outlet										
Rithala	40 MGD	Inlet	7.1	268	143	340		22	0.5	
		outlet	7.5	106	45	160		18	0.4	17.86
	Real Time Reading at Outlet		7.1	39.61	29.26	109.61		19.27		
	40 MGD	Inlet	7.1	268	143	340		22	0.5	
		Outlet	7.5	16	11	40		6	0.3	38.02
	Real Time Reading at Outlet		7.51	13.83	10.16	75.13		6.5		
Corronation Pillar	20 MGD Phase-I & II	Inlet	7	164	180	316	-	35	6.1	19.653
		outlet	7.4	65	68	216	-	28	5.2	-
	Real Time Reading at Outlet									
	10 MGD Phase-III	Inlet	7.1	404	285	440	9	46	7.8	7.5
		outlet	7.4	70	78	196	4.4	37	5	-
	Real Time Reading at Outlet									
Narela	10 MGD Phase-III	Inlet								
		outlet								
	Real Time Reading at Outlet									
Rohini	15 MGD	Inlet	7.2	204	108	323		43	4	9.06
		Outlet	7.6	29	17	48		15	1.5	
	Real Time Reading at Outlet									
Keshopur	12 MGD (PH-I)	Inlet	7.3	320	141	480	7	22	2.3	12.05
		Outlet	7.7	12	6	26	-	1	3.2	
	Real time reading at OUTLET(online)									
	20 MGD (PH-II)	Inlet	7.4	468	182	613	8.4	28	2.8	19.32
		Outlet	7.5	126	119	320	3	24	2.7	
	Real Time Reading at Outlet									
	40 MGD (PH-III)	Inlet	7.4	468	182	613	8.4	26	2.8	41.58
		Outlet	7.6	128	104	300	2.2	23	2.4	
Real Time Reading at Outlet										
Nilothi	40 MGD (PH-I)	Inlet	7.3	268	136	533	4.4	25	4.4	29.16
		Outlet	7.5	116	53	192	0.8	22	0.8	
	Real Time Reading at Outlet									
	20 MGD	Inlet	7.3	244	127	587	5.2	22	2.4	19.3

	(PH-II)	Outlet	7.5	11	6	28	-	4	1	
	Real Time Reading at Outlet									
Pappankalan	(20 MGD)	Inlet	7.4	324	174	-	-	32	3.1	24.59
	PH-I	Outlet	7.7	98	80	-	-	29	3.6	
	Real Time Reading at Outlet									
	(20 MGD)	Inlet	7.4	324	174	-	-	32	3.1	20.6
	PH-II	Outlet	7.7	5	4	-	-	28	3.3	
	Real Time Reading at Outlet									
Najafgarh	(05 MGD)	Inlet	7.5	404	207	-	-	29	3.4	5.18
		Outlet	7.6	112	87	-	-	14	2.8	
	Real Time Reading at Outlet									
Okhla	12 MGD	Inlet	7.4	216	150	360	-	41	2	-
		outlet	7.6	24	13	50	-	34	0.8	6.84
	Real Time Reading at Outlet									
	45 MGD	Inlet	7.5	218	147	350	-	40	1.7	-
		outlet	7.6	27	16	60	-	36	0.9	40.36
	Real Time Reading at Outlet									
	37 MGD	Inlet	7.5	218	147	350	-	40	1.7	-
		outlet	7.7	31	15	60	-	30	0.5	31.59
	Real Time Reading at Outlet									
	16 MGD	Inlet	7.5	218	147	350	-	40	1.7	-
		outlet	7.6	17	8	30	-	24	0.4	14.58
	Real Time Reading at Outlet									
	New 30 MGD	Inlet	7.4	232	135	300	-	42	1.8	-
		Outlet	7.7	6	5	20	-	3	NIL	25.77
	Real Time Reading at Outlet									

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Name of the Plant	Capacity (in MGD)	05.01.21		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC Limit	50	30	250
Yamuna Vihar	10 MGD Phase-I	24	17	-
	10 MGD Phase-II	22	14	-
	25 MGD Phase-III	33	21	-
Rithala	40 MGD	106	45	160
	40 MGD	16	11	40
Corronation pillar	20 MGD Phase-I &II	65	68	216
	10 MGD Phase-III	70	78	196
Rohini	15 MGD	29	17	48
Keshopur	12 MGD	12	6	26
	20 MGD	126	119	320
	40 MGD	128	104	300
Nilothi	40 MGD	116	53	192
	20 MGD	11	6	28
Pappankalan	(20 MGD)	98	80	-
	(20 MGD)	5	4	-
Najafgarh	05 MGD	112	87	-
Okhla	12 MGD	24	13	50
	45 MGD	27	16	60
	37 MGD	31	15	60
	16 MGD	17	8	30
	New 30 MGD	6	5	20

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Parameters of STPs of Delhi as on							06.01.21			
Name of the Plant	Capacity (in MGD)	Parameter								
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4	Daily Flow (MGD)
		DPCC limits	5.5-9.0	50	30	250	10	50	5	
Yamuna Vihar	10 MGD Phase-I	Inlet	7.0	260	137	477	33.2	35	5.0	7.8
		outlet	7.4	25	15	71	7.6	20	2.5	
		Real Time Reading at Outlet		7.2	24	12	50		3	
	10 MGD Phase-II	Inlet	7.1	256	123	608	37.6	40	5.5	7.65
		outlet	7.5	23	12	56	11.6	20	2.0	
	Real Time Reading at Outlet									
	25 MGD Phase-III	Inlet	7.2	524	212	776	44.4	55	4.5	28.93
		outlet	7.5	40	25	133	10.4	20	2.5	
Real Time Reading at Outlet			33	7	63					
Rithala	40 MGD	Inlet	7.2	292	183	440		31	0.8	
		outlet	7.5	116	47	190		26	0.7	13.14
	Real Time Reading at Outlet		7.19	39.93	29.83	112.23		17.36		
	40 MGD	Inlet	7.2	292	183	440		31	0.8	
		Outlet	7.4	18	14	60		7	0.3	39.05
	Real Time Reading at Outlet		7.65	13.92	10.09	75.15		6.62		
Corronation Pillar	20 MGD Phase-I &II	Inlet	6.9	192	175	368	7.4	26	8.5	19.966
		outlet	7.3	70	62	242	4.7	22	7.2	-
	Real Time Reading at Outlet									
	10 MGD Phase-III	Inlet	6.9	298	310	420	-	50	9.8	57.43
		outlet	7.2	76	80	204	-	38	4.4	-
	Real Time Reading at Outlet									
Narela	10 MGD Phase-III	Inlet	6.8	250	203	344	5	42	9.4	1.82
		outlet	7.6	23	17	72	2.9	10	3.5	-
	Real Time Reading at Outlet									
Rohini	15 MGD	Inlet	7.2	460	220			40	6	6.94
		Outlet	7.5	30	18			16	2	
	Real Time Reading at Outlet									
Keshopur	12 MGD (PH-I)	Inlet	7.4	528	156	-	-	27	2.6	13.06
		Outlet	7.7	16	6	-	-	2	2.9	
	Real time reading at OUTLET(online)									
	20 MGD (PH-II)	Inlet	7.4	440	215	-	-	28	3.2	18.9
		Outlet	7.6	112	109	-	-	28	2.7	
	Real Time Reading at Outlet									
	40 MGD (PH-III)	Inlet	7.4	440	215	-	-	28	3.2	40.04
		Outlet	7.5	176	115	-	-	24	2.8	
Real Time Reading at Outlet										
Nilothi	40 MGD (PH-I)	Inlet	7.4	300	139	-	-	27	3.2	30.61
		Outlet	7.7	100	59	-	-	24	2.6	
	Real Time Reading at Outlet									
	20 MGD	Inlet	7.4	252	200	-	-	28	3.1	19.86

	(PH-II)	Outlet	7.4	8	5	-	-	16	2.2	
	Real Time Reading at Outlet									
Pappankalan	(20 MGD)	Inlet	7.4	392	240	-	-	32	3.2	20.13
	PH-I	Outlet	7.8	66	44	-	-	28	3.2	
	Real Time Reading at Outlet									
	(20 MGD)	Inlet	7.4	392	240	-	-	32	3.2	20.1
	PH-II	Outlet	7.7	5	5	-	-	24	3	
	Real Time Reading at Outlet									
Okhla	12 MGD	Inlet	7.6	238	148	370	-	42	2	-
		outlet	7.6	29	15	60	-	32	0.9	7.32
	Real Time Reading at Outlet									
	45 MGD	Inlet	7.4	232	150	360	-	41	2	-
		outlet	7.6	29	17	60	-	32	0.8	41.23
	Real Time Reading at Outlet									
	37 MGD	Inlet	7.4	232	150	360	-	41	2	-
		outlet	7.6	28	14	50	-	32	0.8	31.98
	Real Time Reading at Outlet									
	16 MGD	Inlet	7.4	232	150	360	-	41	2	-
		outlet	7.8	16	7	30	-	22	0.5	14.62
	Real Time Reading at Outlet									
Delhi Gate-I	2.2 MGD	Inlet	7.3	216	137	340	-	34	1.6	
		outlet	7.7	7	5	20	-	NIL	NIL	
	Real Time Reading at Outlet									
Delhi Gate-II	15 MGD	Inlet	7.4	202	135	330	-	32	1.2	
		outlet	7.6	6	4	20	-	NIL	NIL	
	Real Time Reading at Outlet									
Sen Nursing Home	2.2 MGD	Inlet	7.2	227	138	340	-	35	1.7	
		outlet	7.6	7	5	20	-	NIL	NIL	
	Real Time Reading at Outlet									

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Name of the Plant	Capacity (in MGD)	06.01.21		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC Limit	50	30	250
Yamuna Vihar	10 MGD Phase-I	25	15	71
	10 MGD Phase-II	23	12	56
	25 MGD Phase-III	40	25	133
Rithala	40 MGD	116	47	190
	40 MGD	18	14	60
Corronation pillar	20 MGD Phase-I &II	70	62	242
	10 MGD Phase-III	76	80	204
Narela	10 MGD Phase-III	23	17	72
Rohini	15 MGD	30	18	-
Keshopur	12 MGD	16	6	-
	20 MGD	112	109	-
	40 MGD	176	115	-
Nilothi	40 MGD	100	59	-
	20 MGD	8	5	-
Pappankalan	(20 MGD)	66	44	-
	(20 MGD)	5	5	-
Okhla	12 MGD	29	15	60
	45 MGD	29	17	60
	37 MGD	28	14	50
	16 MGD	16	7	30
	New 30 MGD	5	3	10
Delhi Gate-I	2.2 MGD	7	5	20
Delhi Gate-II	15 MGD	6	4	20
Sen Nursing Home	2.2 MGD	7	5	20

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Parameters of STPs of Delhi as on							07.01.21			
Name of the Plant	Capacity (in MGD)	Parameter								
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4	Daily Flow (MGD)
		DPCC limits	5.5-9.0	50	30	250	10	50	5	
Yamuna Vihar	10 MGD Phase-I	Inlet	6.8	332	213			30	4.5	8.13
		outlet	7.4	27	19			10	1.5	
	Real Time Reading at Outlet									
	10 MGD Phase-II	Inlet	7.2	248	164			35	4.0	7.98
		outlet	7.4	39	25			15	1.0	
	Real Time Reading at Outlet									
	25 MGD Phase-III	Inlet	7.4	628	316			50	4.5	29.17
		outlet	7.5	33	25			20	2.5	
Real Time Reading at Outlet			29	24	85					
Rithala	40 MGD	Inlet	7.4	236	155	380		40	1.3	
		outlet	7.6	112	46	180		29	1.2	12.56
	Real Time Reading at Outlet		7.14	84.39	45.79	165.49		17.81		
	40 MGD	Inlet	7.4	236	155	380		40	1.3	
		Outlet	7.7	15	11	40		12	0.5	39.02
	Real Time Reading at Outlet		7.77	13.85	9.76	70.75		6.72		
Corronation Pillar	20 MGD Phase-I &II	Inlet	7	180	185	326	-	28	6.5	19.031
		outlet	7.3	64	58	168	-	22	4.3	-
	Real Time Reading at Outlet									
	10 MGD Phase-III	Inlet	7.1	388	323	484	8.6	37	11.3	7.09
		outlet	7.4	68	73	256	3.8	31	7.4	-
Real Time Reading at Outlet										
Rohini	15 MGD	Inlet	7.2	328	145	502		50	6.5	7.17
		Outlet	7.7	28	16	67		18	2.5	
	Real Time Reading at Outlet									
Keshopur	12 MGD	Inlet	7.3	424	175	-	-	25	2.7	12.81
	(PH-I)	Outlet	7.6	14	9	-	-	1	2.8	
	Real time reading at OUTLET(online)									
	20 MGD (PH-II)	Inlet	7.3	420	205	-	-	26	2.9	17.32
		Outlet	7.5	116	97	-	-	27	2.6	
	Real Time Reading at Outlet									
	40 MGD (PH-III)	Inlet	7.3	420	205	-	-	26	2.9	39.17
		Outlet	7.6	144	105	-	-	23	2.7	
Real Time Reading at Outlet										
Nilothi	40 MGD (PH-I)	Inlet	7.3	296	133	-	-	28	3	32.42
		Outlet	7.5	104	86	-	-	24	2.8	
	Real Time Reading at Outlet									
	20 MGD (PH-II)	Inlet	7.2	310	184	-	-	32	3.2	20.24
		Outlet	7.6	14	9	-	-	10	1.8	
Real Time Reading at Outlet										
	(20 MGD)	Inlet	7.3	500	258	-	-	30	3.2	20.86

Pappankalan	PH-I	Outlet	7.7	67	45	-	-	25	3	
	Real Time Reading at Outlet									
	(20 MGD)	Inlet	7.3	500	258	-	-	30	3.2	20.3
	PH-II	Outlet	7.7	3	3	-	-	20	1	
	Real Time Reading at Outlet									
Najafgarh	(05 MGD)	Inlet	7.5	356	198	613	15.8	37	4.2	4.92
		Outlet	7.7	35	25	80	0.8	19	0.8	
	Real Time Reading at Outlet									
Okhla	12 MGD	Inlet	7.5	218	145	350	-	40	1.9	-
		outlet	7.6	26	14	50	-	30	0.9	6.21
	Real Time Reading at Outlet									
	45 MGD	Inlet	7.3	220	147	360	-	40	2	-
		outlet	7.7	28	16	60	-	30	0.7	40.12
	Real Time Reading at Outlet									
	37 MGD	Inlet	7.3	220	147	360	-	40	2	-
		outlet	7.6	29	13	50	-	33	0.9	31.24
	Real Time Reading at Outlet									
	16 MGD	Inlet	7.3	220	147	360	-	40	2	-
		outlet	7.6	15	8	30	-	26	0.6	14.65
	Real Time Reading at Outlet									
	New 30 MGD	Inlet	7.4	238	132	320	-	40	1.6	-
		Outlet	7.7	7	5	20	-	5	NIL	23.84
	Real Time Reading at Outlet									

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Name of the Plant	Capacity (in MGD)	07.01.21		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC Limit	50	30	250
Yamuna Vihar	10 MGD Phase-I	27	19	-
	10 MGD Phase-II	39	25	-
	25 MGD Phase-III	33	25	-
Rithala	40 MGD	112	46	180
	40 MGD	15	11	40
Corronation pillar	20 MGD Phase-I &II	64	58	168
	10 MGD Phase-III	68	73	256
Rohini	15 MGD	28	16	67
Keshopur	12 MGD	14	9	-
	20 MGD	116	97	-
	40 MGD	144	105	-
Nilothe	40 MGD	104	86	-
	20 MGD	14	9	-
Pappankalan	(20 MGD)	67	45	-
	(20 MGD)	3	3	-
Najafgarh	05 MGD	35	25	80
Okhla	12 MGD	26	14	50
	45 MGD	28	16	60
	37 MGD	29	13	50
	16 MGD	15	8	30
	New 30 MGD	7	5	20

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Parameters of STPs of Delhi as on							08.01.21			
Name of the Plant	Capacity (in MGD)	Parameter								
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4	Daily Flow (MGD)
		DPCC limits	5.5-9.0	50	30	250	10	50	5	
Yamuna Vihar	10 MGD Phase-I	Inlet	7.1	372	203		22.8	40	3.5	8.16
		outlet	7.4	28	20		5.2	20	1.5	
	Real Time Reading at Outlet		7.2	24	12	49		3		
	10 MGD Phase-II	Inlet	7.0	224	169		25.2	35	4.5	7.96
		outlet	7.5	49	28		8.8	20	2.5	
	Real Time Reading at Outlet									
	25 MGD Phase-III	Inlet	7.3	976	272		43.2	45	6.0	28.47
		outlet	7.6	42	26		4.4	30	3.0	
Real Time Reading at Outlet			29	24	84					
Rithala	40 MGD	Inlet	7.3	268	153	360	7	34	0.8	
		outlet	7.5	116	46	180	5	30	0.8	10.73
	Real Time Reading at Outlet		7.04	104.59	47.29	171.72		22.11		
	40 MGD	Inlet	7.3	268	153	360	7	34	0.8	
		Outlet	7.5	16	10	50	2	12	0.2	40.11
	Real Time Reading at Outlet		7.73	14	10.43	78.44		6.69		
Corronation Pillar	20 MGD Phase-I &II	Inlet	7.1	206	193	294	7.2	32	8.9	18.928
		outlet	7.4	58	55	156	3.6	24	6.5	-
	Real Time Reading at Outlet									
	10 MGD Phase-III	Inlet	7	310	308	440	-	59	10.8	7
		outlet	7.3	60	70	218	-	29	6.4	-
	Real Time Reading at Outlet									
Narela	10 MGD Phase-III	Inlet	7	182	190	298	3.7	38	6.3	1.79
		outlet	7.3	24	15	52	1.7	16	1.4	-
	Real Time Reading at Outlet									
Rohini	15 MGD	Inlet	7.2	456	178			48	7.5	7.35
		Outlet	7.6	26	14			15	5.5	
	Real Time Reading at Outlet									
Keshopur	12 MGD (PH-I)	Inlet	7.4	266	137	-	-	26	2.7	12.16
		Outlet	7.6	8	5	-	-	1	2.9	
	Real time reading at OUTLET(online)									
	20 MGD (PH-II)	Inlet	7.4	420	181	-	-	28	3.1	18.48
		Outlet	7.5	180	119	-	-	27	2.8	
	Real Time Reading at Outlet									
	40 MGD (PH-III)	Inlet	7.4	420	181	-	-	28	3.1	40.12
		Outlet	7.5	232	133	-	-	26	2.7	
	Real Time Reading at Outlet									
Nilothi	40 MGD (PH-I)	Inlet	7.3	270	129	-	6.8	24	3	32.78
		Outlet	7.5	94	76	-	0.6	20	2.4	
	Real Time Reading at Outlet									
	20 MGD	Inlet	7.4	252	181	-	7.6	28	3.2	19.7

	(PH-II)	Outlet	7.7	6	5	-	-	16	2.3	
	Real Time Reading at Outlet									
Pappankalan	(20 MGD)	Inlet	7.3	264	185	-	-	32	4.5	20.65
	PH-I	Outlet	7.8	92	44	-	-	28	4	
	Real Time Reading at Outlet									
	(20 MGD)	Inlet	7.3	264	185	-	-	32	4.5	20.64
	PH-II	Outlet	7.7	8	5	-	-	16	0.6	
	Real Time Reading at Outlet									
Najafgarh	(05 MGD)	Inlet	7.4	248	178	-	-	30	4.5	5
		Outlet	7.8	34	22	-	-	18	1.2	
	Real Time Reading at Outlet									
Okhla	12 MGD	Inlet	7.2	224	147	350	-	34	1.8	-
		outlet	7.6	27	16	60	-	26	0.8	6.52
	Real Time Reading at Outlet									
	45 MGD	Inlet	7.4	228	148	350	-	42	2.2	-
		outlet	7.6	29	15	60	-	34	0.7	40.11
	Real Time Reading at Outlet									
	37 MGD	Inlet	7.4	228	148	350	-	42	2.2	-
		outlet	7.7	31	16	70	-	32	0.9	30.25
	Real Time Reading at Outlet									
	16 MGD	Inlet	7.4	228	148	350	-	42	2.2	-
		outlet	7.7	15	7	30	-	32	0.8	14.36
	Real Time Reading at Outlet									
	New 30 MGD	Inlet	7.4	248	135	380	-	43	1.8	-
		Outlet	7.6	7	5	20	-	3	NIL	25.33
	Real Time Reading at Outlet									
Molarbund	0.66 MGD	Inlet	7.4	238	152	350	6	40	1.7	-
		outlet	7.7	21	12	40	1	30	0.9	0.52
	Real Time Reading at Outlet									
Mehrauli	5 MGD	Inlet	7.4	264	153	370	6	40	1.5	
		outlet	7.6	22	13	40	1	26	0.9	
	Real Time Reading at Outlet									
Vasant Kunj	2.2 MGD	Inlet	7.4	210	145	320	6	40	1.6	
		outlet	7.6	22	15	40	1	30	0.7	
	Real Time Reading at Outlet									
	3 MGD	Inlet	7.6	218	135	340	6	42	1.7	
		outlet	7.6	16	11	30	NIL	27	0.4	
	Real Time Reading at Outlet									
Ghitorni	5 MGD	Inlet	7.4	242	147	350	-	43	1.7	-
		outlet	7.7	30	15	60	-	35	1	1.1
	Real Time Reading at Outlet									

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Name of the Plant	Capacity (in MGD)	08.01.21		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC Limit	50	30	250
Yamuna Vihar	10 MGD Phase-I	28	20	-
	10 MGD Phase-II	49	28	-
	25 MGD Phase-III	42	26	-
Rithala	40 MGD	116	46	180
	40 MGD	16	10	50
Corronation pillar	20 MGD Phase-I &II	58	55	156
	10 MGD Phase-III	60	70	218
Narela	10 MGD Phase-III	24	15	52
Rohini	15 MGD	26	14	-
Keshopur	12 MGD	8	5	-
	20 MGD	180	119	-
	40 MGD	232	133	-
Nilothi	40 MGD	94	76	-
	20 MGD	6	5	-
Pappankalan	(20 MGD)	92	44	-
	(20 MGD)	8	5	-
Najafgarh	05 MGD	34	22	-
Okhla	12 MGD	27	16	60
	45 MGD	29	15	60
	37 MGD	31	16	70
	16 MGD	15	7	30
	New 30 MGD	7	5	20
Molarbund	0.66 MGD	21	12	40
Mehrauli	5 MGD	22	13	40
Vasant Kunj	2.2 MGD	22	15	40
	3 MGD	16	11	30
Ghitorni	5 MGD	30	15	60

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Parameters of STPs of Delhi as on							09.01.21			
Name of the Plant	Capacity (in MGD)	Parameter								
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4	Daily Flow (MGD)
		DPCC limits	5.5-9.0	50	30	250	10	50	5	
Yamuna Vihar	10 MGD Phase-I	Inlet	6.8	364	191	664		45	5.5	8.12
		outlet	7.5	22	18	69		25	2.0	
	Real Time Reading at Outlet		7.2	33	12	55		3		
	10 MGD Phase-II	Inlet	7.1	352	186	680		35	5.0	7.92
		outlet	7.5	19	17	64		25	1.5	
	Real Time Reading at Outlet									
	25 MGD Phase-III	Inlet	7.4	1048	332	1456		55	4.0	27.96
		outlet	7.5	38	25	120		30	2.5	
Real Time Reading at Outlet			29	22	81					
Rithala	40 MGD	Inlet	7.3	220	185	440		42	1.9	
		outlet	7.5	74	39	190		30	1.5	11.21
	Real Time Reading at Outlet		7.08	154.19	54.2	193.9		19.66		
	40 MGD	Inlet	7.3	220	185	440		42	1.9	
		Outlet	7.5	17	12	60		13	0.7	40.56
	Real Time Reading at Outlet		7.73	13.49	9.43	65.1		6.69		
Corronation Pillar	20 MGD Phase-I &II	Inlet	7.1	216	183	384	-	29	7.2	19.177
		outlet	7.4	68	63	224	-	21	5.3	-
	Real Time Reading at Outlet									
	10 MGD Phase-III	Inlet	7.1	328	315	414	7.8	37	9.4	6.88
		outlet	7.4	65	68	278	2.5	27	6.1	-
Real Time Reading at Outlet										
Rohini	15 MGD	Inlet	7.2	400	165	643		45	5	5.87
		Outlet	7.5	27	15	70		16	2.5	
	Real Time Reading at Outlet									
Keshopur	12 MGD	Inlet	7.3	236	125	-	-	27	3	12.13
	(PH-I)	Outlet	7.5	10	6	-	-	1	3.2	
	Real time reading at OUTLET(online)									
	20 MGD (PH-II)	Inlet	7.3	468	213	-	-	29	3.3	17.22
		Outlet	7.6	178	111	-	-	28	2.9	
	Real Time Reading at Outlet									
	40 MGD (PH-III)	Inlet	7.3	468	213	-	-	29	3.3	39.62
		Outlet	7.6	198	107	-	-	26	2.8	
	Real Time Reading at Outlet									
Nilothi	40 MGD (PH-I)	Inlet	7.2	160	134	430	-	30	2.5	33.22
		Outlet	7.5	73	57	180	-	25	2.2	
	Real Time Reading at Outlet									
	20 MGD (PH-II)	Inlet	7.3	152	141	480	-	34	3.5	18.84
		Outlet	7.5	9	7	28	-	12	1.8	
Real Time Reading at Outlet										
	(20 MGD)	Inlet	7.4	276	205	-	-	32	4	20.28

Pappankalan	PH-I	Outlet	7.8	84	55	-	-	26	3.8	
	Real Time Reading at Outlet									
	(20 MGD)	Inlet	7.4	276	205	-	-	32	4	20.3
	PH-II	Outlet	7.7	9	6	-	-	15	0.7	
	Real Time Reading at Outlet									
Okhla	12 MGD	Inlet	7.4	228	145	350	-	38	1.9	-
		outlet	7.6	29	16	60	-	28	0.9	6.43
	Real Time Reading at Outlet									
	45 MGD	Inlet	7.4	228	148	350	-	42	2.2	-
		outlet	7.6	29	15	60	-	34	0.7	40.65
	Real Time Reading at Outlet									
	37 MGD	Inlet	7.4	228	148	350	-	42	2.2	-
		outlet	7.6	28	13	50	-	30	0.5	30.14
	Real Time Reading at Outlet									
	16 MGD	Inlet	7.4	228	148	350	-	42	2.2	-
		outlet	7.7	16	8	30	-	30	0.8	14.02
	Real Time Reading at Outlet									
	New 30 MGD	Inlet	7.3	234	128	310	-	42	1.8	-
		Outlet	7.6	6	4	20	-	4	NIL	27.14
	Real Time Reading at Outlet									

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Name of the Plant	Capacity (in MGD)	09.01.21		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC Limit	50	30	250
Yamuna Vihar	10 MGD Phase-I	22	18	69
	10 MGD Phase-II	19	17	64
	25 MGD Phase-III	38	25	120
Rithala	40 MGD	74	39	190
	40 MGD	17	12	60
Corronation pillar	20 MGD Phase-I &II	68	63	224
	10 MGD Phase-III	65	68	278
Rohini	15 MGD	27	15	70
Keshopur	12 MGD	10	6	-
	20 MGD	178	111	-
	40 MGD	198	107	-
Nilothi	40 MGD	73	57	180
	20 MGD	9	7	28
Pappankalan	(20 MGD)	84	55	-
	(20 MGD)	9	6	-
Okhla	12 MGD	29	16	60
	45 MGD	29	15	60
	37 MGD	28	13	50
	16 MGD	16	8	30
	New 30 MGD	6	4	20

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Parameters of STPs of Delhi as on							10.01.21			
Name of the Plant	Capacity (in MGD)	Parameter								
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4	Daily Flow (MGD)
		DPCC limits	5.5-9.0	50	30	250	10	50	5	
Yamuna Vihar	10 MGD Phase-I	Inlet	7.0	292	200			40	5.0	8.20
		outlet	7.5	23	19			10	3.0	
	Real Time Reading at Outlet									
	10 MGD Phase-II	Inlet	7.1	420	244			30	5.5	7.83
		outlet	7.4	18	16			20	3.5	
	Real Time Reading at Outlet									
	25 MGD Phase-III	Inlet	7.3	872	322			45	6.5	28.14
		outlet	7.6	37	25			25	3.5	
Real Time Reading at Outlet										
Rithala	40 MGD	Inlet	7.2	272	159	410		40	1.6	
		outlet	7.6	67	41	180		29	1.3	10.7
	Real Time Reading at Outlet		7	182.13	51.33	194.62		25.88		
	40 MGD	Inlet	7.2	272	159	410		40	1.6	
		Outlet	7.4	18	14	70		14	0.6	39.05
	Real Time Reading at Outlet		7.53	14.13	10.42	80.34		6.51		
Corronation Pillar	20 MGD Phase-I & II	Inlet	6.9	172	195	316	4.4	27	9.4	18.877
		outlet	7.2	58	56	158	1.8	19	4.8	-
	Real Time Reading at Outlet									
	10 MGD Phase-III	Inlet	7.2	348	298	410	-	33	12	6.98
		outlet	7.5	62	72	264	-	26	5.8	-
	Real Time Reading at Outlet									
Rohini	15 MGD	Inlet	7.2	320	140			32	6	8.35
		Outlet	7.6	26	14			10	3	
	Real Time Reading at Outlet									
Nilothi	40 MGD (PH-I)	Inlet	7.2	282	139	-	-	30	3.2	32.69
	Outlet	7.5	86	60	-	-	26	2.5		
	Real Time Reading at Outlet									
Pappankalan	(20 MGD)	Inlet	7.4	325	212	-	-	32	4.2	20.23
	PH-I	Outlet	7.8	86	46	-	-	26	3.4	
	Real Time Reading at Outlet									
	(20 MGD)	Inlet	7.4	325	212	-	-	32	4.2	20.5
	PH-II	Outlet	7.8	8	6	-	-	16	0.8	
	Real Time Reading at Outlet									
Najafgarh	(05 MGD)	Inlet	7.4	338	220	-	-	34	3.8	5.12
		Outlet	7.8	36	22	-	-	18	1.4	
	Real Time Reading at Outlet									
	12 MGD	Inlet	7.4	224	148	340	4	36	1.3	-
		outlet	7.6	28	14	50	1	30	0.9	6.52
	Real Time Reading at Outlet									
	45 MGD	Inlet	7.4	230	150	350	5	40	1.6	-

Okhla

45 MGD	outlet	7.6	27	16	60	1	31	0.7	40.62
Real Time Reading at Outlet									
37 MGD	Inlet	7.4	230	150	350	5	40	1.6	-
	outlet	7.7	29	15	60	1	32	0.7	30.21
Real Time Reading at Outlet									
16 MGD	Inlet	7.4	230	150	350	5	40	1.6	-
	outlet	7.7	14	7	30	NIL	26	0.5	14.47
Real Time Reading at Outlet									

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Name of the Plant	Capacity (in MGD)	10.01.21		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC Limit	50	30	250
Yamuna Vihar	10 MGD Phase-I	23	19	-
	10 MGD Phase-II	18	16	-
	25 MGD Phase-III	37	25	-
Rithala	40 MGD	67	41	180
	40 MGD	18	14	70
Corronation pillar	20 MGD Phase-I &II	58	56	158
	10 MGD Phase-III	62	72	264
Rohini	15 MGD	26	14	-
Nilothi	40 MGD	86	60	-
Pappankalan	(20 MGD)	86	46	-
	(20 MGD)	8	6	-
Najafgarh	05 MGD	36	22	-
Okhla	12 MGD	28	14	50
	45 MGD	27	16	60
	37 MGD	29	15	60
	16 MGD	14	7	30

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Parameters of STPs of Delhi as on							11.01.21			
Name of the Plant	Capacity (in MGD)	Parameter								
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4	Daily Flow (MGD)
		DPCC limits	5.5-9.0	50	30	250	10	50	5	
Yamuna Vihar	10 MGD Phase-I	Inlet	6.9	444	182		25.2	45	5.5	7.65
		outlet	7.5	43	27		6.0	15	3.0	
	Real Time Reading at Outlet									
	10 MGD Phase-II	Inlet	7.0	356	185		19.2	30	5.0	7.60
		outlet	7.5	22	19		3.6	15	2.5	
	Real Time Reading at Outlet									
	25 MGD Phase-III	Inlet	7.2	724	341		46.4	50	6.0	28.74
		outlet	7.5	44	26		5.6	20	2.0	
Real Time Reading at Outlet			30	17	74					
Rithala	40 MGD	Inlet	7.3	232	183	430		36	1.1	
		outlet	7.5	92	44	170		28	1.0	12.23
	Real Time Reading at Outlet		7.23	176.56	48.98	189.91		13.02		
	40 MGD	Inlet	7.3	232	183	430		36	1.1	
		Outlet	7.6	20	15	70		12	0.4	40.15
	Real Time Reading at Outlet		7.58	13.83	9.84	72.08		6.56		
Corronation Pillar	20 MGD Phase-I & II	Inlet	7	198	205	290	-	31	9.3	16.427
		outlet	7.4	90	62	168	-	28	7.7	-
	Real Time Reading at Outlet									
	10 MGD Phase-III	Inlet	6.9	426	320	514	8.6	56	12.6	6.47
		outlet	7.4	98	95	256	3.6	44	10.4	
Real Time Reading at Outlet										
Narela	10 MGD Phase-III	Inlet	7.1	166	178	334	6.5	40	10.4	1.74
		outlet	7.5	26	20	84	3.6	20	5.3	
	Real Time Reading at Outlet									
Rohini	15 MGD	Inlet	7.2	180	105	412		40	5	6.6
		Outlet	7.5	28	16	67		15	3.5	
	Real Time Reading at Outlet									
Keshopur	12 MGD (PH-I)	Inlet	7.3	276	135	533	-	29	3.1	12.11
		Outlet	7.6	13	6	24	-	1	3.3	
	Real time reading at OUTLET(online)									
	20 MGD (PH-II)	Inlet	7.4	488	210	667	-	31	3.2	16.8
		Outlet	7.5	144	125	366	-	28	2.9	
	Real Time Reading at Outlet									
	40 MGD (PH-III)	Inlet	7.4	488	210	667	-	31	3.2	37.45
		Outlet	7.6	88	78	234	-	27	2.8	
Real Time Reading at Outlet										
Nilothi	40 MGD (PH-I)	Inlet	7.4	204	114	347	-	28	2.7	34.41
		Outlet	7.6	136	61	208	-	24	2.5	
	Real Time Reading at Outlet									
	20 MGD	Inlet	7.3	312	157	613	-	29	3.1	19.88

	(PH-II)	Outlet	7.4	14	7	28	-	12	2.4	
	Real Time Reading at Outlet									
Pappankalan	(20 MGD)	Inlet	7.4	380	216	-	-	32	3.8	20.06
	PH-I	Outlet	7.7	106	52	-	-	28	3.2	
	Real Time Reading at Outlet									
	(20 MGD)	Inlet	7.4	380	216	-	-	32	3.8	20
	PH-II	Outlet	7.8	8	6	-	-	10	0.8	
	Real Time Reading at Outlet									
Najafgarh	(05 MGD)	Inlet	7.4	552	236	-	-	32	3.6	5
		Outlet	7.8	49	26	-	-	20	1.4	
	Real Time Reading at Outlet									
Okhla	12 MGD	Inlet	7.4	240	150	350	-	40	1.9	-
		outlet	7.7	26	15	60	-	34	0.9	6.12
	Real Time Reading at Outlet									
	45 MGD	Inlet	7.4	236	153	360	-	41	1.9	-
		outlet	7.7	28	14	50	-	34	0.8	40.16
	Real Time Reading at Outlet									
	37 MGD	Inlet	7.4	236	153	360	-	41	1.9	-
		outlet	7.7	30	16	60	-	36	0.6	29.11
	Real Time Reading at Outlet									
	16 MGD	Inlet	7.4	236	153	360	-	41	1.9	-
		outlet	7.7	17	8	30	-	30	0.7	14.23
	Real Time Reading at Outlet									
	New 30 MGD	Inlet	7.4	230	128	310	-	40	1.9	-
		Outlet	7.6	7	4	20	-	5	NIL	27.59
	Real Time Reading at Outlet									

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Name of the Plant	Capacity (in MGD)	11.01.21		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC Limit	50	30	250
Yamuna Vihar	10 MGD Phase-I	43	27	-
	10 MGD Phase-II	22	19	-
	25 MGD Phase-III	44	26	-
Rithala	40 MGD	92	44	170
	40 MGD	20	15	70
Corronation pillar	20 MGD Phase-I &II	90	62	168
	10 MGD Phase-III	98	95	256
Narela	10 MGD Phase-III	26	20	84
Rohini	15 MGD	28	16	67
Keshopur	12 MGD	13	6	24
	20 MGD	144	125	366
	40 MGD	88	78	234
Nilothi	40 MGD	136	61	208
	20 MGD	14	7	28
Pappankalan	(20 MGD)	106	52	-
	(20 MGD)	8	6	-
Najafgarh	05 MGD	49	26	-
Okhla	12 MGD	26	15	60
	45 MGD	28	14	50
	37 MGD	30	16	60
	16 MGD	17	8	30
	New 30 MGD	7	4	20

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Parameters of STPs of Delhi as on							12.01.21			
Name of the Plant	Capacity (in MGD)	Parameter								
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4	Daily Flow (MGD)
		DPCC limits	5.5-9.0	50	30	250	10	50	5	
Yamuna Vihar	10 MGD Phase-I	Inlet	6.9	312	229			45	4.5	8.1
		outlet	7.5	40	18			20	2.5	
	Real Time Reading at Outlet		7.2	36	13	58				
	10 MGD Phase-II	Inlet	7.2	232	181			40	4.0	7.62
		outlet	7.5	31	15			20	2.0	
	Real Time Reading at Outlet									
	25 MGD Phase-III	Inlet	7.2	420	253			45	4.5	28.91
		outlet	7.6	47	28			20	2.5	
Real Time Reading at Outlet			28	18	74					
Rithala	40 MGD	Inlet	7.5	304	191	450		42	2.1	
		outlet	7.5	125	72	210		36	1.7	10.38
	Real Time Reading at Outlet		7.05	72.5	40.13	155.43		21.67		
	40 MGD	Inlet	7.5	304	191	450		42	2.1	
		Outlet	7.5	19	15	60		16	0.7	39.12
	Real Time Reading at Outlet		7.5	13.74	10.24	74.6		6.48		
Corronation Pillar	20 MGD Phase-I &II	Inlet	7.1	176	188	282	5.5	37	8.2	16.368
		outlet	7.4	84	64	156	3.6	25	5.3	-
	Real Time Reading at Outlet									
	10 MGD Phase-III	Inlet	7	380	280	484	-	50	11.8	6.67
		outlet	7.3	99	78	280	-	40	8.8	-
	Real Time Reading at Outlet									
Rohini	15 MGD	Inlet	7.1	264	125			50	6	6.78
		Outlet	7.6	27	15			18	4	
	Real Time Reading at Outlet									
Keshopur	12 MGD	Inlet	7.3	248	125	480	7.4	28	2.9	12.64
	(PH-I)	Outlet	7.6	15	7	28	-	1	3.1	
	Real time reading at OUTLET(online)									
	20 MGD (PH-II)	Inlet	7.4	428	192	-	8.8	30	3.3	20.44
		Outlet	7.5	156	126	-	4.2	29	3.1	
	Real Time Reading at Outlet									
	40 MGD (PH-III)	Inlet	7.4	428	192	-	8.8	30	3.3	36.25
		Outlet	7.7	120	89	-	2.6	28	3	
	Real Time Reading at Outlet									
Nilothi	40 MGD (PH-I)	Inlet	7.2	358	157	-	6.8	26	2.9	34.55
		Outlet	7.5	94	65	-	0.5	22	2.5	
	Real Time Reading at Outlet									
	20 MGD (PH-II)	Inlet	7.3	280	165	-	8.4	32	2.9	18.23
		Outlet	7.5	12	6	-	-	15	1.9	
	Real Time Reading at Outlet									
	(20 MGD)	Inlet	7.4	432	246	-	-	32	3.9	20.44

Pappankalan	PH-I	Outlet	7.7	109	54	-	-	22	3.2	
	Real Time Reading at Outlet									
	(20 MGD)	Inlet	7.4	432	246	-	-	32	3.9	20.7
	PH-II	Outlet	7.8	9	6	-	-	6	1.6	
	Real Time Reading at Outlet									
Najafgarh	(05 MGD)	Inlet	7.4	409	240	-	-	28	3.2	4.96
		Outlet	7.8	64	38	-	-	22	2	
	Real Time Reading at Outlet									
Okhla	12 MGD	Inlet	7.4	234	150	370	-	42	1.6	-
		outlet	7.7	27	13	50	-	34	0.7	6.24
	Real Time Reading at Outlet									
	45 MGD	Inlet	7.4	224	148	350	-	40	1.8	-
		outlet	7.7	30	17	60	-	32	0.8	39.65
	Real Time Reading at Outlet									
	37 MGD	Inlet	7.4	224	148	350	-	40	1.8	-
		outlet	7.7	30	15	60	-	34	1.1	30.11
	Real Time Reading at Outlet									
	16 MGD	Inlet	7.4	224	148	350	-	40	1.8	-
		outlet	7.7	16	7	30	-	31	0.7	14.65
	Real Time Reading at Outlet									
	New 30 MGD	Inlet	7.4	202	132	300	-	38	1.5	-
		Outlet	7.7	6	3	10	-	3	NIL	27.84
	Real Time Reading at Outlet									

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Name of the Plant	Capacity (in MGD)	12.01.21		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC Limit	50	30	250
Yamuna Vihar	10 MGD Phase-I	40	18	-
	10 MGD Phase-II	31	15	-
	25 MGD Phase-III	47	28	-
Rithala	40 MGD	125	72	210
	40 MGD	19	15	60
Corronation pillar	20 MGD Phase-I &II	84	64	156
	10 MGD Phase-III	99	78	280
Rohini	15 MGD	27	15	-
Keshopur	12 MGD	15	7	28
	20 MGD	156	126	-
	40 MGD	120	89	-
Nilothi	40 MGD	94	65	-
	20 MGD	12	6	-
Pappankalan	(20 MGD)	109	54	-
	(20 MGD)	9	6	-
Najafgarh	05 MGD	64	38	-
Okhla	12 MGD	27	13	50
	45 MGD	30	17	60
	37 MGD	30	15	60
	16 MGD	16	7	30
	New 30 MGD	6	3	10

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Parameters of STPs of Delhi as on							13.01.21			
Name of the Plant	Capacity (in MGD)	Parameter								
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4	Daily Flow (MGD)
		DPCC limits	5.5-9.0	50	30	250	10	50	5	
Yamuna Vihar	10 MGD Phase-I	Inlet	6.9	348	147	792	28.8	40	5.0	7.65
		outlet	7.4	27	18	96	5.6	25	2.5	
	Real Time Reading at Outlet		7.2	34	12	55		3		
	10 MGD Phase-II	Inlet	7.0	288	175	640	16.8	30	4.0	7.59
		outlet	7.4	17	11	56	2.0	20	2.0	
	Real Time Reading at Outlet									
	25 MGD Phase-III	Inlet	7.2	596	217	1136	42.0	50	4.0	27.86
		outlet	7.5	37	24	112	7.2	30	2.5	
Real Time Reading at Outlet			31	19	78					
Rithala	40 MGD	Inlet	7.3	244	177	460		34	1.1	
		outlet	7.4	131	68	200		30	1.1	9.4
	Real Time Reading at Outlet		7.05	84.87	40.98	158.99		19.96		
	40 MGD	Inlet	7.3	244	177	460		34	1.1	
		Outlet	7.5	17	14	60		12	0.4	39.05
	Real Time Reading at Outlet		7.42	13.81	10.52	77.88		6.41		
Corronation Pillar	20 MGD Phase-I & II	Inlet	7	166	195	314	-	35	9.3	16.53
		outlet	7.4	76	68	212	-	19	4.5	-
	Real Time Reading at Outlet									
	10 MGD Phase-III	Inlet	6.8	328	323	438	8.4	44	9.6	6.38
		outlet	7.2	84	73	270	4	31	5.4	-
	Real Time Reading at Outlet									
Narela	10 MGD Phase-III	Inlet	7	154	180	334	6.6	44	5.2	1.76
		outlet	7.5	21	14	56	2.5	14	2.5	-
	Real Time Reading at Outlet									
Rohini	15 MGD	Inlet	7.2	328	145	579		40	6	5.88
		Outlet	7.5	27	16	64		12	2.5	
	Real Time Reading at Outlet									
Keshopur	12 MGD (PH-I)	Inlet	7.3	264	134	-	-	28	2.9	12.64
		Outlet	7.6	14	5	-	-	1	3.2	
	Real time reading at OUTLET(online)									
	20 MGD (PH-II)	Inlet	7.4	560	185	-	-	26	3.3	20.44
		Outlet	7.6	110	102	-	-	27	3.1	
	Real Time Reading at Outlet									
	40 MGD (PH-III)	Inlet	7.4	560	185	-	-	26	3.3	36.25
		Outlet	7.5	188	118	-	-	26	2.8	
Real Time Reading at Outlet										
Nilothi	40 MGD (PH-I)	Inlet	7.3	144	110	-	-	26	3.1	34.55
		Outlet	7.6	86	69	-	-	24	3	
	Real Time Reading at Outlet									
	20 MGD	Inlet	7.3	256	143	-	-	27	2.8	18.23

	(PH-II)	Outlet	7.6	9	7	-	-	12	1.9	
	Real Time Reading at Outlet									
Pappankalan	(20 MGD)	Inlet	7.4	356	225	-	-	32	3.8	20.44
	PH-I	Outlet	7.7	100	58	-	-	22	3	
	Real Time Reading at Outlet									
	(20 MGD)	Inlet	7.4	356	225	-	-	32	3.8	20.7
	PH-II	Outlet	7.7	7	5	-	-	6	1.7	
	Real Time Reading at Outlet									
Najafgarh	(05 MGD)	Inlet	7.4	365	228	-	-	30	3.4	4.96
		Outlet	7.7	31	20	-	-	18	2.2	
	Real Time Reading at Outlet									
Okhla	12 MGD	Inlet	7.4	236	150	370	-	41	1.5	-
		outlet	7.7	27	14	60	-	28	0.5	6.35
	Real Time Reading at Outlet									
	45 MGD	Inlet	7.3	226	148	360	-	42	2	-
		outlet	7.7	25	15	50	-	34	0.8	40.02
	Real Time Reading at Outlet									
	37 MGD	Inlet	7.3	226	148	360	-	42	2	-
		outlet	7.6	29	14	60	-	31	0.9	30.11
	Real Time Reading at Outlet									
	16 MGD	Inlet	7.3	226	148	360	-	42	2	-
		outlet	7.8	14	8	30	30	0.9	0.5	14.63
	Real Time Reading at Outlet									
	New 30 MGD	Inlet	7.3	206	127	310	-	40	1.5	-
		Outlet	7.7	7	5	20	-	2	NIL	26.78
	Real Time Reading at Outlet									
Mehrauli	5 MGD	Inlet	7.4	246	150	370	-	40	1.6	-
		outlet	7.6	23	14	50	-	30	0.8	4.02
	Real Time Reading at Outlet									
Vasant Kunj	2.2 MGD	Inlet	7.2	224	147	340	-	36	1.9	-
		outlet	7.7	25	16	50	-	29	0.9	1.15
	Real Time Reading at Outlet									
	3 MGD	Inlet	7.3	220	148	330	-	35	1.3	-
		outlet	7.7	19	12	40	-	25	0.4	1.49
	Real Time Reading at Outlet									
Kapashera	5 MGD	Inlet	7.3	270	160	380	-	45	2.6	-
		outlet	7.7	7	4	20	-	3	0.5	4.78
	Real Time Reading at Outlet									

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Name of the Plant	Capacity (in MGD)	13.01.21		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC Limit	50	30	250
Yamuna Vihar	10 MGD Phase-I	27	18	96
	10 MGD Phase-II	17	11	56
	25 MGD Phase-III	37	24	112
Rithala	40 MGD	131	68	200
	40 MGD	17	14	60
Corronation pillar	20 MGD Phase-I &II	76	68	212
	10 MGD Phase-III	84	73	270
Narela	10 MGD Phase-III	21	14	56
Rohini	15 MGD	27	16	64
Keshopur	12 MGD	14	5	-
	20 MGD	110	102	-
	40 MGD	188	118	-
Nilothi	40 MGD	86	69	-
	20 MGD	9	7	-
Pappankalan	(20 MGD)	100	58	-
	(20 MGD)	7	5	-
Najafgarh	05 MGD	31	20	-
Okhla	12 MGD	27	14	60
	45 MGD	25	15	50
	37 MGD	29	14	60
	16 MGD	14	8	30
	New 30 MGD	7	5	20
Mehrauli	5 MGD	23	14	50
Vasant Kunj	2.2 MGD	25	16	50
	3 MGD	19	12	40
Kapashera	5 MGD	7	4	20

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Parameters of STPs of Delhi as on							14.01.21			
Name of the Plant	Capacity (in MGD)	Parameter								
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4	Daily Flow (MGD)
		DPCC limits	5.5-9.0	50	30	250	10	50	5	
Yamuna Vihar	10 MGD Phase-I	Inlet	7.1	320	212			30	5.5	7.92
		outlet	7.4	24	15			20	2.0	
	Real Time Reading at Outlet		7.2	29	11	51		3		
	10 MGD Phase-II	Inlet	7.2	316	214			25	4.5	7.81
		outlet	7.5	20	13			15	2.5	
	Real Time Reading at Outlet									
	25 MGD Phase-III	Inlet	7.4	444	228			35	5.5	27.91
		outlet	7.5	36	23			20	3.0	
Real Time Reading at Outlet			31	22	85					
Rithala	40 MGD	Inlet	7.4	212	168	440		33	1.0	
		outlet	7.4	89	49	180		31	1.3	11.77
	Real Time Reading at Outlet		7.18	121.44	43.82	170.13		15.77		
	40 MGD	Inlet	7.4	212	168	440		33	1.0	
		Outlet	7.5	16	13	50		13	0.5	38.25
	Real Time Reading at Outlet		7.41	13.63	10.2	73.09		6.41		
Corronation Pillar	20 MGD Phase-I &II	Inlet	7.1	180	203	302	6.2	40	8.4	17.975
		outlet	7.5	69	63	200	2.8	29	3.6	-
	Real Time Reading at Outlet									
	10 MGD Phase-III	Inlet	6.9	210	265	424	-	48	10.2	5.69
		outlet	7.3	80	78	238	-	32	5	-
	Real Time Reading at Outlet									
Rohini	15 MGD	Inlet	7.1	360	155			45	7	8.01
		Outlet	7.5	28	16			16	3	
	Real Time Reading at Outlet									
Keshopur	12 MGD	Inlet	7.4	304	139	-	-	27	2.9	11.67
	(PH-I)	Outlet	7.6	12	8	-	-	1	3.4	
	Real time reading at OUTLET(online)									
	20 MGD (PH-II)	Inlet	7.4	484	164	-	-	29	3.3	17.43
		Outlet	7.5	138	118	-	-	27	2.8	
	Real Time Reading at Outlet									
	40 MGD (PH-III)	Inlet	7.4	484	164	-	-	29	3.3	36.11
		Outlet	7.5	176	98	-	-	26	2.7	
	Real Time Reading at Outlet									
Nilothi	40 MGD (PH-I)	Inlet	7.3	270	134	-	-	25	2.8	34.45
		Outlet	7.5	88	67	-	-	20	2.5	
	Real Time Reading at Outlet									
	20 MGD (PH-II)	Inlet	7.2	304	164	-	-	32	3.4	18.94
		Outlet	7.5	9	6	-	-	12	2	
Real Time Reading at Outlet										
	(20 MGD)	Inlet	7.4	392	228	-	6.4	30	3.8	20.32

Pappankalan	PH-I	Outlet	7.8	62	45	-	-	20	2.8	
	Real Time Reading at Outlet									
	(20 MGD)	Inlet	7.4	392	228	-	6.4	30	3.8	20.6
	PH-II	Outlet	7.7	9	6	-	-	5	1.4	
	Real Time Reading at Outlet									
Najafgarh	(05 MGD)	Inlet	7.4	380	232	-	5	28	3.6	4.98
		Outlet	7.7	60	31	-	-	16	2.4	
	Real Time Reading at Outlet									
Okhla	12 MGD	Inlet	7.4	222	140	340	-	40	1.4	
		outlet	7.7	22	13	40	-	28	0.7	
	Real Time Reading at Outlet									
	45 MGD	Inlet	7.3	228	143	350	-	39	2.1	
		outlet	7.5	26	14	60	-	32	0.9	
	Real Time Reading at Outlet									
	37 MGD	Inlet	7.3	228	143	350	-	39	2.1	
		outlet	7.7	32	15	60	-	32	1	
	Real Time Reading at Outlet									
	16 MGD	Inlet	7.3	228	143	350	-	39	2.1	
		outlet	7.7	13	10	30	-	23	0.4	
	Real Time Reading at Outlet									
	New 30 MGD	Inlet	7.4	240	135	320	-	40	1.7	
		Outlet	7.7	7	4	20	-	5	NIL	
	Real Time Reading at Outlet									
Molarbund	0.66 MGD	Inlet	7.4	242	155	340	-	40	1.9	
		outlet	7.7	20	13	40	-	30	0.7	
	Real Time Reading at Outlet									
Delhi Gate-I	2.2 MGD	Inlet	7.4	212	133	330	-	36	1.9	
		outlet	7.7	6	3	10	-	NIL	NIL	
	Real Time Reading at Outlet									
Delhi Gate-II	15 MGD	Inlet	7.3	204	128	320	-	32	1.6	
		outlet	7.7	7	4	20	-	NIL	NIL	
	Real Time Reading at Outlet									
Sen Nursing Home	2.2 MGD	Inlet	7.3	218	130	330	-	34	2	
		outlet	7.6	7	4	20	-	NIL	NIL	
	Real Time Reading at Outlet									

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Name of the Plant	Capacity (in MGD)	14.01.21		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC Limit	50	30	250
Yamuna Vihar	10 MGD Phase-I	24	15	-
	10 MGD Phase-II	20	13	-
	25 MGD Phase-III	36	23	-
Rithala	40 MGD	89	49	180
	40 MGD	16	13	50
Corronation pillar	20 MGD Phase-I &II	69	63	200
	10 MGD Phase-III	80	78	238
Rohini	15 MGD	28	16	-
Keshopur	12 MGD	12	8	-
	20 MGD	138	118	-
	40 MGD	176	98	-
Nilothi	40 MGD	88	67	-
	20 MGD	9	6	-
Pappankalan	(20 MGD)	62	45	-
	(20 MGD)	9	6	-
Najafgarh	05 MGD	60	31	-
Okhla	12 MGD	22	13	40
	45 MGD	26	14	60
	37 MGD	32	15	60
	16 MGD	13	10	30
	New 30 MGD	7	4	20
Molarbund	0.66 MGD	20	13	40
Delhi Gate-I	2.2 MGD	6	3	10
Delhi Gate-II	15 MGD	7	4	20
Sen Nursing Home	2.2 MGD	7	4	20