



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



		Parameters of STPs of Delhi as on					05.04.2019			
Name of the Plant	Capacity (in MGD)	Parameter								
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4	
		DPPC limits	5.5-9.0	50	30	250	10	50	5	
Okhla	12 MGD	Inlet	7.2	236	173	440	3	45	2.5	
		outlet	7.8	31	22	80	1	40	Nil	
	45 MGD	Inlet	7.3	246	180	-	4	46	2.8	
		outlet	7.8	36	24	-	1	42	Nil	
	37 MGD	Inlet	7.3	246	180	-	4	46	2.8	
		outlet	7.9	45	28	-	2	44	Nil	
16 MGD	Inlet	7.3	246	180	-	4	46	2.8		
	outlet	7.9	31	21	-	Nil	43	0.5		
Mehrauli	5 MGD	Inlet	7.3	242	180	464	5	46	2.5	
		outlet	8.1	23	16	80	3	42	2	
Vasant Kunj	2.2 MGD	Inlet	7.4	814	430	1280	4	46	2.6	
		outlet	8.1	24	15.6	64	1	44	2.5	
	3 MGD	Inlet	7.3	314	187.5	480	2	43	2.8	
		outlet	7.6	6	10.5	32	Nil	5	2.6	
Kapashera	5 MGD	Inlet	7.5	334	220	469	4	48	3.3	
		outlet	8.2	15	11.5	40	1	40	2.8	
Kondli	25 MGD Phase-II	Inlet	7.3	396	208	344	24	41	6.9	
		outlet	7.6	17	9	36	4	33	3.1	
	45 MGD Phase-IV	Inlet	7.2	320	173	312	26	42	6.8	
		outlet	7.5	30	15	66	5	30	3.3	
Chilla	9 MGD	Inlet	7.1	380	194	355	16	41	6.5	
		outlet	7.6	4	2	10	2	0.26	4.3	
CWG Village	1 MGD	Inlet	7.2	248	125	251	23	29	4.7	
		outlet	7.7	Bdl	0.44	Bdl	Bdl	0.16	1	
Yamuna Vihar	10 MGD Phase-I	Inlet	7.2	368	223	-	-	40	5.5	
		outlet	7.9	36	16	-	-	15	3	
	Phase-II	Inlet	7.4	316	235	-	-	35	5	
		outlet	7.9	34	18	-	-	10	2	
	25 MGD Phase-III	Inlet	7.2	452	232	-	-	50	6.5	
		outlet	7.9	27	20	-	-	25	3.5	
Rithala	40 MGD	Inlet	7.2	324	176	430	-	40	1.5	
		outlet	7.9	29	18	80	-	23	1.2	
	40 MGD	Inlet	7.2	324	176	430	-	40	1.5	
		Outlet	7.8	17	12	70	-	18	0.8	
	Keshopur	12 MGD	Inlet	7.3	424	265	-	-	32	3.6
			outlet	7.6	14	5	-	-	3	2.1
40 MGD		Inlet	7.3	416	270	-	-	33	3.8	
		outlet	7.5	90	68	-	-	28	3.1	
20 MGD		Inlet	7.3	416	270	-	-	33	3.8	
		outlet	7.5	128	128	-	-	30	3.2	
Nazafgarh	5 MGD	Inlet	7.3	280	160	-	-	20	-	
		outlet	7.7	15	8	-	-	4	-	
PappanKalan	20 MGD Phase-I	Inlet	7.4	376	150	-	-	42	3.2	
		outlet	7.8	44	16	-	-	28	0.8	
	20 MGD Phase-II	Inlet	7.4	376	150	-	-	42	3.2	
		outlet	7.5	7	5	-	-	30	2.2	
Corronation pillar	20 MGD Phase-I & II	Inlet	7.4	340	305	445	7.6	42	2.4	
		outlet	7.7	53	32	115	2.4	26	1.3	
	10 MGD Phase-III	Inlet	7.5	312	285	426	-	54	2.6	
		outlet	7.9	72	39	110	-	36	1.5	

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	05.04.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
		50	30	250
Okhla	12 MGD	31	22	80
	45 MGD	36	24	-
	37 MGD	45	28	-
	16 MGD	31	21	-
Mehrauli	5 MGD	23	16	80
Vasant Kunj	2.2 MGD	24	15.6	64
	3 MGD	6	10.5	32
Kapashera	5 MGD	15	11.5	40
Kondli	25 MGD Pahse-II	17	9	36
	45 MGD Phase-IV	30	15	66
Chilla	9 MGD	4	2	10
CWG Village	1 MGD	Bdl	0.44	Bdl
Yamuna Vihar	10 MGD Phase-I	36	16	-
	Phase-II	34	18	-
	25 MGD Phase-III	27	20	-
Rithala	40 MGD Phase-I	29	18	80
	40 MGD Phase-II	17	12	70
Keshopur	12 MGD	14	5	-
	40 MGD	90	68	-
	20 MGD	128	128	-
Nazafgarh	5 MGD	15	8	-
PappanKalan	20 MGD Phase-I	44	16	-
	20 MGD Phase-II	7	5	-
Corronation pillar	20 MGD Pahse-I & II	53	32	115
	10 MGD Pahse-III	72	39	110



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



		Parameters of STPs of Delhi as on					04.04.2019		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPPC limits	5.5-9.0	50	30	250	10	50	5
Okhla	12 MGD	Inlet	7.3	238	190	-	4	43	2.7
		outlet	7.7	26	18	-	2	41	0.4
	45 MGD	Inlet	7.3	288	190	-	4	45	2.8
		outlet	7.7	38	26	-	2	44	0.2
	37 MGD	Inlet	7.3	288	190	-	4	45	2.8
		outlet	7.8	38	26	-	Nil	43	0.2
	16 MGD	Inlet	7.3	288	190	-	4	45	2.8
		outlet	7.8	34	23	-	1	45	0.3
	New 30 MGD	Inlet	7.5	444	250	-	4	40	2.5
		Outlet	7.6	10	7	-	Nil	5	Nil
Kondli	25 MGD Phase-II	Inlet	7.3	306	212	368	22	39	7.3
		outlet	7.6	15	11	32	3	35	3.9
	45 MGD Phase-IV	Inlet	7.1	312	204	376	24	40	7.1
		outlet	7.5	23	16	50	4	33	3.5
Chilla	9 MGD	Inlet	7.1	128	86	120	12	43	7.1
		outlet	7.6	7	3.2	18	2	0.29	5.2
CWG Village	1 MGD	Inlet	7.2	356	215	352	27	26	6.9
		outlet	7.7	Bdl	0.64	Bdl	Bdl	0.15	1.7
Yamuna Vihar	10 MGD Phase-I	Inlet	7.2	448	137	-	-	60	7
		outlet	7.7	30	24	-	-	30	4
	Phase-II	Inlet	7.3	364	186	-	-	40	5
		outlet	7.8	44	28	-	-	20	2.5
	25 MGD Phase-III	Inlet	7.3	628	153	-	-	65	8.5
		outlet	7.9	28	23	-	-	35	5
Rithala	40 MGD	Inlet	7	272	152	350	18	29	0.7
		outlet	7.7	27	17	70	7	24	0.4
	40 MGD	Inlet	7	272	152	350	18	29	0.7
		Outlet	7.6	18	12	60	3	16	0.2
Keshopur	12 MGD	Inlet	7.3	448	221	-	17.4	30	3.5
		outlet	7.6	12	5	-	Nil	3	2.4
	40 MGD	Inlet	7.3	396	282	-	14.2	32	3.9
		outlet	7.5	106	90	-	2.3	29	3.3
	20 MGD	Inlet	7.3	396	282	-	14.2	32	3.9
		outlet	7.5	134	124	-	5.8	29	3.5
Nilothi	40 MGD Phase-I	Inlet	7.2	224	136	-	3.9	26	3
		outlet	7.4	40	24	-	0.4	19	2
Nazafgarh	5 MGD	Inlet	7.3	109	98	-	-	20	
		outlet	7.8	12	9	-	-	5	
PappanKalan	20 MGD Phase-I	Inlet	7.4	409	300	-	-	30	3.2
		outlet	7.9	41	28	-	-	20	0.8
	20 MGD Phase-II	Inlet	7.4	409	300	-	-	30	3.2
		outlet	7.5	7	7	-	-	30	2.4
Corronation pillar	20 MGD Phase-I &II	Inlet	7.5	350	290	448	-	40	2.2
		outlet	7.7	68	36	126	-	24	1.2
	10 MGD Phase-III	Inlet	7.3	510	350	620	8.5	56	2.8
		outlet	7.9	88	42	128	3.4	34	1.6

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	04.04.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
		50	30	250
Okhla	12 MGD	26	18	-
	45 MGD	38	26	-
	37 MGD	38	26	-
	16 MGD	34	23	-
	New 30 MGD	10	7	-
Kondli	25 MGD Pahse-II	15	11	32
	45 MGD Phase-IV	23	16	50
Chilla	9 MGD	7	3.2	18
CWG Village	1 MGD	Bdl	0.64	Bdl
Yamuna Vihar	10 MGD Phase-I	30	24	-
	Phase-II	44	28	-
	25 MGD Phase-III	28	23	-
Rithala	40 MGD Phase-I	27	17	70
	40 MGD Phase-II	18	12	60
Keshopur	12 MGD	12	5	-
	40 MGD	106	90	-
	20 MGD	134	124	-
Nilothi	40 MGD Pahse-I	40	24	-
Nazafgarh	5 MGD	12	9	-
PappanKalan	20 MGD Phase-I	41	28	-
	20 MGD Phase-II	7	7	-
Corronation pillar	20 MGD Pahse-I & II	68	36	126
	10 MGD Pahse-III	88	42	128



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



		Parameters of STPs of Delhi as on					03.04.2019		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPPC limits	5.5-9.0	50	30	250	10	50	5
Okhla	12 MGD	Inlet	7.3	272	238	488	6	45	2.4
		outlet	7.8	29	20	80	3	43	0.5
	45 MGD	Inlet	7.5	316	218	488	6	46	2
		outlet	8.3	35	24	96	2	45	0.5
	37 MGD	Inlet	7.5	316	218	488	6	46	2
		outlet	7.8	29	22	88	1	45	Nil
	16 MGD	Inlet	7.5	316	218	488	6	46	2
		outlet	7.8	27	20	80	Nil	43	Nil
Kondli	25 MGD Phase-II	Inlet	7.2	446	259	458	18	42	6.7
		outlet	7.6	19	10	42	4	35	2.8
	45 MGD Phase-IV	Inlet	7.2	320	205	304	23	42	6.6
		outlet	7.5	25	13	54	5	33	3.1
Chilla	9 MGD	Inlet	7.1	432	221	424	18	39	6.9
		outlet	7.6	5	3	14	3	0.27	4.7
CWG Village	1 MGD	Inlet	7.2	396	200	352	25	26	4.9
		outlet	7.7	Bdl	0.4	Bdl	Bdl	0.17	1.3
Yamuna Vihar	10 MGD Phase-I	Inlet	7.3	348	212	-	-	55	6.5
		outlet	7.6	32	23	-	-	30	4
	Phase-II	Inlet	7	296	213	-	-	45	7.5
		outlet	7.6	40	25	-	-	20	4.5
	25 MGD Phase-III	Inlet	7.2	560	319	-	-	60	7
		outlet	7.6	26	17	-	-	35	4
Rithala	40 MGD	Inlet	7.3	224	163	410	-	32	1.4
		outlet	7.9	28	18	80	-	20	1.1
	40 MGD	Inlet	7.3	224	163	410	-	32	1.4
		Outlet	7.8	16	11	60	-	15	0.7
Keshopur	12 MGD	Inlet	7.3	488	228	787	-	29	3.2
		outlet	7.6	10	7	34	-	2	2.3
	40 MGD	Inlet	7.3	456	227	653	-	30	3.3
		outlet	7.5	84	76	248	-	28	2.8
	20 MGD	Inlet	7.3	456	227	653	-	30	3.3
		outlet	7.5	130	112	324	-	30	3.1
Nilothi	40 MGD Phase-I	Inlet	7.3	216	129	430	-	24	2.8
		outlet	7.4	38	22	86	-	19	2
	20 MGD Phase-II	Inlet	7.2	252	167	560	8.2	28	3
		outlet	7.2	12	8	36	Nil	8	2
Nazafgarh	5 MGD	Inlet	7.3	238	175	-	-	20	
		outlet	7.8	13	6	-	-	4	
PappanKalan	20 MGD Phase-I	Inlet	7.4	340	200	810	9	43	3.2
		outlet	7.9	32	17	110	5	26	0.8
	20 MGD Phase-II	Inlet	7.4	340	200	810	9	43	3.2
		outlet	7.5	7	4	40	Nil	32	2.4
Corronation pillar	20 MGD Phase-I & II	Inlet	7.4	230	210	376	8.1	41	2.1
		outlet	7.6	48	28	120	3	24	1.1
	10 MGD Phase-III	Inlet	7.3	438	318	532	-	58	3
		outlet	7.6	92	44	168	-	36	1.9

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	03.04.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
		50	30	250
Okhla	12 MGD	29	20	80
	45 MGD	35	24	96
	37 MGD	29	22	88
	16 MGD	27	20	80
Kondli	25 MGD Pahse-II	19	10	42
	45 MGD Phase-IV	25	13	54
Chilla	9 MGD	5	3	14
CWG Village	1 MGD	Bdl	0.4	Bdl
Yamuna Vihar	10 MGD Phase-I	32	23	-
	Phase-II	40	25	-
	25 MGD Phase-III	26	17	-
Rithala	40 MGD Phase-I	28	18	80
	40 MGD Phase-II	16	11	60
Keshopur	12 MGD	10	7	34
	40 MGD	84	76	248
	20 MGD	130	112	324
Nilothi	40 MGD Pahse-I	38	22	86
	20 MGD Phase-II	12	8	36
Nazafgarh	5 MGD	13	6	-
PappanKalan	20 MGD Phase-I	32	17	110
	20 MGD Phase-II	7	4	40
Corronation pillar	20 MGD Pahse-I & II	48	28	120
	10 MGD Pahse-III	92	44	168



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	Parameters of STPs of Delhi as on					02.04.2019		
		Parameter							
		DPPC limits	pH 5.5-9.0	TSS (mg/l) 50	BOD (mg/l) 30	COD (mg/l) 250	O&G 10	NH4-H 50	PO4 5
Okhla	12 MGD	Inlet	7.2	222	233	400	4	38	2.5
		outlet	7.8	43	28	112	Nil	35	Nil
	45 MGD	Inlet	7.4	250	223	416	4	40	3
		outlet	7.8	26	19	72	Nil	36	0.5
	37 MGD	Inlet	7.4	250	223	416	4	40	3
		outlet	7.8	30	21	80	Nil	35	0.4
	16 MGD	Inlet	7.4	250	223	416	4	40	3
		outlet	7.9	42	27	102	Nil	38	0.5
Kondli	25 MGD Phase-II	Inlet	7.2	330	212	304	20	42	6.7
		outlet	7.5	18	13	38	4	27	3.4
	45 MGD Phase-IV	Inlet	7.1	314	197	298	25	40	6.6
		outlet	7.4	27	17	59	5	34	3.1
Chilla	9 MGD	Inlet	7.1	260	120	275	19	44	6.6
		outlet	7.6	6	3	16	3	0.32	4.9
CWG Village	1 MGD	Inlet	7.1	596	376	531	29	29	4.5
		outlet	7.6	Bdl	0.49	Bdl	Bdl	0.19	1.3
Yamuna Vihar	10 MGD Phase-I	Inlet	7	308	209	-	135.2	55	6.5
		outlet	7.5	33	20	-	22.8	25	3
	Phase-II	Inlet	7.1	280	186	-	32.4	45	5.5
		outlet	7.4	37	23	-	12.4	35	2.5
	25 MGD Phase-III	Inlet	7.2	388	201	-	142	50	6
		outlet	7.5	27	16	-	38.8	30	4
Rithala	40 MGD	Inlet	6.9	296	169	370	-	29	0.9
		outlet	8	29	19	80	-	24	1.2
	40 MGD	Inlet	6.9	296	169	370	-	29	0.9
		Outlet	7.9	17	12	50	-	15	0.6
Keshopur	12 MGD	Inlet	7.3	368	271	-	-	27	3
		outlet	7.6	7	5	-	-	1.5	2.4
	40 MGD	Inlet	7.3	280	212	-	-	28	2.9
		outlet	7.5	86	77	-	-	25	2.8
	20 MGD	Inlet	7.3	280	212	-	-	28	2.9
		outlet	7.4	142	130	-	-	30	2.6
Nilothi	40 MGD Phase-I	Inlet	7.3	204	134	-	-	25	3.5
		outlet	7.4	36	19	-	-	19	2.8
	20 MGD Phase-II	Inlet	7.5	300	160	-	-	28	2.8
		outlet	7.6	15	7	-	-	9	2.7
Nazafgarh	5 MGD	Inlet	7.4	234	178	-	-	20	4
		outlet	7.7	30	14	-	-	5	2.2
PappanKalan	20 MGD Phase-I	Inlet	7.2	259	205	-	-	40	3.4
		outlet	7.7	34	21	-	-	26	1
	20 MGD Phase-II	Inlet	7.2	259	205	-	-	40	3.4
		outlet	7.6	9	7	-	-	36	2.8
Corronation pillar	20 MGD Phase-I & II	Inlet	7.3	290	230	408	-	38	2.3
		outlet	7.6	62	34	132	-	22	1.2
	10 MGD Phase-III	Inlet	7.2	406	305	515	8.3	56	2.9
		outlet	7.8	90	43	156	3.4	35	1.8

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	02.04.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
		50	30	250
Okhla	12 MGD	43	28	112
	45 MGD	26	19	72
	37 MGD	30	21	80
	16 MGD	42	27	102
Kondli	25 MGD Pahse-II	18	13	38
	45 MGD Phase-IV	27	17	59
Chilla	9 MGD	6	3	16
CWG Village	1 MGD	Bdl	0.49	Bdl
Yamuna Vihar	10 MGD Phase-I	33	20	-
	Phase-II	37	23	-
	25 MGD Phase-III	27	16	-
Rithala	40 MGD Phase-I	29	19	80
	40 MGD Phase-II	17	12	50
Keshopur	12 MGD	7	5	-
	40 MGD	86	77	-
	20 MGD	142	130	-
Nilothi	40 MGD Pahse-I	36	19	-
	20 MGD Phase-II	15	7	-
Nazafgarh	5 MGD	30	14	-
PappanKalan	20 MGD Phase-I	34	21	-
	20 MGD Phase-II	9	7	-
Corronation pillar	20 MGD Pahse-I & II	62	34	132
	10 MGD Pahse-III	90	43	156



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



		Parameters of STPs of Delhi as on					01.04.2019		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCCLimits	5.5-9.0	50	30	250	10	50	5
Okhla	12 MGD	Inlet	7.2	306	194	-	3	42	2.8
		outlet	7.7	32	20	-	Nil	40	0.5
	45 MGD	Inlet	7.2	316	240	-	3	42	2.5
		outlet	7.6	26	19	-	Nil	42	0.5
	37 MGD	Inlet	7.2	316	240	-	3	42	2.5
		outlet	7.6	32	22	-	Nil	40	0.8
	16 MGD	Inlet	7.2	316	240	-	3	42	2.5
		outlet	7.6	32	22	-	Nil	42	Nil
	New 30 MGD	Inlet	7.3	248	220	-	4	43	2.5
		Outlet	7.3	7	6	-	Nil	10	Nil
Molarband	0.66 MGD	Inlet	7.2	538	424	1048	12	55	3.3
		outlet	8	23	17	64	7	35	2.5
Kondli	25 MGD Phase-II	Inlet	7.1	456	261	498	32	44	6.9
		outlet	7.4	89	39	125	12	35	3.1
	45 MGD Phase-IV	Inlet	7.1	290	196	248	28	43	6.8
		outlet	7.5	30	18	64	6	33	3.5
Chilla	9 MGD	Inlet	7.1	200	107	168	-	41	6.7
		outlet	7.6	9	4	24	-	0.29	4.6
CWG Village	1 MGD	Inlet	7.1	588	299	560	-	24	4.7
		outlet	7.6	Bdl	0.57	Bdl	-	0.13	1.2
Yamuna Vihar	10 MGD Phase-I	Inlet	7.1	292	205	-	-	50	8
		outlet	7.6	31	18	-	-	25	4.5
	Phase-II	Inlet	7.2	276	196	-	-	35	7.5
		outlet	7.6	36	17	-	-	25	4
	25 MGD Phase-III	Inlet	7.3	452	211	-	-	55	6
		outlet	7.5	28	19	-	-	35	3.5
Rithala	40 MGD	Inlet	7.2	264	165	340	-	31	0.8
		outlet	7.5	28	17	70	-	16	0.6
	40 MGD	Inlet	7.2	264	165	340	-	31	0.8
		Outlet	7.6	16	10	60	-	13	0.4
Keshopur	12 MGD	Inlet	7.4	484	248	747	16.7	28	2.8
		outlet	7.6	9	5	30	Nil	2	2.6
	40 MGD	Inlet	7.3	432	272	780	12	32	2.9
		outlet	7.5	70	68	222	2	27	2.8
	20 MGD	Inlet	7.3	432	272	780	12	32	2.9
		outlet	7.5	136	128	380	5.4	31	2.7
Nilothi	40 MGD Phase-I	Inlet	7.3	236	129	480	3.8	24	3
		outlet	7.5	38	26	80	0.5	19	2
Nazafgarh	5 MGD	Inlet	7.2	244	222	-	-	20	4
		outlet	7.7	13	14	-	-	5	2.2
Pappankalan	20 MGD Phase-I	Inlet	7.2	608	270	-	-	38	3.4
		outlet	7.7	32	17	-	-	26	1
	20 MGD Phase-II	Inlet	7.2	608	270	-	-	38	3.4
		outlet	7.5	12	7	-	-	36	2.8
Corronation pillar	20 MGD Phase-I & II	Inlet	7.4	240	210	378	7.4	36	2.1
		outlet	7.7	60	33	158	2.5	20	1
	10 MGD Phase-III	Inlet	7.2	418	316	522	-	53	2.6
		outlet	7.4	95	46	168	-	37	1.5
Narela	10 MGD	Inlet	7.4	214	210	378	8.5	51	2.5
		outlet	7.8	67	38	128	3.6	36	1.5

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	01.04.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
		50	30	250
Okhla	12 MGD	32	20	-
	45 MGD	26	19	-
	37 MGD	32	22	-
	16 MGD	32	22	-
	New 30 MGD	7	6	-
Molarband	0.66 MGD	23	17	64
Kondli	25 MGD Pahse-II	89	39	125
	45 MGD Phase-IV	30	18	64
Chilla	9 MGD	9	4	24
CWG Village	1 MGD	Bdl	0.57	Bdl
Yamuna Vihar	10 MGD Phase-I	31	18	-
	Phase-II	36	17	-
	25 MGD Phase-III	28	19	-
Rithala	40 MGD Phase-I	28	17	70
	40 MGD Phase-II	16	10	60
Keshopur	12 MGD	9	5	30
	40 MGD	70	68	222
	20 MGD	136	128	380
Nilothi	40 MGD Pahse-I	38	26	80
Nazafgarh	5 MGD	13	14	-
PappanKalan	20 MGD Phase-I	32	17	-
	20 MGD Phase-II	12	7	-
Corronation pillar	20 MGD Pahse-I & II	60	33	158
	10 MGD Pahse-III	95	46	168
Narela	10 MGD	67	38	128