

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Parameters of STPs of Delhi as on							01.04.2020		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Yamuna Vihar	10 MGD Phase-I	Inlet	7.1	352	225			45	6.5
		outlet	7.4	27	16			30	2.5
	Real Time Reading at Outlet								
	10 MGD Phase-II	Inlet	7.2	268	189			45	6.5
		outlet	7.6	25	14			30	2.5
	Real Time Reading at Outlet								
	25 MGD Phase-III	Inlet	7.0	508	282			50	4.0
		outlet	7.5	36	22			15	2.5
Real Time Reading at Outlet		9.5	37	17	56		10		
Rithala	40 MGD	Inlet	7	244	153	370	ND	36	1.3
		outlet	7.6	65	41	160	ND	28	1.1
	Real Time Reading at Outlet		ND	ND	ND	ND		ND	
	40 MGD	Inlet	7	244	153	370	ND	36	1.3
		Outlet	7.5	16	13	70		18	0.7
	Real Time Reading at Outlet		7.94	13.52	13.98	52.97		7.94	
Corronation Pillar	20 MGD Phase-I & II	Inlet	7.1	236	195	344	-	28	7.4
		outlet	7.5	58	50	108	-	16	2.8
	Real Time Reading at Outlet		7.6	77	29	104	-	17	-
	10 MGD Phase-III	Inlet	7.2	362	288	454	5.4	40	10.5
		outlet	7.5	68	65	128	1.6	31	6.3
	Real Time Reading at Outlet		7.3	69	47	207	-	16	-
Rohini	15 MGD	Inlet	7.1	300	193			44	6.5
		Outlet	7.4	28	17			15	4.5
	Real Time Reading at Outlet								
Keshopur	12 MGD	Inlet	7.3	368	191	623	-	33	3.6
	(PH-I)	Outlet	7.6	10	5	28	-	1	3.5
	Real time reading at OUTLET(online)		7.41	10.72	26.72	54.08	-	10.82	-
	20 MGD	Inlet	7.3	392	226	728	-	32	3.4
	(PH-II)	Outlet	7.6	150	132	364	-	29	3
	Real Time Reading at Outlet		6.62	769.52	216.55	1240.79	-	11.75	-
	40 MGD	Inlet	7.3	392	226	728	-	32	3.4
	(PH-III)	Outlet	7.5	162	139	376	-	30	3.1
	Real Time Reading at Outlet								
Nilothi	40 MGD	Inlet	7.2	260	144	-	6.4	28	-
	(PH-I)	Outlet	7.4	52	29	-	0.2	20	-
	Real Time Reading at Outlet		6.86	62.05	157.51	183.04	-	51.87	-
	20 MGD	Inlet	7.1	276	165	-	-	30	3
	(PH-II)	Outlet	7.3	24	21	-	-	22	2.4
	Real Time Reading at Outlet								

Pappankalan	(20 MGD)	Inlet	7.2	478	224	-	-	34	1.6
	PH-I	Outlet	7.5	72	36	-	-	14	1
	Real Time Reading at Outlet		7.33	84.69	38.87	136.48	-	23.2	-
	(20 MGD)	Inlet	7.3	415	204	-	-	30	2.4
	PH-II	Outlet	7.5	7	4	-	-	8	0.8
	Real Time Reading at Outlet		9.54	29.05	24.97	58.58	-	6.68	-
Najafgarh	(05 MGD)	Inlet	7.3	515	230	-	-	36	3.8
		Outlet	7.6	18	10	-	-	6	1.2
	Real Time Reading at Outlet		7.3	34.55	35.2	85.17	-	6.38	-
Okhla	12 MGD	Inlet	7.3	224	173	424	4	42	1.6
		outlet	7.6	48	28	112	1	39	1
	Real Time Reading at Outlet								
	45 MGD	Inlet	7.3	236	212	440	4	40	1.2
		outlet	7.6	39	24	96	NIL	37	1
	Real Time Reading at Outlet								
	37 MGD	Inlet	7.3	236	212	440	4	40	1.2
		outlet	7.6	44	26	104	1	32	0.9
	Real Time Reading at Outlet								
	16 MGD	Inlet	7.3	236	212	440	4	40	1.2
		outlet	7.7	12	8	32	1	31	NIL
	Real Time Reading at Outlet								

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Name of the Plant	Capacity (in MGD)	01.04.2020		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC Limit	50	30	250
Yamuna Vihar	10 MGD Phase-I	27	16	-
	10 MGD Phase-II	25	14	-
	25 MGD Phase-III	36	22	-
Rithala	40 MGD	65	41	160
	40 MGD	16	13	70
Corronation pillar	20 MGD Phase-I &II	58	50	108
	10 MGD Phase-III	68	65	128
Rohini	15 MGD	28	17	-
Keshopur	12 MGD	10	5	28
	20 MGD	150	132	364
	40 MGD	162	139	376
Nilothi	40 MGD	52	29	-
	20 MGD	24	21	-
Pappankalan	(20 MGD)	72	36	-
	(20 MGD)	7	4	-
Najafgarh	05 MGD	18	10	-
Okhla	12 MGD	48	28	112
	45 MGD	39	24	96
	37 MGD	44	26	104
	16 MGD	12	8	32

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Parameters of STPs of Delhi as on							02.04.2020		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Yamuna Vihar	10 MGD Phase-I	Inlet	7.2	324	229			50	3.5
		outlet	7.5	34	25			20	2.0
	Real Time Reading at Outlet								
	10 MGD Phase-II	Inlet	7.1	400	251			40	5.0
		outlet	7.6	37	28			15	2.5
	Real Time Reading at Outlet								
	25 MGD Phase-III	Inlet	7.2	316	231			45	6.5
		outlet	7.4	40	27			25	3.5
Real Time Reading at Outlet		9.5	14	17	44		10		
Rithala	40 MGD	Inlet	7.1	228	149	390	ND	38	1.4
		outlet	7.8	62	39	150	ND	30	1
	Real Time Reading at Outlet		ND	ND	ND	ND		ND	
	40 MGD	Inlet	7.1	228	149	390	ND	38	1.4
		Outlet	7.6	18	14	60		16	0.8
	Real Time Reading at Outlet		ND	ND	ND	ND		ND	
Corronation Pillar	20 MGD Phase-I &II	Inlet	7	248	205	356	6.8	34	8
		outlet	7.3	68	56	98	1.5	23	2.5
	Real Time Reading at Outlet		7.6	90	36	121	-	17	-
	10 MGD Phase-III	Inlet	7.3	324	270	428	-	48	10.9
		outlet	7.6	81	69	106	-	299	5.3
Real Time Reading at Outlet		7.3	66	47	201	-	15	-	
Rohini	15 MGD	Inlet	7.1	244	155			42	6.5
		Outlet	7.5	27	15			15	4
	Real Time Reading at Outlet								
Nilothi	40 MGD (PH-I)	Inlet	7.2	254	136	-	-	30	-
		Outlet	7.4	60	34	-	-	20	-
	Real Time Reading at Outlet		6.88	53.17	160.65	183.31	-	19.6	-
	20 MGD (PH-II)	Inlet	7.2	294	174	-	-	30	3.2
		Outlet	7.3	22	19	-	-	20	2.2
	Real Time Reading at Outlet								
Okhla	12 MGD	Inlet	7.5	250	186	464	4	40	1
		outlet	7.6	28	19	72	NIL	38	0.9
	Real Time Reading at Outlet								
	45 MGD	Inlet	7.4	238	179	440	4	41	1.2
		outlet	7.7	30	18	64	NIL	39	NIL
	Real Time Reading at Outlet								
	37 MGD	Inlet	7.4	238	179	440	4	41	1.2
		outlet	7.7	35	23	80	1	36	1
	Real Time Reading at Outlet								
	16 MGD	Inlet	7.4	238	179	440	4	41	1.2
outlet		7.7	25	16	56	1	30	0.9	
Real Time Reading at Outlet									

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Name of the Plant	Capacity (in MGD)	02.04.2020		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC Limit	50	30	250
Yamuna Vihar	10 MGD Phase-I	34	25	-
	10 MGD Phase-II	37	28	-
	25 MGD Phase-III	40	27	-
Rithala	40 MGD	62	39	150
	40 MGD	18	14	60
Corronation pillar	20 MGD Phase-I &II	68	56	98
	10 MGD Phase-III	81	69	106
Rohini	15 MGD	27	15	-
Nilothi	40 MGD	60	34	-
	20 MGD	22	19	-
Okhla	12 MGD	28	19	72
	45 MGD	30	18	64
	37 MGD	35	23	80
	16 MGD	25	16	56

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Parameters of STPs of Delhi as on							03.04.2020		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Yamuna Vihar	10 MGD Phase-I	Inlet	7.2	272	217			50	4.0
		outlet	7.5	31	23			35	2.5
	Real Time Reading at Outlet								
	10 MGD Phase-II	Inlet	6.9	324	242			40	3.5
		outlet	7.3	24	24			15	2.0
	Real Time Reading at Outlet								
	25 MGD Phase-III	Inlet	7.2	508	299			45	5.0
		outlet	7.5	34	21			25	3.0
Real Time Reading at Outlet		9.5	28	18	54		10		
Rithala	40 MGD	Inlet	7.2	260	162	350	ND	39	1.4
		outlet	7.7	67	40	150	ND	30	1.1
	Real Time Reading at Outlet		ND	ND	ND	ND		ND	
	40 MGD	Inlet	7.2	260	162	350	ND	39	1.4
		Outlet	7.6	17	12	60		19	0.8
Real Time Reading at Outlet		ND	ND	ND	ND		ND		
Corronation Pillar	20 MGD Phase-I & II	Inlet	6.9	252	208	398	-	30	9.6
		outlet	7.4	58	54	86	-	19	4
	Real Time Reading at Outlet		7.6	118	43	135	-	17	-
	10 MGD Phase-III	Inlet	7.2	312	268	406	4.3	50	11
		outlet	7.5	104	78	128	2	31	5.8
Real Time Reading at Outlet		7.3	61	47	19	-	14	-	
Narela	10 MGD Phase-III	Inlet	7.3	288	215	354	5.2	54	6
		outlet	7.6	34	21	74	1.8	31	2.8
	Real Time Reading at Outlet		7.2	66	57	110	-	11	-
Rohini	15 MGD	Inlet	7.2	396	268			47	7
		Outlet	7.4	30	19			15	4.5
	Real Time Reading at Outlet								
Keshopur	12 MGD	Inlet	7.3	392	192	-	-	34	3.6
	(PH-I)	Outlet	7.6	12	7	-	-	1	3.8
	Real time reading at OUTLET(online)		7.47	11.6	7.81	55	-	10.9	-
	20 MGD	Inlet	7.3	396	206	-	-	33	3.4
	(PH-II)	Outlet	7.6	156	129	-	-	30	3.1
	Real Time Reading at Outlet		6.67	774.67	202.56	1214.28	-	8.75	-
	40 MGD	Inlet	7.3	396	206	-	-	33	3.4
	(PH-III)	Outlet	7.5	164	130	-	-	30	3
Real Time Reading at Outlet									
Nilothi	40 MGD	Inlet	7.1	236	126	430	5.4	28	-
	(PH-I)	Outlet	7.3	50	31	140	1	18	-
	Real Time Reading at Outlet		7.31	46.43	184.82	191.38	-	35.16	-

	20 MGD	Inlet	7.3	302	183	530	8	32	-
	(PH-II)	Outlet	7.4	17	14	44	0.8	22	-
	Real Time Reading at Outlet								
Pappankalan	(20 MGD)	Inlet	7.2	464	225	-	-	38	1.2
	PH-I	Outlet	7.4	58	34	-	-	14	1
	Real Time Reading at Outlet		7.24	73.65	39.2	131.56	-	22.15	-
	(20 MGD)	Inlet	7.3	430	220	-	-	34	2.6
	PH-II	Outlet	7.5	6	5	-	-	8	0.6
	Real Time Reading at Outlet		9.71	41.23	27.23	68.34	-	7.02	-
Okhla	12 MGD	Inlet	7.4	171	155	376	4	42	1.2
		outlet	7.6	25	18	18	1	40	1
	Real Time Reading at Outlet								
	45 MGD	Inlet	7.4	122	160	368	4	43	1.6
		outlet	7.7	45	29	112	NIL	40	1.2
	Real Time Reading at Outlet								
	37 MGD	Inlet	7.4	122	160	368	4	43	1.6
		outlet	7.6	42	28	104	1	39	1
	Real Time Reading at Outlet								
	16 MGD	Inlet	7.4	122	160	368	4	43	1.6
		outlet	7.6	22	15	56	NIL	36	1
	Real Time Reading at Outlet								
	New 30 MGD	Inlet	7.4	236	170	424	3	36	1
		Outlet	7.6	6	4	16	1	3	NIL
	Real Time Reading at Outlet								

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Name of the Plant	Capacity (in MGD)	03.04.2020		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC Limit	50	30	250
Yamuna Vihar	10 MGD Phase-I	31	23	-
	10 MGD Phase-II	24	24	-
	25 MGD Phase-III	34	21	-
Rithala	40 MGD	67	40	150
	40 MGD	17	12	60
Corronation pillar	20 MGD Phase-I &II	58	54	86
	10 MGD Phase-III	104	78	128
Narela	10 MGD Phase-III	34	21	74
Rohini	15 MGD	30	19	-
Keshopur	12 MGD	12	7	-
	20 MGD	156	129	-
	40 MGD	164	130	-
Nilothi	40 MGD	50	31	140
	20 MGD	17	14	44
Pappankalan	(20 MGD)	58	34	-
	(20 MGD)	6	5	-
Okhla	12 MGD	25	18	18
	45 MGD	45	29	112
	37 MGD	42	28	104
	16 MGD	22	15	56
	New 30 MGD	6	4	16

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Parameters of STPs of Delhi as on

04.04.2020

Parameters of Effluent Discharge				Daily Results					
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Yamuna Vihar	10 MGD Phase-I	Inlet	7.1	324	259			40	5.0
		outlet	7.6	41	26			25	2.0
	Real Time Reading at Outlet								
	10 MGD Phase-II	Inlet	7.2	332	264			35	5.5
		outlet	7.5	41	27			15	2.0
	Real Time Reading at Outlet								
	25 MGD Phase-III	Inlet	7.1	288	212			50	4.0
		outlet	7.6	38	25			20	2.5
Real Time Reading at Outlet		9.6	30	19	58		10		
Rithala	40 MGD	Inlet	7.2	252	156	320	ND	36	1.8
		outlet	7.8	63	43	140	ND	28	1.3
	Real Time Reading at Outlet		ND	ND	ND	ND		ND	
	40 MGD	Inlet	7.2	252	156	320	ND	36	1.8
		Outlet	7.7	16	11	50		20	1.1
Real Time Reading at Outlet		ND	ND	ND	ND		ND		
Corronation Pillar	20 MGD Phase-I &II	Inlet	7.1	232	195	314	5.3	27	7.5
		outlet	7.5	54	52	80	1.2	16	3.2
	Real Time Reading at Outlet		7.6	130	49	148	-	17	-
	10 MGD Phase-III	Inlet	7	302	260	342	-	35	5.5
		outlet	7.6	92	75	104	-	24	2.5
Real Time Reading at Outlet		7.4	59	47	187	-	13	-	
Rohini	15 MGD	Inlet	7.2	328	203			42	6.5
		Outlet	7.5	26	15			16	3.5
	Real Time Reading at Outlet								
Keshopur	12 MGD	Inlet	7.3	392	221	-	13.8	34	3.4
	(PH-I)	Outlet	7.5	12	6	-	0.2	2	3.6
	Real time reading at OUTLET(online)		7.46	10.59	5.75	50.36	-	10.42	-
	20 MGD	Inlet	7.3	436	220	-	13.4	36	3.5
	(PH-II)	Outlet	7.6	156	135	-	4.3	30	3
	Real Time Reading at Outlet								
	40 MGD	Inlet	7.3	436	220	-	13.4	36	3.5
	(PH-III)	Outlet	7.5	162	138	-	4.8	31	3
Real Time Reading at Outlet									
Nilothi	40 MGD	Inlet	7.2	286	121	-	-	32	3
	(PH-I)	Outlet	7.4	48	28	-	-	18	2.2
	Real Time Reading at Outlet		7.36	48.09	188.17	193.08	-	29.18	-
	20 MGD	Inlet	7.1	290	174	-	-	30	32
	(PH-II)	Outlet	7.3	16	14	-	-	16	2
	Real Time Reading at Outlet								

Pappankalan	(20 MGD)	Inlet	7.3	428	225	-	-	36	1.6
	PH-I	Outlet	7.5	58	36	-	-	14	0.8
	Real Time Reading at Outlet		7.24	38.56	37.03	109.59	-	15.85	-
	(20 MGD)	Inlet	7.3	408	210	-	-	34	2.4
	PH-II	Outlet	7.6	4	4	-	-	6	0.4
	Real Time Reading at Outlet		9.71	36.83	29.74	68.79	-	7.26	-
Najafgarh	(05 MGD)	Inlet	7.3	488	230	-	-	36	4
		Outlet	7.6	16	10	-	-	6	1
	Real Time Reading at Outlet		7.49	34.55	28.7	80.88	-	6.88	-
Okhla	12 MGD	Inlet	7.4	242	180	448	4	39	1.1
		outlet	7.7	30	20	72	1	30	0.7
	Real Time Reading at Outlet								
	45 MGD	Inlet	7.4	234	186	456	4	41	1.2
		outlet	7.7	41	27	104	NIL	32	0.9
	Real Time Reading at Outlet								
	37 MGD	Inlet	7.6	234	186	456	4	41	1.2
		outlet	7.6	31	20	72	1	31	0.5
	Real Time Reading at Outlet								
	16 MGD	Inlet	7.4	234	186	456	4	41	1.2
		outlet	7.7	23	15	64	1	29	0.6
	Real Time Reading at Outlet								

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Name of the Plant	Capacity (in MGD)	04.04.2020		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC Limit	50	30	250
Yamuna Vihar	10 MGD Phase-I	41	26	-
	10 MGD Phase-II	41	27	-
	25 MGD Phase-III	38	25	-
Rithala	40 MGD	63	43	140
	40 MGD	16	11	50
Corronation pillar	20 MGD Phase-I &II	54	52	80
	10 MGD Phase-III	92	75	104
Rohini	15 MGD	26	15	-
Keshopur	12 MGD	12	6	-
	20 MGD	156	135	-
	40 MGD	162	138	-
Nilothi	40 MGD	48	28	-
	20 MGD	16	14	-
Pappankalan	(20 MGD)	58	36	-
	(20 MGD)	4	4	-
Najafgarh	05 MGD	16	10	-
Okhla	12 MGD	30	20	72
	45 MGD	41	27	104
	37 MGD	31	20	72
	16 MGD	23	15	64

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Parameters of STPs of Delhi as on

05.04.2020

Parameters of GWA for Delhi as on							2016-17-2021		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Yamuna Vihar	10 MGD Phase-I	Inlet	7.3	336	196			45	4.5
		outlet	7.4	40	25			25	3.0
	Real Time Reading at Outlet								
	10 MGD Phase-II	Inlet	7.3	388	272			40	4.5
		outlet	7.6	42	28			20	2.5
	Real Time Reading at Outlet								
	25 MGD Phase-III	Inlet	7.3	352	232			55	5.0
		outlet	7.6	39	28			35	3.0
Real Time Reading at Outlet		9.6	26	17	51		10		
Rithala	40 MGD	Inlet	7	236	168	380	ND	39	1.7
		outlet	7.6	66	40	150	ND	31	1.5
	Real Time Reading at Outlet		ND	ND	ND	ND		ND	
	40 MGD	Inlet	7	236	168	380	ND	39	1.7
		Outlet	7.5	19	12	70		22	0.9
	Real Time Reading at Outlet		ND	ND	ND	ND		ND	
Corronation Pillar	20 MGD Phase-I &II	Inlet	6.9	184	175	248	-	24	8
		outlet	7.4	52	49	84	-	14	3.9
	Real Time Reading at Outlet		7.6	145	54	161	-	17	-
	10 MGD Phase-III	Inlet	7	292	255	316	6	31	6.4
		outlet	7.4	88	72	96	1.8	22	3
	Real Time Reading at Outlet		7.4	57	45	181	-	12	-
Rohini	15 MGD	Inlet	7.1	500	298			40	7.5
		Outlet	7.5	30	18			14	4
	Real Time Reading at Outlet								
Nilothi	40 MGD	Inlet	7.2	306	156	-	-	30	2.5
	(PH-I)	Outlet	7.3	55	31	-	-	25	2
	Real Time Reading at Outlet		7.04	67.84	170.21	189.39	-	36.09	-
Okhla	12 MGD	Inlet	7.4	258	206	472	3	38	1
		outlet	7.7	28	21	80	NIL	29	0.6
	Real Time Reading at Outlet								
	45 MGD	Inlet	7.4	244	180	456	3	39	1
		outlet	7.7	31	19	72	1	29	0.7
	Real Time Reading at Outlet								
	37 MGD	Inlet	7.4	244	180	456	3	39	1
		outlet	7.8	33	23	88	NIL	30	0.6
	Real Time Reading at Outlet								
	16 MGD	Inlet	7.4	244	180	456	3	39	1
outlet		7.8	22	16	56	NIL	28	0.6	
Real Time Reading at Outlet									

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Name of the Plant	Capacity (in MGD)	05.04.2020		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC Limit	50	30	250
Yamuna Vihar	10 MGD Phase-I	40	25	-
	10 MGD Phase-II	42	28	-
	25 MGD Phase-III	39	28	-
Rithala	40 MGD	66	40	150
	40 MGD	19	12	70
Corronation pillar	20 MGD Phase-I &II	52	49	84
	10 MGD Phase-III	88	72	96
Rohini	15 MGD	30	18	-
Nilothi	40 MGD	55	31	-
Okhla	12 MGD	28	21	80
	45 MGD	31	19	72
	37 MGD	33	23	88
	16 MGD	22	16	56

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Parameters of STPs of Delhi as on							06.04.2020		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Yamuna Vihar	10 MGD Phase-I	Inlet	7.1	244	221			45	5.0
		outlet	7.5	31	19			30	2.5
	Real Time Reading at Outlet								
	10 MGD Phase-II	Inlet	7.2	268	236			45	5.5
		outlet	7.5	24	16			35	2.0
	Real Time Reading at Outlet								
	25 MGD Phase-III	Inlet	7.0	284	237			40	4.5
		outlet	7.5	38	22			20	1.5
Real Time Reading at Outlet		9.8	28	18	54		10		
Rithala	40 MGD	Inlet	7	268	147	410	ND	41	1.2
		outlet	7.6	62	42	150	ND	30	1.1
	Real Time Reading at Outlet		ND	ND	ND	ND		ND	
	40 MGD	Inlet	7	268	147	410	ND	41	1.2
		Outlet	7.7	18	14	70		22	0.7
Real Time Reading at Outlet		ND	ND	ND	ND		ND		
Corronation Pillar	20 MGD Phase-I & II	Inlet	7	178	180	232	4.3	25	5.3
		outlet	7.4	55	50	96	1	14	2.1
	Real Time Reading at Outlet		7.6	196	63	195	-	18	-
	10 MGD Phase-III	Inlet	7.1	284	265	304	-	32	6
		outlet	7.5	80	70	98	-	21	2.2
Real Time Reading at Outlet		7.3	60	46	189	-	14	-	
Narela	10 MGD Phase-III	Inlet	7.2	204	190	262	4.9	42	4.2
		outlet	7.5	21	19	66	1.2	22	1.7
	Real Time Reading at Outlet		7.3	119	81	159	-	11	-
Rohini	15 MGD	Inlet	7.2	256	165	640		48	9
		Outlet	7.6	26	15	80		16	4
	Real Time Reading at Outlet								
Keshopur	12 MGD (PH-I)	Inlet	7.3	428	220	706	-	32	3.3
		Outlet	7.5	13	6	32	-	1	3.6
	Real time reading at OUTLET(online)		7.43	12.02	3.41	51.11	-	10.72	-
	20 MGD (PH-II)	Inlet	7.3	448	219	764	-	34	3.2
		Outlet	7.6	154	129	374	-	30	3.1
	Real Time Reading at Outlet								
	40 MGD (PH-III)	Inlet	7.3	448	219	764	-	34	3.2
		Outlet	7.5	162	140	382	-	29	3
Real Time Reading at Outlet									
Ankita	40 MGD (PH-I)	Inlet	7.2	290	131	-	-	28	2.8
		Outlet	7.4	52	30	-	-	20	2.5
	Real Time Reading at Outlet		7.23	54.55	193.55	196.41	-	38.01	-

	20 MGD	Inlet	7.1	288	173	-	-	32	3.2
	(PH-II)	Outlet	7.3	16	12	-	-	20	0.4
	Real Time Reading at Outlet								
Pappankalan	(20 MGD)	Inlet	7.3	468	225	-	-	34	1.4
	PH-I	Outlet	7.6	56	32	-	-	14	1
	Real Time Reading at Outlet		7.21	76.14	42.41	139.72	-	14.7	-
	(20 MGD)	Inlet	7.3	415	205	-	-	34	2.2
	PH-II	Outlet	7.6	15	9	-	-	8	0.6
	Real Time Reading at Outlet		9.86	35.72	28.7	68.35	-	7.27	-
Okhla	12 MGD	Inlet	7.4	262	220	464	-	39	1.3
		outlet	7.7	39	25	96	-	32	0.8
	Real Time Reading at Outlet								
	45 MGD	Inlet	7.3	240	230	432	-	40	1.3
		outlet	7.7	37	22	88	-	31	0.7
	Real Time Reading at Outlet								
	37 MGD	Inlet	7.3	240	230	432	-	40	1.3
		outlet	7.6	35	21	80	-	29	0.5
	Real Time Reading at Outlet								
	16 MGD	Inlet	7.3	240	230	432	-	40	1.3
		outlet	7.9	26	17	64	-	28	NIL
	Real Time Reading at Outlet								

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Name of the Plant	Capacity (in MGD)	06.04.2020		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC Limit	50	30	250
Yamuna Vihar	10 MGD Phase-I	31	19	-
	10 MGD Phase-II	24	16	-
	25 MGD Phase-III	38	22	-
Rithala	40 MGD	62	42	150
	40 MGD	18	14	70
Corronation pillar	20 MGD Phase-I &II	55	50	96
	10 MGD Phase-III	80	70	98
Narela	10 MGD Phase-III	21	19	66
Rohini	15 MGD	26	15	80
Keshopur	12 MGD	13	6	32
	20 MGD	154	129	374
	40 MGD	162	140	382
Nilothi	40 MGD	52	30	-
	20 MGD	16	12	-
Pappankalan	(20 MGD)	56	32	-
	(20 MGD)	15	9	-
Okhla	12 MGD	39	25	96
	45 MGD	37	22	88
	37 MGD	35	21	80
	16 MGD	26	17	64

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Parameters of STPs of Delhi as on

07.04.2020

Parameters of Effluent Discharge							Site Name		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Yamuna Vihar	10 MGD Phase-I	Inlet	7.1	280	237		7.6	50	4.0
		outlet	7.5	20	17		2.8	35	1.5
	Real Time Reading at Outlet								
	10 MGD Phase-II	Inlet	7.0	276	197		16.0	45	3.5
		outlet	7.5	42	28		2.8	20	1.5
	Real Time Reading at Outlet								
	25 MGD Phase-III	Inlet	7.0	356	237		7.2	55	4.5
		outlet	7.4	31	22		3.2	25	2.0
Real Time Reading at Outlet									
Rithala	40 MGD	Inlet	7.2	244	154	430	ND	43	1.9
		outlet	7.8	65	39	140	ND	34	1.4
	Real Time Reading at Outlet		ND	ND	ND	ND		ND	
	40 MGD	Inlet	7.2	244	154	430	ND	43	1.9
		Outlet	7.6	16	11	60		23	1.1
Real Time Reading at Outlet		ND	ND	ND	ND		ND		
Corronation Pillar	20 MGD Phase-I &II	Inlet	7.1	164	175	226	-	24	3.5
		outlet	7.5	57	53	102	-	15	2.4
	Real Time Reading at Outlet		7.4	254	76	228	-	33	-
	10 MGD Phase-III	Inlet	7.2	268	268	314	4.8	30	5.3
		outlet	7.6	86	72	106	1.6	20	1.9
	Real Time Reading at Outlet		7.4	62	46	191	-	15	-
Rohini	15 MGD	Inlet	7.1	228	175			52	10.5
		Outlet	7.5	29	18			17	4.5
	Real Time Reading at Outlet								
Keshopur	12 MGD	Inlet	7.3	504	188	-	-	34	3.4
	(PH-I)	Outlet	7.5	10	6	-	-	2	3.7
	Real time reading at OUTLET(online)								
	20 MGD	Inlet	7.4	468	202	-	-	33	3.2
	(PH-II)	Outlet	7.6	164	134	-	-	31	3.2
	Real Time Reading at Outlet								
	40 MGD	Inlet	7.4	468	202	-	-	33	3.2
	(PH-III)	Outlet	7.5	144	129	-	-	30	3
	Real Time Reading at Outlet								
Nilothi	40 MGD	Inlet	7.1	294	118	448	-	30	3
	(PH-I)	Outlet	7.3	49	30	136	-	22	2.5
	Real Time Reading at Outlet		7	64.22	180.11	193.08	-	20.89	-
	20 MGD	Inlet	7.2	306	176	570	7.9	32	2.8
	(PH-II)	Outlet	7.3	13	9	36	0	18	1.8
	Real Time Reading at Outlet								

Pappankalan	(20 MGD)	Inlet	7.2	468	230	630	14.2	34	1.8
	PH-I	Outlet	7.5	62	36	102	0.6	14	0.8
	Real Time Reading at Outlet		7.48	79.42	48.53	156	-	6.25	-
	(20 MGD)	Inlet	7.3	425	215	600	13.4	36	2.2
	PH-II	Outlet	7.5	8	6	30	0	5	0.3
	Real Time Reading at Outlet		10.2	37.28	29.1	69.81	-	7.5	-
Najafgarh	(05 MGD)	Inlet	7.3	504	232	-	-	34	3.8
		Outlet	7.6	18	8	-	-	6	1.2
	Real Time Reading at Outlet		7.22	35.34	28.77	91.83	-	7.31	-
Okhla	12 MGD	Inlet	7.5	288	200	456	4	37	1.4
		outlet	7.7	40	27	96	1	32	0.9
	Real Time Reading at Outlet								
	45 MGD	Inlet	7.8	230	182	448	3	38	1.2
		outlet	7.8	43	29	104	1	30	0.4
	Real Time Reading at Outlet								
	37 MGD	Inlet	7.4	230	182	448	3	38	1.2
		outlet	7.7	42	28	112	NIL	27	0.4
	Real Time Reading at Outlet								
	16 MGD	Inlet	7.4	230	182	488	3	38	1.2
		outlet	7.8	20	14	56	NIL	28	0.4
	Real Time Reading at Outlet								

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Name of the Plant	Capacity (in MGD)	07.04.2020		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC Limit	50	30	250
Yamuna Vihar	10 MGD Phase-I	20	17	-
	10 MGD Phase-II	42	28	-
	25 MGD Phase-III	31	22	-
Rithala	40 MGD	65	39	140
	40 MGD	16	11	60
Corronation pillar	20 MGD Phase-I &II	57	53	102
	10 MGD Phase-III	86	72	106
Rohini	15 MGD	29	18	-
Keshopur	12 MGD	10	6	-
	20 MGD	164	134	-
	40 MGD	144	129	-
Nilothi	40 MGD	49	30	136
	20 MGD	13	9	36
Pappankalan	(20 MGD)	62	36	102
	(20 MGD)	8	6	30
Najafgarh	05 MGD	18	8	-
Okhla	12 MGD	40	27	96
	45 MGD	43	29	104
	37 MGD	42	28	112
	16 MGD	20	14	56

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Parameters of STPs of Delhi as on

08.04.2020

Parameters of G.O.P. Discharge							Date: 11/02/21		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Yamuna Vihar	10 MGD Phase-I	Inlet	7.1	296	201			45	3.5
		outlet	7.6	31	22			35	1.5
	Real Time Reading at Outlet								
	10 MGD Phase-II	Inlet	7.2	276	189			45	3
		outlet	7.5	30	19			20	1
	Real Time Reading at Outlet								
	25 MGD Phase-III	Inlet	7.1	400	247			45	3
		outlet	7.4	37	27			20	1
Real Time Reading at Outlet									
Rithala	40 MGD	Inlet	7.2	272	161	410	ND	38	1.6
		outlet	7.7	58	36	130	ND	32	1.1
	Real Time Reading at Outlet		ND	ND	ND	ND		ND	
	40 MGD	Inlet	7.2	272	161	410	ND	38	1.6
		Outlet	7.5	19	15	70		19	0.7
Real Time Reading at Outlet		ND	ND	ND	ND		ND		
Corronation Pillar	20 MGD Phase-I & II	Inlet	7	182	178	240	3.1	22	3.3
		outlet	7.4	61	55	98	0.9	13	2
	Real Time Reading at Outlet		7.6	228	73	212	-	21	-
	10 MGD Phase-III	Inlet	7.3	296	278	318	-	28	5
		outlet	7.6	78	69	104	-	22	2.5
Real Time Reading at Outlet		7.2	57	44	181	-	15	-	
Rohini	15 MGD	Inlet	7.1	252	185	566		55	10
		Outlet	7.6	32	20	77		18	5.5
	Real Time Reading at Outlet								
Keshopur	12 MGD	Inlet	7.3	412	201	-	-	35	3.2
	(PH-I)	Outlet	7.6	13	7	-	-	3	3.6
	Real time reading at OUTLET(online)								
	20 MGD	Inlet	7.3	448	214	-	-	38	3.4
	(PH-II)	Outlet	7.5	166	140	-	-	35	3
	Real Time Reading at Outlet								
	40 MGD	Inlet	7.3	448	214	-	-	38	3.4
	(PH-III)	Outlet	7.5	174	142	-	-	32	3
Real Time Reading at Outlet									
Nilothi	40 MGD	Inlet	7.3	326	150	-	5	30	3.2
	(PH-I)	Outlet	7.4	55	32	-	1.8	22	2.5
	Real Time Reading at Outlet		7.26	51.27	210.77	203.26	-	30.05	-
	20 MGD	Inlet	7.1	310	176	-	-	35	3
	(PH-II)	Outlet	7.3	15	11	-	-	20	2
	Real Time Reading at Outlet								

Pappankalan	(20 MGD)	Inlet	7.3	380	200	-	-	34	1.4
	PH-I	Outlet	7.6	52	30	-	-	12	0.6
	Real Time Reading at Outlet		7.33	81.36	49.98	159.24	-	9.3	-
	(20 MGD)	Inlet	7.3	350	198	-	-	30	2
	PH-II	Outlet	7.5	8	6	-	-	8	0.4
	Real Time Reading at Outlet								
Okhla	12 MGD	Inlet	7.5	290	217	448	4	32	1.6
		outlet	7.7	36	21	88	1	30	1
	Real Time Reading at Outlet								
	45 MGD	Inlet	7.5	226	200	424	3	39	1.2
		outlet	7.6	39	25	96	NIL	35	0.9
	Real Time Reading at Outlet								
	37 MGD	Inlet	7.5	226	200	424	3	39	1.2
		outlet	7.7	43	28	104	NIL	30	NIL
	Real Time Reading at Outlet								
	16 MGD	Inlet	7.5	226	200	424	3	39	1.2
		outlet	7.6	27	18	72	1	28	1
	Real Time Reading at Outlet								

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Name of the Plant	Capacity (in MGD)	08.04.2020		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC Limit	50	30	250
Yamuna Vihar	10 MGD Phase-I	31	22	-
	10 MGD Phase-II	30	19	-
	25 MGD Phase-III	37	27	-
Rithala	40 MGD	58	36	130
	40 MGD	19	15	70
Corronation pillar	20 MGD Phase-I &II	61	55	98
	10 MGD Phase-III	78	69	104
Rohini	15 MGD	32	20	77
Keshopur	12 MGD	13	7	-
	20 MGD	166	140	-
	40 MGD	174	142	-
Nilothi	40 MGD	55	32	-
	20 MGD	15	11	-
Pappankalan	(20 MGD)	52	30	-
	(20 MGD)	8	6	-
Okhla	12 MGD	36	21	88
	45 MGD	39	25	96
	37 MGD	43	28	104
	16 MGD	27	18	72

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Parameters of STPs of Delhi as on

09.04.2020

Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Yamuna Vihar	10 MGD Phase-I	Inlet	7	296	205			45	3.5
		outlet	7.5	27	20			35	1.5
	Real Time Reading at Outlet								
	10 MGD Phase-II	Inlet	7.2	272	174	552		40	2
		outlet	7.5	26	21	80		25	1
	Real Time Reading at Outlet								
	25 MGD Phase-III	Inlet	7	396	293	672		40	3
		outlet	7.4	33	21	88		20	1.5
Real Time Reading at Outlet									
Rithala	40 MGD	Inlet	7.1	228	145	320	ND	41	2.1
		outlet	7.8	48	33	120	ND	30	1.6
	Real Time Reading at Outlet		ND	ND	ND	ND		ND	
	40 MGD	Inlet	7.1	228	145	320	ND	41	2.1
		Outlet	7.7	16	11	50		21	1.1
Real Time Reading at Outlet		ND	ND	ND	ND		ND		
Corronation Pillar	20 MGD Phase-I & II	Inlet	7.1	176	170	234	-	20	3.6
		outlet	7.6	58	54	90	-	15	1.8
	Real Time Reading at Outlet		-	-	-	-	-	-	-
	10 MGD Phase-III	Inlet	7.2	316	285	330	4.8	31	5.4
		outlet	7.5	70	66	98	1.8	24	2.9
Real Time Reading at Outlet		7.2	62	46	189	-	15	-	
Rohini	15 MGD	Inlet	7.1	260	170			44	5
		Outlet	7.5	32	19			16	4
	Real Time Reading at Outlet								
Nilothi	40 MGD	Inlet	7.1	294	134	-	-	28	2.8
	(PH-I)	Outlet	7.3	56	33	-	-	20	2
	Real Time Reading at Outlet		7.22	47.53	214.16	204.08	-	24.23	-
Okhla	12 MGD	Inlet	7.3	170	158	392	-	42	1.2
		outlet	7.6	30	21	80	-	36	NIL
	Real Time Reading at Outlet								
	45 MGD	Inlet	7.4	128	148	368	-	43	2
		outlet	7.6	41	26	104	-	37	1
	Real Time Reading at Outlet								
	37 MGD	Inlet	7.4	128	148	368	-	43	2
		outlet	7.7	48	29	120	-	38	1.2
	Real Time Reading at Outlet								
	16 MGD	Inlet	7.4	128	148	368	-	43	2
outlet		7.7	24	15	64	-	33	1.6	
Real Time Reading at Outlet									

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Name of the Plant	Capacity (in MGD)	09.04.2020		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC Limit	50	30	250
Yamuna Vihar	10 MGD Phase-I	27	20	-
	10 MGD Phase-II	26	21	80
	25 MGD Phase-III	33	21	88
Rithala	40 MGD	48	33	120
	40 MGD	16	11	50
Corronation pillar	20 MGD Phase-I &II	58	54	90
	10 MGD Phase-III	70	66	98
Rohini	15 MGD	32	19	-
Nilothi	40 MGD	56	33	-
Okhla	12 MGD	30	21	80
	45 MGD	41	26	104
	37 MGD	48	29	120
	16 MGD	24	15	64

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Parameters of STPs of Delhi as on

10.04.2020

Parameters of WTP of Delhi as on							Date: 14/02/2021		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Yamuna Vihar	10 MGD Phase-I	Inlet	6.9	292	193			40	4
		outlet	7.5	29	17			30	2.5
	Real Time Reading at Outlet								
	10 MGD Phase-II	Inlet	7.1	256	213			45	4
		outlet	7.5	24	21			25	1.5
	Real Time Reading at Outlet								
	25 MGD Phase-III	Inlet	7.2	300	280			40	3.5
		outlet	7.5	38	24			20	1.5
Real Time Reading at Outlet									
Rithala	40 MGD	Inlet	7	252	158	350	ND	43	1.8
		outlet	7.6	44	31	110	ND	27	1.2
	Real Time Reading at Outlet		ND	ND	ND	ND		ND	
	40 MGD	Inlet	7	252	158	350	ND	43	1.8
		Outlet	7.7	17	13	60		15	0.7
Real Time Reading at Outlet		ND	ND	ND	ND		ND		
Corronation Pillar	20 MGD Phase-I & II	Inlet	7.2	184	175	246	1.3	21	2.8
		outlet	7.5	64	58	104	1	16	1.3
	Real Time Reading at Outlet		-	-	-	-	-	-	-
	10 MGD Phase-III	Inlet	7.3	304	280	346	-	27	4.4
		outlet	7.7	75	68	106	-	21	2.5
Real Time Reading at Outlet		7.3	66	49	192	-	15	-	
Narela	10 MGD Phase-III	Inlet	7.1	198	185	224	4.5	35	3.5
		outlet	7.7	22	18	70	1	19	2
	Real Time Reading at Outlet		7.3	139	112	198	-	10	-
Rohini	15 MGD	Inlet	7.2	548	308	992		56	8
		Outlet	7.5	26	15	86		18	4
	Real Time Reading at Outlet								
Keshopur	12 MGD (PH-I)	Inlet	7.4	396	208	693	14.2	33	3.6
		Outlet	7.6	12	6	30	0	1	3.7
	Real time reading at OUTLET(online)								
	20 MGD (PH-II)	Inlet	7.3	384	200	708	14.4	34	3.5
		Outlet	7.5	156	139	358	4	31	3.2
	Real Time Reading at Outlet								
	40 MGD (PH-III)	Inlet	7.3	384	200	708	14.4	34	3.5
		Outlet	7.5	162	140	376	4.2	30	3.1
Real Time Reading at Outlet									
Ankita	40 MGD (PH-I)	Inlet	7.2	304	146	460	6.4	32	3
		Outlet	7.3	54	31	132	1.2	20	2
	Real Time Reading at Outlet		7.29	47.94	222.07	207.64	-	37.26	-

	20 MGD	Inlet	7.1	258	164	530	-	32	3.2
	(PH-II)	Outlet	7.3	8	5	24	-	5	2.2
	Real Time Reading at Outlet								
Pappankalan	(20 MGD)	Inlet	7.3	300	182	-	-	26	1.2
	PH-I	Outlet	7.5	48	24	-	-	10	0.6
	Real Time Reading at Outlet		7.27	86.19	51.56	165	-	16.4	-
	(20 MGD)	Inlet	7.3	290	163	-	-	24	2.2
	PH-II	Outlet	7.5	6	5	-	-	3	0.4
	Real Time Reading at Outlet		11.63	96.66	33.22	104.62	-	36.16	-
Najafgarh	(05 MGD)	Inlet	7.3	420	188	-	-	28	3.8
		Outlet	7.6	15	9	-	-	7	1.2
	Real Time Reading at Outlet		7.48	34.65	32.56	82.25	-	7.11	-
Okhla	12 MGD	Inlet	7.4	238	198	448	3	36	1
		outlet	7.6	23	17	64	NIL	28	0.5
	Real Time Reading at Outlet								
	45 MGD	Inlet	7.4	244	198	456	4	37	1.1
		outlet	7.7	29	17	72	NIL	29	0.7
	Real Time Reading at Outlet								
	37 MGD	Inlet	7.4	244	198	456	4	37	1.1
		outlet	7.8	28	16	64	NIL	29	0.6
	Real Time Reading at Outlet								
	16 MGD	Inlet	7.4	244	198	456	4	37	1.1
		outlet	7.8	19	13	48	NIL	26	0.5
	Real Time Reading at Outlet								
	New 30 MGD	Inlet	7.4	230	225	432	3	37	1
		Outlet	8	7	6	24	NIL	6	0.5
	Real Time Reading at Outlet								
Delhi Gate-I	2.2 MGD	Inlet	7.4	180	190	416	2	33	1
		outlet	7.9	7	6	24	NIL	5	0.4
	Real Time Reading at Outlet								
Delhi Gate-II	15 MGD	Inlet	7.4	176	157	384	3	32	1.1
		outlet	7.8	6	5	24	NIL	4	0.5
	Real Time Reading at Outlet								
Sen Nursing Home	2.2 MGD	Inlet	7.4	196	200	432	3	31	1
		outlet	7.9	8	7	32	NIL	3	0.5
	Real Time Reading at Outlet								

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Name of the Plant	Capacity (in MGD)	10.04.2020		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC Limit	50	30	250
Yamuna Vihar	10 MGD Phase-I	29	17	-
	10 MGD Phase-II	24	21	-
	25 MGD Phase-III	38	24	-
Rithala	40 MGD	44	31	110
	40 MGD	17	13	60
Corronation pillar	20 MGD Phase-I &II	64	58	104
	10 MGD Phase-III	75	68	106
Narela	10 MGD Phase-III	22	18	70
Rohini	15 MGD	26	15	86
Keshopur	12 MGD	12	6	30
	20 MGD	156	139	358
	40 MGD	162	140	376
Nilothi	40 MGD	54	31	132
	20 MGD	8	5	24
Pappankalan	(20 MGD)	48	24	-
	(20 MGD)	6	5	-
Najafgarh	05 MGD	15	9	-
Okhla	12 MGD	23	17	64
	45 MGD	29	17	72
	37 MGD	28	16	64
	16 MGD	19	13	48
	New 30 MGD	7	6	24
Delhi Gate-I	2.2 MGD	7	6	24
Delhi Gate-II	15 MGD	6	5	24
Sen Nursing Home	2.2 MGD	8	7	32