

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Parameters of STPs of Delhi as on

01.05.2020

Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Yamuna Vihar	10 MGD Phase-I	Inlet	7.1	372	161			40	4.0
		outlet	7.5	28	20			20	1.5
	Real Time Reading at Outlet								
	10 MGD Phase-II	Inlet	7.2	472	206			35	3.0
		outlet	7.6	25	20			15	2.0
	Real Time Reading at Outlet								
	25 MGD Phase-III	Inlet	7.2	716	247			45	3.5
		outlet	7.5	38	24			20	1.5
Real Time Reading at Outlet		6.8	20	15	59		10		
Rithala	40 MGD	Inlet	7.1	236	144	290		36	1.4
		outlet	7.7	48	25	110		25	1.1
	Real Time Reading at Outlet		ND	ND	ND	ND		ND	
	40 MGD	Inlet	7.1	236	144	290		36	1.4
		Outlet	7.8	18	25	60		19	0.8
Real Time Reading at Outlet		ND	ND	ND	ND		ND		
Corronation Pillar	20 MGD Phase-I & II	Inlet	7.1	198	205	234	-	19	3
		outlet	7.5	86	82	110	-	12	2.2
	Real Time Reading at Outlet		-	-	-	-	-	-	-
	10 MGD Phase-III	Inlet	7.1	208	225	286	6	28	6.4
		outlet	7.5	90	84	116	1.8	14	2.6
Real Time Reading at Outlet		-	-	-	-	-	-	-	
Narela	10 MGD Phase-III	Inlet	7	188	210	244	3	25	2.8
		outlet	7.6	31	24	80	1.4	13	0.6
	Real Time Reading at Outlet		-	-	-	-	-	-	-
Rohini	15 MGD	Inlet	7.1	212	148			42	5
		Outlet	7.5	28	17			17	4
	Real Time Reading at Outlet								
Keshopur	12 MGD	Inlet	7.3	264	162	-	-	33	3.4
	(PH-I)	Outlet	7.5	10	7	-	-	1	3.6
	Real time reading at OUTLET(online)								
	20 MGD	Inlet	7.3	248	172	-	-	34	3.3
	(PH-II)	Outlet	7.5	104	94	-	-	30	3.1
	Real Time Reading at Outlet								
	40 MGD	Inlet	7.3	248	172	-	-	34	3.3
	(PH-III)	Outlet	7.6	100	89	-	-	31	3
Real Time Reading at Outlet									

Nilothi	40 MGD	Inlet	7.2	286	119	480	5	30	3
	(PH-I)	Outlet	7.4	48	30	132	1	20	2.5
	Real Time Reading at Outlet								
	20 MGD	Inlet	7.1	298	169	520	8	30	3.5
	(PH-II)	Outlet	7.3	9	5	24	0	5	1.5
	Real Time Reading at Outlet								
Pappankalan	(20 MGD)	Inlet	7.3	185	165	-	-	26	1.6
	PH-I	Outlet	7.6	45	20	-	-	12	1
	Real Time Reading at Outlet								
	(20 MGD)	Inlet	7.3	180	160	-	-	22	2
	PH-II	Outlet	7.5	6	5	-	-	1.2	1
	Real Time Reading at Outlet								
Najafgarh	(05 MGD)	Inlet	7.3	210	180	-	-	28	2.6
		Outlet	7.6	15	8	-	-	5	1.2
	Real Time Reading at Outlet								
Okhla	12 MGD	Inlet	7.3	228	127	416	4	38	1.8
		outlet	7.7	37	23	96	1	32	1
	Real Time Reading at Outlet								
	45 MGD	Inlet	7.2	268	136	448	3	41	2
		outlet	7.6	34	19	80	1	35	1
	Real Time Reading at Outlet								
	37 MGD	Inlet	7.2	268	136	448	3	41	2
		outlet	7.6	37	22	88	1	31	0.5
	Real Time Reading at Outlet								
	16 MGD	Inlet	7.2	268	136	448	3	41	2
		outlet	7.8	9	8	32	1	28	0.5
	Real Time Reading at Outlet								

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Name of the Plant	Capacity (in MGD)	01.05.2020		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC Limit	50	30	250
Yamuna Vihar	10 MGD Phase-I	28	20	-
	10 MGD Phase-II	25	20	-
	25 MGD Phase-III	38	24	-
Rithala	40 MGD	48	25	110
	40 MGD	18	25	60
Corronation pillar	20 MGD Phase-I &II	86	82	110
	10 MGD Phase-III	90	84	116
Narela	10 MGD Phase-III	31	24	80
Rohini	15 MGD	28	17	-
Keshopur	12 MGD	10	7	-
	20 MGD	104	94	-
	40 MGD	100	89	-
Nilothi	40 MGD	48	30	132
	20 MGD	9	5	24
Pappankalan	(20 MGD)	45	20	-
	(20 MGD)	6	5	-
Najafgarh	05 MGD	15	8	-
Okhla	12 MGD	37	23	96
	45 MGD	34	19	80
	37 MGD	37	22	88
	16 MGD	9	8	32

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Parameters of STPs of Delhi as on

02.05.2020

Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Yamuna Vihar	10 MGD Phase-I	Inlet	7.2	288	167		11.6	40	4.0
		outlet	7.6	22	18		4.0	25	2.0
	Real Time Reading at Outlet								
	10 MGD Phase-II	Inlet	7.1	224	165		7.6	45	4.0
		outlet	7.5	29	18		2.4	20	1.5
	Real Time Reading at Outlet								
	25 MGD Phase-III	Inlet	7.2	984	268		9.6	40	4.5
		outlet	7.4	39	24		3.6	20	1.5
	Real Time Reading at Outlet								
Rithala	40 MGD	Inlet	7.1	272	153	370		39	1.4
		outlet	7.8	45	22	100		24	1.1
	Real Time Reading at Outlet		ND	ND	ND	ND		ND	
	40 MGD	Inlet	7.1	272	153	370		39	1.4
		Outlet	7.6	17	12	50		14	0.6
	Real Time Reading at Outlet		ND	ND	ND	ND		ND	
Corronation Pillar	20 MGD Phase-I & II	Inlet	7	204	200	248	6	21	3.6
		outlet	7.4	70	69	106	1.8	15	2.6
	Real Time Reading at Outlet		-	-	-	-	-	-	-
	10 MGD Phase-III	Inlet	7	224	235	298	-	26	6
		outlet	7.6	84	88	118	-	16	3
	Real Time Reading at Outlet		-	-	-	-	-	-	-
Rohini	15 MGD	Inlet	7.2	240	145	512		35	9
		Outlet	7.4	32	20	86		18	5
	Real Time Reading at Outlet								
Keshopur	12 MGD (PH-I)	Inlet	7.3	268	172	568	-	34	3.4
		Outlet	7.5	12	6	32	-	1	3.6
	Real time reading at OUTLET(online)								
	20 MGD (PH-II)	Inlet	7.3	260	171	608	-	34	3.3
		Outlet	7.6	114	97	296	-	30	3.2
	Real Time Reading at Outlet								
	40 MGD (PH-III)	Inlet	7.3	260	171	608	-	34	3.3
		Outlet	7.6	104	94	282	-	30	3
	Real Time Reading at Outlet								
Nilothi	40 MGD (PH-I)	Inlet	7.2	220	117	-	-	30	3
		Outlet	7.3	45	29	-	-	20	2
	Real Time Reading at Outlet								

	20 MGD	Inlet	7.2	286	163	-	-	35	2.8
	(PH-II)	Outlet	7.4	11	7	-	-	8	1
	Real Time Reading at Outlet								
Pappankalan	(20 MGD)	Inlet	7.3	196	165	-	-	26	1.6
	PH-I	Outlet	7.6	44	20	-	-	12	1.2
	Real Time Reading at Outlet								
	(20 MGD)	Inlet	7.3	190	160	-	-	24	2.2
	PH-II	Outlet	7.6	6	5	-	-	1	0.8
	Real Time Reading at Outlet								
Okhla	12 MGD	Inlet	7.5	200	140	344	4	37	1.4
		outlet	7.6	38	22	88	NIL	30	0.8
	Real Time Reading at Outlet								
	45 MGD	Inlet	7.4	224	145	360	4	39	1.6
		outlet	7.6	32	20	72	1	36	1
	Real Time Reading at Outlet								
	37 MGD	Inlet	7.4	224	145	360	4	39	1.6
		outlet	7.7	35	23	80	NIL	29	1
	Real Time Reading at Outlet								
	16 MGD	Inlet	7.4	224	145	360	4	39	1.6
		outlet	7.3	14	8	40	1	33	0.8
	Real Time Reading at Outlet								
Molarbund	0.66 MGD	Inlet	7.3	260	170	424	4	37	1.2
		outlet	7.7	14	8	40	1	30	NIL
	Real Time Reading at Outlet								
Delhi Gate-I	2.2 MGD	Inlet	7.2	202	155	384	4	28	2
		outlet	7.7	5	5	24	NIL	4	1
	Real Time Reading at Outlet								
Delhi Gate-II	15 MGD	Inlet	7.3	198	148	368	4	26	2
		outlet	7.6	6	6	32	NIL	NIL	1
	Real Time Reading at Outlet								
Sen Nursing Home	2.2 MGD	Inlet	7.2	220	157	392	4	24	2
		outlet	7.6	7	7	32	1	NIL	0.8
	Real Time Reading at Outlet								

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Name of the Plant	Capacity (in MGD)	02.05.2020		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC Limit	50	30	250
Yamuna Vihar	10 MGD Phase-I	22	18	-
	10 MGD Phase-II	29	18	-
	25 MGD Phase-III	39	24	-
Rithala	40 MGD	45	22	100
	40 MGD	17	12	50
Corronation pillar	20 MGD Phase-I &II	70	69	106
	10 MGD Phase-III	84	88	118
Rohini	15 MGD	32	20	86
Keshopur	12 MGD	12	6	32
	20 MGD	114	97	296
	40 MGD	104	94	282
Nilothi	40 MGD	45	29	-
	20 MGD	11	7	-
Pappankalan	(20 MGD)	44	20	-
	(20 MGD)	6	5	-
Okhla	12 MGD	38	22	88
	45 MGD	32	20	72
	37 MGD	35	23	80
	16 MGD	14	8	40
	New 30 MGD	9	8	40
Molarbund	0.66 MGD	14	8	40
Delhi Gate-I	2.2 MGD	5	5	24
Delhi Gate-II	15 MGD	6	6	32
Sen Nursing Home	2.2 MGD	7	7	32

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Parameters of STPs of Delhi as on

03.05.2020

Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Yamuna Vihar	10 MGD Phase-I	Inlet	7.2	288	168			30	3.5
		outlet	7.5	27	18			15	1.0
	Real Time Reading at Outlet								
	10 MGD Phase-II	Inlet	7.1	232	157			30	2.5
		outlet	7.5	24	18			20	1.5
	Real Time Reading at Outlet								
	25 MGD Phase-III	Inlet	7.1	868	350			40	3.5
		outlet	7.6	36	23			25	1.5
	Real Time Reading at Outlet								
Rithala	40 MGD	Inlet	7	260	141	320		32	1.2
		outlet	7.7	44	23	90		20	1
	Real Time Reading at Outlet		ND	ND	ND	ND		ND	
	40 MGD	Inlet	7	260	141	320		32	1.2
		Outlet	7.5	17	11	60		14	0.7
	Real Time Reading at Outlet		ND	ND	ND	ND		ND	
Corronation Pillar	20 MGD Phase-I & II	Inlet	7.1	212	205	304	-	20	3.2
		outlet	7.5	90	86	118	-	13	2.2
	Real Time Reading at Outlet		-	-	-	-	-	-	-
	10 MGD Phase-III	Inlet	7.1	298	290	402	7.2	28	6.2
		outlet	7.5	88	85	110	3	20	2.6
	Real Time Reading at Outlet		-	-	-	-	-	-	-
Rohini	15 MGD	Inlet	7.1	272	176	-	-	45	6.5
		Outlet	7.6	26	15	-	-	16	3.5
	Real Time Reading at Outlet		-	-	-	-	-	-	-
Nilothe	40 MGD	Inlet	7.1	176	116	-	-	32	3
	(PH-I)	Outlet	7.4	44	28	-	-	20	2.5
	Real Time Reading at Outlet								
Okhla	12 MGD	Inlet	7.4	196	138	344	3	36	1.3
		outlet	7.7	30	24	72	1	29	0.7
	Real Time Reading at Outlet								
	45 MGD	Inlet	7.4	198	131	352	4	38	1.3
		outlet	7.7	29	20	64	NIL	31	0.6
	Real Time Reading at Outlet								
	37 MGD	Inlet	7.4	198	131	352	4	38	1.3
		outlet	7.7	32	22	80	NIL	28	1
	Real Time Reading at Outlet								

16 MGD	Inlet	7.4	198	131	352	4	38	1.3
	outlet	7.6	13	13	32	NIL	30	0.9
Real Time Reading at Outlet								

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Name of the Plant	Capacity (in MGD)	03.05.2020		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC Limit	50	30	250
Yamuna Vihar	10 MGD Phase-I	27	18	-
	10 MGD Phase-II	24	18	-
	25 MGD Phase-III	36	23	-
Rithala	40 MGD	44	23	90
	40 MGD	17	11	60
Corronation pillar	20 MGD Phase-I &II	90	86	118
	10 MGD Phase-III	88	85	110
Rohini	15 MGD	26	15	-
Nilothi	40 MGD	44	28	-
Okhla	12 MGD	30	24	72
	45 MGD	29	20	64
	37 MGD	32	22	80
	16 MGD	13	13	32

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Parameters of STPs of Delhi as on

04.05.2020

Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Yamuna Vihar	10 MGD Phase-I	Inlet	7.2	340	175			40	4.0
		outlet	7.6	25	23			25	2.5
	Real Time Reading at Outlet								
	10 MGD Phase-II	Inlet	7.1	344	234			40	4.5
		outlet	7.5	38	24			20	1.5
	Real Time Reading at Outlet								
	25 MGD Phase-III	Inlet	7.2	1392	316			45	3.5
		outlet	7.4	45	28			15	2.0
	Real Time Reading at Outlet								
Rithala	40 MGD	Inlet	7.2	236	158	310		39	2.1
		outlet	7.8	47	25	100		25	1.4
	Real Time Reading at Outlet		ND	ND	ND	ND		ND	
	40 MGD	Inlet	7.2	236	158	310		39	2.1
		Outlet	7.7	16	11	50		16	0.9
	Real Time Reading at Outlet		ND	ND	ND	ND		ND	
Corronation Pillar	20 MGD Phase-I & II	Inlet	7	162	175	268	5.4	18	4
		outlet	7.5	86	64	100	1.3	12	1.4
	Real Time Reading at Outlet		-	-	-	-	-	-	-
	10 MGD Phase-III	Inlet	7.2	284	278	322	-	26	5
		outlet	7.6	88	92	112	-	20	2.2
	Real Time Reading at Outlet		-	-	-	-	-	-	-
Rohini	15 MGD	Inlet	7.2	310	200	618	-	52	12.5
		Outlet	7.5	28	17	90	-	17	4
	Real Time Reading at Outlet		-	-	-	-	-	-	-
Keshopur	12 MGD (PH-I)	Inlet	7.4	260	161	-	-	35	3.4
		Outlet	7.6	12	7	-	-	2	3.7
	Real time reading at OUTLET(online)								
	20 MGD (PH-II)	Inlet	7.3	264	170	-	-	33	3.4
		Outlet	7.5	98	92	-	-	29	3.1
	Real Time Reading at Outlet								
	40 MGD (PH-III)	Inlet	7.3	264	170	-	-	33	3.4
		Outlet	7.6	96	90	-	-	32	3
	Real Time Reading at Outlet								
Nilothi	40 MGD (PH-I)	Inlet	7.2	280	123	-	5	30	3.2
		Outlet	7.4	54	32	-	0.8	20	2.8
	Real Time Reading at Outlet								

	20 MGD	Inlet	7.2	304	174	-	-	32	3.2
	(PH-II)	Outlet	7.5	9	5	-	-	10	1.5
	Real Time Reading at Outlet								
Pappankalan	(20 MGD)	Inlet	7.3	180	172	510	6.8	25	1.4
	PH-I	Outlet	7.6	42	23	80	1	10	1
	Real Time Reading at Outlet								
	(20 MGD)	Inlet	7.3	175	170	480	6.5	24	2.2
	PH-II	Outlet	7.5	5	4	20	0	1.2	1.4
Najafgarh	Real Time Reading at Outlet								
	(05 MGD)	Inlet	7.3	200	176	-	8.3	28	2.4
		Outlet	7.6	12	8	-	0	4	1.2
Okhla	Real Time Reading at Outlet								
	12 MGD	Inlet	7.1	204	147	368	4	37	1.6
		outlet	7.6	36	22	96	1	32	0.8
	Real Time Reading at Outlet								
	45 MGD	Inlet	7.3	202	150	384	4	36	1
		outlet	7.6	32	18	80	NIL	30	0.6
	Real Time Reading at Outlet								
	37 MGD	Inlet	7.3	202	150	384	4	36	1
		outlet	7.6	34	23	88	1	28	NIL
	Real Time Reading at Outlet								
	16 MGD	Inlet	7.3	202	150	384	4	36	1
		outlet	7.6	20	13	64	NIL	32	NIL
	Real Time Reading at Outlet								
Mehrauli	New 30 MGD	Inlet	7.4	226	155	384	3	34	1
		Outlet	7.6	8	4	16	1	4	NIL
	Real Time Reading at Outlet								
Vasant Kunj	5 MGD	Inlet	7.2	382	198	488	-	42	1.5
		outlet	7.7	40	25	96	-	33	0.7
	Real Time Reading at Outlet								
	2.2 MGD	Inlet	7.3	238	147	360	5	37	1.6
		outlet	7.7	18	9	32	1	32	0.8
Ghitorni	Real Time Reading at Outlet								
	3 MGD	Inlet	7.4	242	148	368	4	40	2
		outlet	7.6	15	7	24	NIL	35	1
Ghitorni	Real Time Reading at Outlet								
	5 MGD	Inlet	7.4	240	150	368	4	42	1.6
		outlet	7.7	35	14	72	1	38	0.6
	Real Time Reading at Outlet								
	Real Time Reading at Outlet								

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Name of the Plant	Capacity (in MGD)	04.05.2020		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC Limit	50	30	250
Yamuna Vihar	10 MGD Phase-I	25	23	-
	10 MGD Phase-II	38	24	-
	25 MGD Phase-III	45	28	-
Rithala	40 MGD	47	25	100
	40 MGD	16	11	50
Corronation pillar	20 MGD Phase-I &II	86	64	100
	10 MGD Phase-III	88	92	112
Rohini	15 MGD	28	17	90
Keshopur	12 MGD	12	7	-
	20 MGD	98	92	-
	40 MGD	96	90	-
Nilothi	40 MGD	54	32	-
	20 MGD	9	5	-
Pappankalan	(20 MGD)	42	23	80
	(20 MGD)	5	4	20
Najafgarh	05 MGD	12	8	-
Okhla	12 MGD	36	22	96
	45 MGD	32	18	80
	37 MGD	34	23	88
	16 MGD	20	13	64
	New 30 MGD	8	4	16
Mehrauli	5 MGD	40	25	96
Vasant Kunj	2.2 MGD	18	9	32
	3 MGD	15	7	24
Ghitorni	5 MGD	35	14	72

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Parameters of STPs of Delhi as on

05.05.2020

Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Yamuna Vihar	10 MGD Phase-I	Inlet	7.2	180	125			35	6.0
		outlet	7.6	30	19			30	2.5
	Real Time Reading at Outlet								
	10 MGD Phase-II	Inlet	7.0	240	154			25	5.5
		outlet	7.6	22	19			20	3.0
	Real Time Reading at Outlet								
	25 MGD Phase-III	Inlet	7.2	696	290			35	6.0
		outlet	7.6	38	27			30	2.5
Real Time Reading at Outlet									
Rithala	40 MGD	Inlet	7	264	152	340		34	1.2
		outlet	7.7	49	28	90		22	0.9
	Real Time Reading at Outlet		ND	ND	ND	ND		ND	
	40 MGD	Inlet	7	264	152	340		34	1.2
		Outlet	7.5	18	14	60		14	0.6
Real Time Reading at Outlet		ND	ND	ND	ND		ND		
Corronation Pillar	20 MGD Phase-I & II	Inlet	6.9	158	165	252	-	20	6.4
		outlet	7.5	74	60	118	-	13	1.9
	Real Time Reading at Outlet		-	-	-	-	-	-	-
	10 MGD Phase-III	Inlet	7.1	180	235	208	-	28	4.6
		outlet	7.6	92	94	128	-	21	1.1
Real Time Reading at Outlet		-	-	-	-	-	-	-	
Rohini	15 MGD	Inlet	7.1	480	288	-	-	35	10
		Outlet	7.5	26	15	-	-	12	5
	Real Time Reading at Outlet								
Keshopur	12 MGD	Inlet	7.3	248	167	-	-	34	3.4
	(PH-I)	Outlet	7.5	10	6	-	-	1	3.6
	Real time reading at OUTLET(online)								
	20 MGD	Inlet	7.3	264	172	-	-	33	3.6
	(PH-II)	Outlet	7.5	100	95	-	-	30	3.1
	Real Time Reading at Outlet								
	40 MGD	Inlet	7.3	264	172	-	-	33	3.6
	(PH-III)	Outlet	7.6	108	94	-	-	31	3.2
Real Time Reading at Outlet									
Nilothi	40 MGD	Inlet	7.1	278	128	440	-	30	2.8
	(PH-I)	Outlet	7.3	58	33	140	-	22	2.5
	Real Time Reading at Outlet								

	20 MGD	Inlet	7.2	296	177	570	-	32	3
	(PH-II)	Outlet	7.4	20	15	36	-	18	1.8
	Real Time Reading at Outlet								
Pappankalan	(20 MGD)	Inlet	7.2	185	165	-	-	26	1.2
	PH-I	Outlet	7.5	40	22	-	-	12	1
	Real Time Reading at Outlet								
	(20 MGD)	Inlet	7.2	180	160	-	-	24	2
	PH-II	Outlet	7.5	4	4	-	-	1	1.2
	Real Time Reading at Outlet								
Najafgarh	(05 MGD)	Inlet	7.3	230	180	-	-	26	2.2
		Outlet	7.6	10	8	-	-	4	1.2
	Real Time Reading at Outlet								
Okhla	12 MGD	Inlet	7.3	202	143	320	3	40	2
		outlet	7.7	29	21	56	1	34	1.1
	Real Time Reading at Outlet								
	45 MGD	Inlet	7.3	196	135	312	4	39	1.5
		outlet	7.7	28	21	56	1	33	1
	Real Time Reading at Outlet								
	37 MGD	Inlet	7.3	196	135	312	4	39	1.5
		outlet	7.8	33	23	88	NIL	35	0.7
	Real Time Reading at Outlet								
	16 MGD	Inlet	7.3	196	135	312	4	39	1.5
		outlet	7.7	16	11	32	NIL	29	0.5
	Real Time Reading at Outlet								

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Name of the Plant	Capacity (in MGD)	05.05.2020		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC Limit	50	30	250
Yamuna Vihar	10 MGD Phase-I	30	19	-
	10 MGD Phase-II	22	19	-
	25 MGD Phase-III	38	27	-
Rithala	40 MGD	49	28	90
	40 MGD	18	14	60
Corronation pillar	20 MGD Phase-I &II	74	60	118
	10 MGD Phase-III	92	94	128
Rohini	15 MGD	26	15	-
Keshopur	12 MGD	10	6	-
	20 MGD	100	95	-
	40 MGD	108	94	-
Nilothi	40 MGD	58	33	140
	20 MGD	20	15	36
Pappankalan	(20 MGD)	40	22	-
	(20 MGD)	4	4	-
Najafgarh	05 MGD	10	8	-
Okhla	12 MGD	29	21	56
	45 MGD	28	21	56
	37 MGD	33	23	88
	16 MGD	16	11	32

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Parameters of STPs of Delhi as on

06.05.2020

Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Yamuna Vihar	10 MGD Phase-I	Inlet	6.9	236	162			40	3.5
		outlet	7.4	26	20			20	1.5
	Real Time Reading at Outlet								
	10 MGD Phase-II	Inlet	7.1	196	162			30	4.0
		outlet	7.5	26	16			15	2.0
	Real Time Reading at Outlet								
	25 MGD Phase-III	Inlet	7.2	736	338			45	5.5
		outlet	7.6	44	29			20	2.5
	Real Time Reading at Outlet								
Rithala	40 MGD	Inlet	7.2	248	148	320		36	1.7
		outlet	7.6	46	23	100		24	1.3
	Real Time Reading at Outlet		ND	ND	ND	ND		ND	
	40 MGD	Inlet	7.2	248	148	320		36	1.7
		Outlet	7.7	17	12	60		13	1.2
	Real Time Reading at Outlet		ND	ND	ND	ND		ND	
Corronation Pillar	20 MGD Phase-I & II	Inlet	7	168	178	218	4.2	21	5
		outlet	7.4	76	80	122	1.6	14	1.7
	Real Time Reading at Outlet		-	-	-	-	-	-	-
	10 MGD Phase-III	Inlet	7.2	212	255	344	-	27	8.8
		outlet	7.6	88	90	120	-	18	4
	Real Time Reading at Outlet		-	-	-	-	-	-	-
Rohini	15 MGD	Inlet	6.9	270	175	554	-	40	12.5
		Outlet	7.5	34	21	115	-	15	5.5
	Real Time Reading at Outlet		-	-	-	-	-	-	-
Keshopur	12 MGD (PH-I)	Inlet	7.4	220	172	427	9.6	33	3.6
		Outlet	7.7	10	8	32	0	3	3.7
	Real time reading at OUTLET(online)								
	20 MGD (PH-II)	Inlet	7.4	296	181	533	8.4	37	3.8
		Outlet	7.6	92	78	260	3	33	3.4
	Real Time Reading at Outlet								
	40 MGD (PH-III)	Inlet	7.4	296	181	533	8.4	37	3.8
		Outlet	7.6	94	88	280	2.8	31	3.3
	Real Time Reading at Outlet								
Nilothi	40 MGD (PH-I)	Inlet	7.1	246	136	-	-	28	3
		Outlet	7.2	55	35	-	-	20	2.5
	Real Time Reading at Outlet								

	20 MGD	Inlet	7.2	304	183	-	8.4	35	3
	(PH-II)	Outlet	7.4	16	14	-	0	15	2
	Real Time Reading at Outlet								
Pappankalan	(20 MGD)	Inlet	7.2	202	190	-	-	26	1.5
	PH-I	Outlet	7.5	46	25	-	-	11	1.1
	Real Time Reading at Outlet								
	(20 MGD)	Inlet	7.3	196	184	-	-	24	2.1
	PH-II	Outlet	7.5	6	5	-	-	1.1	1.2
	Real Time Reading at Outlet								
Najafgarh	(05 MGD)	Inlet	7.3	214	204	-	-	26	2.5
		Outlet	7.5	15	10	-	-	3	1
	Real Time Reading at Outlet								
Okhla	12 MGD	Inlet	7.1	192	135	336	4	38	1.3
		outlet	7.4	32	20	72	1	30	1
	Real Time Reading at Outlet								
	45 MGD	Inlet	7.2	196	137	344	3	37	1.4
		outlet	7.5	24	18	56	NIL	31	1
	Real Time Reading at Outlet								
	37 MGD	Inlet	7.2	196	137	344	3	37	1.4
		outlet	7.6	32	20	80	1	30	1.1
	Real Time Reading at Outlet								
	16 MGD	Inlet	7.2	196	137	344	3	37	1.4
		outlet	7.7	12	8	32	NIL	29	0.9
	Real Time Reading at Outlet								

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Name of the Plant	Capacity (in MGD)	06.05.2020		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC Limit	50	30	250
Yamuna Vihar	10 MGD Phase-I	26	20	-
	10 MGD Phase-II	26	16	-
	25 MGD Phase-III	44	29	-
Rithala	40 MGD	46	23	100
	40 MGD	17	12	60
Corronation pillar	20 MGD Phase-I &II	76	80	122
	10 MGD Phase-III	88	90	120
Rohini	15 MGD	34	21	115
Keshopur	12 MGD	10	8	32
	20 MGD	92	78	260
	40 MGD	94	88	280
Nilothi	40 MGD	55	35	-
	20 MGD	16	14	-
Pappankalan	(20 MGD)	46	25	-
	(20 MGD)	6	5	-
Najafgarh	05 MGD	15	10	-
Okhla	12 MGD	32	20	72
	45 MGD	24	18	56
	37 MGD	32	20	80
	16 MGD	12	8	32

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Parameters of STPs of Delhi as on

07.05.2020

Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Yamuna Vihar	10 MGD Phase-I	Inlet	7.2	204	180	528	12.8	40	3.5
		outlet	7.5	26	19	80	5.6	20	1.5
	Real Time Reading at Outlet								
	10 MGD Phase-II	Inlet	7.1	248	184	512	10.4	45	4.0
		outlet	7.6	16	14	48	4.4	25	3.0
	Real Time Reading at Outlet								
	25 MGD Phase-III	Inlet	6.9	744	365	952	16.0	50	3.5
		outlet	7.5	29	21	80	2.8	30	1.5
	Real Time Reading at Outlet								
Rithala	40 MGD	Inlet	7.1	256	139	310		33	1.4
		outlet	7.7	48	24	90		22	1.1
	Real Time Reading at Outlet		ND	ND	ND	ND		ND	
	40 MGD	Inlet	7.1	256	139	310		33	1.4
		Outlet	7.5	16	11	60		19	0.8
	Real Time Reading at Outlet		ND	ND	ND	ND		ND	
Corronation Pillar	20 MGD Phase-I & II	Inlet	6.9	170	185	228	-	20	6.1
		outlet	7.4	83	86	124	-	16	2.2
	Real Time Reading at Outlet		-	-	-	-	-	-	-
	10 MGD Phase-III	Inlet	7.1	202	250	338	3.2	26	8.3
		outlet	7.5	90	95	128	1.6	17	3
	Real Time Reading at Outlet		-	-	-	-	-	-	-
Rohini	15 MGD	Inlet	7.1	250	163	-	-	48	10
		Outlet	7.5	28	17	-	-	17	4
	Real Time Reading at Outlet		-	-	-	-	-	-	-
Nilothe	40 MGD (PH-I)	Inlet	7.2	238	129	-	-	30	3.2
		Outlet	7.3	54	34	-	-	20	2.5
	Real Time Reading at Outlet								
	20 MGD (PH-II)	Inlet	7.1	290	183	-	-	32	3.2
		Outlet	7.3	9	6	-	-	12	1.5
	Real Time Reading at Outlet								
Pappankalan	(20 MGD) PH-I	Inlet	7.2	198	168	-	-	26	1.7
		Outlet	7.5	45	26	-	-	12	0.9
	Real Time Reading at Outlet								
	(20 MGD) PH-II	Inlet	7.3	192	166	-	-	25	2
		Outlet	7.5	5	4	-	-	1.3	1.3
	Real Time Reading at Outlet								

Najafgarh	(05 MGD)	Inlet	7.2	206	172	-	-	30	2.4
		Outlet	7.4	16	8	-	-	5	1.1
	Real Time Reading at Outlet								
Okhla	12 MGD	Inlet	7.2	202	140	344	3	40	1.3
		outlet	7.6	34	23	72	1	31	0.7
	Real Time Reading at Outlet								
	45 MGD	Inlet	7.2	204	145	352	4	38	1.4
		outlet	7.6	28	19	64	NIL	32	0.9
	Real Time Reading at Outlet								
	37 MGD	Inlet	7.2	204	145	352	4	38	1.4
		outlet	7.6	27	16	56	NIL	28	0.5
	Real Time Reading at Outlet								
	16 MGD	Inlet	7.2	204	145	352	4	38	1.4
		outlet	7.6	11	8	32	NIL	30	0.7
	Real Time Reading at Outlet								

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Name of the Plant	Capacity (in MGD)	07.05.2020		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC Limit	50	30	250
Yamuna Vihar	10 MGD Phase-I	26	19	80
	10 MGD Phase-II	16	14	48
	25 MGD Phase-III	29	21	80
Rithala	40 MGD	48	24	90
	40 MGD	16	11	60
Corronation pillar	20 MGD Phase-I &II	83	86	124
	10 MGD Phase-III	90	95	128
Rohini	15 MGD	28	17	-
Nilothi	40 MGD	54	34	-
	20 MGD	9	6	-
Pappankalan	(20 MGD)	45	26	-
	(20 MGD)	5	4	-
Najafgarh	05 MGD	16	8	-
Okhla	12 MGD	34	23	72
	45 MGD	28	19	64
	37 MGD	27	16	56
	16 MGD	11	8	32

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Parameters of STPs of Delhi as on

08.05.2020

Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Yamuna Vihar	10 MGD Phase-I	Inlet	7.2	212	141			40	3.5
		outlet	7.6	15	14			20	1.5
	Real Time Reading at Outlet								
	10 MGD Phase-II	Inlet	7.2	232	162			30	4.0
		outlet	7.5	25	20			15	2.0.
	Real Time Reading at Outlet								
	25 MGD Phase-III	Inlet	7.2	616	348			45	5.5
		outlet	7.5	53	28			20	2.5
	Real Time Reading at Outlet								
Rithala	40 MGD	Inlet	7.2	232	148	290		41	2.1
		outlet	7.8	45	21	100		29	1.3
	Real Time Reading at Outlet		ND	ND	ND	ND		ND	
	40 MGD	Inlet	7.2	232	148	290		41	2.1
		Outlet	7.7	18	14	70		18	1.1
	Real Time Reading at Outlet		ND	ND	ND	ND		ND	
Corronation Pillar	20 MGD Phase-I & II	Inlet	7	176	188	232	3.8	19	6.5
		outlet	7.5	78	82	110	1.1	16	2.5
	Real Time Reading at Outlet		-	-	-	-	-	-	-
	10 MGD Phase-III	Inlet	7	232	275	296	-	29	8.8
		outlet	7.6	86	89	118	-	20	3.6
	Real Time Reading at Outlet		-	-	-	-	-	-	-
Narela	10 MGD Phase-III	Inlet	7.2	190	185	280	4	32	4.6
		outlet	7.6	22	18	66	2.6	13	0.8
	Real Time Reading at Outlet		-	-	-	-	-	-	-
Rohini	15 MGD	Inlet	7.1	230	145	451	-	42	7.5
		Outlet	7.6	28	18	96	-	18	4
	Real Time Reading at Outlet		-	-	-	-	-	-	-
Keshopur	12 MGD (PH-I)	Inlet	7.4	256	160	479	-	34	3.4
		Outlet	7.6	10	6	30	-	2	3.7
	Real time reading at OUTLET(online)								
	20 MGD (PH-II)	Inlet	7.3	268	180	572	-	36	3.7
		Outlet	7.6	102	93	278	-	33	3.4
	Real Time Reading at Outlet								
	40 MGD (PH-III)	Inlet	7.3	268	180	572	-	36	3.7
		Outlet	7.6	108	95	276	-	33	3.4
	Real Time Reading at Outlet								

Nilothi	40 MGD	Inlet	7	256	137	470	-	32	3
	(PH-I)	Outlet	7.2	62	35	152	-	22	2
	Real Time Reading at Outlet								
	20 MGD	Inlet	7.1	314	178	-	-	35	3
	(PH-II)	Outlet	7.3	8	6	-	-	10	1.5
	Real Time Reading at Outlet								
Pappankalan	(20 MGD)	Inlet	7.3	258	204	-	-	24	3.4
	PH-I	Outlet	7.6	60	30	-	-	16	1.2
	Real Time Reading at Outlet								
	(20 MGD)	Inlet	7.2	310	208	-	-	22	3.2
	PH-II	Outlet	7.4	8	5	-	-	1.2	1.4
	Real Time Reading at Outlet								
Najafgarh	(05 MGD)	Inlet	7.3	284	188	-	-	28	4.6
		Outlet	7.6	22	12	-	-	3.4	0.5
	Real Time Reading at Outlet								
Okhla	12 MGD	Inlet	7.3	222	140	344	4	39	1.4
		outlet	7.6	35	20	80	1	33	0.9
	Real Time Reading at Outlet								
	45 MGD	Inlet	7.2	230	152	368	4	40	1.8
		outlet	7.7	30	18	72	1	35	1
	Real Time Reading at Outlet								
	37 MGD	Inlet	7.2	230	152	368	4	40	1.8
		outlet	7.7	31	21	80	1	32	0.9
	Real Time Reading at Outlet								
	16 MGD	Inlet	7.2	230	152	368	4	40	1.8
		outlet	7.6	13	10	32	NIL	29	0.5
	Real Time Reading at Outlet								
	New 30 MGD	Inlet	7.4	218	133	360	4	41	1.3
		Outlet	7.8	7	6	24	1	6	0.5
	Real Time Reading at Outlet								
Molarbund	0.66 MGD	Inlet	7.6	242	147	416	3	36	1.1
		outlet	7.7	16	10	40	1	28	0.5
	Real Time Reading at Outlet								
Delhi Gate-I	2.2 MGD	Inlet	7.2	196	134	352	3	27	1.5
		outlet	7.6	7	6	24	NIL	5	0.3
	Real Time Reading at Outlet								
Delhi Gate-II	15 MGD	Inlet	7.3	192	128	360	4	28	1.3
		outlet	7.3	6	5	24	NIL	4	NIL
	Real Time Reading at Outlet								
Sen Nursing Home	2.2 MGD	Inlet	7.2	204	153	400	3	26	1.4
		outlet	7.7	7	7	24	NIL	3	NIL
	Real Time Reading at Outlet								

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Name of the Plant	Capacity (in MGD)	08.05.2020		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC Limit	50	30	250
Yamuna Vihar	10 MGD Phase-I	15	14	-
	10 MGD Phase-II	25	20	-
	25 MGD Phase-III	53	28	-
Rithala	40 MGD	45	21	100
	40 MGD	18	14	70
Corronation pillar	20 MGD Phase-I &II	78	82	110
	10 MGD Phase-III	86	89	118
Narela	10 MGD Phase-III	22	18	66
Rohini	15 MGD	28	18	96
Keshopur	12 MGD	10	6	30
	20 MGD	102	93	278
	40 MGD	108	95	276
Nilothi	40 MGD	62	35	152
	20 MGD	8	6	-
Pappankalan	(20 MGD)	60	30	-
	(20 MGD)	8	5	-
Najafgarh	05 MGD	22	12	-
Okhla	12 MGD	35	20	80
	45 MGD	30	18	72
	37 MGD	31	21	80
	16 MGD	13	10	32
	New 30 MGD	7	6	24
Molarbund	0.66 MGD	16	10	40
Delhi Gate-I	2.2 MGD	7	6	24
Delhi Gate-II	15 MGD	6	5	24
Sen Nursing Home	2.2 MGD	7	7	24

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Parameters of STPs of Delhi as on

09.05.2020

Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Yamuna Vihar	10 MGD Phase-I	Inlet	7.1	180	152			50	3.0
		outlet	7.6	17	14			30	1.0
	Real Time Reading at Outlet								
	10 MGD Phase-II	Inlet	7.2	232	207			30	4.0
		outlet	7.5	24	19			20	2.0
	Real Time Reading at Outlet								
	25 MGD Phase-III	Inlet	7.2	584	264			55	5.0
		outlet	7.5	28	21			25	2.0
Real Time Reading at Outlet		6.2	15	14	48		10		
Rithala	40 MGD	Inlet	7	244	161	330	19	36	1.6
		outlet	7.6	47	23	110	8	22	1
	Real Time Reading at Outlet		ND	ND	ND	ND		ND	
	40 MGD	Inlet	7	244	161	330	19	36	1.6
		Outlet	7.8	17	12	60	6	15	0.7
Real Time Reading at Outlet		ND	ND	ND	ND		ND		
Corronation Pillar	20 MGD Phase-I & II	Inlet	7.1	196	205	316	-	20	6.2
		outlet	7.5	82	86	128	-	17	2.4
	Real Time Reading at Outlet		-	-	-	-	-	-	-
	10 MGD Phase-III	Inlet	7.1	342	310	408	5.4	28	8.6
		outlet	7.5	88	93	120	2.4	21	3.4
Real Time Reading at Outlet		-	-	-	-	-	-	-	
Rohini	15 MGD	Inlet	6.9	280	208	-	-	52	12.5
		Outlet	7.4	30	19	-	-	16	3.5
	Real Time Reading at Outlet		-	-	-	-	-	-	-
Keshopur	12 MGD	Inlet	7.4	264	163	-	-	34	3.4
	(PH-I)	Outlet	7.6	13	7	-	-	2	3.6
	Real time reading at OUTLET(online)								
	20 MGD	Inlet	7.3	272	183	-	-	36	3.6
	(PH-II)	Outlet	7.6	110	92	-	-	32	3.2
	Real Time Reading at Outlet								
	40 MGD	Inlet	7.3	272	183	-	-	36	3.6
	(PH-III)	Outlet	7.6	110	94	-	-	33	3.4
Real Time Reading at Outlet									
Nilothi	40 MGD	Inlet	7.1	284	139	-	6.2	30	2.8
	(PH-I)	Outlet	7.3	60	37	-	1.8	20	2.5
	Real Time Reading at Outlet								

	20 MGD	Inlet	7	324	186	-	9	32	3.5
	(PH-II)	Outlet	7.3	18	14	-	0	8	1.8
	Real Time Reading at Outlet								
Pappankalan	(20 MGD)	Inlet	7.3	255	198	-	-	24	3.2
	PH-I	Outlet	7.6	64	31	-	-	18	1.4
	Real Time Reading at Outlet								
Najafgarh	(05 MGD)	Inlet	7.3	198	172	-	-	28	4.8
		Outlet	7.5	20	10	-	-	3.2	0.6
	Real Time Reading at Outlet								
Okhla	12 MGD	Inlet	7.4	202	145	360	2	33	1
		outlet	7.6	32	21	72	NIL	28	0.7
	Real Time Reading at Outlet								
	45 MGD	Inlet	7.3	206	146	360	3	36	1.1
		outlet	7.6	30	19	64	NIL	27	0.6
	Real Time Reading at Outlet								
	37 MGD	Inlet	7.3	206	146	360	3	36	1.1
		outlet	7.7	29	16	56	NIL	32	0.7
	Real Time Reading at Outlet								
	16 MGD	Inlet	7.3	206	146	360	3	36	1.1
		outlet	7.6	15	9	40	NIL	28	0.4
	Real Time Reading at Outlet								

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Name of the Plant	Capacity (in MGD)	09.05.2020		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC Limit	50	30	250
Yamuna Vihar	10 MGD Phase-I	17	14	-
	10 MGD Phase-II	24	19	-
	25 MGD Phase-III	28	21	-
Rithala	40 MGD	47	23	110
	40 MGD	17	12	60
Corronation pillar	20 MGD Phase-I &II	82	86	128
	10 MGD Phase-III	88	93	120
Rohini	15 MGD	30	19	-
Keshopur	12 MGD	13	7	-
	20 MGD	110	92	-
	40 MGD	110	94	-
Nilothi	40 MGD	60	37	-
	20 MGD	18	14	-
Pappankalan	(20 MGD)	64	31	-
Najafgarh	05 MGD	20	10	-
Okhla	12 MGD	32	21	72
	45 MGD	30	19	64
	37 MGD	29	16	56
	16 MGD	15	9	40

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Parameters of STPs of Delhi as on

10.05.2020

Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Yamuna Vihar	10 MGD Phase-I	Inlet	7.2	240	218	496		60	6.5
		outlet	7.6	25	14	64		45	3.5
	Real Time Reading at Outlet								
	10 MGD Phase-II	Inlet	7.2	136	114	392		45	6.0
		outlet	7.5	25	18	80		40	4.5
	Real Time Reading at Outlet								
	25 MGD Phase-III	Inlet	7.2	276	218	520		55	7.5
		outlet	7.6	28	20	80		35	3.0
	Real Time Reading at Outlet								
Rithala	40 MGD	Inlet	7.1	248	148	320		38	1.5
		outlet	7.7	48	24	120		25	0.8
	Real Time Reading at Outlet		ND	ND	ND	ND		ND	
	40 MGD	Inlet	7.1	248	148	320		38	1.5
		Outlet	7.6	16	11	60		16	0.6
	Real Time Reading at Outlet		ND	ND	ND	ND		ND	
Corronation Pillar	20 MGD Phase-I & II	Inlet	7.1	152	168	238	4	18	6.4
		outlet	7.5	58	62	94	2.3	14	2.8
	Real Time Reading at Outlet		-	-	-	-	-	-	-
	10 MGD Phase-III	Inlet	7	256	285	398	-	26	7.8
		outlet	7.6	62	80	106	-	19	2.8
	Real Time Reading at Outlet		-	-	-	-	-	-	-
Rohini	15 MGD	Inlet	7.2	210	145	438	-	50	7.5
		Outlet	7.5	26	15	74	-	15	5.5
	Real Time Reading at Outlet		-	-	-	-	-	-	-
Keshopur	12 MGD (PH-I)	Inlet	7.3	268	161	-	-	34	3.4
		Outlet	7.5	10	6	-	-	2	3.6
	Real time reading at OUTLET(online)								
	20 MGD (PH-II)	Inlet	7.3	260	169	-	-	34	3.6
		Outlet	7.6	116	100	-	-	30	3.1
	Real Time Reading at Outlet								
	40 MGD (PH-III)	Inlet	7.3	260	169	-	-	34	3.6
		Outlet	7.6	104	97	-	-	30	3.2
	Real Time Reading at Outlet								
Nilothe	40 MGD (PH-I)	Inlet	7.1	228	129	-	-	30	3
		Outlet	7.3	60	36	-	-	20	2.5
	Real Time Reading at Outlet								

Pappankalan	(20 MGD)	Inlet	7.2	298	212	-	-	24	3.6
	PH-I	Outlet	7.6	68	33	-	-	14	1
	Real Time Reading at Outlet		-	-	-	-	-	-	-
Okhla	12 MGD	Inlet	7.4	196	145	352	3	35	1.1
		outlet	7.6	30	18	64	1	28	0.5
	Real Time Reading at Outlet								
	45 MGD	Inlet	7.4	202	147	360	4	37	1
		outlet	7.7	33	20	80	1	28	0.7
	Real Time Reading at Outlet								
	37 MGD	Inlet	7.4	202	147	360	4	37	1
		outlet	7.8	35	21	88	1	32	0.6
	Real Time Reading at Outlet								
	16 MGD	Inlet	7.4	202	147	360	4	37	1
		outlet	7.7	13	9	32	NIL	29	0.5
	Real Time Reading at Outlet								

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Name of the Plant	Capacity (in MGD)	10.05.2020		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC Limit	50	30	250
Yamuna Vihar	10 MGD Phase-I	25	14	64
	10 MGD Phase-II	25	18	80
	25 MGD Phase-III	28	20	80
Rithala	40 MGD	48	24	120
	40 MGD	16	11	60
Corronation pillar	20 MGD Phase-I &II	58	62	94
	10 MGD Phase-III	62	80	106
Rohini	15 MGD	26	15	74
Keshopur	12 MGD	10	6	-
	20 MGD	116	100	-
	40 MGD	104	97	-
Nilothi	40 MGD	60	36	-
Pappankalan	(20 MGD)	68	33	-
Okhla	12 MGD	30	18	64
	45 MGD	33	20	80
	37 MGD	35	21	88
	16 MGD	13	9	32