



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	Parameters of STPs of Delhi as on					01.07.2019		
		Parameter							
		DPPC limits	pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
Okhla	12 MGD	Inlet	7.4	350	185	432	3	42	3.8
		outlet	7.9	48	30	120	3	45	1.8
	Real Time Reading at Outlet		7.64	32.42	26.94	123.61		8.35	
	45 MGD	Inlet	7.6	266	185	400	3	42	4
		outlet	7.3	25	18	72	Nil	35	0.5
	Real Time Reading at Outlet		7.77	91.29	31.83	153.84		1.03	
	37 MGD	Inlet	7.6	266	185	400	3	42	4
		outlet	7.6	48	27	104	1	36	0.8
	Real Time Reading at Outlet		7.54	46.45	14.04	90.34		30.18	
	16 MGD	Inlet	7.6	266	185	400	3	42	4
		outlet	7.8	43	25	96	Nil	38	1.6
	Real Time Reading at Outlet								
New 30 MGD	Inlet	7.6	340	190	432	2	38	2.6	
	Outlet	7.8	9	6	24	Nil	0.4	2.2	
Real Time Reading at Outlet									
Molarbund	0.66 MGD	Inlet	7.1	610	375	760		60	4.6
		outlet	7.6	16	8	48		12	3.8
	Real Time Reading at Outlet								
Delhi Gate-I	2.2 MGD	Inlet	7.1	144	122	288	-	40	2.8
		outlet	7.4	4	6	24	-	25	0.8
	Real Time Reading at Outlet								
Delhi Gate-II	15 MGD	Inlet	7.3	112	119	256	-	40	3
		outlet	7.5	5	6	24	-	20	1.2
	Real Time Reading at Outlet								
Sen Nursing Home	2.2 MGD	Inlet	7.1	248	173	416	-	38	3.3
		outlet	7.8	9	8	32	-	33	1.2
	Real Time Reading at Outlet								
Kondli	25 MGD Phase-II	Inlet	7.3	292	172	328	-	43	7.2
		outlet	7.6	15	10	34	-	33	2.9
	Real Time Reading at Outlet		7.4	22	21	66		23.05	
	45 MGD Phase-IV	Inlet	7.2	282	178	332	-	42	7
		outlet	7.6	30	19	72	-	36	3.8
Real Time Reading at Outlet		7.9	27	14	45		12.48		
Chilla	9 MGD	Inlet	7.2	140	115	194	-	46	7
		outlet	7.6	9	3.3	26	-	0.35	5.2
	Real Time Reading at Outlet		7.2	12	3.59	19		6.45	
CWG Village	1 MGD	Inlet	7.1	196	139	232	-	28	5.8
		outlet	7.7	Bdl	0.24	Bdl	-	0.1	1.6
	Real Time Reading at Outlet		7.8	0.16	0.12	1.42		0.09	
	10 MGD Phase-I	Inlet	7.3	256	175	620	-	65	6
		outlet	7.7	29	18	140	-	35	3
	Real Time Reading at Outlet		7.3	43	61	197		14	

Yamuna Vihar	10 MGD Phase-II	Inlet	7.5	276	187	510	-	70	5.5
		outlet	7.7	41	25	110	-	35	2.5
	Real Time Reading at Outlet								
	25 MGD Phase-III	Inlet	7.5	256	170	530	-	65	6
		outlet	7.8	35	21	120	-	35	3
Real Time Reading at Outlet		7.3	84	26	110		25		
Rithala	40 MGD	Inlet	7.1	260	163	380	-	32	1.2
		outlet	7.9	30	18	100	-	27	1.1
	Real Time Reading at Outlet		7.53	340	55.88	267		31.06	
	40 MGD	Inlet	7.1	260	163	380	-	32	1.2
		Outlet	7	17	11	60	-	14	0.5
Real Time Reading at Outlet		7.62	17.95	14.86	63.39		32.41		
Rohiini 15 MGD	15 MGD	Inlet	7.4	236	178	486	-	48	8.5
		Outlet	7.9	25	14	83	-	16	3.5
	Real Time Reading at Outlet		7.2	22.9	8.83	66.84		11.62	
Keshopur	12 MGD	Inlet	7.3	260	187	-	9.4	31	3
		outlet	7.7	9	6	-	0	9	1.5
	Real Time Reading at Outlet		NA	NA	NA	NA	-	NA	-
	40 MGD	Inlet	7.3	352	196	-	12.2	32	3.1
		outlet	7.5	98	121	-	2.8	29	2.8
	Real Time Reading at Outlet		6.32	294.18	106.69	320.37	-	40	-
	20 MGD	Inlet	7.3	352	196	-	12.2	32	3.1
outlet		7.6	104	101	-	2.8	27	2.7	
Real Time Reading at Outlet		7.38	143.52	74.32	255.28	-	24.58	-	
Nilothi	40 MGD Phase-I	Inlet	7.3	190	139	-	6.6	27	2.6
		outlet	7.5	40	22	-	0.4	20	2.1
	Real Time Reading at Outlet		6.96	45.18	31.74	125.23	-	29.42	-
Pappankalan	20 MGD Phase-II	Inlet	7.4	298	229	-	13.9	34	5.3
		outlet	7.7	29	19	-	2.2	22	0.8
	Real Time Reading at Outlet		7.44	29.76	21.19	134.77	-	11.1	-
	20 MGD Phase-II	Inlet	7.3	304	238	-	-	36	5.6
		outlet	7.8	5	4	-	-	14	3.2
Real Time Reading at Outlet		7.03	13.91	13.43	48.53	-	1.63	-	
Najafgarh	5 MGD Phase-II	Inlet	7.3	122	102	-	-	22	2.4
		outlet	7.6	14	6	-	-	0.6	2
	Real Time Reading at Outlet		7.49	33.73	25.01	71.43	-	25.74	-
Corronation pillar	20 MGD Phase-I & II	Inlet	6.9	244	180	358	-	38	2.4
		outlet	7.2	74	52	120	-	22	1.2
	Real Time Reading at Outlet		7.2	58	30	131		22	
	10 MGD Phase-III	Inlet	6.9	385	230	448	7.9	52	2.6
		outlet	7.5	68	49	128	2.6	35	1.7
Real Time Reading at Outlet		7.2	58	30	101		24		

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	01.07.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
		50	30	250
Okhla	12 MGD	48	30	120
	45 MGD	25	18	72
	37 MGD	48	27	104
	16 MGD	43	25	96
	New 30 MGD	9	6	24
Molarbund	0.66 MGD	16	8	48
Delhi Gate-I	2.2 MGD	4	6	24
Delhi Gate-II	15 MGD	5	6	24
Sen Nursing Home	2.2 MGD	9	8	32
Kondli	25 MGD	15	10	34
	45 MGD	30	19	72
Chilla	9 MGD	9	3.3	26
CWG Village	1 MGD	Bdl	0.24	Bdl
Yamuna Vihar	10 MGD	29	18	140
	10 MGD	41	25	110
	25 MGD	35	21	120
Rithala	40 MGD	30	18	100
	40 MGD	17	11	60
Rohiini	15 MGD	25	14	83
Keshopur	12 MGD	9	6	-
	40 MGD	98	121	-
	20 MGD	104	101	-
Nilothi	40 MGD	40	22	-
Najafgarh	5 MGD	14	6	-
Pappankalan	20 MGD	29	19	-
	20 MGD	5	4	-
Corronation pillar	20 MGD	74	52	120
	10 MGD	68	49	128



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	Parameters of STPs of Delhi as on					02.07.2019		
		Parameter							
		DPPC limits	pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
Okhla	12 MGD	Inlet	7.4	268	218	512	4	40	3
		outlet	7.6	47	29	112	2	42	2
	Real Time Reading at Outlet		7.8	31.61	26.71	121.6		16.16	
	45 MGD	Inlet	7.3	254	178	488	4	42	3.2
		outlet	7.7	22	17	64	1	33	0.6
	Real Time Reading at Outlet		7.7	34	22.64	83.8		28.53	
	37 MGD	Inlet	7.3	254	178	488	4	42	3.2
		outlet	7.6	46	24	104	2	35	0.8
	Real Time Reading at Outlet		7.5	23.62	17.41	93.16		30.1	
	16 MGD	Inlet	7.3	254	178	488	4	42	3.2
outlet		7.7	31	19	72	Nil	36	1.5	
Real Time Reading at Outlet		7.31	34.38	9.45	81.51		12.76		
Kondli	25 MGD Phase-II	Inlet	7.2	280	154	304	-	41	6.5
		outlet	7.6	17	13	32	-	30	3
	Real Time Reading at Outlet		7.4	22	28	83		23.38	
	45 MGD Phase-IV	Inlet	7.1	274	162	288	-	43	6.9
		outlet	7.5	28	17	64	-	35	4.3
Real Time Reading at Outlet		7.7	27	15	40		16.67		
Chilla	9 MGD	Inlet	7.2	184	131	228	-	46	6.8
		outlet	7.6	9	3.6	24	-	0.32	4.2
	Real Time Reading at Outlet		7	13	3.15	18		6.36	
CWG Village	1 MGD	Inlet	7.1	884	432	768	-	26	5.2
		outlet	7.7	1	0.28	0.8	-	0.18	1.6
	Real Time Reading at Outlet		7.7	0.15	0.11	1.48		0.08	
Yamuna Vihar	10 MGD Phase-I	Inlet	6.8	480	223	-	-	65	6.5
		outlet	7.8	30	19	-	-	40	3.5
	Real Time Reading at Outlet		7.5	40	35	115		15	
	10 MGD Phase-II	Inlet	7.5	284	195	-	-	55	6
		outlet	8.1	40	26	-	-	35	3
	Real Time Reading at Outlet								
	25 MGD Phase-III	Inlet	7.5	368	213	-	-	60	5.5
outlet		7.7	30	20	-	-	30	2.5	
Real Time Reading at Outlet		7.3	68	20	83		25		
Rithala	40 MGD	Inlet	7.1	272	147	410	-	31	1
		outlet	7.9	29	16	80	-	28	0.9
	Real Time Reading at Outlet		7.22	656.48	65.55	427		35.38	
	40 MGD	Inlet	7.1	272	147	410	-	31	1
		Outlet	7.6	16	12	50	-	13	0.6
Real Time Reading at Outlet		7.65	17.94	14.54	63.1		15.63		
Rohiini 15 MGD	15 MGD	Inlet	7.6	464	360	-	-	48	10.5
		Outlet	8	26	15	-	-	12	5
	Real Time Reading at Outlet		7.1	22.8	8.89	88.6		11.39	

Keshopur	12 MGD	Inlet	7.3	244	179	496	-	29	3.3
		outlet	7.7	11	7	32	-	8	1.8
	Real Time Reading at Outlet		7.57	7.82	2.3	17.42	-	7.78	-
	40 MGD	Inlet	7.2	288	204	640	-	30	3.4
		outlet	7.5	102	125	320	-	28	2.7
	Real Time Reading at Outlet		6.52	235.69	104.71	291.02	-	32.9	-
20 MGD	Inlet	7.2	288	204	640	-	30	3.4	
	outlet	7.6	110	103	280	-	28	2.9	
Real Time Reading at Outlet		NA	NA	NA	NA	NA	NA	NA	
Nilothi	40 MGD Phase-I	Inlet	7.2	160	128	460	-	28	2.8
		outlet	7.4	38	21	92	-	20	2.4
	Real Time Reading at Outlet		NA	NA	NA	NA	NA	NA	NA
	20 MGD Phase-II	Inlet	7.3	308	159	540	9.8	30	3
outlet		7.3	16	14	40	0	12	1.8	
Real Time Reading at Outlet		NA	8.39	2.91	23.74	NA	NA	NA	
Pappankalan	20 MGD Phase-II	Inlet	7.4	375	298	-	-	38	4.4
		outlet	7.8	44	22	-	-	18	0.9
	Real Time Reading at Outlet		7.44	28.43	20.49	133.23	-	27.4	-
	20 MGD Phase-II	Inlet	7.3	295	285	-	14.2	36	4.5
outlet		7.7	8	4	-	0.8	16	3.2	
Real Time Reading at Outlet		7.02	10.99	5.4	30.44	-	1.7	-	
Najafgarh	5 MGD Phase-II	Inlet	7.4	384	270	-	-	40	5
		outlet	7.7	13	7	-	-	6	2
	Real Time Reading at Outlet		7.54	33.83	25.67	73.89	-	21.09	-
Corronation pillar	20 MGD Phase-I & II	Inlet	6.7	272	188	380	8.1	41	2.7
		outlet	7.3	94	56	138	3.1	21	1.4
	Real Time Reading at Outlet		7.1	59	31	132		26	
	10 MGD Phase-III	Inlet	7	310	225	438	-	54	2.9
outlet		7.3	82	52	136	-	37	1.8	
Real Time Reading at Outlet		7.2	61	33	111		23		
Narela	10 MGD Phase-III	Inlet	7.2	130	155	284	7.4	60	2.9
		outlet	7.5	53	40	94	3.2	39	1.6
	Real Time Reading at Outlet		7.1	57	32	112		35	

Dir.(T&QC)



**OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054**



Name of the Plant	Capacity (in MGD)	02.07.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
		50	30	250
Okhla	12 MGD	47	29	112
	45 MGD	22	17	64
	37 MGD	46	24	104
	16 MGD	31	19	72
Kondli	25 MGD	17	13	32
	45 MGD	28	17	64
Chilla	9 MGD	9	3.6	24
CWG Village	1 MGD	1	0.28	0.8
Yamuna Vihar	10 MGD	30	19	-
	10 MGD	40	26	-
	25 MGD	30	20	-
Rithala	40 MGD	29	16	80
	40 MGD	16	12	50
Rohiini	15 MGD	26	15	-
Keshopur	12 MGD	11	7	32
	40 MGD	102	125	320
	20 MGD	110	103	280
Nilothi	40 MGD	38	21	92
	20 MGD	16	14	40
Najafgarh	5 MGD	13	7	-
Pappankalan	20 MGD	44	22	-
	20 MGD	8	4	-
Corronation pillar	20 MGD	94	56	138
	10 MGD	82	52	136
Narela	10 MGD	53	40	94



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	Parameters of STPs of Delhi as on					03.07.2019		
		Parameter							
		DPPC limits	pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
Okhla	12 MGD	Inlet	7.2	284	215	432	5	40	1.8
		outlet	7.6	43	25	96	3	38	0.5
	Real Time Reading at Outlet		6.98	31.04	26.34	120.16		20.74	
	45 MGD	Inlet	7.2	340	240	480	6	43	2.6
		outlet	7.8	24	14	64	2	36	0.5
	Real Time Reading at Outlet		7.52	31.05	22.19	122.7		30.1	
	37 MGD	Inlet	7.2	340	240	480	6	43	2.6
		outlet	7.6	26	20	72	2	35	Nil
Real Time Reading at Outlet		7.6	33.35	22.26	81.91		29.64		
16 MGD	Inlet	7.2	340	240	480	6	43	2.6	
	outlet	7.6	26	15	64	1	36	0.3	
Real Time Reading at Outlet		7.58	18.47	12.51	65.97		30.33		
Kondli	25 MGD Phase-II	Inlet	7.2	304	181	344	-	42	6.6
		outlet	7.6	15	9	35	-	32	2.8
	Real Time Reading at Outlet		7.4	21	12	44		22.97	
	45 MGD Phase-IV	Inlet	7.2	270	165	328	-	40.56	6.8
outlet		7.5	27	15	58	-	33.67	3.7	
Real Time Reading at Outlet		7.8	28	15	42		7.04		
Chilla	9 MGD	Inlet	7.2	152	121	216	-	44.08	6.5
		outlet	7.6	8	3.1	21	-	0.34	3.8
	Real Time Reading at Outlet		7.2	9	3	18		6.27	
CWG Village	1 MGD	Inlet	7.1	736	397	784	-	22.89	5.3
		outlet	7.7	1	0.27	0.2	-	0.12	1.8
	Real Time Reading at Outlet		7.7	0.16	0.12	1.43		0.09	
Yamuna Vihar	10 MGD Phase-I	Inlet	7.4	316	197	-	-	65	6
		outlet	7.5	44	25	-	-	35	2.5
	Real Time Reading at Outlet		7.4	43	51	164		13	
	10 MGD Phase-II	Inlet	7.4	248	183	-	-	70	6.5
		outlet	7.6	37	24	-	-	40	2.5
	Real Time Reading at Outlet								
25 MGD Phase-III	Inlet	7.3	236	187	-	-	60	6	
	outlet	7.5	23	20	-	-	30	3	
Real Time Reading at Outlet		7.4	40	35	115		15		
Rithala	40 MGD	Inlet	7.1	256	156	310	-	36	1.4
		outlet	8	28	16	80	-	24	1.1
	Real Time Reading at Outlet		7.18	52.6	9.09	61.01		39.81	
	40 MGD	Inlet	7.1	256	156	310	-	36	1.4
Outlet		7.8	18	13	60	-	17	0.8	
Real Time Reading at Outlet		7.65	17.91	14.89	63.37		15.63		
Rohiini 15 MGD	15 MGD	Inlet	7.5	424	278	627	-	45	7.5
		Outlet	7.9	25	14	124	-	14	5
	Real Time Reading at Outlet		7.1	22.96	8.97	89.34		11.36	

Keshopur	12 MGD	Inlet	7.3	272	187	-	-	30	3.1
		outlet	7.7	14	8	-	-	4	1.6
	Real Time Reading at Outlet		7.68	7.71	2.27	17.17	-	7.42	-
	40 MGD	Inlet	7.2	328	192	-	-	33	3.4
		outlet	7.5	102	103	-	-	31	2.9
	Real Time Reading at Outlet		6.59	280.84	102.22	306.33	-	29.6	-
20 MGD	Inlet	7.2	328	192	-	-	33	3.4	
	outlet	7.5	80	69	-	-	28	3	
Real Time Reading at Outlet		7.69	83.88	48.93	147.25	-	38.63	-	
Nilothi	40 MGD Phase-I	Inlet	7.3	156	126	-	-	25	2.5
		outlet	7.5	34	22	-	-	18	2
Real Time Reading at Outlet		NA	NA	NA	NA	NA	NA	NA	
Pappankalan	20 MGD Phase-II	Inlet	7.4	285	225	560	-	36	4.6
		outlet	7.8	21	20	136	-	17	0.6
	Real Time Reading at Outlet		7.6	32.59	21.15	135.07	-	18	-
	20 MGD Phase-II	Inlet	7.4	233	260	600	-	35	4.4
		outlet	7.8	9	8	80	-	16	3
Real Time Reading at Outlet		7.03	12.95	12.94	45.18	-	1.84	-	
Najafgarh	5 MGD Phase-II	Inlet	7.4	394	192	460	-	42	4.8
		outlet	7.8	16	14	88	-	8	2.2
Real Time Reading at Outlet		7.53	33.8	26.15	74.83	-	21.52	-	
Corronation pillar	20 MGD Phase-I & II	Inlet	7	232	178	346	-	36	2.5
		outlet	7.4	78	53	120	-	20	1.3
	Real Time Reading at Outlet		7.1	59	31	132		27	
	10 MGD Phase-III	Inlet	6.9	372	275	436	8.2	51	3.2
		outlet	7.4	69	50	126	3.2	33	1.9
Real Time Reading at Outlet		7.3	68	37	125		22		

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	03.07.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
		50	30	250
Okhla	12 MGD	43	25	96
	45 MGD	24	14	64
	37 MGD	26	20	72
	16 MGD	26	15	64
Kondli	25 MGD	15	9	35
	45 MGD	27	15	58
Chilla	9 MGD	8	3.1	21
CWG Village	1 MGD	1	0.27	0.2
Yamuna Vihar	10 MGD	44	25	-
	10 MGD	37	24	-
	25 MGD	23	20	-
Rithala	40 MGD	28	16	80
	40 MGD	18	13	60
Rohiini	15 MGD	25	14	124
Keshopur	12 MGD	14	8	-
	40 MGD	102	103	-
	20 MGD	80	69	-
Nilothi	40 MGD	34	22	-
Najafgarh	5 MGD	16	14	88
Pappankalan	20 MGD	21	20	136
	20 MGD	9	8	80
Corronation pillar	20 MGD	78	53	120
	10 MGD	69	50	126



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	Parameters of STPs of Delhi as on					04.07.2019		
		Parameter							
		DPPC limits	pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
Okhla	12 MGD	Inlet	7.3	216	180	320	2	38	2.2
		outlet	7.7	41	28	104	Nil	35	0.5
	Real Time Reading at Outlet								
	45 MGD	Inlet	7.4	256	188	344	2	40	2.2
		outlet	7.7	32	19	72	Nil	33	2
	Real Time Reading at Outlet		7.7	39.43	22.9	89.13		27.45	
	37 MGD	Inlet	7.4	256	188	344	2	40	2.2
		outlet	7.7	32	20	72	Nil	30	1.5
	Real Time Reading at Outlet		7.6	25.4	12	69.39		30.48	
	16 MGD	Inlet	7.4	256	188	344	2	40	2.2
outlet		7.7	37	21	88	Nil	32	Nil	
Real Time Reading at Outlet		7.3	20.16	10.29	49.21		12.14		
Kondli	25 MGD Phase-II	Inlet	7.2	330	240	-	-	40	6.9
		outlet	7.7	13	8	-	-	31	3
	Real Time Reading at Outlet		7.4	21	9	36		22	
	45 MGD Phase-IV	Inlet	7.2	322	219	-	-	39	6.6
		outlet	7.5	26	16	-	-	33	4.2
Real Time Reading at Outlet		7.6	28	15	42		18		
Chilla	9 MGD	Inlet	7.2	280	153	328	-	40	6.9
		outlet	7.6	7	3.4	16	-	0.27	4.7
	Real Time Reading at Outlet		7.2	10	3.4	18		6.33	
CWG Village	1 MGD	Inlet	7.2	396	242	413	-	25	4.6
		outlet	7.6	Bdl	Bdl	0.4	-	0.1	1.4
	Real Time Reading at Outlet		7.7	0.15	0.12	1.4		0.09	
Yamuna Vihar	10 MGD Phase-I	Inlet	7.2	252	178	762	-	55	6.5
		outlet	7.6	45	28	30	-	35	3.5
	Real Time Reading at Outlet		7.4	42	35	117		18	
	10 MGD Phase-II	Inlet	7.4	236	180	710	-	60	5
		outlet	7.7	29	24	90	-	35	2.5
	Real Time Reading at Outlet								
25 MGD Phase-III	Inlet	7.3	212	170	610	-	50	5.5	
	outlet	7.7	34	22	98	-	30	3	
Real Time Reading at Outlet		7.4	39	20	72		25		
Rithala	40 MGD	Inlet	7	264	15	360	-	31	1.1
		outlet	7.9	32	17	90	-	22	0.9
	Real Time Reading at Outlet		6.99	41.24	10.51	58.43		62.61	
	40 MGD	Inlet	7	264	15	360	-	31	1.1
		Outlet	7.6	24	13	60	-	12	0.6
Real Time Reading at Outlet		7.69	17.14	16.14	64.34		13.71		
Rohiini 15 MGD	15 MGD	Inlet	7.4	340	218	-	-	48	8
		Outlet	7.8	27	15	-	-	15	4
	Real Time Reading at Outlet		7.04	22.82	9.02	89.05		11.65	

Keshopur	12 MGD	Inlet	7.4	196	167	533	-	29	3.1
		outlet	7.7	12	6	28	-	5	1.2
	Real Time Reading at Outlet		7.66	8.51	2.6	19.68	-	7.23	-
	40 MGD	Inlet	7.3	308	208	600	-	33	3.4
		outlet	7.6	108	123	300	-	32	3
	Real Time Reading at Outlet		6.64	252.49	104.91	296.88	-	27.3	-
20 MGD	Inlet	7.3	308	208	600	-	33	3.4	
		7.6	102	112	340	-	28	2.9	
	Real Time Reading at Outlet		7.7	77.77	53.07	152.79	-	25.42	-
Nilothi	40 MGD Phase-I	Inlet	7.3	138	127	-	-	26	3
		outlet	7.4	36	25	-	-	19	2.5
	Real Time Reading at Outlet		NA	NA	NA	NA	NA	NA	NA
Pappankalan	20 MGD Phase-II	Inlet	7.2	326	258	-	14.2	38	5.2
		outlet	7.6	40	30	-	2	12	0.8
	Real Time Reading at Outlet		7.6	34.42	22.62	137.95	-	12.2	-
	20 MGD Phase-II	Inlet	7.4	262	230	-	-	39	5
		outlet	7.6	7	6	-	-	10	2
Real Time Reading at Outlet		NA	NA	NA	NA	NA	NA	-	
Najafgarh	5 MGD Phase-II	Inlet	7.2	158	122	-	-	18	3.5
		outlet	7.6	17	13	-	-	10	4.2
	Real Time Reading at Outlet		7.35	33.98	27.1	77.98	-	20.1	-
Corronation pillar	20 MGD Phase-I & II	Inlet	6.9	276	185	356	8.3	38	2.4
		outlet	7.3	62	42	118	3.2	23	1.4
	Real Time Reading at Outlet		7.2	59	31	132		27	
	10 MGD Phase-III	Inlet	7	390	310	508	-	52	2.8
		outlet	7.4	84	54	134	-	32	2
Real Time Reading at Outlet		7.3	76	42	145		22		

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	04.07.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
		50	30	250
Okhla	12 MGD	41	28	104
	45 MGD	32	19	72
	37 MGD	32	20	72
	16 MGD	37	21	88
Kondli	25 MGD	13	8	-
	45 MGD	26	16	-
Chilla	9 MGD	7	3.4	16
CWG Village	1 MGD	Bdl	Bdl	0.4
Yamuna Vihar	10 MGD	45	28	30
	10 MGD	29	24	90
	25 MGD	34	22	98
Rithala	40 MGD	32	17	90
	40 MGD	24	13	60
Rohiini	15 MGD	27	15	-
Keshopur	12 MGD	12	6	28
	40 MGD	108	123	300
	20 MGD	102	112	340
Nilothi	40 MGD	36	25	-
Najafgarh	5 MGD	17	13	-
Pappankalan	20 MGD	40	30	-
	20 MGD	7	6	-
Corronation pillar	20 MGD	62	42	118
	10 MGD	84	54	134