



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Parameters of STPs of Delhi as on							03.08.2019		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Okhla	12 MGD	Inlet	7.2	227	185	376	3	40	3
		outlet	7.6	43	29	112	Nil	36	0.8
	Real Time Reading at Outlet								
	45 MGD	Inlet	7.3	228	183	360	3	43	2.8
		outlet	7.7	39	23	104	Nil	38	0.5
	Real Time Reading at Outlet								
	37 MGD	Inlet	7.3	228	183	360	3	43	2.8
		outlet	7.6	28	18	72	Nil	39	1
	Real Time Reading at Outlet								
	16 MGD	Inlet	7.3	228	183	360	3	43	2.8
		outlet	7.6	30	20	80	Nil	37	Nil
	Real Time Reading at Outlet								
Kondli	25 MGD Phase-II	Inlet	7.3	346	199	378	-	40	6
		outlet	7.7	13	7	28	-	33	2.9
	Real Time Reading at Outlet		7.4	15	10	30		26.53	
	45 MGD Phase-IV	Inlet	7.3	316	183	346	-	40	7.1
		outlet	7.5	30	18	61	-	33	4.2
	Real Time Reading at Outlet		7.9	31	21	63		74.88	
Yamuna Vihar	10 MGD Phase-I	Inlet	7.3	408	212	-	-	40	5
		outlet	7.6	34	21	-	-	10	2
	Real Time Reading at Outlet		7.3	52	91	326		10	
	10 MGD Phase-II	Inlet	7.2	552	213	-	-	45	5.5
		outlet	7.6	23	19	-	-	20	1.5
	Real Time Reading at Outlet								
	25 MGD Phase-III	Inlet	7.2	1012	254	-	-	35	7
		outlet	7.6	37	28	-	-	30	3.5
Real Time Reading at Outlet									
Rithala	40 MGD	Inlet	7	312	138	280	-	27	0.8
		outlet	7.5	26	16	70	-	22	0.7
	Real Time Reading at Outlet		7.25	10.09	10.61	62.25		14.8	
	40 MGD	Inlet	7	312	138	280	-	27	0.8
		Outlet	7.6	16	11	50	-	14	0.5
Real Time Reading at Outlet		7.53	62.4	16.47	80.45		22.55		
Rohiini 15 MGD	15 MGD	Inlet	7.4	248	185	-	-	54	9
		Outlet	7.7	36	21	-	-	16	4
	Real Time Reading at Outlet		7.17	25.25	12.23	108.14		12.12	
Keshopur	12 MGD	Inlet	7.3	312	151	-	-	27	2
		outlet	7.7	10	6	-	-	3	1.7
	Real Time Reading at Outlet		NA	NA	NA	NA	-	NA	-
	40 MGD	Inlet	7.3	384	138	-	-	25	2.2
		outlet	7.4	72	103	-	-	28	1.9
Real Time Reading at Outlet		7.06	342.45	95.75	355.56	-	29.2	-	

	20 MGD	Inlet	7.3	384	138	-	-	25	2.2
		outlet	7.6	94	91	-	-	20	2
	Real Time Reading at Outlet		7.72	165.65	80.7	280.59	-	21.1	-
Nilothi	40 MGD Phase-I	Inlet	7.3	298	103	-	-	26	3.4
		outlet	7.6	32	22	-	-	17	2.8
	Real Time Reading at Outlet		7.32	31.32	24.57	104.19	-	20.92	-
Pappankalan	20 MGD Phase-II	Inlet	7.3	391	193	-	-	24	4.5
		outlet	7.5	33	24	-	-	13	0.8
	Real Time Reading at Outlet		NA	NA	NA	NA	-	NA	-
	20 MGD Phase-II	Inlet	7.3	576	275	-	-	20	4
		outlet	7.5	6	4	-	-	0.8	1
	Real Time Reading at Outlet		6.96	11.87	4.74	32.4	-	1.52	-
Corronation pillar	20 MGD Phase-I & II	Inlet	6.9	220	225	316	8	35	1.7
		outlet	7.3	59	46	96	2.9	21	0.6
	Real Time Reading at Outlet		7.2	59	31	133		27	
	10 MGD Phase-III	Inlet	7	254	245	-	-	59	2.5
		outlet	7.5	68	49	-	-	38	1.3
	Real Time Reading at Outlet		7.6	111	47			12	

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	03.08.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC limits	50	30	250
Okhla	12 MGD	43	29	112
	45 MGD	39	23	104
	37 MGD	28	18	72
	16 MGD	30	20	80
Kondli	25 MGD	13	7	28
	45 MGD	30	18	61
Yamuna Vihar	10 MGD	34	21	-
	10 MGD	23	19	-
	25 MGD	37	28	-
Rithala	40 MGD	26	16	70
	40 MGD	16	11	50
Rohiini	15 MGD	36	21	-
Keshopur	12 MGD	10	6	-
	40 MGD	72	103	-
	20 MGD	94	91	-
Nilothi	40 MGD	32	22	-
Pappankalan	20 MGD	33	24	-
	20 MGD	6	4	-
Corronation pillar	20 MGD	59	46	96
	10 MGD	68	49	-



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Parameters of STPs of Delhi as on							04.08.2019		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Okhla	12 MGD	Inlet	7.3	256	195	448	2	36	2
		outlet	7.6	39	23	96	1	31	0.4
	Real Time Reading at Outlet								
	45 MGD	Inlet	7.3	264	177	456	3	37	2.2
		outlet	7.7	35	20	80	1	35	0.6
	Real Time Reading at Outlet								
	37 MGD	Inlet	7.3	264	177	456	3	37	2.2
		outlet	7.6	30	18	72	1	34	0.8
	Real Time Reading at Outlet								
	16 MGD	Inlet	7.3	264	177	456	3	37	2.2
		outlet	7.7	28	17	64	Nil	30	Nil
	Real Time Reading at Outlet								
Kondli	25 MGD Phase-II	Inlet	7.2	292	165	301	-	39	6.4
		outlet	7.6	15	9	32	-	30	3.1
	Real Time Reading at Outlet								
	45 MGD Phase-IV	Inlet	7.2	276	154	298	-	41	7
		outlet	7.5	29	16	60	-	33	4.1
	Real Time Reading at Outlet		7.8	34	62	62		90.42	
Yamuna Vihar	10 MGD Phase-I	Inlet	7.4	212	195	-	-	60	5.5
		outlet	7.6	21	23	-	-	40	4.5
	Real Time Reading at Outlet		7.4	53	111	388		10	
	10 MGD Phase-II	Inlet	7.2	268	191	-	-	50	5
		outlet	7.6	25	19	-	-	45	2
	Real Time Reading at Outlet								
	25 MGD Phase-III	Inlet	7.4	864	327	-	-	45	4.5
		outlet	7.6	39	25	-	-	30	3
Real Time Reading at Outlet		7.3	40	26	83		25		
Rithala	40 MGD	Inlet	7.1	228	162	320	-	28	0.7
		outlet	7.7	25	15	80	-	26	0.4
	Real Time Reading at Outlet								
	40 MGD	Inlet	7.1	228	162	320	-	28	0.7
		Outlet	7.5	19	13	50	-	18	0.3
Real Time Reading at Outlet									
Rohiini 15 MGD	15 MGD	Inlet	7.2	168	138	461		49	9.5
		Outlet	7.6	25	14	88		15	2.5
	Real Time Reading at Outlet		7.58	31.68	14.66	139.23		8.42	
Keshopur	12 MGD	Inlet	7.4	118	94	-	-	24	1.7
		outlet	7.7	7	4	-	-	2	1.5
	Real Time Reading at Outlet		NA	NA	NA	NA	NA	NA	NA
	40 MGD	Inlet	7.4	148	119	-	-	24	2
		outlet	7.5	64	66	-	-	22	1.7
Real Time Reading at Outlet		NA	NA	NA	NA	NA	NA	NA	

	20 MGD	Inlet	7.4	148	119	-	-	24	2
		outlet	7.5	68	68	-	-	20	1.4
	Real Time Reading at Outlet		NA	NA	NA	NA	NA	NA	NA
Nilothi	40 MGD Phase-I	Inlet	7.3	326	122	-	-	28	2.8
		outlet	7.5	30	22	-	-	14	2.2
	Real Time Reading at Outlet		NA	NA	NA	NA	NA	NA	NA
Pappankalan	20 MGD Phase-II	Inlet	7.3	410	235	-	-	30	4.5
		outlet	7.6	32	23	-	-	8	0.8
	Real Time Reading at Outlet		NA	NA	NA	NA	NA	NA	NA
	20 MGD Phase-II	Inlet	7.3	480	253	-	-	32	4
		outlet	7.6	6	5	-	-	0.6	1
	Real Time Reading at Outlet		6.96	9.8	1.89	24.62	-	1.52	-
Corronation pillar	20 MGD Phase-I & II	Inlet	7	250	210	350	-	38	1.9
		outlet	7.4	64	49	110	-	28	0.8
	Real Time Reading at Outlet		7.2	59	31	133		25	
	10 MGD Phase-III	Inlet	7.1	295	265	416	-	57	2.7
		outlet	7.5	66	46	108	-	40	2.8
	Real Time Reading at Outlet		7.6	115	47	192		12	

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	04.08.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC limits	50	30	250
Okhla	12 MGD	39	23	96
	45 MGD	35	20	80
	37 MGD	30	18	72
	16 MGD	28	17	64
Kondli	25 MGD	15	9	32
	45 MGD	29	16	60
Yamuna Vihar	10 MGD	21	23	-
	10 MGD	25	19	-
	25 MGD	39	25	-
Rithala	40 MGD	25	15	80
	40 MGD	19	13	50
Rohiini	15 MGD	25	14	88
Keshopur	12 MGD	7	4	-
	40 MGD	64	66	-
	20 MGD	68	68	-
Nilothi	40 MGD	30	22	-
Pappankalan	20 MGD	32	23	-
	20 MGD	6	5	-
Corronation pillar	20 MGD	64	49	110
	10 MGD	66	46	108



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Parameters of STPs of Delhi as on							05.08.2019		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Okhla	12 MGD	Inlet	7.1	426	225	416	4	40	2
		outlet	7.7	43	26	112	2	38	1.8
	Real Time Reading at Outlet								
	45 MGD	Inlet	7.2	312	210	416	3	43	2.5
		outlet	7.4	48	28	112	Nil	38	0.8
	Real Time Reading at Outlet								
	37 MGD	Inlet	7.2	312	210	416	3	43	2.5
		outlet	7.6	49	29	120	1	40	2.8
	Real Time Reading at Outlet								
	16 MGD	Inlet	7.2	312	210	416	3	43	2.5
		outlet	7.6	25	17	64	Nil	40	Nil
	Real Time Reading at Outlet								
	New 30 MGD	Inlet	7.4	482	215	432	-	42	2.2
		Outlet	7.4	5	4	16	-	4	2
	Real Time Reading at Outlet								
Molarbund	0.66 MGD	Inlet	7.4	486	370	768	-	45	4
		outlet	7.8	10	8	32	-	10	2.5
	Real Time Reading at Outlet								
Delhi Gate-I	2.2 MGD	Inlet	7.4	166	151	304	3	35	2.8
		outlet	7.5	3	5	16	Nil	4	Nil
	Real Time Reading at Outlet								
Delhi Gate-II	15 MGD	Inlet	7.4	146	153	288	-	33	2.5
		outlet	7.6	9	10	40	-	5	0.5
	Real Time Reading at Outlet								
Sen Nursing Home	2.2 MGD	Inlet	7.2	322	195	408	3	40	3
		outlet	7.5	7	10	40	Nil	3	Nil
	Real Time Reading at Outlet								
Kondli	25 MGD Phase-II	Inlet	7.3	330	203	373	-	41	6.5
		outlet	7.8	13	7	26	-	26	2.7
	Real Time Reading at Outlet		7.4	15	7	21	-	24.78	
	45 MGD Phase-IV	Inlet	7.3	254	173	262	-	42	7.1
		outlet	7.6	25	15	56	-	31	4.6
Real Time Reading at Outlet		8.3	24	14	34		31		
Yamuna Vihar	10 MGD Phase-I	Inlet	7.3	336	228	860	7.2	40	7.5
		outlet	7.6	34	26	86	3.6	30	5
	Real Time Reading at Outlet		7.3	54	111	388		10	
	10 MGD Phase-II	Inlet	7.2	436	270	910	10.4	35	7
		outlet	7.5	18	11	68	3.6	25	4.5

	Real Time Reading at Outlet								
	25 MGD Phase-III	Inlet	7.4	764	332	1210	8	35	6.5
		outlet	7.5	37	21	128	4.3	20	3
	Real Time Reading at Outlet		7.5	39	22	78		24	
Rithala	40 MGD	Inlet	7	264	168	340	-	30	0.9
		outlet	7.8	27	16	80	-	27	0.5
	Real Time Reading at Outlet		7.53	68.14	17.83	84.07		19.71	
	40 MGD	Inlet	7	264	168	340	-	30	0.9
		Outlet	7.7	17	12	60	-	16	0.4
	Real Time Reading at Outlet		7.75	18	11.3	62.58		14.82	
Keshopur	12 MGD	Inlet	7.4	312	191	667	-	25	2.7
		outlet	7.7	9	5	28	-	4	1.7
	Real Time Reading at Outlet		NA	NA	NA	NA	NA	NA	NA
	40 MGD	Inlet	7.4	304	200	640	-	26	2.6
		outlet	7.4	86	109	282	-	24	2.2
	Real Time Reading at Outlet		7	373.09	101.4	363.12	-	34	-
	20 MGD	Inlet	7.4	304	200	640	-	26	2.6
		outlet	7.6	86	53	240	-	21	2
	Real Time Reading at Outlet		NA	NA	NA	NA	NA	NA	NA
Nilothi	40 MGD Phase-I	Inlet	7.2	314	112	-	5.4	28	3.2
		outlet	7.5	27	19	-	0.7	17	2.5
	Real Time Reading at Outlet		7.23	31.07	25.07	105.25	-	20.27	-
Pappankalan	20 MGD Phase-II	Inlet	7.2	419	251	520	-	26	4.2
		outlet	7.5	32	24	90	-	8	0.8
	Real Time Reading at Outlet		NA	NA	NA	NA	NA	NA	NA
	20 MGD Phase-II	Inlet	7.3	511	308	-	-	27	3.3
		outlet	7.6	4	3	-	-	0.2	1.2
	Real Time Reading at Outlet		NA	NA	NA	NA	NA	NA	NA
Najafgarh	5 MGD Phase-II	Inlet	7.3	163	139	380	-	28	3.4
		outlet	7.5	17	11	50	-	7	1.4
	Real Time Reading at Outlet								
Corronation pillar	20 MGD Phase-I & II	Inlet	6.9	204	185	346	7.6	30	2
		outlet	7.5	70	50	128	2	20	1
	Real Time Reading at Outlet		7.2	59	31	132		23	
	10 MGD Phase-III	Inlet	7.2	274	270	442	-	48	2.4
		outlet	7.6	78	52	128	-	35	1.3
	Real Time Reading at Outlet		7.4	118	47	194		12	

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	05.08.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC limits	50	30	250
Okhla	12 MGD	43	26	112
	45 MGD	48	28	112
	37 MGD	49	29	120
	16 MGD	25	17	64
	New 30 MGD	5	4	16
Molarbund	0.66 MGD	10	8	32
Delhi Gate-I	2.2 MGD	3	5	16
Delhi Gate-II	15 MGD	9	10	40
Sen Nursing Home	2.2 MGD	7	10	40
Kondli	25 MGD	13	7	26
	45 MGD	25	15	56
Yamuna Vihar	10 MGD	34	26	86
	10 MGD	18	11	68
	25 MGD	37	21	128
Rithala	40 MGD	27	16	80
	40 MGD	17	12	60
Keshopur	12 MGD	9	5	28
	40 MGD	86	109	282
	20 MGD	86	53	240
Nilothe	40 MGD	27	19	-
Najafgarh	5 MGD	17	11	50
Pappankalan	20 MGD	32	24	90
	20 MGD	4	3	-
Corronation pillar	20 MGD	70	50	128
	10 MGD	78	52	128



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Parameters of STPs of Delhi as on							06.08.2019		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Okhla	12 MGD	Inlet	6.9	520	188	392	5	35	3
		outlet	7.4	38	27	112	Nil	28	Nil
	Real Time Reading at Outlet								
	45 MGD	Inlet	7.3	542	210	424	2	35	3.3
		outlet	7.5	42	28	112	Nil	30	Nil
	Real Time Reading at Outlet								
	37 MGD	Inlet	7.3	542	210	424	2	35	3.3
		outlet	7.5	47	29	120	Nil	32	2.5
	Real Time Reading at Outlet								
	16 MGD	Inlet	7.3	542	210	424	2	35	3.3
		outlet	7.6	40	21	88	Nil	34	Nil
	Real Time Reading at Outlet								
	New 30 MGD	Inlet	7.4	394	175	368	1	33	2.5
		Outlet	7.4	5	4	16	Nil	3	1.5
	Real Time Reading at Outlet								
Kondli	25 MGD Phase-II	Inlet	7.3	286	167	352	-	37	5.4
		outlet	7.7	15	9	34	-	28	2.6
	Real Time Reading at Outlet		7.4	15	8	24		26	
	45 MGD Phase-IV	Inlet	7.2	268	158	344	-	45	5.6
		outlet	7.6	23	13	50	-	30	3
	Real Time Reading at Outlet		7.9	39	19	69		52.55	
Yamuna Vihar	10 MGD Phase-I	Inlet	7.2	188	109	-	-	30	5.5
		outlet	7.5	50	24	-	-	20	1.5
	Real Time Reading at Outlet		7.4	38	31	79		60	
	10 MGD Phase-II	Inlet	7.3	238	72	-	-	20	4.5
		outlet	7.6	58	25	-	-	15	2
	Real Time Reading at Outlet								
	25 MGD Phase-III	Inlet	7.2	288	122	-	-	40	4.5
		outlet	7.6	63	39	-	-	30	2.5
Real Time Reading at Outlet		7.4	42	28	89		25		
Rithala	40 MGD	Inlet	7	348	139	260	-	19	0.9
		outlet	7.5	26	16	70	-	13	0.3
	Real Time Reading at Outlet		7.82	51.66	16.66	75.36		12.32	
	40 MGD	Inlet	7	348	139	260	-	19	0.9
		Outlet	7.4	16	11	50	-	11	0.2
Real Time Reading at Outlet									
Keshopur	12 MGD	Inlet	7.3	200	126	-	18.2	14	2.2
		outlet	7.8	9	5	-	0	1	1.6
	Real Time Reading at Outlet		NA	NA	NA	NA		NA	NA
	40 MGD	Inlet	7.3	148	94	-	14.4	18	2.6
		outlet	7.4	106	94	-	6.2	23	2.1
	Real Time Reading at Outlet		6.96	393.83	91.98	342.97	-	37.1	-
	20 MGD	Inlet	7.3	148	94	-	14.4	18	2.6

	20 MGD		outlet	7.6	92	84	-	3.6	21	2
	Real Time Reading at Outlet			NA	NA	NA	NA	NA	NA	NA
Nilothi	40 MGD Phase-I	Inlet	7.1	480	132	510	8.2	20	2.2	
		outlet	7.5	28	20	78	0.8	10	1.6	
	Real Time Reading at Outlet		7.29	30.45	25.22	105.65	-	20.77	-	
	20 MGD Phase-II	Inlet	7.3	266	87	267	-	14	2.3	
		outlet	7.4	10	7	28	-	8	1	
	Real Time Reading at Outlet		NA	NA	NA	NA	NA	NA	NA	
Pappankalan	20 MGD Phase-II	Inlet	7.3	329	175	520	10.2	18	4	
		outlet	7.8	37	23	90	1.2	12	0.6	
	Real Time Reading at Outlet		NA	NA	NA	NA	NA	NA	NA	
	20 MGD Phase-II	Inlet	7.2	325	185	-	9.9	18	3.2	
		outlet	7.6	5	4	-	0	1.8	1	
	Real Time Reading at Outlet		6.95	9.84	4.84	29.52	-	1.48	-	
Najafgarh	5 MGD Phase-II	Inlet	7.2	220	158	480	-	22	3.2	
		outlet	7.7	14	13	50	-	2.2	1.2	
	Real Time Reading at Outlet		7.48	33.93	31.93	90.38	-	18.21	-	
Corronation pillar	20 MGD Phase-I & II	Inlet	7	214	190	386	-	28	1.8	
		outlet	7.4	59	45	112	-	18	0.7	
	Real Time Reading at Outlet		7.2	59	31	133		24		
	10 MGD Phase-III	Inlet	7.1	258	265	414	8	46	2.2	
		outlet	7.5	62	48	104	3.1	34	1.2	
	Real Time Reading at Outlet		7.5	114	45	184		10		
Narela	10 MGD Phase-III	Inlet	7	162	165	254	7	52	2.4	
		outlet	7.5	47	39	92	2.1	33	1.4	
	Real Time Reading at Outlet		7.8	57	32	112		3		

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	06.08.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC limits	50	30	250
Okhla	12 MGD	38	27	112
	45 MGD	42	28	112
	37 MGD	47	29	120
	16 MGD	40	21	88
	New 30 MGD	5	4	16
Kondli	25 MGD	15	9	34
	45 MGD	23	13	50
Yamuna Vihar	10 MGD	50	24	-
	10 MGD	58	25	-
	25 MGD	63	39	-
Rithala	40 MGD	26	16	70
	40 MGD	16	11	50
Keshopur	12 MGD	9	5	-
	40 MGD	106	94	-
	20 MGD	92	84	-
Nilothi	40 MGD	28	20	78
	20 MGD	10	7	28
Najafgarh	5 MGD	14	13	50
Pappankalan	20 MGD	37	23	90
	20 MGD	5	4	-
Corronation pillar	20 MGD	59	45	112
	10 MGD	62	48	104
Narela	10 MGD	47	39	92



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Parameters of STPs of Delhi as on							07.08.2019		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Okhla	12 MGD	Inlet	7.2	316	185	392	1	42	2.8
		outlet	7.6	33	21	80	Nil	35	0.8
	Real Time Reading at Outlet								
	45 MGD	Inlet	7.3	329	200	400	2	40	2.6
		outlet	7.6	34	24	88	Nil	33	0.5
	Real Time Reading at Outlet								
	37 MGD	Inlet	7.3	329	200	400	2	40	2.6
		outlet	7.6	31	21	80	Nil	34	2.5
	Real Time Reading at Outlet								
	16 MGD	Inlet	7.3	329	200	400	2	40	2.6
		outlet	7.6	28	19	72	Nil	33	Nil
	Real Time Reading at Outlet								
	New 30 MGD	Inlet	7.4	468	228	424	2	42	2.6
		Outlet	7.6	5	4	16	Nil	6	1.5
Real Time Reading at Outlet									
Kondli	25 MGD Phase-II	Inlet	7.3	354	200	376	-	40	5.1
		outlet	7.6	11	7	31	-	15	2.9
	Real Time Reading at Outlet		7.5	14	6	19		24.32	
	45 MGD Phase-IV	Inlet	7.3	378	228	390	-	41	5.3
		outlet	7.5	25	14	62	-	27	3.4
	Real Time Reading at Outlet		8	23	12	28		53.31	
Yamuna Vihar	10 MGD Phase-I	Inlet	7.2	256	189	-	-	40	4.5
		outlet	7.6	29	17	-	-	20	2.5
	Real Time Reading at Outlet		7.3	38	31	73		57	
	10 MGD Phase-II	Inlet	7.3	296	177	-	-	35	5.5
		outlet	7.5	16	10	-	-	15	3
	Real Time Reading at Outlet								
	25 MGD Phase-III	Inlet	7.4	380	239	-	-	45	6
		outlet	7.5	35	19	-	-	30	3.5
Real Time Reading at Outlet									
Rithala	40 MGD	Inlet	7	260	153	290	-	22	0.8
		outlet	7.5	31	18	80	-	14	0.5
	Real Time Reading at Outlet		8	55.41	13.87	72.03		10.49	
	40 MGD	Inlet	7	260	153	290	-	22	0.8
		Outlet	7.5	17	13	60	-	11	0.3
Real Time Reading at Outlet		7.09	17.77	11.65	62.05		14.48		
Keshopur	12 MGD	Inlet	7.5	248	159	-	-	24	2.6
		outlet	7.8	8	5	-	-	0	1.7
	Real Time Reading at Outlet		NA	NA	NA	NA	NA	NA	NA
	40 MGD	Inlet	7.4	302	199	-	-	23	2.4
		outlet	7.4	92	89	-	-	22	2.4
	Real Time Reading at Outlet		6.97	353.06	93.25	337.77	-	37	-
30 MGD	Inlet	7.4	302	199	-	-	23	2.4	
	outlet	7.4	92	89	-	-	22	2.4	

	20 MGD		outlet	7.6	86	80	-	-	19	2
	Real Time Reading at Outlet			NA	NA	NA	NA	NA	NA	NA
Nilothi	40 MGD Phase-I	Inlet	7.2	250	117	-	-	22	-	-
		outlet	7.4	29	20	-	-	12	-	-
	Real Time Reading at Outlet			7.29	34.43	25.98	107.68	-	19.26	-
Pappankalan	20 MGD Phase-II	Inlet	7.3	306	170	-	-	25	4	
		outlet	7.8	27	20	-	-	10	0.8	
	Real Time Reading at Outlet			NA	NA	NA	NA	NA	NA	NA
	20 MGD Phase-II	Inlet	7.4	562	309	-	-	30	3.4	
		outlet	7.6	6	4	-	-	0.4	1	
	Real Time Reading at Outlet			6.97	10.76	5.7	32.07	-	1.48	-
Najafgarh	5 MGD Phase-II	Inlet	7.3	332	189	-	-	38	3.4	
		outlet	7.5	24	18	-	-	0.6	1.4	
	Real Time Reading at Outlet			7.27	34.04	31.8	90.57	-	18.01	-
Corronation pillar	20 MGD Phase-I & II	Inlet	6.9	298	230	398	8.2	31	2.5	
		outlet	7.5	78	54	142	2.8	19	2.8	
	Real Time Reading at Outlet			7.1	59	31	133		23	
	10 MGD Phase-III	Inlet	7	278	280	482	-	49	2.8	
		outlet	7.4	84	56	152	-	38	2	
	Real Time Reading at Outlet			7.6	159	51	240		9	

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	07.08.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC limits	50	30	250
Okhla	12 MGD	33	21	80
	45 MGD	34	24	88
	37 MGD	31	21	80
	16 MGD	28	19	72
	New 30 MGD	5	4	16
Kondli	25 MGD	11	7	31
	45 MGD	25	14	62
Yamuna Vihar	10 MGD	29	17	-
	10 MGD	16	10	-
	25 MGD	35	19	-
Rithala	40 MGD	31	18	80
	40 MGD	17	13	60
Keshopur	12 MGD	8	5	-
	40 MGD	92	89	-
	20 MGD	86	80	-
Nilothi	40 MGD	29	20	-
Najafgarh	5 MGD	24	18	-
Pappankalan	20 MGD	27	20	-
	20 MGD	6	4	-
Corronation pillar	20 MGD	78	54	142
	10 MGD	84	56	152



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Parameters of STPs of Delhi as on							08.08.2019		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Okhla	12 MGD	Inlet	7.2	230	178	440	4	38	2
		outlet	7.6	44	28	104	1	33	0.5
	Real Time Reading at Outlet								
	45 MGD	Inlet	7.3	270	180	432	4	40	2.3
		outlet	7.6	34	22	88	Nil	33	0.5
	Real Time Reading at Outlet								
	37 MGD	Inlet	7.3	270	180	432	4	40	2.3
		outlet	7.7	40	25	96	Nil	35	1
	Real Time Reading at Outlet								
	16 MGD	Inlet	7.3	270	180	432	4	40	2.3
		outlet	7.8	21	15	56	Nil	35	Nil
	Real Time Reading at Outlet								
	New 30 MGD	Inlet	7.3	268	183	440	3	40	2
		Outlet	7.7	6	4	16	Nil	5	1.8
Real Time Reading at Outlet									
Kondli	25 MGD Phase-II	Inlet	7.3	254	156	280	-	37	6.8
		outlet	7.6	18	11	42	-	15	3.7
	Real Time Reading at Outlet		7.5	17	8	27		22.12	
	45 MGD Phase-IV	Inlet	7.3	318	172	352	-	37	7
		outlet	7.5	27	15	54	-	25	2.9
	Real Time Reading at Outlet		7.9	23	12	28		29.76	
Yamuna Vihar	10 MGD Phase-I	Inlet	7.1	292	189	-	-	45	4.5
		outlet	7.5	33	21	-	-	15	2.5
	Real Time Reading at Outlet		7.3	39	31	72		57	
	10 MGD Phase-II	Inlet	7.2	260	176	-	-	30	5
		outlet	7.6	30	22	-	-	15	3
	Real Time Reading at Outlet								
	25 MGD Phase-III	Inlet	7.2	444	229	-	-	45	5.5
		outlet	7.6	28	21	-	-	25	3
Real Time Reading at Outlet									
Rithala	40 MGD	Inlet	7.1	272	169	390	-	30	1
		outlet	7.6	30	17	80	-	24	0.9
	Real Time Reading at Outlet		7.74	77.05	22.22	95.86		15.45	
	40 MGD	Inlet	7.1	272	169	390	-	30	1
		Outlet	7.5	18	13	70	-	15	0.6
Real Time Reading at Outlet		7.18	17.87	10.23	61.45		14.67		
Keshopur	12 MGD	Inlet	7.3	368	246	-	-	27	3.2
		outlet	7.7	21	12	-	-	2	4.8
	Real Time Reading at Outlet		NA	NA	NA	NA	NA	NA	NA
	40 MGD	Inlet	7.2	384	226	-	-	29	3.6
		outlet	7.5	104	105	-	-	23	3.1
	Real Time Reading at Outlet		7.07	429.7	102.63	393.39	-	37.1	-
	20 MGD	Inlet	7.2	384	226	-	-	29	3.6
outlet		7.5	104	105	-	-	23	3.1	

	20 MGD		outlet	7.5	84	82	-	-	24	3.2
	Real Time Reading at Outlet			NA	NA	NA	NA	NA	NA	NA
Nilothi	40 MGD Phase-I	Inlet	7.3	272	124	-	-	25	2.8	
		outlet	7.5	27	19	-	-	14	2.1	
	Real Time Reading at Outlet		7.34	29.93	25.24	105.6	-	19.45	-	
Pappankalan	20 MGD Phase-II	Inlet	7.3	308	215	-	18	28	4.5	
		outlet	7.8	46	26	-	0.3	12	0.8	
	Real Time Reading at Outlet		7.17	18.95	25.37	75.16	-	17.8	-	
	20 MGD Phase-II	Inlet	7.4	381	255	-	21	30	4	
		outlet	7.6	5	5	-	0	0.2	1	
	Real Time Reading at Outlet		NA	NA	NA	NA	NA	NA	NA	
Najafgarh	5 MGD Phase-II	Inlet	7.3	251	175	-	10	32	3.2	
		outlet	7.8	16	11	-	0.7	0.4	1.2	
	Real Time Reading at Outlet		7.55	34.03	32.91	93.68	-	18.65	-	
Corronation pillar	20 MGD Phase-I & II	Inlet	7.1	264	205	346	-	30	2.3	
		outlet	7.4	70	49	134	-	20	1.2	
	Real Time Reading at Outlet		7.2	59	31	133		23		
	10 MGD Phase-III	Inlet	7.2	288	295	452	7.4	51	2.5	
		outlet	7.5	95	60	160	2.3	40	1.6	
	Real Time Reading at Outlet		6.1	261	42	390		6		

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	08.08.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC limits	50	30	250
Okhla	12 MGD	44	28	104
	45 MGD	34	22	88
	37 MGD	40	25	96
	16 MGD	21	15	56
	New 30 MGD	6	4	16
Kondli	25 MGD	18	11	42
	45 MGD	27	15	54
Yamuna Vihar	10 MGD	33	21	-
	10 MGD	30	22	-
	25 MGD	28	21	-
Rithala	40 MGD	30	17	80
	40 MGD	18	13	70
Keshopur	12 MGD	21	12	-
	40 MGD	104	105	-
	20 MGD	84	82	-
Nilothi	40 MGD	27	19	-
Najafgarh	5 MGD	16	11	-
Pappankalan	20 MGD	46	26	-
	20 MGD	5	5	-
Corronation pillar	20 MGD	70	49	134
	10 MGD	95	60	160



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



		Parameters of STPs of Delhi as on					09.08.2019		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Okhla	12 MGD	Inlet	7.2	294	167	384	5	38	2.2
		outlet	7.6	31	19	72	3	30	0.8
	Real Time Reading at Outlet								
	45 MGD	Inlet	7.3	340	218	400	5	40	2.5
		outlet	7.8	34	21	80	2	35	0.8
	Real Time Reading at Outlet								
	37 MGD	Inlet	7.3	340	218	400	5	40	2.5
		outlet	7.6	27	18	72	1	33	1.2
	Real Time Reading at Outlet								
	16 MGD	Inlet	7.3	340	218	400	5	40	2.5
		outlet	7.6	20	15	56	2	34	0.5
	Real Time Reading at Outlet								
	New 30 MGD	Inlet	7.4	396	245	408	6	40	2.2
		Outlet	7.6	5	4	16	Nil	4	1.5
Real Time Reading at Outlet									
Mehrauli	5 MGD	Inlet	7.5	216	215	360	5	35	2
		outlet	7.6	14	10	40	Nil	20	1
	Real Time Reading at Outlet								
Vasant Kunj	2.2 MGD	Inlet	7.3	316	263	432	6	35	2.8
		outlet	7.6	26	18	72	2	29	2
	Real Time Reading at Outlet								
	3 MGD	Inlet	7.2	204	215	352	7	36	3
		outlet	7.8	15	9	40	1	8	1.8
Real Time Reading at Outlet									
Ghitorni	5 MGD	Inlet	7.5	310	283	496	6	38	2.5
		outlet	7.8	47	27	112	2	27	2
	Real Time Reading at Outlet								
Kondli	25 MGD Phase-II	Inlet	7.3	328	198	362	18	42	6.1
		outlet	7.7	14	9	34	3	19	4.4
	Real Time Reading at Outlet		7.5	15	6.26	21		24.24	
	45 MGD Phase-IV	Inlet	7.3	296	192	312	24	43	6.8
		outlet	7.6	29	16	61	4	31	2
Real Time Reading at Outlet		7.9	25	15	37		80.8		
Yamuna Vihar	10 MGD Phase-I	Inlet	7	252	180	632	-	40	4.5
		outlet	7.6	30	18	96	-	25	2.5
	Real Time Reading at Outlet		7.4	77	360	519		4.3	
	10 MGD Phase-II	Inlet	7.4	256	196	472	-	35	5
		outlet	7.5	20	11	56	-	20	1.5
	Real Time Reading at Outlet		7.5	27	15	51		13	
	25 MGD Phase-III	Inlet	7.4	260	784	-	-	45	5
		outlet	7.7	51	152	-	-	20	3.5
Real Time Reading at Outlet		7.4	28	16	52		25		

Rithala	40 MGD	Inlet	7.1	268	187	410	-	36	1.6
		outlet	7.6	29	18	80	-	22	1.1
	Real Time Reading at Outlet		7.49	31.02	14.96	65.4		24	
	40 MGD	Inlet	7.1	268	187	410	-	36	1.6
		Outlet	7.5	19	14	70	-	16	0.7
	Real Time Reading at Outlet		7.25	20.12	26.13	82.5		14.82	
Keshopur	12 MGD	Inlet	7.3	332	199	573	-	26	3
		outlet	7.6	14	8	30	-	2	4.4
	Real Time Reading at Outlet		NA	NA	NA	NA	NA	NA	NA
	40 MGD	Inlet	7.3	412	229	622	-	30	3.3
		outlet	7.5	110	106	302	-	24	2.8
	Real Time Reading at Outlet		7.14	408.35	102.67	372.35	-	31.6	-
	20 MGD	Inlet	7.3	412	229	622	-	30	3.3
		outlet	7.6	68	81	256	-	26	2.9
	Real Time Reading at Outlet		NA	NA	NA	NA	NA	NA	NA
Nilothi	40 MGD Phase-I	Inlet	7.3	222	119	390	6.6	27	3
		outlet	7.5	24	18	78	0.5	15	2.4
	Real Time Reading at Outlet		7.38	29.66	24.61	104.02	-	17.44	-
	20 MGD Phase-II	Inlet	7.2	308	156	480	-	30	3.2
		outlet	7.4	7	5	30	-	6	2
	Real Time Reading at Outlet		6.95	22.24	2.51	15.55	-	5.32	-
Pappankalan	20 MGD Phase-II	Inlet	7.3	307	196	580	-	28	4.4
		outlet	7.7	26	22	70	-	15	0.3
	Real Time Reading at Outlet		7.23	19.67	42.19	63.68	-	16.9	-
	20 MGD Phase-II	Inlet	7.3	288	183	560	-	30	4.2
		outlet	7.6	8	6	30	-	0.2	3.1
	Real Time Reading at Outlet		6.97	16.87	12.1	52.06	-	1.63	-
Najafgarh	5 MGD Phase-II	Inlet	7.3	320	204	-	-	30	3.8
		outlet	7.6	15	11	-	-	24	3
	Real Time Reading at Outlet		7.72	34.29	34.33	98.18	-	19.38	-
Corronation pillar	20 MGD Phase-I & II	Inlet	7.2	244	200	328	7.9	32	2.6
		outlet	7.5	66	47	112	2.5	22	1.5
	Real Time Reading at Outlet		7.2	59	31	133		25	
	10 MGD Phase-III	Inlet	7.3	262	265	404	-	48	2.4
		outlet	7.6	82	54	142	-	36	1.3
	Real Time Reading at Outlet		7.7	178	62	284		8	
Narela	10 MGD Phase-III	Inlet	7.2	202	180	234	7.3	47	2
		outlet	7.5	48	40	102	2.2	32	1
	Real Time Reading at Outlet		7.6	140	38	169		6	

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	09.08.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC limits	50	30	250
Okhla	12 MGD	31	19	72
	45 MGD	34	21	80
	37 MGD	27	18	72
	16 MGD	20	15	56
	New 30 MGD	5	4	16
Mehrauli	5 MGD	14	10	40
Vasant Kunj	2.2 MGD	26	18	72
	3 MGD	15	9	40
Ghitorni	5 MGD	47	27	112
Kondli	25 MGD	14	9	34
	45 MGD	29	16	61
Yamuna Vihar	10 MGD	30	18	96
	10 MGD	20	11	56
	25 MGD	51	152	-
Rithala	40 MGD	29	18	80
	40 MGD	19	14	70
Keshopur	12 MGD	14	8	30
	40 MGD	110	106	302
	20 MGD	68	81	256
Nilothi	40 MGD	24	18	78
	20 MGD	7	5	30
Najafgarh	5 MGD	15	11	-
Pappankalan	20 MGD	26	22	70
	20 MGD	8	6	30
Corronation pillar	20 MGD	66	47	112
	10 MGD	82	54	142
Narela	10 MGD	48	40	102



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Parameters of STPs of Delhi as on							10.08.2019		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Okhla	12 MGD	Inlet	7.3	318	205	424	6	38	2.2
		outlet	7.6	36	23	96	3	29	1.5
	Real Time Reading at Outlet								
	45 MGD	Inlet	7.3	326	228	416	5	39	2.4
		outlet	7.6	46	28	112	2	32	0.8
	Real Time Reading at Outlet								
	37 MGD	Inlet	7.3	326	228	416	5	39	2.4
		outlet	7.6	32	22	88	1	33	1
	Real Time Reading at Outlet								
	16 MGD	Inlet	7.3	326	228	416	5	39	2.4
		outlet	7.6	26	18	72	1	31	0.5
	Real Time Reading at Outlet								
	New 30 MGD	Inlet	7.4	214	140	376	5	38	2.4
		Outlet	7.7	6	4	16	Nil	4	1.6
	Real Time Reading at Outlet								
Kondli	25 MGD Phase-II	Inlet	7.3	246	151	264	-	40	5.9
		outlet	7.7	19	11	40	-	19	3.8
	Real Time Reading at Outlet		7.4	15	10	29		24.57	
	45 MGD Phase-IV	Inlet	7.3	340	191	376	-	41	7
		outlet	7.6	24	13	50	-	31	2.6
	Real Time Reading at Outlet		8	25	16	41		53.8	
Yamuna Vihar	10 MGD Phase-I	Inlet	7.2	340	199	-	18.4	45	4
		outlet	7.6	35	23	-	12.4	20	2.5
	Real Time Reading at Outlet		7.4	20	19	58		25	
	10 MGD Phase-II	Inlet	7.2	484	216	-	38.8	40	5
		outlet	7.6	22	19	-	7.2	25	2.5
	Real Time Reading at Outlet								
	25 MGD Phase-III	Inlet	7.3	996	274	-	10	45	5
		outlet	7.7	34	25	-	3.2	20	3
Real Time Reading at Outlet									
Rithala	40 MGD	Inlet	7	244	168	370	16	28	0.7
		outlet	7.6	25	20	90	6	20	0.6
	Real Time Reading at Outlet		7.42	33.21	16.61	67.93		26	
	40 MGD	Inlet	7	244	168	370	16	28	0.7
		Outlet	7.4	18	13	60	4	13	0.4
Real Time Reading at Outlet		7.27	23.82	21.15	86.07		14.85		
Keshopur	12 MGD	Inlet	7.3	296	200	-	14.8	26	3.2
		outlet	7.7	12	6	-	0	1.8	3
	Real Time Reading at Outlet		NA	NA	NA	NA	NA	NA	NA
	40 MGD	Inlet	7.3	328	218	-	12	27	3.4
		outlet	7.4	114	122	-	5.9	23	2.8
	Real Time Reading at Outlet		7.11	228.64	100.41	279.89	-	27.45	-
20 MGD	Inlet	7.3	328	218	-	12	27	3.4	

	20 MGD		outlet	7.6	64	88	-	2.2	22	2.6
	Real Time Reading at Outlet			NA	NA	NA	NA	NA	NA	NA
Nilothe	40 MGD Phase-I	Inlet	7.3	204	123	-	-	28	3	
		outlet	7.5	22	18	-	-	18	2.5	
	Real Time Reading at Outlet		7.49	32.19	25.34	106.03	-	16.92	-	
Pappankalan	20 MGD Phase-II	Inlet	7.2	330	183	-	-	30	4.4	
		outlet	7.9	34	27	-	-	14	0.4	
	Real Time Reading at Outlet		7.31	21.57	22.27	77.44	-	20.9	-	
	20 MGD Phase-II	Inlet	7.3	347	188	-	-	32	4	
		outlet	7.6	6	5	-	-	0.1	2.8	
	Real Time Reading at Outlet		6.99	9.84	2.51	25.77	-	1.54	-	
Corronation pillar	20 MGD Phase-I & II	Inlet	7	272	210	408	-	34	2.3	
		outlet	7.4	62	42	108	-	19	1.2	
	Real Time Reading at Outlet		7.1	59	31	133		25		
	10 MGD Phase-III	Inlet	7	298	300	426	8.1	50	2	
		outlet	7.5	70	44	134	3.2	37	1.1	
	Real Time Reading at Outlet		7.4	58	28	100		30		

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	10.08.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC limits	50	30	250
Okhla	12 MGD	36	23	96
	45 MGD	46	28	112
	37 MGD	32	22	88
	16 MGD	26	18	72
	New 30 MGD	6	4	16
Kondli	25 MGD	19	11	40
	45 MGD	24	13	50
Yamuna Vihar	10 MGD	35	23	-
	10 MGD	22	19	-
	25 MGD	34	25	-
Rithala	40 MGD	25	20	90
	40 MGD	18	13	60
Keshopur	12 MGD	12	6	-
	40 MGD	114	122	-
	20 MGD	64	88	-
Nilothi	40 MGD	22	18	-
Pappankalan	20 MGD	34	27	-
	20 MGD	6	5	-
Corronation pillar	20 MGD	62	42	108
	10 MGD	70	44	134