



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Parameters of STPs of Delhi as on							03.10.2019		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPPC limits	5.5-9.0	50	30	250	10	50	5
Okhla	12 MGD	Inlet	7.4	208	163	400	-	38	2.8
		outlet	7.6	17	10	48	-	33	0.5
	Real Time Reading at Outlet		7.3	30	22	107		10	
	45 MGD	Inlet	7.4	182	152	376	-	38	2.5
		outlet	7.6	31	19	80	-	33	0.8
	Real Time Reading at Outlet		7.3	40	21	86		46	
	37 MGD	Inlet	7.4	182	152	376	-	38	2.5
		outlet	7.6	10	7	32	-	30	1.8
	Real Time Reading at Outlet		6.9	10	16	58		27	
	16 MGD	Inlet	7.4	182	152	376	-	38	2.5
		outlet	7.6	8	5	24	-	28	0.5
	Real Time Reading at Outlet		7.8	12	9	46		6	
Kondli	25 MGD Phase-II	Inlet	7.3	244	139	258	15.5	40	6.7
		outlet	7.7	13	7	34	3.5	30	2.8
	Real Time Reading at Outlet		7.4	17	10	31		18.36	
	45 MGD Phase-IV	Inlet	7.2	252	142	268	18	38.72	6.6
		outlet	7.6	25	17	56	3.2	31.62	2.6
	Real Time Reading at Outlet		7.6	24	14	52			
CWG Village	1 MGD	Inlet	7.2	324	216	348	21	28.12	4.5
		outlet	7.7	1	0.87	0.8	Nil	0.12	1.2
	Real Time Reading at Outlet		7.4	0.17	0.12	1.6		0.28	
Yamuna Vihar	10 MGD Phase-I	Inlet	7.2	284	164	-	-	50	5
		outlet	7.5	26	18	-	-	30	3.5
	Real Time Reading at Outlet		7.2	38	16	66		25	
	10 MGD Phase-II	Inlet	7.3	292	174	-	-	45	5
		outlet	7.6	24	18	-	-	30	3
	Real Time Reading at Outlet		7.3	22	11	49		20	
	25 MGD Phase-III	Inlet	7.4	320	204	-	-	60	6.5
		outlet	7.6	36	22	-	-	35	4
Real Time Reading at Outlet		7.3	38	33	98		25		
Rithala	40 MGD	Inlet	7.1	232	161	360	-	34	1.9
		outlet	7.7	27	17	80	-	19	1.1
	Real Time Reading at Outlet		7.11	39.38	17.81	72.48		31.39	
	40 MGD	Inlet	7.1	232	161	360	-	34	1.9
		Outlet	7.6	18	13	70	-	17	0.6
Real Time Reading at Outlet		7.06	17.67	11.38	61.63		14.41		
Keshopur	12 MGD	Inlet	7.3	276	181	-	-	30	3.1
		outlet	7.7	13	7	-	-	3	1.8
	Real Time Reading at Outlet		NA	NA	NA	NA	NA	NA	NA
	40 MGD	Inlet	7.3	368	195	-	-	32	3.4
		outlet	7.5	92	91	-	-	29	3
Real Time Reading at Outlet		6.14	0	334.57	0	-	595.5	-	

	20 MGD	Inlet	7.3	368	195	-	-	32	3.4
		outlet	7.6	74	71	-	-	26	2.8
	Real Time Reading at Outlet		NA	NA	NA	NA	NA	NA	NA
Nilothe	40 MGD Phase-I	Inlet	7.1	312	136	-	-	30	2.8
		outlet	7.4	39	27	-	-	16	1.8
	Real Time Reading at Outlet		NA	NA	NA	NA	NA	NA	NA
	20 MGD Phase-II	Inlet	7.3	280	166	-	9.6	32	3.4
		outlet	7.5	8	5	-	0	7	1.4
	Real Time Reading at Outlet		NA	8.75	2.77	19.86	NA	NA	NA
Pappankalan	20 MGD Phase-II	Inlet	7.4	268	-	620	-	34	3.6
		outlet	7.8	67	42	150	-	16	0.9
	Real Time Reading at Outlet		7.42	51.72	21.97	75.36	-	36.05	-
	20 MGD Phase-II	Inlet	7.3	480		680	-	40	3.8
		outlet	7.7	5	4	20	-	2	2.6
	Real Time Reading at Outlet		7.08	9.36	1.81	25.65	-	1.33	-
Corronation pillar	20 MGD Phase-I & II	Inlet	7	242	205	382	-	38	6.8
		outlet	7.4	58	53	110	-	18	4
	Real Time Reading at Outlet		7.3	80	50	129		38	
	10 MGD Phase-III	Inlet	7.2	400	315	498	7.6	52	7.2
		outlet	7.4	80	58	138	3.6	30	4
	Real Time Reading at Outlet		7.4	98	36	158		27	

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	03.10.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC limits	50	30	250
Okhla	12 MGD	17	10	48
	45 MGD	31	19	80
	37 MGD	10	7	32
	16 MGD	8	5	24
Kondli	25 MGD	13	7	34
	45 MGD	25	17	56
CWG Village	1 MGD	1	0.87	0.8
Yamuna Vihar	10 MGD	26	18	-
	10 MGD	24	18	-
	25 MGD	36	22	-
Rithala	40 MGD	27	17	80
	40 MGD	18	13	70
Keshopur	12 MGD	13	7	-
	40 MGD	92	91	-
	20 MGD	74	71	-
Nilothi	40 MGD	39	27	-
	20 MGD	8	5	-
Pappankalan	20 MGD	67	42	150
	20 MGD	5	4	20
Corronation pillar	20 MGD	58	53	110
	10 MGD	80	58	138



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



		Parameters of STPs of Delhi as on					04.10.2019		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Okhla	12 MGD	Inlet	7.2	280	176	320	3	30	1.8
		outlet	7.5	16	13	48	Nil	26	Nil
	Real Time Reading at Outlet		6.9	29	23	113	Nil	12	
	45 MGD	Inlet	7.4	198	163	304	2	32	2
		outlet	7.4	27	18	64	Nil	25	Nil
	Real Time Reading at Outlet		7.17	35	19	76		35	
	37 MGD	Inlet	7.4	198	163	304	2	32	2
		outlet	7.8	17	13	48	Nil	26	1
	Real Time Reading at Outlet		6.87	19	11	47		26	
	16 MGD	Inlet	7.4	198	163	304	2	32	2
		outlet	7.7	5	6	4	Nil	23	0.8
	Real Time Reading at Outlet		7.82	38	14	89		8	
Mehrauli	5 MGD	Inlet	7.5	278	193	424	-	43	2.8
		outlet	7.7	10	11	40	-	35	2.3
	Real Time Reading at Outlet								
Vasant Kunj	2.2 MGD	Inlet	7.4	338	215	472	-	43	3.5
		outlet	7.7	12	10	40	-	36	2.5
	Real Time Reading at Outlet								
	3 MGD	Inlet	7.5	224	228	448	-	40	2.8
		outlet	7.6	18	12	48	-	5	2.2
Real Time Reading at Outlet									
Kondli	25 MGD Phase-II	Inlet	7.3	340	212	368	15	35	6.9
		outlet	7.6	12	8	26	2.8	27	3.2
	Real Time Reading at Outlet		7.5	18	19	55		18.78	
	45 MGD Phase-IV	Inlet	7.1	364	223	372	16.5	34	6.7
		outlet	7.6	28	18	66	3.1	28	3.5
Real Time Reading at Outlet		7.7	26	19	66		23.92		
Chilla	9 MGD	Inlet	7.1	272	158	294	15	37	6.4
		outlet	7.6	6	3.5	14	2.1	2.24	4.6
	Real Time Reading at Outlet		7.8	9	4	19		7.3	
CWG Village	1 MGD	Inlet	7.2	196	157	213	21	21.56	4.2
		outlet	7.8	1	0.59	1.6	Nil	0.02	1.2
	Real Time Reading at Outlet		7.6	0.17	0.12	1.62		0.08	
Yamuna Vihar	10 MGD Phase-I	Inlet	7.2	248	161	-	-	55	6
		outlet	7.5	32	22	-	-	35	4
	Real Time Reading at Outlet		7.3	35	16	65		22	
	10 MGD Phase-II	Inlet	7.2	256	188	-	-	45	4.5
		outlet	7.5	29	21	-	-	25	3
	Real Time Reading at Outlet		7.2	28	11	52		26	
	25 MGD Phase-III	Inlet	7.3	600	344	-	-	60	5.5
		outlet	7.6	37	25	-	-	35	4
Real Time Reading at Outlet		7.3	36	16	55		22		

Rithala	40 MGD	Inlet	7.2	284	188	410	-	40	2.1
		outlet	8	28	16	80	-	29	1.8
	Real Time Reading at Outlet		7.27	60.01	18.14	81.49		27.36	
	40 MGD	Inlet	7.2	284	188	410	-	40	2.1
		Outlet	7.9	17	12	60	-	22	1.1
	Real Time Reading at Outlet		6.95	17.82	13.34	63.48		14.19	
Keshopur	12 MGD	Inlet	7.3	320	174	-	-	31	3.2
		outlet	7.7	10	6	-	-	2	1.9
	Real Time Reading at Outlet		NA	NA	NA	NA	NA	NA	NA
	40 MGD	Inlet	7.2	296	195	-	-	32	3
		outlet	7.5	110	91	-	-	26	2.8
	Real Time Reading at Outlet		6.16	0	0	0	-	567.65	-
	20 MGD	Inlet	7.2	296	195	-	-	32	3
		outlet	7.6	70	83	-	-	28	2.7
	Real Time Reading at Outlet		NA	NA	NA	NA	NA	NA	NA
Nilothe	40 MGD Phase-I	Inlet	7.2	340	124	-	-	26	2.6
		outlet	7.4	46	27	-	-	15	2
	Real Time Reading at Outlet		NA	NA	NA	NA	NA	NA	NA
	20 MGD Phase-II	Inlet	7.2	304	161	560	-	30	3
		outlet	7.4	8	6	28	-	8	2
	Real Time Reading at Outlet		NA	10.94	3.04	25.3	NA	NA	NA
Pappankalan	20 MGD Phase-II	Inlet	7.4	379	-	-	-	36	3.6
		outlet	7.6	52	-	-	-	20	0.7
	Real Time Reading at Outlet		7.38	42.96	22.67	75.57	-	55.15	-
	20 MGD Phase-II	Inlet	7.4	358	-	-	-	38	3.8
		outlet	7.6	5	-	-	-	2.1	2.5
	Real Time Reading at Outlet		7.09	8.73	1.71	24.34	-	1.31	-
Corronation pillar	20 MGD Phase-I & II	Inlet	7.1	290	235	416	7.8	40	7.2
		outlet	7.4	57	48	106	3.6	22	3.8
	Real Time Reading at Outlet		7.3	82	50	128		31	
	10 MGD Phase-III	Inlet	7.1	416	320	520	-	50	7
		outlet	7.4	72	55	136	-	32	3.6
	Real Time Reading at Outlet		7.2	117	32	156		27	
Narela	10 MGD Phase-III	Inlet	7.1	226	220	320	7.8	48	6.2
		outlet	7.4	56	32	118	3.2	33	3.4
	Real Time Reading at Outlet		7.7	138	37	169		20	

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	04.10.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC limits	50	30	250
Okhla	12 MGD	16	13	48
	45 MGD	27	18	64
	37 MGD	17	13	48
	16 MGD	5	6	4
Mehrauli	5 MGD	10	11	40
Vasant Kunj	2.2 MGD	12	10	40
	3 MGD	18	12	48
Kondli	25 MGD	12	8	26
	45 MGD	28	18	66
Chilla	9 MGD	6	3.5	14
CWG Village	1 MGD	1	0.59	1.6
Yamuna Vihar	10 MGD	32	22	-
	10 MGD	29	21	-
	25 MGD	37	25	-
Rithala	40 MGD	28	16	80
	40 MGD	17	12	60
Keshopur	12 MGD	10	6	-
	40 MGD	110	91	-
	20 MGD	70	83	-
Nilothi	40 MGD	46	27	-
	20 MGD	8	6	28
Pappankalan	20 MGD	52	-	-
	20 MGD	5	-	-
Corronation pillar	20 MGD	57	48	106
	10 MGD	72	55	136
Narela	10 MGD	56	32	118



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Parameters of STPs of Delhi as on							05.10.2019		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Okhla	12 MGD	Inlet	7.4	236	185	456	-	42	2
		outlet	7.6	29	18	72	-	35	Nil
	Real Time Reading at Outlet		7.01	29.48	23.11	111		17.25	
	45 MGD	Inlet	7.4	234	180	448	-	40	2.2
		outlet	7.6	45	29	104	-	34	Nil
	Real Time Reading at Outlet		7.34	34.84	20.9	81		31	
	37 MGD	Inlet	7.4	234	180	448	-	40	2.2
		outlet	7.4	16	10	48	-	32	1.8
	Real Time Reading at Outlet		6.7	8.83	9.38	26		26	
	16 MGD	Inlet	7.4	234	180	448	-	40	2.2
outlet		7.6	4	4	16	-	30	0.8	
Real Time Reading at Outlet		8.02	10.57	4.64	34		6.77		
Kondli	25 MGD Phase-II	Inlet	7.3	330	201	356	-	40	6.6
		outlet	7.7	13	7	32	-	30	2.9
	Real Time Reading at Outlet		7.5	17	9	29		18.78	
	45 MGD Phase-IV	Inlet	7.2	266	152	284	-	38	6.5
		outlet	7.6	26	17	58	-	28	2.6
	Real Time Reading at Outlet		7.7	26	20	66		23.12	
Chilla	9 MGD	Inlet	7.2	116	76	132	17	39	5.7
		outlet	7.6	4	1.5	12	2.5	3.12	4.2
	Real Time Reading at Outlet		7.5	9	5	20		3.85	
CWG Village	1 MGD	Inlet	7.1	428	294	456	16	24.6	4.3
		outlet	7.7	1	0.84	0.86	Nil	1	1.2
	Real Time Reading at Outlet		7.6	0.12	0.13	1.5		0.07	
Yamuna Vihar	10 MGD Phase-I	Inlet	7.2	296	230	-	-	55	5
		outlet	7.6	32	20	-	-	35	3
	Real Time Reading at Outlet								
	10 MGD Phase-II	Inlet	7.2	280	161	-	-	50	5
		outlet	7.5	30	20	-	-	30	3
	Real Time Reading at Outlet		7.3	20	10	47		18	
	25 MGD Phase-III	Inlet	7.3	604	309	-	-	60	6.5
outlet		7.6	36	35	-	-	40	4	
Real Time Reading at Outlet		7.2	29	8	44		24		
Rithala	40 MGD	Inlet	7.4	244	155	360	-	46	2.9
		outlet	7.9	29	18	90	-	32	1.6
	Real Time Reading at Outlet		7.5	23.88	15.74	63.36		17.34	
	40 MGD	Inlet	7.4	244	155	360	-	46	2.9
		Outlet	7.8	16	11	60	-	24	1.1
Real Time Reading at Outlet		6.93	17.68	11.69	61.94		14.15		
	12 MGD	Inlet	7.4	256	171	533	9.7	34	3
		outlet	7.8	7	5	25	0	3	2.2
	Real Time Reading at Outlet		NA	NA	NA	NA	NA	NA	NA

Keshopur	40 MGD	Inlet	7.4	296	161	533	10	30	2.9
		outlet	7.6	86	75	272	4.3	25	2.5
	Real Time Reading at Outlet		6.21	0	0	0	-	544.15	-
	20 MGD	Inlet	7.4	296	161	533	10	30	2.9
		outlet	7.6	66	59	224	2.6	28	3
	Real Time Reading at Outlet		NA	NA	NA	NA	NA	NA	NA
Nilothi	40 MGD Phase-I	Inlet	7.2	388	125	-	-	28	2.5
		outlet	7.5	43	25	-	-	15	2
	Real Time Reading at Outlet		NA	NA	NA	NA	NA	NA	NA
	20 MGD Phase-II	Inlet	7.3	280	159	-	-	30	3
		outlet	7.5	6	5	-	-	5	1.8
	Real Time Reading at Outlet		NA	NA	NA	NA	NA	NA	NA
Pappankalan	20 MGD Phase-II	Inlet	7.4	320	-	-	-	-	-
		outlet	7.8	49	28	-	-	-	-
	Real Time Reading at Outlet		7.17	42.43	22.41	75.66	-	38.75	-
	20 MGD Phase-II	Inlet	7.3	346	210	-	-	-	-
		outlet	7.6	5	6	-	-	-	-
	Real Time Reading at Outlet		7.07	9.13	1.49	24.73	-	1.37	-
Corronation pillar	20 MGD Phase-I & II	Inlet	7.2	184	175	272	-	42	6.4
		outlet	7.5	54	45	96	-	23	3.3
	Real Time Reading at Outlet		7.3	105	54	160		37	
	10 MGD Phase-III	Inlet	7.1	316	295	464	8.7	54	6.8
		outlet	7.4	68	51	128	3.8	34	3.4
	Real Time Reading at Outlet		7.2	103	37	161		24	
Narela	10 MGD Phase-III	Inlet	6.9	216	255	310	8.4	50	7.3
		outlet	7.3	47	28	104	3.1	36	3.7
	Real Time Reading at Outlet		7.4	41	24	78		27	

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	05.10.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC limits	50	30	250
Okhla	12 MGD	29	18	72
	45 MGD	45	29	104
	37 MGD	16	10	48
	16 MGD	4	4	16
Kondli	25 MGD	13	7	32
	45 MGD	26	17	58
Chilla	9 MGD	4	1.5	12
CWG Village	1 MGD	1	0.84	0.86
Yamuna Vihar	10 MGD	32	20	-
	10 MGD	30	20	-
	25 MGD	36	35	-
Rithala	40 MGD	29	18	90
	40 MGD	16	11	60
Keshopur	12 MGD	7	5	25
	40 MGD	86	75	272
	20 MGD	66	59	224
Nilothi	40 MGD	43	25	-
	20 MGD	6	5	-
Pappankalan	20 MGD	49	28	-
	20 MGD	5	6	-
Corronation pillar	20 MGD	54	45	96
	10 MGD	68	51	128
Narela	10 MGD	47	28	104



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Parameters of STPs of Delhi as on							06.10.2019		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Okhla	12 MGD	Inlet	7.4	254	195	432	4	35	2
		outlet	7.6	27	19	72	Nil	29	Nil
	Real Time Reading at Outlet		7.19	44.66	25.75	161		12	
	45 MGD	Inlet	7.4	258	198	448	4	36	2.2
		outlet	7.6	35	21	88	1	30	1
	Real Time Reading at Outlet		7.43	38.16	20.85	82		32	
	37 MGD	Inlet	7.4	258	198	448	4	36	2.2
		outlet	7.2	12	8	40	Nil	27	0.8
	Real Time Reading at Outlet		6.73	4.14	9.95	29		26	
	16 MGD	Inlet	7.4	258	198	448	4	36	2.2
outlet		7.8	8	6	24	Nil	26	0.4	
Real Time Reading at Outlet		7.96	9.48	5.04	30		6.76		
Kondli	25 MGD Phase-II	Inlet	7.3	296	185	316	-	39	6.4
		outlet	7.7	15	8	38	-	29	2.4
	Real Time Reading at Outlet		7.5	17	8	27		18.66	
	45 MGD Phase-IV	Inlet	7.3	280	181	308	-	40	6.8
		outlet	7.6	26	18	66	-	27	3.6
	Real Time Reading at Outlet		7.7	27	19	81		31.64	
Yamuna Vihar	10 MGD Phase-I	Inlet	7.1	208	136	480	-	50	4.5
		outlet	7.5	32	18	72	-	35	3
	Real Time Reading at Outlet								
	10 MGD Phase-II	Inlet	7.3	240	184	600	-	30	4.5
		outlet	7.5	27	18	56	-	15	3
	Real Time Reading at Outlet								
	25 MGD Phase-III	Inlet	7	340	167	800	-	60	5.5
		outlet	7.5	28	19	104	-	45	4
Real Time Reading at Outlet									
Rithala	40 MGD	Inlet	7.2	272	161	350	-	36	1.4
		outlet	7.9	28	17	70	-	29	1
	Real Time Reading at Outlet		7.18	28.48	16.34	66.77		31.48	
	40 MGD	Inlet	7.2	272	161	350	-	36	1.4
		Outlet	7.6	18	13	50	-	18	0.7
Real Time Reading at Outlet		6.89	17.64	12.42	62.28		29.23		
Keshopur	12 MGD	Inlet	7.4	284	201	-	-	30	3.3
		outlet	7.7	11	6	-	-	3	1.8
	Real Time Reading at Outlet		NA	NA	NA	NA	NA	NA	NA
	40 MGD	Inlet	7.3	288	222	-	-	31	3.1
		outlet	7.5	112	120	-	-	28	2.9
	Real Time Reading at Outlet		6.31	0	0	0	-	397.65	-
	20 MGD	Inlet	7.3	288	222	-	-	31	3.1
outlet		7.6	84	122	-	-	27	2.6	
Real Time Reading at Outlet		NA	NA	NA	NA	NA	NA	NA	
	40 MGD Phase-	Inlet	7.1	388	116	450	-	28	2.5

Nilothi	I	outlet	7.4	38	23	90	-	15	1.8
	Real Time Reading at Outlet		NA	NA	NA	NA	NA	NA	NA
Pappankalan	20 MGD Phase-II	Inlet	7.4	336	206	-	19.4	34	4.3
		outlet	7.7	62	34	-	0.8	22	0.6
	Real Time Reading at Outlet		NA	NA	NA	NA	NA	NA	NA
	20 MGD Phase-II	Inlet	7.4	352	218	740	21.8	40	4.5
		outlet	7.6	7	5	22	0	2.3	3.1
	Real Time Reading at Outlet		7.05	10.07	2.31	27.91	-	1.38	-
Corronation pillar	20 MGD Phase-I &II	Inlet	7	216	195	368	-	39	8
		outlet	7.4	55	47	116	-	26	3.7
	Real Time Reading at Outlet		7.3	110	57	169		33	
	10 MGD Phase-III	Inlet	7.2	327	265	416	-	50	7.2
		outlet	7.6	72	59	132	-	33	3.9
	Real Time Reading at Outlet		7.2	108	39	170		23	

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	06.10.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC limits	50	30	250
Okhla	12 MGD	27	19	72
	45 MGD	35	21	88
	37 MGD	12	8	40
	16 MGD	8	6	24
Kondli	25 MGD	15	8	38
	45 MGD	26	18	66
Yamuna Vihar	10 MGD	32	18	72
	10 MGD	27	18	56
	25 MGD	28	19	104
Rithala	40 MGD	28	17	70
	40 MGD	18	13	50
Keshopur	12 MGD	11	6	-
	40 MGD	112	120	-
	20 MGD	84	122	-
Nilothi	40 MGD	38	23	90
Pappankalan	20 MGD	62	34	-
	20 MGD	7	5	22
Corronation pillar	20 MGD	55	47	116
	10 MGD	72	59	132



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Parameters of STPs of Delhi as on							07.10.2019		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Okhla	12 MGD	Inlet	7.3	208	205	-		40	2.4
		outlet	7.6	29	19	-		35	1.6
	Real Time Reading at Outlet		7.1	32	24	119		17	
	45 MGD	Inlet	7.4	222	180	-	-	39	2
		outlet	7.6	48	28	-	-	21	1.6
	Real Time Reading at Outlet		7.41	42.5	22.7	90		38	
	37 MGD	Inlet	7.4	222	180	-	-	39	2
		outlet	7.7	15	10	-	-	24	0.8
	Real Time Reading at Outlet		6.72	10.56	13.41	47		26	
	16 MGD	Inlet	7.4	222	180	-	-	39	2
		outlet	7.6	6	6	-	-	23	1.9
	Real Time Reading at Outlet		7.93	10.8	7.96	39		6.8	
	New 30 MGD	Inlet	7.6	204	232	-	-	35	2.1
		Outlet	7.6	4	4	-	-	3	0.4
Real Time Reading at Outlet									
Delhi Gate-I	2.2 MGD	Inlet	7.3	224	183	440	-	39	1.5
		outlet	7.6	6	6	24	-	5	0.5
	Real Time Reading at Outlet								
Delhi Gate-II	15 MGD	Inlet	7.3	218	178	424	-	40	1.2
		outlet	7.6	8	8	32	-	4	0.4
	Real Time Reading at Outlet								
Sen Nursing Home	2.2 MGD	Inlet	7.3	258	40	472	-	41	1.3
		outlet	7.7	6	6	24	-	5	0.4
	Real Time Reading at Outlet								
Kondli	25 MGD Phase-II	Inlet	7.2	350	198	366	-	39	6.6
		outlet	7.7	12	7	26	-	28	2.8
	Real Time Reading at Outlet		7.5	17	8	27		18.89	
	45 MGD Phase-IV	Inlet	7.2	266	166	292	-	38	6.5
		outlet	7.6	28	18	62	-	30	3.1
Real Time Reading at Outlet		7.6	30	18	78		28.35		
Chilla	9 MGD	Inlet	7.2	200	133	224	18	40	6.4
		outlet	7.6	7	4	18	2	3.28	4.4
	Real Time Reading at Outlet		7.1	13	4.8	22		5.32	
CWG Village	1 MGD	Inlet	7.2	404	250	418	16	21.28	4.7
		outlet	7.7	1	0.77	1.6	Nil	0.14	1.2
	Real Time Reading at Outlet		7.4	0.18	0.13	1.66		0.29	
	10 MGD Phase-I	Inlet	7.2	348	189	-	8.4	45	2.5
		outlet	7.5	27	18	-	5.2	35	1.5
	Real Time Reading at Outlet		7.3	37	16	66		20	
	10 MGD Phase-II	Inlet	7.1	264	174	-	9.2	35	4

Yamuna Vihar	10 MGD Phase-II	outlet	7.5	24	14	-	3.6	15	1
		Real Time Reading at Outlet	7.3	21	11	40		21	
	25 MGD Phase-III	Inlet	7	724	488	-	30.4	65	2
		outlet	7.3	37	22	-	6.8	25	1.5
	Real Time Reading at Outlet								
Rithala	40 MGD	Inlet	7.1	256	164	370	-	32	1.2
		outlet	7.9	29	19	80	-	27	0.9
	Real Time Reading at Outlet		7.41	43.46	16	72.69		19.46	
	40 MGD	Inlet	7.1	256	164	370	-	32	1.2
		Outlet	7.7	19	14	70	-	16	0.6
	Real Time Reading at Outlet		6.87	17.67	13.78	63.41		14.04	
Keshopur	12 MGD	Inlet	7.4	256	174	-	-	30	3
		outlet	7.6	9	5	-	-	2	1.8
	Real Time Reading at Outlet		NA	NA	NA	NA	NA	NA	NA
	40 MGD	Inlet	7.3	440	233	-	-	32	3.3
		outlet	7.5	106	96	-	-	27	2.8
	Real Time Reading at Outlet		6.22	0	0	0	-	570.4	-
	20 MGD	Inlet	7.3	440	233	-	-	32	3.3
		outlet	7.6	68	66	-	-	28	2.6
	Real Time Reading at Outlet		NA	NA	NA	NA	NA	NA	NA
Nilothi	40 MGD Phase-I	Inlet	7.2	348	121	-	8	28	2
		outlet	7.5	38	23	-	1	16	1
	Real Time Reading at Outlet		NA	NA	NA	NA	NA	NA	NA
	20 MGD Phase-II	Inlet	7.5	264	161	-	9.6	32	2.8
		outlet	7.1	8	7	-	0	5	1.8
	Real Time Reading at Outlet		NA	NA	NA	NA	NA	NA	NA
Pappankalan	20 MGD Phase-II	Inlet	7.3	482	212	-	-	37	6
		outlet	7.7	49	29	-	-	32	0.9
	Real Time Reading at Outlet		7.31	48	24.31	74.16	-	52.85	-
	20 MGD Phase-II	Inlet	7.3	490	222	-	-	28	5.7
		outlet	7.6	10	7	-	-	2.6	5.3
	Real Time Reading at Outlet		7.07	8.43	1.04	22.76	-	1.35	-
Najafgarh	5 MGD Phase-II	Inlet	7.3	323	188	-	9.8	28	5
		outlet	7.6	41	27	-	0.2	8	2
	Real Time Reading at Outlet		NA	NA	NA	NA	NA	NA	NA
Corronation pillar	20 MGD Phase-I & II	Inlet	6.9	220	190	386	-	41	5.9
		outlet	7.3	70	60	138	-	27	3.2
	Real Time Reading at Outlet		7.3	157	66	236		31	
	10 MGD Phase-III	Inlet	7.1	290	280	400	8.2	49	6.9
		outlet	7.7	56	53	168	3.8	32	3.4
	Real Time Reading at Outlet		7.3	131				21	

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	07.10.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC limits	50	30	250
Okhla	12 MGD	29	19	-
	45 MGD	48	28	-
	37 MGD	15	10	-
	16 MGD	6	6	-
	New 30 MGD	4	4	-
Delhi Gate-I	2.2 MGD	6	6	24
Delhi Gate-II	15 MGD	8	8	32
Sen Nursing Home	2.2 MGD	6	6	24
Kondli	25 MGD	12	7	26
	45 MGD	28	18	62
Chilla	9 MGD	7	4	18
CWG Village	1 MGD	1	0.77	1.6
Yamuna Vihar	10 MGD	27	18	-
	10 MGD	24	14	-
	25 MGD	37	22	-
Rithala	40 MGD	29	19	80
	40 MGD	19	14	70
Keshopur	12 MGD	9	5	-
	40 MGD	106	96	-
	20 MGD	68	66	-
Nilothi	40 MGD	38	23	-
	20 MGD	8	7	-
Najafgarh	5 MGD	41	27	-
Pappankalan	20 MGD	49	29	-
	20 MGD	10	7	-
Corronation pillar	20 MGD	70	60	138
	10 MGD	56	53	168



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



		Parameters of STPs of Delhi as on					08.10.2019		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Okhla	12 MGD	Inlet	7.4	258	208	472	-	41	2.1
		outlet	7.7	30	18	72	-	32	1.1
	Real Time Reading at Outlet		7.3	32	26	130		11	
	45 MGD	Inlet	7.4	264	193	456	-	38	2
		outlet	7.6	43	26	104	-	30	1.4
	Real Time Reading at Outlet		7.3	38	21	83		38	
	37 MGD	Inlet	7.4	264	193	456	-	38	2
		outlet	7.7	12	8	32	-	26	0.8
	Real Time Reading at Outlet		6.7	29	17	89		26	
	16 MGD	Inlet	7.4	264	193	456	-	38	2
outlet		7.7	8	6	24	-	18	0.4	
Real Time Reading at Outlet		7.9	25	10	54		6.2		
Kondli	25 MGD Phase-II	Inlet	7.3	308	213	336	17	40.72	6.7
		outlet	7.8	13	7	32	3.1	31.54	2.7
	Real Time Reading at Outlet		7.5	16	8	26		18.56	
	45 MGD Phase-IV	Inlet	7.3	278	173	304	18.5	39.82	6.8
		outlet	7.6	27	17	60	3.5	30.68	2.9
	Real Time Reading at Outlet		7.6	39	21	103		38.13	
Yamuna Vihar	10 MGD Phase-I	Inlet	7	300	206	-	-	50	4
		outlet	7.5	31	25	-	-	40	2.5
	Real Time Reading at Outlet		7.3	36	16	65		22	
	10 MGD Phase-II	Inlet	7.1	224	159	-	-	30	4.5
		outlet	7.5	27	17	-	-	20	3.5
	Real Time Reading at Outlet		7.3	30	13	56		23	
	25 MGD Phase-III	Inlet	7	284	213	-	-	50	5.5
		outlet	7.5	33	24	-	-	40	3
Real Time Reading at Outlet		6.6	60	30	50		22		
Rithala	40 MGD	Inlet	7.2	268	165	390	-	33	1.6
		outlet	8	30	20	90	-	24	1.2
	Real Time Reading at Outlet		7.33	47.63	18.13	77.42		22.4	
	40 MGD	Inlet	7.2	268	165	390	-	33	1.6
		Outlet	7.8	16	11	60	-	19	0.8
Real Time Reading at Outlet		6.87	17.7	16.5	65.38		14.04		
Keshopur	12 MGD	Inlet	7.3	324	208	-	-	31	3.2
		outlet	7.7	12	6	-	-	3	1.9
	Real Time Reading at Outlet		NA	NA	NA	NA	NA	NA	NA
	40 MGD	Inlet	7.3	428	234	-	-	32	3.1
		outlet	7.4	84	89	-	-	29	2.8
	Real Time Reading at Outlet		6.21	2299.82	255.34	1722.93	-	534.35	-
	20 MGD	Inlet	7.3	428	234	-	-	32	3.1
outlet		7.6	66	86	-	-	28	2.7	
Real Time Reading at Outlet		NA	NA	NA	NA	NA	NA	NA	
	40 MGD Phase-I	Inlet	7.2	290	119	410	-	26	2.5

Nilothi	I	outlet	7.5	36	22	90	-	15	1.8
	Real Time Reading at Outlet		NA	NA	NA	NA	NA	NA	NA
	20 MGD Phase-II	Inlet	7.3	302	167	520	-	30	3
		outlet	7.5	7	7	28	-	4	1.6
	Real Time Reading at Outlet		NA	NA	NA	NA	NA	NA	NA
Pappankalan	20 MGD Phase-II	Inlet	7.2	660	350	-	-	36	5.7
		outlet	7.6	47	30	-	-	18	0.8
	Real Time Reading at Outlet		NA	NA	NA	NA	NA	NA	NA
	20 MGD Phase-II	Inlet	7.3	547	323	-	-	38	5.4
		outlet	7.6	6	5	-	-	2.8	5
	Real Time Reading at Outlet		7.06	8.95	1.72	24.93	-	1.34	-
Corronation pillar	20 MGD Phase-I & II	Inlet	7	244	210	372	9	38	6
		outlet	7.4	66	59	126	4.2	24	2.9
	Real Time Reading at Outlet		7.3	99	48	102		27	
	10 MGD Phase-III	Inlet	7.2	314	290	452	-	52	7
		outlet	7.5	58	56	124	-	38	3.5
	Real Time Reading at Outlet		7.4	114	34	160		26	

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	08.10.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC limits	50	30	250
Okhla	12 MGD	30	18	72
	45 MGD	43	26	104
	37 MGD	12	8	32
	16 MGD	8	6	24
Kondli	25 MGD	13	7	32
	45 MGD	27	17	60
Yamuna Vihar	10 MGD	31	25	-
	10 MGD	27	17	-
	25 MGD	33	24	-
Rithala	40 MGD	30	20	90
	40 MGD	16	11	60
Keshopur	12 MGD	12	6	-
	40 MGD	84	89	-
	20 MGD	66	86	-
Nilothi	40 MGD	36	22	90
	20 MGD	7	7	28
Pappankalan	20 MGD	47	30	-
	20 MGD	6	5	-
Corronation pillar	20 MGD	66	59	126
	10 MGD	58	56	124



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Parameters of STPs of Delhi as on							09.10.2019		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Okhla	12 MGD	Inlet	7.4	258	165	392	-	37	2.1
		outlet	7.9	28	20	80	-	31	0.5
	Real Time Reading at Outlet		7.1	30.94	26.87	132		16	
	45 MGD	Inlet	7.4	276	163	392	-	35	2.7
		outlet	7.4	24	17	64	-	27	2
	Real Time Reading at Outlet		7.4	38.18	21.71	84		34.92	
	37 MGD	Inlet	7.4	276	163	392	-	35	2.7
		outlet	7.8	16	10	40	-	21	1.8
	Real Time Reading at Outlet		6.7	11.34	13.59	55		26	
	16 MGD	Inlet	7.4	276	163	392	-	35	2.7
		outlet	7.7	10	8	32	-	12	1.5
	Real Time Reading at Outlet		7.8	8.64	6.03	32		7.48	
Kondli	25 MGD Phase-II	Inlet	7.2	334	206	342	16.5	41.6	6.7
		outlet	7.7	14	9	30	2.5	30.92	3.3
	Real Time Reading at Outlet		7.5	17	9	28		18.74	
	45 MGD Phase-IV	Inlet	7.2	292	186	312	19.5	40.54	6.9
		outlet	7.6	28	16	63	3.8	28.72	3
	Real Time Reading at Outlet		7.5	71	23	163		33.03	
Chilla	9 MGD	Inlet	7.1	152	139	164	-	40.58	6.8
		outlet	7.6	5	3.4	12	-	3.48	4.7
	Real Time Reading at Outlet		7.2	8	3.22	18		5.26	
CWG Village	1 MGD	Inlet	7.2	636	324	644	-	22.18	4.9
		outlet	7.7	1	0.5	0.8	-	0.08	1.4
	Real Time Reading at Outlet		7.4	0.15	0.12	1.61		0.3	
Yamuna Vihar	10 MGD Phase-I	Inlet	7.1	316	183	-	-	55	2.5
		outlet	7.5	35	24	-	-	35	3
	Real Time Reading at Outlet		7.3	36	16	65		23	
	10 MGD Phase-II	Inlet	6.9	248	156	-	-	35	5
		outlet	7.5	41	25	-	-	15	3.5
	Real Time Reading at Outlet		7.3	83	16	84		25	
	25 MGD Phase-III	Inlet	7.2	460	290	-	-	45	5.5
		outlet	7.6	41	22	-	-	25	3.5
Real Time Reading at Outlet		7.6	59	3	50		25		
Rithala	40 MGD	Inlet	7.1	280	188	420	-	31	1.3
		outlet	7.8	28	17	70	-	24	0.8
	Real Time Reading at Outlet		7.2	56.93	18.85	81.41		28.87	
	40 MGD	Inlet	7.1	280	188	420	-	31	1.3
		Outlet	7.6	17	12	50	-	16	0.6
Real Time Reading at Outlet		6.84	17.74	15.27	64.59		13.97		
	12 MGD	Inlet	7.5	312	154	540	-	35	3.3
		outlet	7.7	13	6	32	-	2	2
	Real Time Reading at Outlet		NA	NA	NA	NA	NA	NA	NA

Keshopur	40 MGD	Inlet	7.4	420	174	667	-	32	3.2
		outlet	7.6	102	97	352	-	29	3
	Real Time Reading at Outlet		6.21	2762.22	298.12	2065.38	-	637.15	-
	20 MGD	Inlet	7.4	420	174	667	-	32	3.2
		outlet	7.5	74	84	256	-	31	2.7
	Real Time Reading at Outlet		NA	NA	NA	NA	NA	NA	NA
Nilothi	40 MGD Phase-I	Inlet	7.2	284	118	-	-	25	2.8
		outlet	7.5	30	22	-	-	14	2
	Real Time Reading at Outlet		NA	NA	NA	NA	NA	NA	NA
	20 MGD Phase-II	Inlet	7.2	296	164	-	-	30	3
		outlet	7.5	9	7	-	-	12	1.8
	Real Time Reading at Outlet		NA	NA	NA	NA	NA	NA	NA
Pappankalan	20 MGD Phase-II	Inlet	7.3	544	290	-	16.6	42	5.6
		outlet	7.8	44	27	-	0.6	20	1.6
	Real Time Reading at Outlet		NA	NA	NA	NA	NA	NA	NA
	20 MGD Phase-II	Inlet	7.2	530	281	540	-	44	5.7
		outlet	7.5	6	5	20	-	3.4	5
	Real Time Reading at Outlet		7.1	9.66	2.47	27.8	-	1.37	-
Najafgarh	5 MGD Phase-II	Inlet	7.4	380	220	-	-	34	3.5
		outlet	7.8	44	26	-	-	10	2.8
	Real Time Reading at Outlet		NA	NA	NA	NA	NA	NA	NA
Corronation pillar	20 MGD Phase-I & II	Inlet	7.1	236	185	357	-	36	5.8
		outlet	7.5	65	58	118	-	22	4
	Real Time Reading at Outlet		7.3	49	38	72		27	
	10 MGD Phase-III	Inlet	7.1	296	275	424	7.9	45	8.1
		outlet	7.6	64	60	136	3.5	34	5.2
	Real Time Reading at Outlet		7.4	110	35	154		25	

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	09.10.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC limits	50	30	250
Okhla	12 MGD	28	20	80
	45 MGD	24	17	64
	37 MGD	16	10	40
	16 MGD	10	8	32
Kondli	25 MGD	14	9	30
	45 MGD	28	16	63
Chilla	9 MGD	5	3.4	12
CWG Village	1 MGD	1	0.5	0.8
Yamuna Vihar	10 MGD	35	24	-
	10 MGD	41	25	-
	25 MGD	41	22	-
Rithala	40 MGD	28	17	70
	40 MGD	17	12	50
Keshopur	12 MGD	13	6	32
	40 MGD	102	97	352
	20 MGD	74	84	256
Nilothi	40 MGD	30	22	-
	20 MGD	9	7	-
Najafgarh	5 MGD	44	26	-
Pappankalan	20 MGD	44	27	-
	20 MGD	6	5	20
Corronation pillar	20 MGD	65	58	118
	10 MGD	64	60	136



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Parameters of STPs of Delhi as on							10.10.2019		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Okhla	12 MGD	Inlet	7.3	266	185	-	4	40	2
		outlet	7.6	29	18	-	1	32	Nil
	Real Time Reading at Outlet		7.18	30.73	28.55	139		15	
	45 MGD	Inlet	7.48	322	215	-	4	42	2
		outlet	7.6	34	22	-	1	35	1
	Real Time Reading at Outlet		7.4	19.14	22.52	87		34	
	37 MGD	Inlet	7.48	322	215	-	4	42	2
		outlet	7.6	21	13	-	Nil	30	2.2
	Real Time Reading at Outlet		6.7	15.19	13.24	55		26	
	16 MGD	Inlet	7.48	322	215	-	4	42	2
		outlet	7.6	10	8	-	Nil	28	0.8
	Real Time Reading at Outlet		7.9	28.32	11.13	51		7	
Kondli	25 MGD Phase-II	Inlet	7.3	314	193	336	15.8	41	6.8
		outlet	7.7	12	7	32	2	30	3.4
	Real Time Reading at Outlet		7.5	16	9	29		19.06	
	45 MGD Phase-IV	Inlet	7.3	314	194	330	18	41	6.7
		outlet	7.6	29	16	68	3.5	31	3.7
	Real Time Reading at Outlet		7.6	25	12	45		33.62	
Chilla	9 MGD	Inlet	7.1	148	120	168	18.5	43	6.8
		outlet	7.6	8	4	20	2.2	3.18	3.5
	Real Time Reading at Outlet		7.2	8	4.28	25		5.36	
CWG Village	1 MGD	Inlet	7.1	184	134	216	19.5	24.06	5.6
		outlet	7.7	1	0.56	0.8	Nil	1.9	1.9
	Real Time Reading at Outlet		7.4	0.17	0.12	1.6		0.29	
Yamuna Vihar	10 MGD Phase-I	Inlet	7	296	199	742	7.4	50	5
		outlet	7.5	29	21	82	5.6	30	2.5
	Real Time Reading at Outlet								
	10 MGD Phase-II	Inlet	7.1	352	206	839	8.8	35	4.5
		outlet	7.6	23	17	71	3.6	20	2.5
	Real Time Reading at Outlet								
	25 MGD Phase-III	Inlet	7.2	440	270	904	18.8	50	4.5
outlet		7.5	28	18	80	7.2	25	2	
Real Time Reading at Outlet									
Rithala	40 MGD	Inlet	7.2	252	160	350	-	35	1.4
		outlet	7.7	29	16	90	-	20	0.7
	Real Time Reading at Outlet		7.15	56.78	19.73	83.56		32.03	
	40 MGD	Inlet	7.2	252	160	350	-	35	1.4
		Outlet	7.7	18	13	70	-	13	0.5
Real Time Reading at Outlet		6.82	17.91	17.14	66.43		13.93		
	12 MGD	Inlet	7.3	248	152	-	12.2	31	3.5
		outlet	7.6	10	6	-	Nil	2	3.4
	Real Time Reading at Outlet		NA	NA	NA	NA	NA	NA	NA

Keshopur	40 MGD	Inlet	7.4	432	163	-	11	34	3.6
		outlet	7.5	116	90	-	5	29	3
	Real Time Reading at Outlet		NA	NA	NA	NA	NA	NA	NA
	20 MGD	Inlet	7.4	432	163	-	11	34	3.6
		outlet	7.6	62	75	-	3.1	31	3.6
	Real Time Reading at Outlet		NA	NA	NA	NA	NA	NA	NA
Nilothi	40 MGD Phase-I	Inlet	7.1	218	116	-	-	28	2.5
		outlet	7.5	32	20	-	-	12	2
	Real Time Reading at Outlet		NA	NA	NA	NA	NA	NA	NA
	20 MGD Phase-II	Inlet	7.2	298	158	-	-	30	3
		outlet	7.4	8	8	-	-	10	1.5
	Real Time Reading at Outlet		NA	NA	NA	NA	NA	NA	NA
Pappankalan	20 MGD Phase-II	Inlet	7.3	389	223	780	-	48	5.4
		outlet	7.7	62	34	130	-	24	1
	Real Time Reading at Outlet		NA	NA	NA	NA	NA	NA	NA
	20 MGD Phase-II	Inlet	7.3	395	230	-	18.3	46	5.6
		outlet	7.6	8	6	-	Nil	2.4	4.9
	Real Time Reading at Outlet		7.1	10.68	2.68	29.75	-	1.38	-
Najafgarh	5 MGD Phase-II	Inlet	7.3	326	190	-	-	30	3.6
		outlet	7.5	33	24	-	-	12	2.5
	Real Time Reading at Outlet		7.6	35.73	22.84	71.94	-	20.64	-
Corronation pillar	20 MGD Phase-I & II	Inlet	7	288	205	396	8.6	38	6.6
		outlet	7.4	58	55	114	3.9	26	3.7
	Real Time Reading at Outlet		7.3	52	42	79		29	
	10 MGD Phase-III	Inlet	7.2	338	295	448	-	47	7.9
		outlet	7.7	76	70	146	-	36	4.6
	Real Time Reading at Outlet		7.4	163	45	231		25	

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	10.10.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC limits	50	30	250
Okhla	12 MGD	29	18	-
	45 MGD	34	22	-
	37 MGD	21	13	-
	16 MGD	10	8	-
Kondli	25 MGD	12	7	32
	45 MGD	29	16	68
Chilla	9 MGD	8	4	20
CWG Village	1 MGD	1	0.56	0.8
Yamuna Vihar	10 MGD	29	21	82
	10 MGD	23	17	71
	25 MGD	28	18	80
Rithala	40 MGD	29	16	90
	40 MGD	18	13	70
Keshopur	12 MGD	10	6	-
	40 MGD	116	90	-
	20 MGD	62	75	-
Nilothi	40 MGD	32	20	-
	20 MGD	8	8	-
Najafgarh	5 MGD	33	24	-
Pappankalan	20 MGD	62	34	130
	20 MGD	8	6	-
Corronation pillar	20 MGD	58	55	114
	10 MGD	76	70	146