

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Parameters of STPs of Delhi as on							04.01.2020		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Yamuna Vihar	10 MGD Phase-I	Inlet	7.1	372	260	664		30	5
		outlet	7.3	45	19	136		10	2
	Real Time Reading at Outlet		7.3	45	18	116		12	
	10 MGD Phase-II	Inlet	7	308	182	584		35	4.5
		outlet	7.2	24	15	80		15	2
	Real Time Reading at Outlet								
	25 MGD Phase-III	Inlet	7.2	600	313	1281		30	4.5
		outlet	7.3	27	18	104		20	1.5
	Real Time Reading at Outlet		7	32	19	82		12	
Rithala	40 MGD	Inlet	7.1	268	169	370	26	34	1.4
		outlet	7.6	29	19	90	9	21	1.1
	Real Time Reading at Outlet		ND	ND	ND	ND		ND	
	40 MGD	Inlet	7.1	268	169	370	26	34	1.4
		Outlet	7.5	19	14	70	5	16	0.9
	Real Time Reading at Outlet		ND	ND	ND	ND		ND	
Corronation pillar	20 MGD Phase-I & II	Inlet	7	234	185	342	35	10.5	7.8
		outlet	7.6	80	73	118	23	6.4	3
	Real Time Reading at Outlet								
	10 MGD Phase-III	Inlet	7	332	305	404	59	13.8	
		outlet	7.4	128	113	130	41	7.2	
	Real Time Reading at Outlet		62.3	32.3	87.7	10.4			
Rohiini 15 MGD	15 MGD	Inlet	7.2	260	155	-	-	54	6.5
		Outlet	7.8	28	17	-	-	16	4.5
	Real Time Reading at Outlet		7.7	56.7	43.7	121.2	14.9		
KESHOPUR	12 MGD	Inlet	7.3	444	200	-	16	31	3.2
	(PH-I)	Outlet	7.6	11	4	-	0	1	2.3
	Real time reading at OUTLET(online)		7.08	0	4.16	24.6	-	0.96	-
	20 MGD	Inlet	7.3	420	226	-	12.6	36	3.5
	(PH-II)	Outlet	7.6	96	81	-	3.8	29	3
	Real time reading at OUTLET(online)		7.63	464.42	70.77	622.3	-	182.25	-
	40 MGD	Inlet	7.3	420	226	-	12.6	36	3.5
	(PH-III)	Outlet	7.5	140	110	-	3	28	3.2
	Real time reading at OUTLET(online)		7.79	101.1	58.95	179.4	-	24.83	-
DARBANKALAN	(20 MGD)	Inlet	7.3	294	217	740	-	40	5
	PH-I	Outlet	7.7	62	32	120	-	18	1.4
	Real time reading at OUTLET(online)		7.58	54.3	30.66	82.69	-	23.4	-

TAFELANG	(20 MGD)	Inlet	7.3	329	225	780	-	38	5.2
	PH-II	Outlet	7.6	6	5	20	-	1.8	4.4
	Real time reading at OUTLET(online)		6.48	6.17	6.69	40.16	-	0.39	-
NAJAFGARH	(05 MGD)	Inlet	7.3	311	208	-	-	34	4.2
		Outlet	7.6	34	23	-	-	10	3.8
	Real time reading at OUTLET(online)		7.54	40.95	26.66	101.82	-	18	-
Okhla	12 MGD	Inlet	7.4	254	173	392	-	40	2.2
		outlet	7.6	43	29	112	-	36	1.8
	Real Time Reading at Outlet								
	45 MGD	Inlet	7.4	264	193	392	-	42	2
		outlet	7.6	41	28	104	-	34	0.8
	Real Time Reading at Outlet								
	37 MGD	Inlet	7.4	264	193	392	-	42	2
		outlet	7.7	19	13	48	-	30	1
	Real Time Reading at Outlet								
	16 MGD	Inlet	7.4	264	193	392	-	42	2
		outlet	7.6	28	18	72	-	28	0.5
	Real Time Reading at Outlet								

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Name of the Plant	Capacity (in MGD)	04.01.2020		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC Limit	50	30	250
Yamuna Vihar	10 MGD Phase-I	45	19	136
	10 MGD Phase-II	24	15	80
	25 MGD Phase-III	27	18	104
Rithala	40 MGD	29	19	90
	40 MGD	19	14	70
Corronation pillar	20 MGD Phase-I &II	80	73	118
	10 MGD Phase-III	128	113	130
Rohiini 15 MGD	15 MGD	28	17	-
KESHOPUR	12 MGD	11	4	-
	20 MGD	96	81	-
	40 MGD	140	110	-
PAPPANKALAN	(20 MGD)	62	32	120
	(20 MGD)	6	5	20
NAJAFGARH	05 MGD	34	23	-
Okhla	12 MGD	43	29	112
	45 MGD	41	28	104
	37 MGD	19	13	48
	16 MGD	28	18	72

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Parameters of STPs of Delhi as on							05.01.2020		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Yamuna Vihar	10 MGD Phase-I	Inlet	6.9	260	181			50	5
		outlet	7.3	39	25			30	2.5
	Real Time Reading at								
	10 MGD Phase-II	Inlet	7.2	208	133			45	4
		outlet	7.3	33	22			25	2
	Real Time Reading at								
	25 MGD Phase-III	Inlet	7.2	544	318			55	6
		outlet	7.3	42	26			35	4
	Real Time Reading at								
Rithala	40 MGD	Inlet	7.1	232	174	370	ND	35	1.1
		outlet	7.7	30	20	80	ND	25	0.8
	Real Time Reading at		ND	ND	ND	ND		ND	
	40 MGD	Inlet	7.1	232	174	370	ND	35	1.1
		Outlet	7.5	17	12	60	ND	18	0.7
	Real Time Reading at		ND	ND	ND	ND		ND	
Corronation pillar	20 MGD Phase-I	Inlet	7.1	252	215	364	39	11.6	
		outlet	7.5	88	75	122	27	6.2	
	Real Time Reading at		7.6	73.9	33.2	99.4	18.3		
	10 MGD Phase-III	Inlet	7.1	296	300	398	57	12.4	6
		outlet	7.5	126	115	138	39	6.8	1.8
	Real Time Reading at		7.6	55.4	31.1	119.5	17.5		
Rohiini 15 MGD	15 MGD	Inlet	7.3	200	148	451	-	50	7.0
		Outlet	7.5	35	22	99	-	15	5
	Real Time Reading at								
KESHOPUR	12 MGD (PH-I)	Inlet	7.3	376	174	-	-	30	3.1
		Outlet	7.5	12	5	-	-	2	2.2
	Real time reading at		7.02	6.87	3.13	25.62	-	1.03	-
	20 MGD (PH-II)	Inlet	7.3	360	181	-	-	32	3.2
		Outlet	7.6	84	78	-	-	27	3
	Real time reading at		7.61	852.9	72.75	869.36	-	176.7	-
	40 MGD (PH-III)	Inlet	7.3	360	181	-	-	32	3.2
		Outlet	7.5	124	102	-	-	28	3.2
	Real time reading at		7.79	107.77	65.58	201.39	-	43.7	-
DARBANKALANI	(20 MGD)	Inlet	7.3	310	210	-	-	40	5
	PH-I	Outlet	7.8	64	36	-	-	20	1.6
	Real time reading at		7.37	54.66	33.73	87.07	-	21.65	-

CAFFAINALAN	(20 MGD)	Inlet	7.3	324	215	-	-	38	4.8
	PH-II	Outlet	7.7	5	5	-	-	1.6	4
	Real time reading at		6.55	6.2	6.72	40.41	-	0.4	-
Okhla	12 MGD	Inlet	7.3	258	193	456	3	39	1.5
		outlet	7.6	39	25	104	1	31	1.1
	Real Time Reading at								
	45 MGD	Inlet	7.4	268	215	464	3	40	1.6
		outlet	7.6	38	24	104	1	32	1
	Real Time Reading at								
	37 MGD	Inlet	7.4	268	215	464	3	40	1.6
		outlet	7.8	21	14	48	1	29	1
	Real Time Reading at								
	16 MGD	Inlet	7.4	268	215	464	3	40	1.6
		outlet	7.7	22	13	56	1	30	0.7
	Real Time Reading at								

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Name of the Plant	Capacity (in MGD)	05.01.2020		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC Limit	50	30	250
Yamuna Vihar	10 MGD Phase-I	39	25	-
	10 MGD Phase-II	33	22	-
	25 MGD Phase-III	42	26	-
Rithala	40 MGD	30	20	80
	40 MGD	17	12	60
Corronation pillar	20 MGD Phase-I &II	88	75	122
	10 MGD Phase-III	126	115	138
Rohiini 15 MGD	15 MGD	35	22	99
KESHOPUR	12 MGD	12	5	-
	20 MGD	84	78	-
	40 MGD	124	102	-
PAPPANKALAN	(20 MGD)	64	36	-
	(20 MGD)	5	5	-
Okhla	12 MGD	39	25	104
	45 MGD	38	24	104
	37 MGD	21	14	48
	16 MGD	22	13	56

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Parameters of STPs of Delhi as on							06.01.2020		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Yamuna Vihar	10 MGD Phase-I	Inlet	7	304	226			50	3.5
		outlet	7.2	30	18			20	1.5
	Real Time Reading at Outlet		7.2	55	22	168		12	
	10 MGD Phase-II	Inlet	7.2	268	188			35	3
		outlet	7.3	26	19			15	1.5
	Real Time Reading at Outlet								
	25 MGD Phase-III	Inlet	7.3	496	301			45	4
		outlet	7.3	35	25			15	2.5
Real Time Reading at Outlet		7.1	32	22	99		12		
Rithala	40 MGD	Inlet	7	308	177	450	ND	31	1.3
		outlet	7.6	29	19	100	ND	17	0.8
	Real Time Reading at Outlet								
	40 MGD	Inlet	7	308	177	450	ND	31	1.3
		Outlet	7.7	20	14	70	ND	14	0.5
Real Time Reading at Outlet									
Corronation pillar	20 MGD Phase-I &II	Inlet	6.9	232	210	338	31	11.9	7.2
		outlet	7.5	78	72	120	22	5.8	2.4
	Real Time Reading at Outlet		7.6	99.7	35	108.4	10.2		
	10 MGD Phase-III	Inlet	7.2	340	310	416	52	14	7.8
		outlet	7.7	138	120	146	42	7.2	2.6
Real Time Reading at Outlet		7.4	55.4	35.1	122.5	18.9			
Rohiini 15 MGD	15 MGD	Inlet	7.1	264	158	-	-	38	6.5
		Outlet	7.5	32	20	-	-	14	4.5
	Real Time Reading at Outlet								
KESHOPUR	12 MGD (PH-I)	Inlet	7.3	628	224	672	-	30	3.2
		Outlet	7.6	14	6	32	-	1	2.5
	Real time reading at OUTLET(online)		7	2.52	5.7	28.59	-	1.05	-
	20 MGD (PH-II)	Inlet	7.3	468	234	680	-	31	3.5
		Outlet	7.5	90	82	280	-	28	2.9
	Real time reading at OUTLET(online)		7.6	1025.93	73.44	987.55	-	169.1	-
	40 MGD (PH-III)	Inlet	7.3	468	234	680	-	31	3.5
		Outlet	7.5	132	110	356	-	29	3.2
	Real time reading at OUTLET(online)		7.72	104.47	65.4	196.17	-	23.44	-
NILOTHI	20 MGD (PH-II)	Inlet	7.1	304	167	540	-	32	3
		Outlet	7.4	9	7	28	-	8	1.6
	Real time reading OUTLET(online)		6.98	7.28	3.27	25.24	-	2.07	-

PAPPANKALAN	(20 MGD)	Inlet	7.4	315	208	-	-	45	5.4
	PH-I	Outlet	7.8	81	40	-	-	25	1.2
	Real time reading at OUTLET(online)		7.46	67.69	41.63	104.99	-	25.3	-
	(20 MGD)	Inlet	7.4	269	182	-	-	43	5.2
	PH-II	Outlet	7.6	6	5	-	-	2.1	4.8
	Real time reading at OUTLET(online)		6.73	6.17	6.61	39.92	-	0.39	-
NAJAFGARH	(05 MGD)	Inlet	7.5	332	212	-	-	32	5
		Outlet	7.7	19	10	-	-	9	4.4
	Real time reading at OUTLET(online)		7.5	43.34	25.87	104.23	-	18.09	-
Okhla	12 MGD	Inlet	7.4	226	186	384	-	38	2.6
		outlet	7.6	40	26	104	-	32	1.6
	Real Time Reading at Outlet								
	45 MGD	Inlet	7.4	226	199	400	-	37	2
		outlet	7.7	39	25	104	-	33	1
	Real Time Reading at Outlet								
	37 MGD	Inlet	7.4	226	199	400	-	37	2
		outlet	7.8	20	15	56	-	29	0.7
	Real Time Reading at Outlet								
	16 MGD	Inlet	7.4	226	199	400	-	37	2
		outlet	7.7	30	19	72	-	31	0.6
	Real Time Reading at Outlet								

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Name of the Plant	Capacity (in MGD)	06.01.2020		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC Limit	50	30	250
Yamuna Vihar	10 MGD Phase-I	30	18	-
	10 MGD Phase-II	26	19	-
	25 MGD Phase-III	35	25	-
Rithala	40 MGD	29	19	100
	40 MGD	20	14	70
Corronation pillar	20 MGD Phase-I &II	78	72	120
	10 MGD Phase-III	138	120	146
Rohiini 15 MGD	15 MGD	32	20	-
KESHOPUR	12 MGD	14	6	32
	20 MGD	90	82	280
	40 MGD	132	110	356
	20 MGD	9	7	28
PAPPANKALAN	(20 MGD)	81	40	-
	(20 MGD)	6	5	-
NAJAFGARH	05 MGD	19	10	-
Okhla	12 MGD	40	26	104
	45 MGD	39	25	104
	37 MGD	20	15	56
	16 MGD	30	19	72

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Parameters of STPs of Delhi as on							07.01.2020		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Yamuna Vihar	10 MGD Phase-I	Inlet	7.4	376	243	608	24	55	4
		outlet	7.4	36	16	120	13.2	25	2
		Real Time Reading at	7.1	46	15	99		12	
	10 MGD Phase-II	Inlet	7	232	160	424	17.6	35	2.5
		outlet	7.4	30	21	96	9.6	25	2
		Real Time Reading at							
	25 MGD Phase-III	Inlet	7.3	544	289	872	22	40	3.5
		outlet	7.4	38	23	120	8.2	15	2
		Real Time Reading at	7.1	30	18	75		12	
Rithala	40 MGD	Inlet	7.1	284	133	410	ND	32	1.1
		outlet	7.7	28	21	80	ND	15	0.7
		Real Time Reading at	7.65	33.83	25.42	97.46		9.82	
	40 MGD	Inlet	7.1	284	133	410	ND	32	1.1
		Outlet	7.8	16	13	60	ND	12	0.5
		Real Time Reading at	7.1	19.62	10.69	46.59		11.6	
Corronation pillar	20 MGD Phase-I	Inlet	7	210	220	312	37	10.9	
		outlet	7.5	92	74	126	26	6.1	
		Real Time Reading at	7.4	135	37	140	11		
	10 MGD Phase-III	Inlet	7.1	382	330	428	49	13.6	6.8
		outlet	7.7	172	129	154	38	7.4	2.8
Rohiini 15 MGD	15 MGD	Inlet	7.2	184	135	467	-	53	9.0
		Outlet	7.6	30	19	90	-	16	5
	Real Time Reading at								
KESHOPUR	12 MGD (PH-I)	Inlet	7.4	416	183	-	-	34	3.9
		Outlet	7.6	11	6	-	-	1	2.8
		Real time reading at	NA	NA	NA	NA	NA	NA	NA
	20 MGD (PH-II)	Inlet	7.3	532	290	-	-	33	3.2
		Outlet	7.6	104	84	-	-	31	2.7
		Real time reading at	7.58	414.35	62.53	500.77	-	33.75	-
	40 MGD (PH-III)	Inlet	7.3	532	290	-	-	33	3.2
		Outlet	7.6	132	99	-	-	29	3
		Real time reading at	7.64	71.39	66.06	142.01	-	1500	-
NILOTHI	20 MGD (PH-II)	Inlet	7	322	169	-	9.1	30	3
		Outlet	7.3	8	7	-	0	5	1.8
	Real time reading		7.02	7.21	4.23	25.17	-	2.01	-

PAPPANKALAN	(20 MGD)	Inlet	7.4	289	192	480	-	42	5.5
	PH-I	Outlet	7.9	61	31	220	-	23	1.5
	Real time reading at		7.5	123.16	39.26	115.88	-	21	-
	(20 MGD)	Inlet	7.2	268	188	-	-	40	5.4
	PH-II	Outlet	7.5	4	4	-	-	2.4	4.1
	Real time reading at		6.79	6.16	6.64	39.89	-	0.4	-
NAJAFGARH	(05 MGD)	Inlet	7.4	324	208	720	-	33	5.3
		Outlet	7.8	19	13	80	-	11	3
	Real time reading at		7.46	48.55	27.08	115.52	-	18.21	-
Okhla	12 MGD	Inlet	7.6	140	170	344	5	43	2.2
		outlet	7.8	40	23	96	2	35	1.2
	Real Time Reading at								
	45 MGD	Inlet	7.6	196	159	376	4	41	2.4
		outlet	7.7	39	23	88	1	33	0.8
	Real Time Reading at								
	37 MGD	Inlet	7.6	196	159	376	4	41	2.4
		outlet	7.8	18	13	48	NIL	29	0.6
	Real Time Reading at								
	16 MGD	Inlet	7.6	196	159	376	4	41	2.6
		outlet	7.7	27	16	64	1	31	2.4
	Real Time Reading at								

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Name of the Plant	Capacity (in MGD)	07.01.2020		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC Limit	50	30	250
Yamuna Vihar	10 MGD Phase-I	36	16	120
	10 MGD Phase-II	30	21	96
	25 MGD Phase-III	38	23	120
Rithala	40 MGD	28	21	80
	40 MGD	16	13	60
Corronation pillar	20 MGD Phase-I &II	92	74	126
	10 MGD Phase-III	172	129	154
Rohiini 15 MGD	15 MGD	30	19	90
KESHOPUR	12 MGD	11	6	-
	20 MGD	104	84	-
	40 MGD	132	99	-
NILOTHI	20 MGD	8	7	-
PAPPANKALAN	(20 MGD)	61	31	220
	(20 MGD)	4	4	-
NAJAFGARH	05 MGD	19	13	80
Okhla	12 MGD	40	23	96
	45 MGD	39	23	88
	37 MGD	18	13	48
	16 MGD	27	16	64

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Parameters of STPs of Delhi as on							08.01.2020		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Yamuna Vihar	10 MGD Phase-I	Inlet	7.3	444	260			35	2.5
		outlet	7.5	37	23			10	2
		Real Time Reading at	7.2	42	11	67		10	
	10 MGD Phase-II	Inlet	7.2	376	215			20	2
		outlet	7.4	44	26			10	1.5
		Real Time Reading at							
	25 MGD Phase-III	Inlet	7.2	644	374			40	3.5
		outlet	7.4	46	24			25	2
Real Time Reading at		7	22	7	107		12		
Rithala	40 MGD	Inlet	6.9	220	136	210	14	17	0.6
		outlet	7.5	31	17	80	6	12	0.4
		Real Time Reading at	ND	ND	ND	ND		ND	
	40 MGD	Inlet	6.9	220	136	210	14	17	0.6
		Outlet	7.6	18	12	50	6	12	0.4
	Real Time Reading at	ND	ND	ND	ND		ND		
Corronation pillar	20 MGD Phase-I	Inlet	6.8	202	215	296	28	10.2	6.8
		outlet	7.4	88	70	114	20	5.8	2
		Real Time Reading at	7.5	150	31	134	11		
	10 MGD Phase-III	Inlet	7	376	325	420	46	12.8	
		outlet	7.5	168	125	150	32	7	
	Real Time Reading at	7.3	56	33	115	21			
Rohiini 15 MGD	15 MGD	Inlet	7.2	168	133	-	-	40	8.5
		Outlet	7.4	46	27	-	-	16	4.5
	Real Time Reading at								
KESHOPUR	12 MGD (PH-I)	Inlet	7.4	416	232	773	15	34	4.2
		Outlet	7.5	7	3	28	0	1	3.2
		Real time reading at	6.95	17.86	6.31	32.58	-	1.15	-
	20 MGD (PH-II)	Inlet	7.4	444	232	853	12.4	31	3
		Outlet	7.6	78	75	304	1.2	32	2.9
		Real time reading at	7.57	254.56	58.63	381.7	-	33.25	-
	40 MGD (PH-III)	Inlet	7.4	444	232	853	12.4	31	3
		Outlet	7.6	146	112	416	4	30	3
Real time reading at									
PAPPANKALAN	(20 MGD) PH-I	Inlet	7.3	310	207	-	16.8	40	5.3
		Outlet	7.8	64	32	-	2	22	1.4
	Real time reading at	6.36	62.52	31.49	89.67	-	12.1	-	
	(20 MGD) PH-II	Inlet	7.4	285	179	-	-	38	5
		Outlet	7.7	5	5	-	-	2.5	4
	Real time reading at	6.81	6.37	6.71	40.91	-	0.4	-	

Okhla	12 MGD	Inlet	7.4	274	195	448	3	41	1.8
		outlet	7.6	41	26	104	1	33	0.8
	Real Time Reading at								
	45 MGD	Inlet	7.3	272	233	456	3	38	2
		outlet	7.7	39	24	96	1	32	0.8
	Real Time Reading at								
	37 MGD	Inlet	7.3	272	233	456	3	38	2
		outlet	7.7	19	13	48	NIL	30	0.4
	Real Time Reading at								
	16 MGD	Inlet	7.3	272	233	456	3	38	2
		outlet	7.6	32	21	72	NIL	29	0.7
	Real Time Reading at								

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Name of the Plant	Capacity (in MGD)	08.01.2020		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC Limit	50	30	250
Yamuna Vihar	10 MGD Phase-I	37	23	-
	10 MGD Phase-II	44	26	-
	25 MGD Phase-III	46	24	-
Rithala	40 MGD	31	17	80
	40 MGD	18	12	50
Corronation pillar	20 MGD Phase-I &II	88	70	114
	10 MGD Phase-III	168	125	150
Rohiini 15 MGD	15 MGD	46	27	-
KESHOPUR	12 MGD	7	3	28
	20 MGD	78	75	304
	40 MGD	146	112	416
PAPPANKALAN	(20 MGD)	64	32	-
	(20 MGD)	5	5	-
Okhla	12 MGD	41	26	104
	45 MGD	39	24	96
	37 MGD	19	13	48
	16 MGD	32	21	72

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Parameters of STPs of Delhi as on							09.01.2020		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Yamuna Vihar	10 MGD Phase-I	Inlet	7.3	376	202			40	3
		outlet	7.5	43	25			10	1.5
	Real Time Reading at		7.1	41	10	61		10	
	10 MGD Phase-II	Inlet	7.4	408	262			25	2.5
		outlet	7.4	48	26			10	1
	Real Time Reading at								
	25 MGD Phase-III	Inlet	7.3	500	319			45	3.5
		outlet	7.2	38	20			15	1.5
Real Time Reading at		7.2	41	10	61		10		
Rithala	40 MGD	Inlet	7	320	173	330	ND	32	1.6
		outlet	7.7	29	19	90	ND	24	1
	Real Time Reading at		7.65	30.1	18.49	87.06		12.4	
	40 MGD	Inlet	7	320	173	330	ND	32	1.6
		Outlet	7.6	16	13	60	ND	17	0.6
	Real Time Reading at		6.94	17.91	10.14	42.35		11.33	
Corronation pillar	20 MGD Phase-I	Inlet	6.9	312	260	416	33	10.6	
		outlet	7.5	98	80	130	75		
	Real Time Reading at		7.5	41	31	75	10		
	10 MGD Phase-III	Inlet	6.9	348	320	438	59	12.4	7
		outlet	7.4	150	123	160	44	6.9	3.8
	Real Time Reading at		7.3	53	32	111	20		
Rohiini 15 MGD	15 MGD	Inlet	7.1	196	145	440	-	45	7
		Outlet	7.6	32	20	84	-	17	3.5
	Real Time Reading at								
KESHOPUR	12 MGD (PH-I)	Inlet	7.3	404	207	-	-	32	3.8
		Outlet	7.6	9	8	-	-	1	3.1
	Real time reading at		7.03	19.15	3.66	23.18	-	1.11	-
	20 MGD (PH-II)	Inlet	7.3	540	231	-	-	30	3.2
		Outlet	7.6	72	65	-	-	30	2.9
	Real time reading at		7.59	297.19	66.59	503.85	-	23.25	-
	40 MGD (PH-III)	Inlet	7.3	540	231	-	-	30	3.2
		Outlet	7.5	138	112	-	-	28	3
	Real time reading at		NA	NA	NA	NA	NA	NA	NA
NILOTHI	20 MGD (PH-II)	Inlet	7.2	298	163	-	-	32	2.8
		Outlet	7.4	7	5	-	-	2	1.5
	Real time reading		6.95	6.88	5.72	25.1	-	1.98	-
	(20 MGD)	Inlet	7.3	321	205	-	-	42	5.5

PAPPANKALAN	PH-I	Outlet	7.7	71	32	-	-	22	1
	Real time reading at		6.05	68.04	33.55	94.7	-	25.1	-
	(20 MGD)	Inlet	7.3	292	185	-	-	40	5.1
	PH-II	Outlet	7.5	6	5	-	-	2.4	3.8
	Real time reading at		6.68	6.31	6.67	40.66	-	0.39	-
NAJAFGARH	(05 MGD)	Inlet	7.4	333	215	-	-	38	4.9
		Outlet	7.7	21	12	-	-	9	3
	Real time reading at		7.38	170.23	50.45	353.47	-	18.93	-
Okhla	12 MGD	Inlet	7.4	254	172	424	4	39	1.9
		outlet	7.7	38	24	96	1	32	1
	Real Time Reading at								
	45 MGD	Inlet	7.4	258	176	440	4	38	1.8
		outlet	7.6	36	23	88	1	30	1
	Real Time Reading at								
	37 MGD	Inlet	7.4	258	176	440	4	38	1.8
		outlet	7.6	25	15	64	NIL	31	NIL
	Real Time Reading at								
	16 MGD	Inlet	7.4	258	176	440	4	38	1.8
		outlet	7.7	30	19	72	NIL	28	NIL
	Real Time Reading at								

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Name of the Plant	Capacity (in MGD)	09.01.2020		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC Limit	50	30	250
Yamuna Vihar	10 MGD Phase-I	43	25	-
	10 MGD Phase-II	48	26	-
	25 MGD Phase-III	38	20	-
Rithala	40 MGD	29	19	90
	40 MGD	16	13	60
Corronation pillar	20 MGD Phase-I &II	98	80	130
	10 MGD Phase-III	150	123	160
Rohiini 15 MGD	15 MGD	32	20	84
KESHOPUR	12 MGD	9	8	-
	20 MGD	72	65	-
	40 MGD	138	112	-
	20 MGD	7	5	-
PAPPANKALAN	(20 MGD)	71	32	-
	(20 MGD)	6	5	-
NAJAFGARH	05 MGD	21	12	-
Okhla	12 MGD	38	24	96
	45 MGD	36	23	88
	37 MGD	25	15	64
	16 MGD	30	19	72

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Parameters of STPs of Delhi as on							10.01.2020		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Yamuna Vihar	10 MGD Phase-I	Inlet	7.2	312	188	656		50	5
		outlet	7.5	30	20	88		20	2
		Real Time Reading at	7	37	9	48		10	
	10 MGD Phase-II	Inlet	7.3	316	198	664		25	4
		outlet	7.3	26	18	72		20	2
		Real Time Reading at							
	25 MGD Phase-III	Inlet	7.1	572	227	1136		30	4.5
		outlet	7.3	39	25	120		25	2.5
		Real Time Reading at							
Rithala	40 MGD	Inlet	7.1	268	185	420	ND	27	0.8
		outlet	7.7	28	18	90	ND	16	0.5
		Real Time Reading at	7.61	30.95	21.59	91.17		11.7	
	40 MGD	Inlet	7.1	268	185	420	ND	27	0.8
		Outlet	7.8	17	12	60	ND	12	0.3
		Real Time Reading at	6.94	19.46	10.33	44.12		11.33	
Corronation pillar	20 MGD Phase-I	Inlet	6.8	276	220	386	39	10	7.6
		outlet	7.6	106	82	156	21	6.2	3.6
		Real Time Reading at	7.6	46.2	31.8	81.1	10.3		
	10 MGD Phase-III	Inlet	7	359	328	456	56	12.2	
		outlet	7.5	154	120	162	39	7.2	
		Real Time Reading at	7.4	57.1	32.9	116.1	19.1		
Narela	10 MGD Phase-III	Inlet	7.1	248	225	354	36	9.6	7.8
		outlet	7.5	32	23	78	18	3.9	3
		Real Time Reading at	7.4	28.6	19.7	78.9	5.1		
Rohiini 15 MGD	15 MGD	Inlet	7.1	188	148	-	-	50	6
		Outlet	7.4	42	25	-	-	17	4
	Real Time Reading at								
KESHOPUR	12 MGD (PH-I)	Inlet	7.3	608	210	-	-	33	3.6
		Outlet	7.6	13	8	-	-	1	2.9
		Real time reading at	6.99	5.59	2.3	21.14	-	1.03	-
	20 MGD (PH-II)	Inlet	7.3	296	179	-	-	31	3.3
		Outlet	7.6	88	74	-	-	29	2.8
		Real time reading at	7.57	205.05	141.3	413.68	-	35.65	-
	40 MGD (PH-III)	Inlet	7.3	296	179	-	-	31	3.3
		Outlet	7.5	132	109	-	-	29	3.1
		Real time reading at	NA	NA	NA	NA	NA	NA	NA
	(20 MGD)	Inlet	7.4	376	215	-	-	56	5.8

PAPPANKALAN	PH-I	Outlet	7.7	55	30	-	-	18	7
	Real time reading at		6.23	88.3	41.97	117.28	-	14.75	-
	(20 MGD)	Inlet	7.4	349	202	-	15.6	55	5.1
	PH-II	Outlet	7.5	5	4	-	0	2.5	6
	Real time reading at		NA	NA	NA	NA	NA	NA	NA
NAJAFGARH	(05 MGD)	Inlet	7.5	292	194	-	11.3	53	5.2
		Outlet	7.7	32	23	-	0.2	16	4
	Real time reading at		7.45	75	38.22	181.32	-	17.81	-
Okhla	12 MGD	Inlet	7.4	280	190	448	-	40	2
		outlet	7.7	44	28	112	-	32	1.1
	Real Time Reading at								
	45 MGD	Inlet	7.3	228	152	424	-	42	2.1
		outlet	7.6	46	25	112	-	30	1
	Real Time Reading at								
	37 MGD	Inlet	7.3	228	152	424	-	42	2.1
		outlet	7.7	19	12	48	-	29	0.7
	Real Time Reading at								
	16 MGD	Inlet	7.3	228	152	424	-	42	2.1
		outlet	7.6	8	8	32	-	29	0.6
	Real Time Reading at								
	New 30 MGD	Inlet	7.4	286	207	456	-	39	1.8
		outlet	7.7	10	9	40	-	3	0.5
	Real Time Reading at								

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Name of the Plant	Capacity (in MGD)	10.01.2020		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC Limit	50	30	250
Yamuna Vihar	10 MGD Phase-I	30	20	88
	10 MGD Phase-II	26	18	72
	25 MGD Phase-III	39	25	120
Rithala	40 MGD	28	18	90
	40 MGD	17	12	60
Corronation pillar	20 MGD Phase-I &II	106	82	156
	10 MGD Phase-III	154	120	162
Narela	10 MGD Phase-III	32	23	78
Rohiini 15 MGD	15 MGD	42	25	-
KESHOPUR	12 MGD	13	8	-
	20 MGD	88	74	-
	40 MGD	132	109	-
PAPPANKALAN	(20 MGD)	55	30	-
	(20 MGD)	5	4	-
NAJAFGARH	05 MGD	32	23	-
Okhla	12 MGD	44	28	112
	45 MGD	46	25	112
	37 MGD	19	12	48
	16 MGD	8	8	32
	New 30 MGD	10	9	40

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Parameters of STPs of Delhi as on							11.01.2020		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Yamuna Vihar	10 MGD Phase-I	Inlet	7.3	388	227			40	4.5
		outlet	7.4	21	19			15	2.5
		Real Time Reading at	7.1	38	9	46		10	
	10 MGD Phase-II	Inlet	7.1	340	187			30	4
		outlet	7.4	29	21			10	2
		Real Time Reading at							
	25 MGD Phase-III	Inlet	7.2	496	376			55	3.5
		outlet	7.4	46	24			20	2.0
		Real Time Reading at							
Rithala	40 MGD	Inlet	7.1	264	198	380	ND	29	1.6
		outlet	7.6	29	20	80	ND	15	0.8
		Real Time Reading at	7.52	35.31	26.88	99.65		12.8	
	40 MGD	Inlet	7.1	264	198	380	ND	29	1.6
		Outlet	7.7	17	13	70	ND	10	0.4
	Real Time Reading at	6.91	20.07	10.76	47.31		11.29		
Corronation pillar	20 MGD Phase-I	Inlet	6.9	256	210	328	44	10.8	
		outlet	7.5	66	70	128	27	6	
		Real Time Reading at	7.6	49.9	31.9	82.4	10.6		
	10 MGD Phase-III	Inlet	7.1	312	305	376	59	13.8	7.8
		outlet	7.6	124	115	140	41	8	3.4
	Real Time Reading at	7.6	59.4	34.1	124	15.8			
Rohiini 15 MGD	15 MGD	Inlet	7.3	240	160	518	-	48	12.5
		Outlet	7.7	37	22	80	-	14	6
	Real Time Reading at								
KESHOPUR	12 MGD (PH-I)	Inlet	7.4	392	206	-	14.4	34	3.7
		Outlet	7.6	14	6	-	0	1	2.7
		Real time reading at	6.96	6.46	2.62	21.8	-	0.99	-
	20 MGD (PH-II)	Inlet	7.4	356	189	-	11	36	3.4
		Outlet	7.6	116	83	-	1.8	28	3.2
		Real time reading at	7.83	96.44	96.37	245.59	-	3.75	-
	40 MGD (PH-III)	Inlet	7.4	356	189	-	11	36	3.4
		Outlet	7.5	124	105	-	3.2	30	3.1
		Real time reading at	NA	NA	NA	NA	NA	NA	NA
DARBANKALAN	(20 MGD) PH-I	Inlet	7.3	365	238	-	-	52	6
		Outlet	7.8	54	32	-	-	20	7.5
	Real time reading at	5.98	177.33	54.05	168.67	-	41.25	-	

Paffanbagan	(20 MGD)	Inlet	7.3	328	220	-	-	50	5
	PH-II	Outlet	7.5	5	4	-	-	2.4	5.6
	Real time reading at		6.57	6.67	6.79	42.35	-	0.39	-
Okhla	12 MGD	Inlet	7.3	292	215	464	4	43	2.8
		outlet	7.6	41	27	104	1	35	1.4
	Real Time Reading at								
	45 MGD	Inlet	7.4	252	160	424	3	41	2.2
		outlet	7.6	38	24	96	1	33	1.2
	Real Time Reading at								
	37 MGD	Inlet	7.4	252	160	424	3	41	2.2
		outlet	7.5	18	13	48	1	30	0.9
	Real Time Reading at								
	16 MGD	Inlet	7.4	252	160	424	3	41	2.2
		outlet	7.6	21	13	56	NIL	32	1
	Real Time Reading at								

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Name of the Plant	Capacity (in MGD)	11.01.2020		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC Limit	50	30	250
Yamuna Vihar	10 MGD Phase-I	21	19	-
	10 MGD Phase-II	29	21	-
	25 MGD Phase-III	46	24	-
Rithala	40 MGD	29	20	80
	40 MGD	17	13	70
Corronation pillar	20 MGD Phase-I &II	66	70	128
	10 MGD Phase-III	124	115	140
Rohiini 15 MGD	15 MGD	37	22	80
KESHOPUR	12 MGD	14	6	-
	20 MGD	116	83	-
	40 MGD	124	105	-
PAPPANKALAN	(20 MGD)	54	32	-
	(20 MGD)	5	4	-
Okhla	12 MGD	41	27	104
	45 MGD	38	24	96
	37 MGD	18	13	48
	16 MGD	21	13	56

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Parameters of STPs of Delhi as on							12.01.2020		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Yamuna Vihar	10 MGD Phase-I	Inlet	7.1	296	191	608		55	4
		outlet	7.4	35	23	96		25	1.5
		Real Time Reading at	7.1	38	9	46		10	
	10 MGD Phase-II	Inlet	7.2	256	159	544		45	3.5
		outlet	7.4	22	14	80		35	1.5
		Real Time Reading at							
	25 MGD Phase-III	Inlet	7.3	492	282	928		45	4
		outlet	7.4	41	28	120		30	2
		Real Time Reading at	6.8	27	19	80		12	
Rithala	40 MGD	Inlet	7.1	280	193	340	ND	33	1.5
		outlet	7.7	30	22	90	ND	25	1
		Real Time Reading at	7.46	38.99	29.51	105.19		14.4	
	40 MGD	Inlet	7.1	280	193	340	ND	33	1.5
		Outlet	7.5	16	11	60	ND	18	0.4
		Real Time Reading at	6.91	18.64	10.61	45.43		11.29	
Corronation pillar	20 MGD Phase-I	Inlet	6.7	252	215	336	35	11.8	7.8
		outlet	7.3	72	80	134	29	6.8	3.4
		Real Time Reading at	7.6	57.6	32.7	87.3	11.1		
	10 MGD Phase-III	Inlet	6.9	368	325	410	64	14.4	
		outlet	7.4	132	118	144	44	9.2	
		Real Time Reading at	7.7	61.9	35.9	132.1	16.2		
Rohiini 15 MGD	15 MGD	Inlet	7.3	240	160	518	-	48	12.5
		Outlet	7.7	37	22	80	-	14	6
	Real Time Reading at								
KESHOPUR	12 MGD (PH-I)	Inlet	7.3	448	206	-	-	34	3.2
		Outlet	7.7	17	9	-	-	3	2.2
		Real time reading at	6.92	7.09	6.15	31.47	-	0.99	-
	20 MGD (PH-II)	Inlet	7.3	368	198	-	-	33	3.4
		Outlet	7.5	96	72	-	-	28	3.1
		Real time reading at	7.86	155.34	139.48	382.41	-	3.35	-
	40 MGD (PH-III)	Inlet	7.3	368	198	-	-	33	3.4
		Outlet	7.5	114	105	-	-	32	3.1
		Real time reading at	NA	NA	NA	NA	NA	NA	NA
DARBANKALAN	(20 MGD) PH-I	Inlet	7.3	354	228	-	-	50	5.8
		Outlet	7.8	56	33	-	-	20	6
		Real time reading at	6.23	265.7	69.67	227.57	-	16.35	-

Paffanbagan	(20 MGD)	Inlet	7.3	320	209	-	-	48	5.4
	PH-II	Outlet	7.6	5	4	-	-	2.5	5.6
	Real time reading at		6.53	6.64	6.9	42.53	-	0.39	-
Okhla	12 MGD	Inlet	7.4	250	185	432	3	40	2
		outlet	7.6	35	21	80	1	31	1
	Real Time Reading at								
	45 MGD	Inlet	7.4	244	172	424	3	39	1.9
		outlet	7.7	34	21	80	1	32	1
	Real Time Reading at								
	37 MGD	Inlet	7.4	244	172	424	3	39	1.9
		outlet	7.7	15	11	40	NIL	29	0.7
	Real Time Reading at								
	16 MGD	Inlet	7.4	244	172	424	3	39	1.9
		outlet	7.7	20	14	56	NIL	29	0.7
	Real Time Reading at								

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Name of the Plant	Capacity (in MGD)	12.01.2020		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC Limit	50	30	250
Yamuna Vihar	10 MGD Phase-I	35	23	96
	10 MGD Phase-II	22	14	80
	25 MGD Phase-III	41	28	120
Rithala	40 MGD	30	22	90
	40 MGD	16	11	60
Corronation pillar	20 MGD Phase-I &II	72	80	134
	10 MGD Phase-III	132	118	144
Rohiini 15 MGD	15 MGD	37	22	80
KESHOPUR	12 MGD	17	9	-
	20 MGD	96	72	-
	40 MGD	114	105	-
PAPPANKALAN	(20 MGD)	56	33	-
	(20 MGD)	5	4	-
Okhla	12 MGD	35	21	80
	45 MGD	34	21	80
	37 MGD	15	11	40
	16 MGD	20	14	56

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Parameters of STPs of Delhi as on							13.01.2020		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Yamuna Vihar	10 MGD Phase-I	Inlet	7.3	424	237		38.8	55	4.5
		outlet	7.5	58	32		11.6	30	3.5
	Real Time Reading at		7.1	46	12	77		10	
	10 MGD Phase-II	Inlet	7.2	428	264		39.2	45	3
		outlet	7.4	49	28		10	30	2.5
	Real Time Reading at								
	25 MGD Phase-III	Inlet	7.4	640	348		59.6	50	5.5
		outlet	7.5	56	31		6	30	2.5
	Real Time Reading at		7.0	28	19	79		12	
Rithala	40 MGD	Inlet	7	248	179	390	ND	30	1.8
		outlet	7.8	29	20	80	ND	28	1.2
	Real Time Reading at		7.4	38.33	31.89	108.14		15.41	
	40 MGD	Inlet	7	248	179	390	ND	30	1.8
		Outlet	7.6	16	12	50	ND	19	0.8
	Real Time Reading at		7.07	18.82	10.65	45.92		11.55	
Corronation pillar	20 MGD Phase-I	Inlet	7.2	296	230	356	39	11.4	
		outlet	7.6	86	85	138	30	6.2	
	Real Time Reading at		7.6	64.2	32.8	89.6	10.8		
	10 MGD Phase-III	Inlet	7.1	354	323	404	62	13.8	7.6
		outlet	7.5	178	130	220	40	8.6	2.8
	Real Time Reading at		7.5	67.8	36.9	137.5	18.3		
Narela	10 MGD Phase-III	Inlet	7.3	252	221	360	38	10.2	8
		outlet	7.6	41	28	98	16	4.6	3.4
	Real Time Reading at		7.4	30.8	21.4	88.3	5.4		
Rohiini 15 MGD	15 MGD	Inlet	7.4	280	183	579	-	52	10
		Outlet	7.7	35	21	83	-	16	6
	Real Time Reading at								
KESHOPUR	12 MGD (PH-I)	Inlet	7.3	276	189	580	-	33	3.4
		Outlet	7.6	15	6	32	-	2	2.8
	Real time reading at		7	4.96	3.64	22.54	-	0.93	-
	20 MGD (PH-II)	Inlet	7.3	496	284	827	-	34	3.2
		Outlet	7.5	116	86	272	-	29	3
	Real time reading at		7.86	296.27	137.91	477.94	-	3.7	-
	40 MGD (PH-III)	Inlet	7.3	496	284	827	-	34	3.2
		Outlet	7.5	146	127	328	-	31	3.1
	Real time reading at								

NILOTHI	20 MGD	Inlet	7.2	318	164	580	-	32	3
	(PH-II)	Outlet	7.4	7	5	28	-	5	1.5
	Real time reading		7.2	6.71	6.55	24.87	-	1.83	-
PAPPANKALAN	(20 MGD)	Inlet	7.4	223	168	-	15	34	6
	PH-I	Outlet	7.8	78	34	-	3	20	6.4
	Real time reading at		5.92	480.39	93.61	344.27	-	52.4	-
	(20 MGD)	Inlet	7.4	314	200	610	10	32	5.9
	PH-II	Outlet	7.5	7	5	20	0	4	3
	Real time reading at		6.71	6.91	6.96	43.86	-	0.39	-
NAJAFGARH	(05 MGD)	Inlet	7.4	165	133	-	22	42	6.2
		Outlet	7.6	36	25	-	0.4	18	6.5
	Real time reading at		7.31	23.41	18.82	91.45	-	18.48	-
Okhla	12 MGD	Inlet	7.4	344	180	472	-	48	2.9
		outlet	7.7	39	26	96	-	37	1.2
	Real Time Reading at								
	45 MGD	Inlet	7.5	242	183	424	-	46	3
		outlet	7.6	35	21	80	-	35	1.4
	Real Time Reading at								
	37 MGD	Inlet	7.5	242	188	424	-	46	3
		outlet	7.7	12	9	32	-	38	0.9
	Real Time Reading at								
	16 MGD	Inlet	7.5	242	188	424	-	46	3
		outlet	7.7	25	15	64	-	34	0.7
	Real Time Reading at								

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Name of the Plant	Capacity (in MGD)	13.01.2020		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC Limit	50	30	250
Yamuna Vihar	10 MGD Phase-I	58	32	-
	10 MGD Phase-II	49	28	-
	25 MGD Phase-III	56	31	-
Rithala	40 MGD	29	20	80
	40 MGD	16	12	50
Corronation pillar	20 MGD Phase-I &II	86	85	138
	10 MGD Phase-III	178	130	220
Narela	10 MGD Phase-III	41	28	98
Rohiini 15 MGD	15 MGD	35	21	83
KESHOPUR	12 MGD	15	6	32
	20 MGD	116	86	272
	40 MGD	146	127	328
	20 MGD	7	5	28
PAPPANKALAN	(20 MGD)	78	34	-
	(20 MGD)	7	5	20
NAJAFGARH	05 MGD	36	25	-
Okhla	12 MGD	39	26	96
	45 MGD	35	21	80
	37 MGD	12	9	32
	16 MGD	25	15	64

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Parameters of STPs of Delhi as on							14.01.2020		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Yamuna Vihar	10 MGD Phase-I	Inlet	7.2	276	204	611		50	4
		outlet	7.4	46	29	139		30	1.5
		Real Time Reading at	0.2	41	11	64		10	
	10 MGD Phase-II	Inlet	7	348	211	688		35	4.5
		outlet	7.4	40	27	119		20	2
		Real Time Reading at							
	25 MGD Phase-III	Inlet	7.3	508	262	1089		45	3.5
		outlet	7.5	46	27	136		30	2
Real Time Reading at		7	28	19	81		12		
Rithala	40 MGD	Inlet	7.1	288	209	450	ND	38	1.9
		outlet	7.8	28	17	80	ND	26	1.3
	Real Time Reading at		7.46	42.05	28.68	106.49		13.96	
	40 MGD	Inlet	7.1	288	209	450	ND	38	1.9
		Outlet	7.6	18	14	70	ND	21	1.1
Real Time Reading at		7.07	19.72	10.62	46.45		11.55		
Corronation pillar	20 MGD Phase-I	Inlet	7	244	224	306	34	12.2	7
		outlet	7.5	90	88	146	21	7.4	2.8
	Real Time Reading at		7.6	72.3	32.4	91.7	10.6		
	10 MGD Phase-III	Inlet	7.2	392	330	476	57	15.1	
		outlet	7.4	170	128	216	43	9.4	
	Real Time Reading at		7.4	69.3	37.6	141.6	20.4		
Rohiini 15 MGD	15 MGD	Inlet	7.2	560	298	-	-	53	9.0
		Outlet	7.5	39	23	-	-	15	5
	Real Time Reading at								
KESHOPUR	12 MGD (PH-I)	Inlet	7.4	380	193	-	-	32	4.2
		Outlet	7.5	12	6	-	-	1	4
	Real time reading at		6.96	5.53	5.71	18.09	-	0.94	-
	20 MGD (PH-II)	Inlet	7.4	504	259	-	-	30	3.7
		Outlet	7.6	112	86	-	-	31	3.2
	Real time reading at		7.8	140.06	116.97	321.47	-	10.5	-
	40 MGD (PH-III)	Inlet	7.4	504	259	-	-	30	3.7
		Outlet	7.5	134	116	-	-	30	2.9
Real time reading at		7.44	89.2	26.34	70.78	-	40.78	-	
DARBANKALANI	(20 MGD)	Inlet	7.4	306	196	-	-	32	6.1
	PH-I	Outlet	7.7	51	22	-	-	19	6.5
	Real time reading at		5.99	63.92	38.57	102.21	-	82.3	-

Paffanbagan	(20 MGD)	Inlet	7.4	327	206	580	-	30	5.6
	PH-II	Outlet	7.6	6	5	40	-	6	3.2
	Real time reading at		6.68	7.12	7.06	44.89	-	0.38	-
Okhla	12 MGD	Inlet	7.2	230	188	432	3	40	1.8
		outlet	7.6	40	24	96	1	30	1
	Real Time Reading at								
	45 MGD	Inlet	7.5	250	206	448	3	41	1.9
		outlet	7.7	32	22	88	1	31	1.1
	Real Time Reading at								
	37 MGD	Inlet	7.5	250	206	448	3	41	1.9
		outlet	7.6	20	14	56	NIL	29	0.6
	Real Time Reading at								
	16 MGD	Inlet	7.4	250	206	448	3	41	1.9
		outlet	7.6	25	17	64	NIL	30	0.9
	Real Time Reading at								

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Name of the Plant	Capacity (in MGD)	14.01.2020		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC Limit	50	30	250
Yamuna Vihar	10 MGD Phase-I	46	29	139
	10 MGD Phase-II	40	27	119
	25 MGD Phase-III	46	27	136
Rithala	40 MGD	28	17	80
	40 MGD	18	14	70
Corronation pillar	20 MGD Phase-I &II	90	88	146
	10 MGD Phase-III	170	128	216
Rohiini 15 MGD	15 MGD	39	23	-
KESHOPUR	12 MGD	12	6	-
	20 MGD	112	86	-
	40 MGD	134	116	-
PAPPANKALAN	(20 MGD)	51	22	-
	(20 MGD)	6	5	40
Okhla	12 MGD	40	24	96
	45 MGD	32	22	88
	37 MGD	20	14	56
	16 MGD	25	17	64

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Parameters of STPs of Delhi as on							15.01.2020		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Yamuna Vihar	10 MGD Phase-I	Inlet	7.3	512	368			55	3.5
		outlet	7.4	48	28			35	2
		Real Time Reading at	7.2	40	10	62		10	
	10 MGD Phase-II	Inlet	7.2	436	287			35	4
		outlet	7.4	46	26			20	1.5
		Real Time Reading at							
	25 MGD Phase-III	Inlet	7.2	588	382			55	4
		outlet	7.5	43	22			30	2.5
		Real Time Reading at	7	33	19	84		12	
Rithala	40 MGD	Inlet	7.2	272	213	430	ND	34	1.6
		outlet	7.6	31	22	90	ND	28	1.3
		Real Time Reading at	7.38	38.32	28.76	103.99		15.55	
	40 MGD	Inlet	7.2	272	213	430	ND	34	1.6
		Outlet	7.7	17	12	60	ND	19	0.7
		Real Time Reading at	7.07	20.7	11.03	49.11		11.55	
Corronation pillar	20 MGD Phase-I	Inlet	7.1	228	235	320	39	14.6	
		outlet	7.6	78	82	138	19	7.9	
		Real Time Reading at	7.6	89.7	33.7	103.9	10.8		
	10 MGD Phase-III	Inlet	7.1	318	305	380	68	16.4	6
		outlet	7.6	166	126	188	40	10	2.4
		Real Time Reading at	7.6	69.7	36.3	141.3	13.8		
Rohiini 15 MGD	15 MGD	Inlet	7.3	172	140	467	-	55	7.5
		Outlet	7.6	28	17	90	-	18	4.5
	Real Time Reading at								
KESHOPUR	12 MGD (PH-I)	Inlet	7.3	516	183	-	-	33	4
		Outlet	7.6	18	9	-	-	1	3.7
		Real time reading at	6.97	5.88	3.15	23.5	-	0.96	-
	20 MGD (PH-II)	Inlet	7.3	556	225	-	-	31	3.6
		Outlet	7.6	90	81	-	-	30	3.4
		Real time reading at	7.77	126.86	136.91	350.63	-	8.75	-
	40 MGD (PH-III)	Inlet	7.3	556	225	-	-	31	3.6
		Outlet	7.5	164	118	-	-	30	3.4
		Real time reading at							
NILOTHI	20 MGD (PH-II)	Inlet	7.2	316	166		8.6	32	3
		Outlet	7.4	8	6		0	10	1.5
	Real time reading	7.21	7.29	3.22	25.3	-	1.92	-	
	(20 MGD)	Inlet	7.3	343	210	-	8.2	35	7.4

PAPPANKALAN	PH-I	Outlet	7.8	108	42	-	1.3	18	8
	Real time reading at		6.03	111.52	62.28	159.53	-	68.6	-
	(20 MGD)	Inlet	7.3	379	215	-	-	32	7.2
	PH-II	Outlet	7.5	6	5	-	-	8	4
	Real time reading at		6.75	7.04	6.94	44.3	-	40	-
NAJAFGARH	(05 MGD)	Inlet	7.5	299	182	-	-	40	6.3
		Outlet	7.8	24	11	-	-	19	1.5
	Real time reading at		7.44	139.61	52.88	452.47	-	19.41	-
Okhla	12 MGD	Inlet	7.2	388	195	464	-	40	2
		outlet	7.6	37	22	88	-	32	1.1
	Real Time Reading at								
	45 MGD	Inlet	7.3	346	218	480	-	42	2.1
		outlet	7.6	46	29	112	-	33	1
	Real Time Reading at								
	37 MGD	Inlet	7.3	346	218	480	-	42	2.1
		outlet	7.7	16	16	48	-	29	0.7
	Real Time Reading at								
	16 MGD	Inlet	7.3	346	218	480	-	42	2.1
		outlet	7.6	29	21	80	-	29	0.4
	Real Time Reading at								

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Name of the Plant	Capacity (in MGD)	15.01.2020		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC Limit	50	30	250
Yamuna Vihar	10 MGD Phase-I	48	28	-
	10 MGD Phase-II	46	26	-
	25 MGD Phase-III	43	22	-
Rithala	40 MGD	31	22	90
	40 MGD	17	12	60
Corronation pillar	20 MGD Phase-I &II	78	82	138
	10 MGD Phase-III	166	126	188
Rohiini 15 MGD	15 MGD	28	17	90
KESHOPUR	12 MGD	18	9	-
	20 MGD	90	81	-
	40 MGD	164	118	-
	20 MGD	8	6	-
PAPPANKALAN	(20 MGD)	108	42	-
	(20 MGD)	6	5	-
NAJAFGARH	05 MGD	24	11	-
Okhla	12 MGD	37	22	88
	45 MGD	46	29	112
	37 MGD	16	16	48
	16 MGD	29	21	80

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Parameters of STPs of Delhi as on							16.01.2020		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Yamuna Vihar	10 MGD Phase-I	Inlet	7.1	384	196	632		55	3.5
		outlet	7.5	37	23	96		30	2.5
	Real Time Reading at Outlet		7.1	42	12	70		10	
	10 MGD Phase-II	Inlet	7.2	332	161	544		40	4
		outlet	7.5	41	28	88		20	2.5
	Real Time Reading at Outlet								
	25 MGD Phase-III	Inlet	7.1	696	233	1088		55	4.5
		outlet	7.3	38	26	120		25	2
	Real Time Reading at Outlet		6.9	28	20	82		12	
Rithala	40 MGD	Inlet	7.2	260	173	360	ND	32	1.2
		outlet	7.6	30	20	100	ND	19	0.9
	Real Time Reading at Outlet		7.42	40.2	28.49	104.75		13.95	
	40 MGD	Inlet	7.2	260	173	360	ND	32	1.2
		Outlet	7.7	18	14	60	ND	16	0.5
	Real Time Reading at Outlet		7.1	20.27	10.9	48.3		11.6	
Corronation pillar	20 MGD Phase-I &II	Inlet	7	236	225	332	41	14.2	6.6
		outlet	7.4	75	73	130	21	7.4	3
	Real Time Reading at Outlet		7.6	110	35	116	11		
	10 MGD Phase-III	Inlet	6.9	310	300	66	15.8		
		outlet	7.5	148	115	170	44	9.6	
	Real Time Reading at Outlet		7.4	71	37	144	22		
Rohiini 15 MGD	15 MGD	Inlet	7.1	256	145	-	-	35	4.5
		Outlet	7.4	71	40	-	-	18	1.5
	Real Time Reading at Outlet								
KESHOPUR	12 MGD (PH-I)	Inlet	7.3	340	198	-	-	34	3.9
		Outlet	7.4	19	14	-	-	2	3.1
	Real time reading at OUTLET(online)		7.05	4.08	2.56	20.03	-	0.8	-
	20 MGD (PH-II)	Inlet	7.3	564	242	-	-	32	3.3
		Outlet	7.6	90	75	-	-	30	2.9
	Real time reading at OUTLET(online)		7.78	279.36	161.78	516.6	-	8.4	-
	40 MGD (PH-III)	Inlet	7.3	564	242	-	-	32	3.3
		Outlet	7.5	144	106	-	-	31	2.8
	Real time reading at OUTLET(online)		7.42	135.74	50.19	201.88	-	493.25	-
NILOTHI	20 MGD (PH-II)	Inlet	7.1	308	165	-	-	35	-
		Outlet	7.3	9	5	-	-	10	-
	Real time reading at OUTLET(online)		7.21	7.18	3.92	25.23	-	2.04	-

PAPPANKALAN	(20 MGD)	Inlet	7.3	330	205	-	-	33	-
	PH-I	Outlet	7.8	102	46	-	-	16	-
	Real time reading at OUTLET(online)		7.37	85.56	43.05	119.24	-	35.1	-
	(20 MGD)	Inlet	7.3	286	194	-	-	30	-
	PH-II	Outlet	7.5	7	6	-	-	7	-
	Real time reading at OUTLET(online)		6.8	7.03	7.1	44.77	-	0.4	-
NAJAFGARH	(05 MGD)	Inlet	7.4	334	210	-	-	37	-
		Outlet	7.4	21	15	-	-	17	-
	Real time reading at OUTLET(online)		7.47	13.5	18.72	69.09	-	20.08	-
Okhla	12 MGD	Inlet	7.4	378	183	424	3	38	2.9
		outlet	7.8	30	20	80	1	33	1.8
	Real Time Reading at Outlet								
	45 MGD	Inlet	7.5	314	177	392	3	40	3
		outlet	7.7	40	25	104	1	32	0.9
	Real Time Reading at Outlet								
	37 MGD	Inlet	7.5	314	177	392	3	40	3
		outlet	7.7	18	12	48	NIL	30	NIL
	Real Time Reading at Outlet								
	16 MGD	Inlet	7.5	314	177	392	3	40	3
		outlet	7.8	35	23	88	NIL	29	1.2
	Real Time Reading at Outlet								

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Name of the Plant	Capacity (in MGD)	16.01.2020		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC Limit	50	30	250
Yamuna Vihar	10 MGD Phase-I	37	23	96
	10 MGD Phase-II	41	28	88
	25 MGD Phase-III	38	26	120
Rithala	40 MGD	30	20	100
	40 MGD	18	14	60
Corronation pillar	20 MGD Phase-I &II	75	73	130
	10 MGD Phase-III	148	115	170
Rohiini 15 MGD	15 MGD	71	40	-
KESHOPUR	12 MGD	19	14	-
	20 MGD	90	75	-
	40 MGD	144	106	-
NILOTHI	20 MGD	9	5	-
PAPPANKALAN	(20 MGD)	102	46	-
	(20 MGD)	7	6	-
NAJAFGARH	05 MGD	21	15	-
Okhla	12 MGD	30	20	80
	45 MGD	40	25	104
	37 MGD	18	12	48
	16 MGD	35	23	88

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Parameters of STPs of Delhi as on							17.01.2020		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Yamuna Vihar	10 MGD Phase-I	Inlet	7.3	324	268		15.2	35	2.5
		outlet	7.4	68	43		8	20	1.5
		Real Time Reading at	7.1	42	12	70		10	
	10 MGD Phase-II	Inlet	7.2	324	247		11.2	30	3.5
		outlet	7.5	34	25		5.6	25	2
		Real Time Reading at							
	25 MGD Phase-III	Inlet	7.1	744	367		24	35	3
		outlet	7.4	47	32		9.6	20	2
		Real Time Reading at	6.9	35	20	94		12	
Rithala	40 MGD	Inlet	6.9	244	145	290	ND	28	0.8
		outlet	7.5	32	21	100	ND	15	0.6
	Real Time Reading at		7.52	35.17	13.04	76.41		12.68	
	40 MGD	Inlet	6.9	244	145	290	ND	28	0.8
		Outlet	7.4	17	12	50	ND	11	0.4
Real Time Reading at		6.94	18.11	10.47	44.51		18.11		
Corronation pillar	20 MGD Phase-I	Inlet	6.9	257	230	328	37	15.4	
		outlet	7.3	70	72	128	26	7.8	
		Real Time Reading at							
	10 MGD Phase-III	Inlet	7.1	348	310	400	55	16.4	6.9
		outlet	7.4	154	125	168	38	8.8	2.8
Real Time Reading at									
Narela	10 MGD Phase-III	Inlet	6.9	240	220	308	35	10.6	7.6
		outlet	7.4	27	19	58	16	4.8	2.9
	Real Time Reading at								
Rohiini 15 MGD	15 MGD	Inlet	7.2	208	135	-	-	50	12.5
		Outlet	7.4	30	19	-	-	17	6
	Real Time Reading at								
KESHOPUR	12 MGD (PH-I)	Inlet	7.3	272	172	640	-	32	3.8
		Outlet	7.6	13	9	34	-	1	3.2
	Real time reading at		6.95	5.98	1.8	10.02	-	1.04	-
	20 MGD (PH-II)	Inlet	7.4	380	190	747	-	31	3.4
		Outlet	7.6	88	79	288	-	29	3
	Real time reading at		7.78	224.21	98.58	332.3	-	6.9	-
	40 MGD (PH-III)	Inlet	7.4	380	190	747	-	31	3.4
		Outlet	7.5	138	112	400	-	30	2.9
Real time reading at		7.47	160.8	45.51	224.72	-	470.12	-	
DADRAKHALAN	(20 MGD)	Inlet	7.3	362	232	-	-	36	4.8
	PH-I	Outlet	7.8	96	42	-	-	14	0.6
	Real time reading at								

FAFANALAY	(20 MGD)	Inlet	7.3	310	208	-	-	32	4.5
	PH-II	Outlet	7.6	6	5	-	-	1.8	3.8
	Real time reading at		6.81	7.08	7.19	45.25	-	0.41	-
NAJAFGARH	(05 MGD)	Inlet	7.3	328	226	-	-	38	4.5
		Outlet	7.6	24	18	-	-	16	0.4
	Real time reading at		7.38	111.06	35.28	320.84	-	19.14	-
Okhla	12 MGD	Inlet	7.2	250	200	432	4	41	1.7
		outlet	7.6	39	25	104	2	33	0.8
	Real Time Reading at								
	45 MGD	Inlet	7.3	264	240	440	4	38	1.8
		outlet	7.6	33	23	88	2	32	0.9
	Real Time Reading at								
	37 MGD	Inlet	7.3	264	240	440	4	38	1.8
		outlet	7.6	20	15	56	NIL	30	0.5
	Real Time Reading at								
	16 MGD	Inlet	7.3	264	240	440	4	38	1.8
		outlet	7.6	28	21	80	NIL	29	0.4
	Real Time Reading at								

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Name of the Plant	Capacity (in MGD)	17.01.2020		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC Limit	50	30	250
Yamuna Vihar	10 MGD Phase-I	68	43	-
	10 MGD Phase-II	34	25	-
	25 MGD Phase-III	47	32	-
Rithala	40 MGD	32	21	100
	40 MGD	17	12	50
Corronation pillar	20 MGD Phase-I &II	70	72	128
	10 MGD Phase-III	154	125	168
Narela	10 MGD Phase-III	27	19	58
Rohiini 15 MGD	15 MGD	30	19	-
KESHOPUR	12 MGD	13	9	34
	20 MGD	88	79	288
	40 MGD	138	112	400
PAPPANKALAN	(20 MGD)	96	42	-
	(20 MGD)	6	5	-
NAJAFGARH	05 MGD	24	18	-
Okhla	12 MGD	39	25	104
	45 MGD	33	23	88
	37 MGD	20	15	56
	16 MGD	28	21	80

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Parameters of STPs of Delhi as on							18.01.2020		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Yamuna Vihar	10 MGD Phase-I	Inlet	7.1	504	268			50	5.0
		outlet	7.3	29	16			30	4.0
	Real Time Reading at		-	-	-	-		-	-
	10 MGD Phase-II	Inlet	7.2	360	215			35	4
		outlet	7.3	33	20			20	2
	Real Time Reading at								
	25 MGD Phase-III	Inlet	7.1	464	229			55	3.5
		outlet	7.3	28	16			30	3.0
Real Time Reading at		7.1	30	20	81		12		
Rithala	40 MGD	Inlet	7	304	203	410	ND	30	1.1
		outlet	7.6	35	23	110	ND	18	0.7
	Real Time Reading at		7.47	37.24	27.49	102.2		14.34	
	40 MGD	Inlet	7	304	203	410	ND	30	1.1
		Outlet	7.5	18	14	70	ND	12	0.4
	Real Time Reading at		7.04	19.79	10.58	46.04	ND	11.51	
Corronation pillar	20 MGD Phase-I	Inlet	6.8	218	205	312	35	13.6	7.2
		outlet	7.2	66	68	124	22	8	3.4
	Real Time Reading at								
	10 MGD Phase-III	Inlet	6.9	364	318	420	59	16	
		outlet	7.3	132	110	150	36	9	
Real Time Reading at									
Rohiini 15 MGD	15 MGD	Inlet	7.2	216	138	-	-	40	4.0
		Outlet	7.4	56	31	-	-	17	2
	Real Time Reading at								
KESHOPUR	12 MGD (PH-I)	Inlet	7.3	344	200	-	13.7	31	3.3
		Outlet	7.6	16	10	-	0	2	2.8
	Real time reading at		6.95	6	3.9	24.14	-	1.19	-
	20 MGD (PH-II)	Inlet	7.3	436	245	-	12.3	30	3.5
		Outlet	7.6	78	70	-	2.2	28	2.9
	Real time reading at		7.76	209.28	101.41	333.43	-	8.55	-
	40 MGD (PH-III)	Inlet	7.3	436	245	-	12.3	30	3.5
		Outlet	7.5	132	114	-	3.5	28	3.1
Real time reading at		7.42	151.61	45.89	202.64	-	449.57	-	
NILOTHI	20 MGD (PH-II)	Inlet	7.3	302	176	570	-	32	3.2
		Outlet	7.5	8	7	28	-	8	1.8
	Real time reading		7.08	7.59	2.07	25.36	-	2.28	-
DADDANKALAN	(20 MGD)	Inlet	7.4	313	210	-	-	35	5.4
	PH-I	Outlet	7.5	55	25	-	-	15	0.8
	Real time reading at		7.21	87.64	42.58	120.15	-	34.45	-

TAF FANNALAN	(20 MGD)	Inlet	7.3	232	183	540	8.6	33	5.3
	PH-II	Outlet	7.7	7	4	20	0	1.9	4.5
	Real time reading at		6.69	6.98	7.16	44.83	-	0.42	-
Okhla	12 MGD	Inlet	7.4	240	164	440	-	42	2.5
		outlet	7.6	31	20	80	-	345	1
	Real Time Reading at								
	45 MGD	Inlet	7.5	246	155	448	-	40	2.1
		outlet	7.6	34	24	88	-	33	1.2
	Real Time Reading at								
	37 MGD	Inlet	7.5	246	155	448	-	40	2.1
		outlet	7.8	18	11	40	-	29	0.9
	Real Time Reading at								
	16 MGD	Inlet	7.5	246	155	448	-	40	2.1
		outlet	7.7	27	18	72	-	31	0.6
	Real Time Reading at								

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Name of the Plant	Capacity (in MGD)	18.01.2020		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC Limit	50	30	250
Yamuna Vihar	10 MGD Phase-I	29	16	-
	10 MGD Phase-II	33	20	-
	25 MGD Phase-III	28	16	-
Rithala	40 MGD	35	23	110
	40 MGD	18	14	70
Corronation pillar	20 MGD Phase-I &II	66	68	124
	10 MGD Phase-III	132	110	150
Rohiini 15 MGD	15 MGD	56	31	-
KESHOPUR	12 MGD	16	10	-
	20 MGD	78	70	-
	40 MGD	132	114	-
PAPPANKALAN	(20 MGD)	55	25	-
	(20 MGD)	7	4	20
Okhla	12 MGD	31	20	80
	45 MGD	34	24	88
	37 MGD	18	11	40
	16 MGD	27	18	72

29

16

0

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Parameters of STPs of Delhi as on							19.01.2020		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Yamuna Vihar	10 MGD Phase-I	Inlet	7.0	344	247			50	5.5
		outlet	7.4	35	22			20	2.5
	Real Time Reading at		-	-	-	-		-	-
	10 MGD Phase-II	Inlet	7.3	324	210			45	4
		outlet	7.4	49	32			20	1.5
	Real Time Reading at								
	25 MGD Phase-III	Inlet	7.3	322	219			55	3.5
		outlet	7.5	40	28			30	1.0
	Real Time Reading at		6.9	24	18	70		12	
Rithala	40 MGD	Inlet	7	296	188	390	18	32	1.2
		outlet	7.7	34	22	110	9	21	0.9
	Real Time Reading at		7.46	44.73	28.2	107.4		13.87	
	40 MGD	Inlet	7	296	188	390	18	32	1.2
		Outlet	7.6	17	12	60	4	16	0.5
	Real Time Reading at		6.99	18.2	10.7	45.87		11.42	
Corronation pillar	20 MGD Phase-I	Inlet	7	242	228	334	40	13.8	
		outlet	7.4	74	75	130	30	8.6	
	Real Time Reading at								
	10 MGD Phase-III	Inlet	7	324	315	412	62	15.6	7.9
		outlet	7.5	126	105	136	39	8.8	3.4
	Real Time Reading at								
Rohiini 15 MGD	15 MGD	Inlet	7.4	264	158	470	-	55	5.0
		Outlet	7.7	36	21	112	-	16	2.5
	Real Time Reading at								
KESHOPUR	12 MGD (PH-I)	Inlet	7.2	372	234	-	-	32	3.7
		Outlet	7.6	14	8	-	-	1	3.1
	Real time reading at		6.98	4.83	3.61	29.14	-	1.15	-
	20 MGD (PH-II)	Inlet	7.3	404	242	-	-	32	3.6
		Outlet	7.5	72	71	-	-	29	3.2
	Real time reading at		7.71	238	120.3	372.12	-	12.7	-
	40 MGD (PH-III)	Inlet	7.3	404	242	-	-	32	3.6
		Outlet	7.6	118	112	-	-	29	3.2
	Real time reading at		7.4	102.89	44.6	152	-	1500	-
DARBANKALAN	(20 MGD)	Inlet	7.4	328	222	-	-	36	5.2
	PH-I	Outlet	7.6	62	32	-	-	16	0.8
	Real time reading at		7.24	48.9	38.35	97.89	-	35.65	-

Paffanbagan	(20 MGD)	Inlet	7.3	285	202	-	-	34	5.3
	PH-II	Outlet	7.6	6	5	-	-	1.8	4.2
	Real time reading at		6.65	7.01	7.29	45.36	-	0.42	-
Okhla	12 MGD	Inlet	7.4	264	201	440	3	38	2.6
		outlet	7.6	25	16	64	1	354	1.6
	Real Time Reading at								
	45 MGD	Inlet	7.6	278	205	456	4	40	2.2
		outlet	7.7	32	22	80	1	32	1.3
	Real Time Reading at								
	37 MGD	Inlet	7.6	278	205	456	4	40	2.2
		outlet	7.7	20	16	56	1	30	1
	Real Time Reading at								
	16 MGD	Inlet	7.6	278	205	456	4	40	2.2
		outlet	7.6	29	19	64	NIL	29	0.7
	Real Time Reading at								

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Name of the Plant	Capacity (in MGD)	19.01.2020		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC Limit	50	30	250
Yamuna Vihar	10 MGD Phase-I	35	22	-
	10 MGD Phase-II	49	32	-
	25 MGD Phase-III	40	28	-
Rithala	40 MGD	34	22	110
	40 MGD	17	12	60
Corronation pillar	20 MGD Phase-I &II	74	75	130
	10 MGD Phase-III	126	105	136
Rohiini 15 MGD	15 MGD	36	21	112
KESHOPUR	12 MGD	14	8	-
	20 MGD	72	71	-
	40 MGD	118	112	-
PAPPANKALAN	(20 MGD)	62	32	-
	(20 MGD)	6	5	-
Okhla	12 MGD	25	16	64
	45 MGD	32	22	80
	37 MGD	20	16	56
	16 MGD	29	19	64

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Parameters of STPs of Delhi as on							20.01.2020		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Yamuna Vihar	10 MGD Phase-I	Inlet	7.4	420	325			40	5.0
		outlet	7.4	84	52			15	2.5
	Real Time Reading at		-	-	-	-		-	-
	10 MGD Phase-II	Inlet	7.2	424	308			35	5.0
		outlet	7.6	46	30			20	2.0
	Real Time Reading at								
	25 MGD Phase-III	Inlet	7.3	300	191			50	6.5
		outlet	7.4	45	32			30	2.0
	Real Time Reading at		7.0	29	20	85		12	
Rithala	40 MGD	Inlet	7	276	168	370	ND	28	0.8
		outlet	7.7	38	24	90	ND	24	0.8
	Real Time Reading at		7.45	42.78	30.93	110.03		14.02	
	40 MGD	Inlet	7	276	168	370	ND	28	0.8
		Outlet	7.6	17	14	60	ND	17	0.6
	Real Time Reading at		6.96	17.6	10.23	42.89		11.38	
Corronation pillar	20 MGD Phase-I	Inlet	6.9	224	195	308	37	13	6.4
		outlet	7.3	78	82	136	32	6.8	2.6
	Real Time Reading at								
	10 MGD Phase-III	Inlet	7.1	348	328	428	48	13.2	
		outlet	7.4	129	125	144	30	8	
	Real Time Reading at								
Narela	10 MGD Phase-III	Inlet	7.1	212	200	278	30	11.6	7.4
		outlet	7.6	31	23	60	15	2	3.2
	Real Time Reading at								
Rohiini 15 MGD	15 MGD	Inlet	7.3	212	135	-	-	52	10.0
		Outlet	7.5	63	33	-	-	17	5.5
	Real Time Reading at								
Okhla	12 MGD	Inlet	7.3	284	184	416	-	41	2.2
		outlet	7.8	30	20	80	-	33	1.5
	Real Time Reading at								
	45 MGD	Inlet	7.5	360	195	440	-	42	1.8
		outlet	7.6	38	26	104	-	30	1.2
	Real Time Reading at								
	37 MGD	Inlet	7.5	360	195	440	-	42	1.8
		outlet	7.6	21	15	56	-	33	0.7
	Real Time Reading at								

	16 MGD	Inlet	7.5	360	195	440	-	42	1.8
		outlet	7.7	28	19	72	-	35	1
	Real Time Reading at								

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Name of the Plant	Capacity (in MGD)	20.01.2020		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC Limit	50	30	250
Yamuna Vihar	10 MGD Phase-I	84	52	-
	10 MGD Phase-II	46	30	-
	25 MGD Phase-III	45	32	-
Rithala	40 MGD	38	24	90
	40 MGD	17	14	60
Corronation pillar	20 MGD Phase-I & II	78	82	136
	10 MGD Phase-III	129	125	144
Narela	10 MGD Phase-III	31	23	60
Rohiini 15 MGD	15 MGD	63	33	-
Okhla	12 MGD	30	20	80
	45 MGD	38	26	104
	37 MGD	21	15	56
	16 MGD	28	19	72

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Parameters of STPs of Delhi as on							21.01.2020		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Yamuna Vihar	10 MGD Phase-I	Inlet	7.3	364	237			50	4.0
		outlet	7.4	32	22			15	2.5
	Real Time Reading at		-	-	-	-	-	-	-
	10 MGD Phase-II	Inlet	7.0	372	227			40	3.5
		outlet	7.4	37	31			20	2.0
	Real Time Reading at								
	25 MGD Phase-III	Inlet	7.2	532	284			55	5.5
		outlet	7.4	46	26			20	2.5
Real Time Reading at		7.0	39	22	110		12		
Rithala	40 MGD	Inlet	7.1	260	165	390	ND	30	1.2
		outlet	7.6	32	22	80	ND	21	0.9
	Real Time Reading at		7.43	36.16	29.65	104.01		15.19	
	40 MGD	Inlet	7.1	260	165	390	ND	30	1.2
		Outlet	7.5	16	11	50	ND	18	0.5
Real Time Reading at		6.91	17.35	10.26	42.97		11.29		
Corronation pillar	20 MGD Phase-I	Inlet	6.8	202	185	324	32	11.8	
		outlet	7.4	88	83	140	19	6.5	
	Real Time Reading at								
	10 MGD Phase-III	Inlet	6.9	372	335	416	56	12.6	7.4
		outlet	7.7	143	135	152	32	7.2	3
Real Time Reading at									
Rohiini 15 MGD	15 MGD	Inlet	7.2	380	240	630	-	53	11.0
		Outlet	7.6	28	14	93	-	16	5
	Real Time Reading at								
KESHOPUR	12 MGD (PH-I)	Inlet	7.3	372	186	-	-	34	3.3
		Outlet	7.6	18	9	-	-	1	2.9
	Real time reading at		7.13	5.94	2.92	20.9	-	0.71	-
	20 MGD (PH-II)	Inlet	7.3	296	170	-	-	33	3.4
		Outlet	7.6	78	74	-	-	31	3
	Real time reading at		7.71	272.48	74.84	287.02	-	12.25	-
	40 MGD (PH-III)	Inlet	7.3	296	170	-	-	33	3.4
		Outlet	7.5	110	91	-	-	32	3.2
Real time reading at		7.39	84.24	26.04	64.03	-	32.47	-	
NILOTHI	20 MGD (PH-II)	Inlet	7.2	318	164	590	-	32	3
		Outlet	7.4	8	6	28	-	10	1.5
	Real time reading								
	(20 MGD)	Inlet	7.3	455	245	980	-	35	5.5

PAPPANKALAN	PH-I	Outlet	7.6	117	54	230	-	24	1.2
	Real time reading at		7.24	50.83	35.3	93.25	-	45.6	-
	(20 MGD)	Inlet	7.3	354	225	740	-	33	5.2
	PH-II	Outlet	7.5	8	6	30	-	8	4.2
	Real time reading at		6.64	7.06	7.45	46.06	-	0.41	-
Okhla	12 MGD	Inlet	7.4	268	183	408	4	41	2
		outlet	7.7	34	23	88	1	34	1.2
	Real Time Reading at								
	45 MGD	Inlet	7.4	284	215	432	3	39	2.2
		outlet	7.6	41	27	104	1	29	1.3
	Real Time Reading at								
	37 MGD	Inlet	7.4	284	215	432	3	39	2.2
		outlet	7.6	36	24	88	NIL	31	0.9
	Real Time Reading at								
	16 MGD	Inlet	7.4	284	215	431	3	39	2.2
		outlet	7.7	31	21	80	1	27	0.7
	Real Time Reading at								
KoNDli	25 MGD Phase-II	Inlet	7.3	472	248	486	-	37	6.2
		outlet	7.7	14	7	32	-	25	3.4
	Real Time Reading at								
	45 MGD Phase-IV	Inlet	7.2	416	237	428	-	38	5.9
		outlet	7.5	30	17	68	-	27	2.8
	Real Time Reading at								
Chilla	9 MGD	Inlet	7.1	376	231	388	-	39	6.8
		outlet	7.6	6	2.6	14	-	4	3.7
	Real Time Reading at								

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Name of the Plant	Capacity (in MGD)	21.01.2020		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC Limit	50	30	250
Yamuna Vihar	10 MGD Phase-I	32	22	-
	10 MGD Phase-II	37	31	-
	25 MGD Phase-III	46	26	-
Rithala	40 MGD	32	22	80
	40 MGD	16	11	50
Corronation pillar	20 MGD Phase-I & II	88	83	140
	10 MGD Phase-III	143	135	152
Rohiini 15 MGD	15 MGD	28	14	93
KESHOPUR	12 MGD	18	9	-
	20 MGD	78	74	-
	40 MGD	110	91	-
ILOTHI	20 MGD	8	6	28
PAPPANKALAN	(20 MGD)	117	54	230
	(20 MGD)	8	6	30
Okhla	12 MGD	34	23	88
	45 MGD	41	27	104
	37 MGD	36	24	88
	16 MGD	31	21	80
Kondli	25 MGD Phase-II	14	7	32
	45 MGD Phase-IV	30	17	68
Chilla	9 MGD	6	2.6	14

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Parameters of STPs of Delhi as on							22.01.2020		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Yamuna Vihar	10 MGD Phase-I	Inlet	7.1	352	215	776		45	6.5
		outlet	7.5	27	17	80		35	2.5
	Real Time Reading at		-	-	-	-	-	-	-
	10 MGD Phase-II	Inlet	7.2	396	242	784		35	5.0
		outlet	7.4	29	20	88		30	2.0
	Real Time Reading at								
	25 MGD Phase-III	Inlet	7.2	380	215	892		45	6.0
		outlet	7.4	46	25	144		20	3.5
Real Time Reading at		7.1	39	23	109		12		
Rithala	40 MGD	Inlet	7	272	156	360	ND	31	1.5
		outlet	7.7	31	20	90	ND	24	1.2
	Real Time Reading at		7.5	37.78	26.28	100.95		12.32	
	40 MGD	Inlet	7	272	156	360	ND	31	1.5
		Outlet	7.8	17	12	60	ND	13	1.1
Real Time Reading at		6.94	18.31	10.42	44.42		11.33		
Corronation pillar	20 MGD Phase-I	Inlet	7	228	220	356	45	12.8	6.9
		outlet	7.5	98	85	150	26	6.9	2.8
	Real Time Reading at								
	10 MGD Phase-III	Inlet	7	396	340	426	60	13.8	
		outlet	7.4	150	138	156	34	8.6	
Real Time Reading at									
Rohiini 15 MGD	15 MGD	Inlet	7.2	208	135	-	-	52	6.0
		Outlet	7.6	30	19	-	-	18	5
	Real Time Reading at								
KESHOPUR	12 MGD (PH-I)	Inlet	7.3	480	198	827	-	33	3.4
		Outlet	7.6	16	9	34	-	1	2.8
	Real time reading at		6.95	6.13	3.56	20.45	-	1.05	-
	20 MGD (PH-II)	Inlet	7.3	648	226	893	-	32	3.6
		Outlet	7.5	82	70	232	-	30	3.2
	Real time reading at		7.72	411.36	86.6	402.5	-	11.15	-
	40 MGD (PH-III)	Inlet	7.3	648	226	893	-	32	3.6
		Outlet	7.5	118	111	317	-	31	3.3
Real time reading at		7.32	106.34	35.05	115.67	-	28.72	-	
DARBANKALAN	(20 MGD)	Inlet	7.3	391	220		-	40	5.7
	PH-I	Outlet	7.8	114	52		-	28	1.1
	Real time reading at		7.22	64.65	35.83	99.21	-	37.4	-

CAFFAINNABIN	(20 MGD)	Inlet	7.3	318	208		-	38	5.6
	PH-II	Outlet	7.5	12	8		-	12	4.9
	Real time reading at		6.63	7.06	7.41	45.92	-	0.42	-
NAJAFGARH	(05 MGD)	Inlet	7.3	396	250	480		38	5
		Outlet	7.6	26	20	92		11	2
	Real time reading at		7.39	161.26	36.09	405.67		18.69	
Okhla	12 MGD	Inlet	7.4	226	205	440	4	40	1.9
		outlet	7.7	36	25	96	1	32	1.1
	Real Time Reading at								
	45 MGD	Inlet	7.4	290	230	456	3	42	1.8
		outlet	7.7	34	22	96	1	32	1
	Real Time Reading at								
	37 MGD	Inlet	7.4	290	230	456	3	42	1.8
		outlet	7.7	31	21	80	NIL	30	1
	Real Time Reading at								
	16 MGD	Inlet	7.4	290	230	456	3	42	1.8
		outlet	7.7	34	23	88	NIL	29	0.7
	Real Time Reading at								
KoNDli	25 MGD Phase-II	Inlet	7.3	368	228	378	19	37	6.4
		outlet	7.7	13	6	28	2.8	26	3.8
	Real Time Reading at								
	45 MGD Phase-IV	Inlet	7.3	444	238	452	18.5	38	5.8
		outlet	7.6	27	15	56	3.8	29	3.1
	Real Time Reading at								
Chilla	9 MGD	Inlet	7.1	252	180	262	16.5	39	6.8
		outlet	7.5	7	2.9	16	2.5	3	4.2
	Real Time Reading at								
CWG Village	1 MGD	Inlet	7.2	256	182	268	21.5	22	5.4
		outlet	7.7	1	0.4	1.6	1	0.22	1.6
	Real Time Reading at								

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Name of the Plant	Capacity (in MGD)	22.01.2020		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC Limit	50	30	250
Yamuna Vihar	10 MGD Phase-I	27	17	80
	10 MGD Phase-II	29	20	88
	25 MGD Phase-III	46	25	144
Rithala	40 MGD	31	20	90
	40 MGD	17	12	60
Corronation pillar	20 MGD Phase-I &II	98	85	150
	10 MGD Phase-III	150	138	156
Rohiini 15 MGD	15 MGD	30	19	-
KESHOPUR	12 MGD	16	9	34
	20 MGD	82	70	232
	40 MGD	118	111	317
PAPPANKALAN	(20 MGD)	114	52	-
	(20 MGD)	12	8	-
NAJAFGARH	05 MGD	26	20	92
Okhla	12 MGD	36	25	96
	45 MGD	34	22	96
	37 MGD	31	21	80
	16 MGD	34	23	88
Kondli	25 MGD Phase-II	13	6	28
	45 MGD Phase-IV	27	15	56
Chilla	9 MGD	7	2.9	16
CWA Village	1 MGD	1	0.4	1.6

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Parameters of STPs of Delhi as on							23.01.2020		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Yamuna Vihar	10 MGD Phase-I	Inlet	7.3	356	273			45	3.5
		outlet	7.6	39	26			35	2.5
	Real Time Reading at		-	-	-	-	-	-	-
	10 MGD Phase-II	Inlet	7.0	388	278			50	4.0
		outlet	7.5	36	24			40	3.5
	Real Time Reading at								
	25 MGD Phase-III	Inlet	7.1	556	306			55	4.5
		outlet	7.4	47	35			25	3.0
	Real Time Reading at		7.0	36	22	101		12	
Rithala	40 MGD	Inlet	7.1	256	154	340	ND	35	1.7
		outlet	7.6	38	22	100	ND	26	1.4
	Real Time Reading at		7.51	40.13	30.33	107.47		11.61	
	40 MGD	Inlet	7.1	256	154	340	ND	35	1.7
		Outlet	7.5	18	13	70	ND	16	1.2
	Real Time Reading at		6.94	16.87	10.37	43		11.33	
Corronation pillar	20 MGD Phase-I	Inlet	6.8	268	225	380	50	13.9	
		outlet	7.3	106	98	158	30	8.6	
	Real Time Reading at								
	10 MGD Phase-III	Inlet	7.1	410	345	428	59		
		outlet	7.6	126	110	138	37	8	3.6
Real Time Reading at									
Rohiini 15 MGD	15 MGD	Inlet	7.4	288	175	-	-	35	5.0
		Outlet	7.7	33	20	-	-	12	2.5
	Real Time Reading at								
KESHOPUR	12 MGD (PH-I)	Inlet	7.4	192	165	-	-	32	3.4
		Outlet	7.6	20	13	-	-	2	3
	Real time reading at		6.97	5.56	3.82	24.15	-	0.99	-
	20 MGD (PH-II)	Inlet	7.3	416	190	-	-	34	3.3
		Outlet	7.5	86	75	-	-	31	3.2
	Real time reading at		7.7	80.16	34.16	97.6	-	13.5	-
	40 MGD (PH-III)	Inlet	7.3	416	190	-	-	34	3.3
		Outlet	7.5	156	117	-	-	30	3
	Real time reading at		7.27	123.09	50.41	178.84	-	31.2	-
NILOTHI	20 MGD (PH-II)	Inlet	7.3	310	165	-	7.8	32	2.8
		Outlet	7.5	7	6	-	0	8	1.6
	Real time reading		7.19	7.14	4.36	25.22	-	2.12	-

PAPPANKALAN	(20 MGD)	Inlet	7.3	477	230	-	18	40	5.6
	PH-I	Outlet	7.7	81	42	-	0.6	26	1.2
	Real time reading at		7.17	57.66	31.76	89.02	-	34.65	-
	(20 MGD)	Inlet	7.3	303	204	-	16	38	5.4
	PH-II	Outlet	7.6	7	5	-	0	15	4.8
	Real time reading at		6.58	7.21	7.39	46.54	-	0.43	-
NAJAFGARH	(05 MGD)	Inlet	7.3	280	210	-	10	40	5
		Outlet	7.6	49	25	-	0	12	1.8
	Real time reading at		7.36	13.19	10.93	44.65		18.15	
Okhla	12 MGD	Inlet	7.5	286	195	440	3	41	2.2
		outlet	7.6	38	25	112	2	35	1.2
	Real Time Reading at								
	45 MGD	Inlet	7.4	314	187	464	3	39	2.4
		outlet	7.6	40	27	112	1	30	0.8
	Real Time Reading at								
	37 MGD	Inlet	7.4	314	187	464	3	39	2.4
		outlet	7.7	29	18	80	1	33	0.6
	Real Time Reading at								
	16 MGD	Inlet	7.4	314	187	464	3	39	2.4
		outlet	7.7	35	22	88	NIL	29	0.7
	Real Time Reading at								
KoNDli	25 MGD Phase-II	Inlet	7.2	428	225	444	-	38	6.1
		outlet	7.7	10	6	22	-	21	3.4
	Real Time Reading at								
	45 MGD Phase-IV	Inlet	7.2	448	231	454	-	38	6.4
		outlet	7.5	27	16	58	-	24	3.1
	Real Time Reading at								
Chilla	9 MGD	Inlet	7.1	272	172	284	-	37	6.3
		outlet	7.7	9	4	22	-	3	4
	Real Time Reading at								

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Name of the Plant	Capacity (in MGD)	23.01.2020		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC Limit	50	30	250
Yamuna Vihar	10 MGD Phase-I	39	26	-
	10 MGD Phase-II	36	24	-
	25 MGD Phase-III	47	35	-
Rithala	40 MGD	38	22	100
	40 MGD	18	13	70
Corronation pillar	20 MGD Phase-I &II	106	98	158
	10 MGD Phase-III	126	110	138
Rohiini 15 MGD	15 MGD	33	20	-
KESHOPUR	12 MGD	20	13	-
	20 MGD	86	75	-
	40 MGD	156	117	-
NILOTHI	20 MGD	7	6	-
PAPPANKALAN	(20 MGD)	81	42	-
	(20 MGD)	7	5	-
NAJAFGARH	05 MGD	49	25	-
Okhla	12 MGD	38	25	112
	45 MGD	40	27	112
	37 MGD	29	18	80
	16 MGD	35	22	88
Kondli	25 MGD Phase-II	10	6	22
	45 MGD Phase-IV	27	16	58
Chilla	9 MGD	9	4	22