



**OFFICE OF THE DIRECTOR (T&QC)**  
**DELHI JAL BOARD: GOVT. OF NCT OF DELHI**  
**WATER WORKS WAZIRABAD:DELHI-110054**



Name of the Plant	Capacity (in MGD)	Parameters of STPs of Delhi as on					05.07.2019		
		Parameter							
		DPPC limits	pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
Okhla	12 MGD	Inlet	7.3	182	166	384	-	42	2.8
		outlet	7.6	42	26	104	-	36	0.5
	Real Time Reading at Outlet		7.1	30	26	120		15	
	45 MGD	Inlet	7.4	202	260	408	-	43	2.5
		outlet	7.6	40	21	88	-	35	2.3
	Real Time Reading at Outlet		7.73	37	24	97		27	
	37 MGD	Inlet	7.4	202	260	408	-	43	2.5
		outlet	7.7	41	23	96	-	33	2.2
	Real Time Reading at Outlet		7.6	27	12	71		30	
	16 MGD	Inlet	7.4	202	260	408	-	43	2.5
		outlet	7.7	27	18	72	-	34	Nil
	Real Time Reading at Outlet		7.37	19	10	52		12	
New 30 MGD	Inlet	7.3	250	228	456	-	42	3.3	
	Outlet	7.7	7	6	24	-	5	2.5	
Real Time Reading at Outlet									
Mehrauli	5 MGD	Inlet	7.4	102	117	248	1	35	2.8
		outlet	7.6	7	7	32	Nil	15	2.6
Real Time Reading at Outlet									
Vasant Kunj	2.2 MGD	Inlet	7.4	576	390	632	5	34	3
		outlet	7.9	32	18	72	Nil	33	2.9
	Real Time Reading at Outlet								
	3 MGD	Inlet	7.5	114	143	272	Nil	40	2.8
outlet		7.8	15	10	40	Nil	8	3	
Real Time Reading at Outlet									
Kondli	25 MGD Phase-II	Inlet	7.2	288	236	317	-	35	7
		outlet	7.6	13	9	30	-	29	3.2
	Real Time Reading at Outlet		7.4	21	9	36		21.29	
	45 MGD Phase-IV	Inlet	7.2	282	248	305	-	36	6.8
outlet		7.5	29	17	64	-	31	4	
Real Time Reading at Outlet		7.8	27	15	40		14.56		
Chilla	9 MGD	Inlet	7.3	188	117	-	-	34.76	7.1
		outlet	7.7	9	4	-	-	0.38	4.4
Real Time Reading at Outlet		7.2	12	3.45	18		6.51		
CWG Village	1 MGD	Inlet	7.2	324	241	-	-	21.67	5.2
		outlet	7.7	1	Bdl	-	-	0.12	1.6
Real Time Reading at Outlet		7.7	0.15	0.12	1.41		0.09		
Rithala	40 MGD	Inlet	7	196	153	360	-	29	0.9
		outlet	7.8	30	17	90	-	20	0.6
	Real Time Reading at Outlet		6.88	64.19	14	73.66		65.59	
	40 MGD	Inlet	7	196	153	360	-	29	0.9
Outlet		7.6	18	12	70	-	12	0.4	
Real Time Reading at Outlet		7.58	17.92	18.12	65.82		15.48		

Rohiini 15 MGD	15 MGD	Inlet	7.8	212	155	524	-	43	8.5
		Outlet	8	24	13	96	-	12	5.5
	Real Time Reading at Outlet		6.97	22.85	9.01	89.07		10.95	
Keshopur	12 MGD	Inlet	7.3	324	182	-	-	32	3.4
		outlet	7.7	9	6	-	-	16	1.7
	Real Time Reading at Outlet		7.64	7.82	2.44	18.21	-	6.59	-
	40 MGD	Inlet	7.4	416	220	-	-	34	3.2
		outlet	7.5	98	102	-	-	31	3
	Real Time Reading at Outlet		6.65	240.11	99.72	281.23	-	26.3	-
	20 MGD	Inlet	7.4	416	220	-	-	34	3.2
outlet		7.6	88	81	-	-	29	2.8	
Real Time Reading at Outlet		7.69	59.63	49.09	130.84	-	39.11	-	
Nilothi	40 MGD Phase-I	Inlet	7.4	146	117	-	8.4	28	2
		outlet	7.5	34	25	-	0.5	19	1.5
	Real Time Reading at Outlet		NA	NA	NA	NA	NA	NA	NA
Pappankalan	20 MGD Phase-II	Inlet	7.3	264	190	640	-	40	5
		outlet	7.6	20	19	126	-	12	1
	Real Time Reading at Outlet		7.43	18.08	20.79	129.02	-	7.1	-
	20 MGD Phase-II	Inlet	7.3	235	185	680	-	38	5
		outlet	7.7	5	5	84	-	8	2.2
Real Time Reading at Outlet		6.98	10.8	7.85	33.93	-	1.76	-	
Corronation pillar	20 MGD Phase-I & II	Inlet	7.2	282	190	396	-	40	2.1
		outlet	7.5	70	45	110	-	21	1.2
	Real Time Reading at Outlet		7.2	58	31	142		29	
	10 MGD Phase-III	Inlet	7.1	396	315	498	8.4	50	2.9
		outlet	7.5	80	52	136	3.4	35	1.9
Real Time Reading at Outlet		7.3	78	40	141		22		
Narela	10 MGD Phase-III	Inlet	7.3	360	230	468	7.8	59	2.6
		outlet	7.4	68	49	110	3	38	1.7
	Real Time Reading at Outlet		7	57	31	111		38	

Dir.(T&QC)







OFFICE OF THE DIRECTOR (T&QC)  
DELHI JAL BOARD: GOVT. OF NCT OF DELHI  
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	05.07.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
		50	30	250
Okhla	12 MGD	42	26	104
	45 MGD	40	21	88
	37 MGD	41	23	96
	16 MGD	27	18	72
	New 30 MGD	7	6	24
Mehrauli	5 MGD	7	7	32
Vasant Kunj	2.2 MGD	32	18	72
	3 MGD	15	10	40
Kondli	25 MGD	13	9	30
	45 MGD	29	17	64
Chilla	9 MGD	9	4	-
CWG Village	1 MGD	1	Bdl	-
Rithala	40 MGD	30	17	90
	40 MGD	18	12	70
Rohiini	15 MGD	24	13	96
Keshopur	12 MGD	9	6	-
	40 MGD	98	102	-
	20 MGD	88	81	-
Nilothi	40 MGD	34	25	-
Pappankalan	20 MGD	20	19	126
	20 MGD	5	5	84
Corronation pillar	20 MGD	70	45	110
	10 MGD	80	52	136
Narela	10 MGD	68	49	110



**OFFICE OF THE DIRECTOR (T&QC)**  
**DELHI JAL BOARD: GOVT. OF NCT OF DELHI**  
**WATER WORKS WAZIRABAD:DELHI-110054**



Name of the Plant	Capacity (in MGD)	Parameters of STPs of Delhi as on					06.07.2019		
		Parameter							
		DPPC limits	pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
Okhla	12 MGD	Inlet	7.3	404	188	424	3	42	2.6
		outlet	7.7	43	23	96	2	38	0.3
	Real Time Reading at Outlet								
	45 MGD	Inlet	7.3	362	190	400	3	43	3
		outlet	7.8	31	19	80	2	41	0.4
	Real Time Reading at Outlet								
	37 MGD	Inlet	7.3	362	190	400	3	43	3
		outlet	7.8	22	18	64	Nil	36	0.3
	Real Time Reading at Outlet								
	16 MGD	Inlet	7.3	362	190	400	3	43	3
outlet		7.7	18	12	48	Nil	38	0.3	
Real Time Reading at Outlet									
Kondli	25 MGD Phase-II	Inlet	7.3	270	168	314	-	38	7.2
		outlet	7.7	12	8	28	-	30	2.9
	Real Time Reading at Outlet		7.4	21	11	40		21.74	
	45 MGD Phase-IV	Inlet	7.3	256	157	308	-	37	7.1
outlet		7.6	27	15	60	-	33	3.3	
Real Time Reading at Outlet		7.8	27	15	40		6.27		
Chilla	9 MGD	Inlet	7.2	164	105	-	-	40	6.6
		outlet	7.7	8	3	-	-	0.3	4.7
	Real Time Reading at Outlet		7.2	15	4	19		6.66	
Rithala	40 MGD	Inlet	7.2	244	169	360	-	36	1.3
		outlet	7.8	31	18	90	-	23	0.9
	Real Time Reading at Outlet		6.94	55.9	18.15	76.39		23.58	
	40 MGD	Inlet	7.2	244	169	360	-	36	1.3
Outlet		7.8	17	11	60	-	12	0.5	
Real Time Reading at Outlet		7.54	18.29	12.48	62.73		15.41		
Rohiini 15 MGD	15 MGD	Inlet	7.5	268	180	-	-	55	7.5
		Outlet	7.9	26	15	-	-	15	2
	Real Time Reading at Outlet		6.9	22.93	9.09	89.6		11.29	
Keshopur	12 MGD	Inlet	7.3	228	168	-	-	32	3.2
		outlet	7.7	10	6	-	-	14	2.1
	Real Time Reading at Outlet		7.68	7.71	2.46	18.25		6.71	
	40 MGD	Inlet	7.3	360	175	-	-	33	3
		outlet	7.5	102	100	-	-	30	2.7
	Real Time Reading at Outlet		6.66	300.29	103.59	319.17		25.4	
20 MGD	Inlet	7.3	360	175	-	-	33	3	
	outlet	7.6	94	93	-	-	28	2.6	
Real Time Reading at Outlet		7.68	92.89	53.92	168.74		26.76		
Nilothi	40 MGD Phase-I	Inlet	7.3	156	126	-	-	28	2.4
		outlet	7.5	38	24	-	-	20	1.6
20 MGD Phase-II	Inlet	7.3	282	235	-	-	36	4.8	
	outlet	7.7	35	26	-	-	14	0.9	

Pappankalan	Real Time Reading at Outlet								
	20 MGD Phase-II	Inlet	7.3	280	243	-	-	36	5
		outlet	7.6	9	4	-	-	11	2
	Real Time Reading at Outlet		6.95	12.76	8.61	37.52		1.58	
Corronation pillar	20 MGD Phase-I &II	Inlet	7.3	240	178	356	7.9	39	2.4
		outlet	7.4	96	52	134	3	23	1.5
	Real Time Reading at Outlet		7.2	58	31	131		26	
	10 MGD Phase-III	Inlet	7.2	378	295	490	-	52	2.6
		outlet	7.4	72	49	128	-	37	1.8
	Real Time Reading at Outlet		7.3	63	35	120		21	

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)  
DELHI JAL BOARD: GOVT. OF NCT OF DELHI  
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	06.07.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
		50	30	250
Okhla	12 MGD	43	23	96
	45 MGD	31	19	80
	37 MGD	22	18	64
	16 MGD	18	12	48
Kondli	25 MGD	12	8	28
	45 MGD	27	15	60
Chilla	9 MGD	8	3	-
Rithala	40 MGD	31	18	90
	40 MGD	17	11	60
Rohiini	15 MGD	26	15	-
Keshopur	12 MGD	10	6	-
	40 MGD	102	100	-
	20 MGD	94	93	-
Nilothi	40 MGD	38	24	-
Pappankalan	20 MGD	35	26	-
	20 MGD	9	4	-
Corronation pillar	20 MGD	96	52	134
	10 MGD	72	49	128





**OFFICE OF THE DIRECTOR (T&QC)**  
**DELHI JAL BOARD: GOVT. OF NCT OF DELHI**  
**WATER WORKS WAZIRABAD:DELHI-110054**



Name of the Plant	Capacity (in MGD)	Parameters of STPs of Delhi as on					07.07.2019		
		Parameter							
		DPPC limits	pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
Okhla	12 MGD	Inlet	7.4	328	188	448	3	40	2.8
		outlet	7.79	40	24	96	1	35	0.6
	Real Time Reading at Outlet								
	45 MGD	Inlet	7.3	338	195	464	3	42	2.4
		outlet	7.6	32	20	72	1	32	0.5
	Real Time Reading at Outlet								
	37 MGD	Inlet	7.3	338	195	464	3	42	2.4
		outlet	7.6	34	22	80	1	34	0.6
	Real Time Reading at Outlet								
	16 MGD	Inlet	7.3	338	195	464	3	42	2.4
outlet		7.7	18	14	56	Nil	30	0.6	
Real Time Reading at Outlet									
Kondli	25 MGD Phase-II	Inlet	7.3	256	163	336	-	33	6.8
		outlet	7.6	13	9	32	-	29	2.5
	Real Time Reading at Outlet		7.4	21	13	4		22.76	
	45 MGD Phase-IV	Inlet	7.2	244	181	312	-	34	6.9
outlet		7.5	29	18	64	-	31	0.6	
Real Time Reading at Outlet		7.7	27	14	40		29		
Yamuna Vihar	10 MGD Phase-I	Inlet	7.2	204	167	-	-	60	5
		outlet	7.6	36	19	-	-	25	2.5
	Real Time Reading at Outlet		7.3	44		103		9	
	10 MGD Phase-II	Inlet	7.4	236	166	-	-	55	6
		outlet	7.6	30	19	-	-	30	3.5
	Real Time Reading at Outlet								
25 MGD Phase-III	Inlet	7.4	200	166	-	-	65	6	
	outlet	7.5	29	17	-	-	45	4	
Real Time Reading at Outlet		7	58	23	89		24		
Rithala	40 MGD	Inlet	7.1	248	165	370	-	34	1.2
		outlet	7.8	30	17	90	-	22	0.8
	Real Time Reading at Outlet		6.89	754.55	85.25	504.54		25.06	
	40 MGD	Inlet	7.1	248	165	370	-	34	1.2
Outlet		7.5	19	14	60	-	14	0.5	
Real Time Reading at Outlet		7.53	18.24	12.01	62.17		15.37		
Rohiini 15 MGD	15 MGD	Inlet	7.2	280	218	-	-	50	8
		Outlet	7.8	25	15	-	-	15	2.5
Real Time Reading at Outlet		7.04	23.15	9.2		-	11.57		
Keshopur	12 MGD	Inlet	7.2	208	173	-	-	27	3.1
		outlet	7.6	17	8	-	-	14	1.7
	Real Time Reading at Outlet								
	40 MGD	Inlet	7.2	300	209	-	-	30	3.2
outlet		7.5	94	113	-	-	32	2.4	
Real Time Reading at Outlet									

	20 MGD	Inlet	7.2	300	209	-	-	30	3.2
		outlet	7.7	84	83	-	-	28	2.2
	Real Time Reading at Outlet		7.44	83.31	52.88	158.01			
Nilothi	40 MGD Phase-I	Inlet	7.3	178	119	-	-	26	2.8
		outlet	7.4	35	24	-	-	19	1.9
	Real Time Reading at Outlet		7.5	31.77	20.48	101.52		18.68	
Pappankalan	20 MGD Phase-II	Inlet	7.3	260	205	-	-	38	5
		outlet	7.8	32	23	-	-	16	0.9
	Real Time Reading at Outlet								
	20 MGD Phase-II	Inlet	7.3	254	220	-	-	40	5.2
		outlet	7.7	7	6	-	-	10	2.2
	Real Time Reading at Outlet		6.96	11.8	7.67	34.77		1.68	
Corronation pillar	20 MGD Phase-I &II	Inlet	7.2	234	185	346	-	38	2.6
		outlet	7.3	84	54	128	-	24	1.7
	Real Time Reading at Outlet		7.1	58	31	131		28	
	10 MGD Phase-III	Inlet	7.1	330	250	460	8	49	2.9
		outlet	7.5	78	51	134	3.1	34	2
	Real Time Reading at Outlet		7.3	76	38	135		20	

Dir.(T&QC)







OFFICE OF THE DIRECTOR (T&QC)  
DELHI JAL BOARD: GOVT. OF NCT OF DELHI  
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	07.07.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
		50	30	250
Okhla	12 MGD	40	24	96
	45 MGD	32	20	72
	37 MGD	34	22	80
	16 MGD	18	14	56
Kondli	25 MGD	13	9	32
	45 MGD	29	18	64
Yamuna Vihar	10 MGD	36	19	-
	10 MGD	30	19	-
	25 MGD	29	17	-
Rithala	40 MGD	30	17	90
	40 MGD	19	14	60
Rohini	15 MGD	25	15	-
Keshopur	12 MGD	17	8	-
	40 MGD	94	113	-
	20 MGD	84	83	-
Nilothi	40 MGD	35	24	-
Pappankalan	20 MGD	32	23	-
	20 MGD	7	6	-
Corronation pillar	20 MGD	84	54	128
	10 MGD	78	51	134



**OFFICE OF THE DIRECTOR (T&QC)  
DELHI JAL BOARD: GOVT. OF NCT OF DELHI  
WATER WORKS WAZIRABAD:DELHI-110054**



Name of the Plant	Capacity (in MGD)	Parameters of STPs of Delhi as on					08.07.2019		
		Parameter							
		DPPC limits	pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
Okhla	12 MGD	Inlet	7.4	268	210	416	3	42	2.5
		outlet	7.9	39	27	104	Nil	36	1.5
	Real Time Reading at Outlet								
	45 MGD	Inlet	7.5	168	171	400	3	42	3.2
		outlet	7.7	17	12	48	Nil	33	2
	Real Time Reading at Outlet								
	37 MGD	Inlet	7.5	168	171	400	3	42	3.2
		outlet	7.7	42	25	104	1	34	1.8
	Real Time Reading at Outlet								
	16 MGD	Inlet	7.5	168	171	400	3	42	3.2
outlet		7.8	21	15	56	Nil	35	2.2	
Real Time Reading at Outlet									
Kondli	25 MGD Phase-II	Inlet	7.3	256	166	-	-	39	6.9
		outlet	7.6	15	10	-	-	30	2.8
	Real Time Reading at Outlet		7.4	21	15			24.02	
	45 MGD Phase-IV	Inlet	7.2	304	191	-	-	38	7.1
outlet		7.5	27	15	-	-	31	4	
Real Time Reading at Outlet									
Chilla	9 MGD	Inlet	7.2	180	114	206	-	41	6.8
		outlet	7.6	7	3	16	-	0.32	4.6
	Real Time Reading at Outlet		7.4	16	4	20		6.37	
CWG Village	1 MGD	Inlet	7.2	648	338	680	-	23	5.2
		outlet	7.7	Bdl	0.33	0.8	-	0.11	1.4
	Real Time Reading at Outlet		7.7	0.17	0.12	1.3		0.09	
Yamuna Vihar	10 MGD Phase-I	Inlet	6.8	672	256	882	-	50	6
		outlet	7.6	47	31	120	-	30	3
	Real Time Reading at Outlet		7.2	40	35	115		4.5	
	10 MGD Phase-II	Inlet	7.3	536	226	880	-	45	5
		outlet	7.5	29	23	64	-	25	2
	Real Time Reading at Outlet								
25 MGD Phase-III	Inlet	7.3	884	224	582	-	80	7.5	
	outlet	7.5	61	39	110	-	30	4.5	
Real Time Reading at Outlet		7.2	71	23	105		25		
Rithala	40 MGD	Inlet	6.9	260	172	360	26	29	1.2
		outlet	7.7	29	16	90	10	21	0.9
	Real Time Reading at Outlet		6.89	561.64	58.34	374.03		26.42	
	40 MGD	Inlet	6.9	260	172	360	26	29	1.2
		Outlet	7.6	17	12	60	6	12	0.6
Real Time Reading at Outlet		7.53	18.29	11.8	62.82		15.37		
	12 MGD	Inlet	7.3	244	158	-	-	29	3.2
		outlet	7.7	13	6	-	-	12	1.9
	Real Time Reading at Outlet		7.67	7.95	2.51	18.85	-	6.52	-

Keshopur	40 MGD	Inlet	7.2	328	192	-	-	33	3.3
		outlet	7.5	96	111	-	-	30	2.9
	Real Time Reading at Outlet		NA	NA	NA	NA	NA	NA	NA
	20 MGD	Inlet	7.2	328	192	-	-	33	3.3
		outlet	7.6	98	96	-	-	28	2.7
Real Time Reading at Outlet		7.5	67.21	53.27	144.78	-	29.54	-	
Nilothi	40 MGD Phase-I	Inlet	7.3	156	114	-	6.2	26	2.4
		outlet	7.5	31	23	-	0	18	1.8
Pappankalan	20 MGD Phase-II	Inlet	7.3	334	203	-	-	32	3.5
		outlet	7.7	70	53	-	-	25	4.5
	Real Time Reading at Outlet		7.33	70.78	60.54	192.52	-	11.05	-
	20 MGD Phase-II	Inlet	7.4	326	228	-	13.8	34	3.6
		outlet	7.8	8	7	-	0.6	12	2.2
Real Time Reading at Outlet		6.97	13.95	12.27	45.38	-	1.75	-	
Najafgarh	5 MGD Phase-II	Inlet	7.3	374	175	-	-	30	3.5
		outlet	7.8	15	10	-	-	10	2
	Real Time Reading at Outlet		7.33	33.94	26.87	76.96	-	18.34	-
Corronation pillar	20 MGD Phase-I & II	Inlet	7.1	270	192	356	8	41	2.4
		outlet	7.4	76	50	128	2.7	22	1.3
	Real Time Reading at Outlet		6.9	58	31	132		38	
	10 MGD Phase-III	Inlet	7.2	314	248	432	-	50	2.3
		outlet	7.5	70	54	126	-	36	1.2
Real Time Reading at Outlet		7.2	68	38	135		25		

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)  
DELHI JAL BOARD: GOVT. OF NCT OF DELHI  
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	08.07.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
		50	30	250
Okhla	12 MGD	39	27	104
	45 MGD	17	12	48
	37 MGD	42	25	104
	16 MGD	21	15	56
Kondli	25 MGD	15	10	-
	45 MGD	27	15	-
Chilla	9 MGD	7	3	16
CWG Village	1 MGD	Bdl	0.33	0.8
Yamuna Vihar	10 MGD	47	31	120
	10 MGD	29	23	64
	25 MGD	61	39	110
Rithala	40 MGD	29	16	90
	40 MGD	17	12	60
Keshopur	12 MGD	13	6	-
	40 MGD	96	111	-
	20 MGD	98	96	-
Nilothi	40 MGD	31	23	-
Najafgarh	5 MGD	15	10	-
Pappankalan	20 MGD	70	53	-
	20 MGD	8	7	-
Corronation pillar	20 MGD	76	50	128
	10 MGD	70	54	126





**OFFICE OF THE DIRECTOR (T&QC)**  
**DELHI JAL BOARD: GOVT. OF NCT OF DELHI**  
**WATER WORKS WAZIRABAD:DELHI-110054**



Name of the Plant	Capacity (in MGD)	Parameters of STPs of Delhi as on					09.07.2019		
		Parameter							
		DPPC limits	pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
Okhla	12 MGD	Inlet	7.2	274	228	464	4	38	2.5
		outlet	7.6	39	25	104	1	33	0.6
	Real Time Reading at Outlet								
	45 MGD	Inlet	7.3	370	215	-	-	40	3.2
		outlet	7.6	34	21	-	-	34	0.8
	Real Time Reading at Outlet								
	37 MGD	Inlet	7.3	370	215	-	-	40	3.2
		outlet	7.8	29	20	-	-	35	0.8
	Real Time Reading at Outlet								
	16 MGD	Inlet	7.3	370	215	-	-	40	3.2
outlet		7.7	20	15	-	-	35	0.5	
Real Time Reading at Outlet									
Kondli	25 MGD Phase-II	Inlet	7.3	228	155	280	-	39	7
		outlet	7.6	12	8	26	-	28	3
	Real Time Reading at Outlet		7.4	21	18	57		24.91	
	45 MGD Phase-IV	Inlet	7.2	322	180	376	-	38	6.8
		outlet	7.5	24	13	51	-	29	3.9
Real Time Reading at Outlet		7.7	27	15	41		9.8		
Chilla	9 MGD	Inlet	7.2	192	127	-	-	41	7
		outlet	7.6	10	3.7	-	-	0.28	4.8
	Real Time Reading at Outlet		7.2	18	3.6			6.4	
CWG Village	1 MGD	Inlet	7.2	772	437	-	-	23	5.4
		outlet	7.7	1	0.17	-	-	0.12	1.8
	Real Time Reading at Outlet		7.7	0.19	0.13			0.09	
Yamuna Vihar	10 MGD Phase-I	Inlet	6.8	292	170	779	20.8	65	7
		outlet	7.5	30	18	93	12	30	4.5
	Real Time Reading at Outlet		7.2	42	59	191		1.7	
	10 MGD Phase-II	Inlet	7.3	216	147	557	8	60	7.5
		outlet	7.5	16	13	58	4.4	20	4.5
	Real Time Reading at Outlet								
25 MGD Phase-III	Inlet	7.3	240	155	633	9.2	55	6.5	
	outlet	7.5	46	30	135	4.8	35	3.5	
Real Time Reading at Outlet									
Rithala	40 MGD	Inlet	7	284	175	410	-	27	0.8
		outlet	7.6	31	18	90	-	19	0.5
	Real Time Reading at Outlet		7.51	60.8	8.94	64.58	-	25.48	
	40 MGD	Inlet	7	284	175	410	-	27	0.8
		Outlet	7.7	18	13	60	-	11	0.4
Real Time Reading at Outlet		7.51	18.18	14.15	63.64	-	15.34		
Rohiini 15 MGD	15 MGD	Inlet	7.4	284	165	419	-	54	10
		Outlet	7.9	24	13	115	-	16	3
	Real Time Reading at Outlet		7.15	22.87	8.41	87.3		12.28	

Keshopur	12 MGD	Inlet	7.5	232	108	400	21	29	3.2
		outlet	7.8	12	4	28	0	4	1.7
	Real Time Reading at Outlet		NA	NA	NA	NA	-	NA	-
	40 MGD	Inlet	7.5	256	119	460	10.8	28	3.5
		outlet	7.7	98	92	280	7.2	24	2.9
	Real Time Reading at Outlet		6.68	192.57	98.79	254.41	-	16.9	-
20 MGD	Inlet	7.5	256	119	460	10.8	28	3.5	
	outlet	7.7	152	77	280	5.2	25	2.8	
Real Time Reading at Outlet		7.49	614.25	79.83	628.29	-	39.91	-	
Nilothi	40 MGD Phase-I	Inlet	7.3	144	121	480	-	26	2.6
		outlet	7.5	28	22	90	-	16	2
	Real Time Reading at Outlet		7.55	31.15	20.94	102.39	-	18.36	-
	20 MGD Phase-II	Inlet	7.2	160	133	510	5.8	28	3
outlet		7.3	9	8	40	0	15	1.6	
Real Time Reading at Outlet		NA	9.18	2.97	23.83	-	NA	-	
Pappankalan	20 MGD Phase-II	Inlet	7.2	494	270	940	-	34	3.6
		outlet	7.7	55	35	160	-	22	3.9
	Real Time Reading at Outlet		7.42	39.05	29.96	148.97	-	7.4	-
	20 MGD Phase-II	Inlet	7.3	486	265	-	-	35	4
outlet		7.5	8	6	-	-	11	2.2	
Real Time Reading at Outlet		6.99	12.55	15.47	48.28	-	1.72	-	
Najafgarh	5 MGD Phase-II	Inlet	7.2	214	165	653	-	28	3.4
		outlet	7.7	21	12	88	-	12	2.5
	Real Time Reading at Outlet		7.55	34	27.38	78.65	-	18.3	-
Corronation pillar	20 MGD Phase-I & II	Inlet	7.2	290	235	494	-	44	2.3
		outlet	7.5	84	52	128	-	25	1.2
	Real Time Reading at Outlet		7.4	59	31	132		14	
	10 MGD Phase-III	Inlet	7	328	305	464	7.4	58	2.8
outlet		7.4	76	60	118	2.3	40	1.6	
Real Time Reading at Outlet		7.4	63	35	117		15		
Narela	10 MGD Phase-III	Inlet	6.8	140	195	276	8.4	60	2.9
		outlet	7.5	64	48	124	3.4	36	1.9
	Real Time Reading at Outlet		7	56	32	111		52	

Dir.(T&QC)







OFFICE OF THE DIRECTOR (T&QC)  
DELHI JAL BOARD: GOVT. OF NCT OF DELHI  
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	09.07.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
		50	30	250
Okhla	12 MGD	39	25	104
	45 MGD	34	21	-
	37 MGD	29	20	-
	16 MGD	20	15	-
Kondli	25 MGD	12	8	26
	45 MGD	24	13	51
Chilla	9 MGD	10	3.7	-
CWG Village	1 MGD	1	0.17	-
Yamuna Vihar	10 MGD	30	18	93
	10 MGD	16	13	58
	25 MGD	46	30	135
Rithala	40 MGD	31	18	90
	40 MGD	18	13	60
Rohiini	15 MGD	24	13	115
Keshopur	12 MGD	12	4	28
	40 MGD	98	92	280
	20 MGD	152	77	280
Nilothi	40 MGD	28	22	90
	20 MGD	9	8	40
Najafgarh	5 MGD	21	12	88
Pappankalan	20 MGD	55	35	160
	20 MGD	8	6	-
Corronation pillar	20 MGD	84	52	128
	10 MGD	76	60	118
Narela	10 MGD	64	48	124



**OFFICE OF THE DIRECTOR (T&QC)  
DELHI JAL BOARD: GOVT. OF NCT OF DELHI  
WATER WORKS WAZIRABAD:DELHI-110054**



Name of the Plant	Capacity (in MGD)	Parameters of STPs of Delhi as on						10.07.2019	
		Parameter							
		DPPC limits	pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
Okhla	12 MGD	Inlet	7.38	180	188	464	4	38	3
		outlet	7.76	39	22	96	2	30	0.8
	Real Time Reading at Outlet								
	45 MGD	Inlet	7.42	198	173	400	4	40	3.2
		outlet	7.72	47	25	112	2	35	1.5
	Real Time Reading at Outlet								
	37 MGD	Inlet	7.42	198	173	400	4	40	3.2
		outlet	7.75	15	9	40	Nil	33	0.8
	Real Time Reading at Outlet								
	16 MGD	Inlet	7.42	198	173	400	4	40	3.2
outlet		7.8	26	17	72	Nil	36	1	
Real Time Reading at Outlet									
Kondli	25 MGD Phase-II	Inlet	7.2	296	179	-	18	39	6.9
		outlet	7.7	15	9	-	2.3	31	3.1
	Real Time Reading at Outlet		7.3	22	22	67		25.53	
	45 MGD Phase-IV	Inlet	7.2	266	165	-	-	40	6.5
		outlet	7.6	27	15	-	-	32	4.2
Real Time Reading at Outlet		7.7	27	14	39		10.46		
Chilla	9 MGD	Inlet	7.1	184	116	237	-	41	6.8
		outlet	7.6	7	2.9	19	-	0.24	3.4
	Real Time Reading at Outlet		7.2	17	4			6.43	
CWG Village	1 MGD	Inlet	7.1	516	288	403	-	21	4.7
		outlet	7.6	1	0.52	1.6	-	0.1	1.5
	Real Time Reading at Outlet		7.7	0.18	0.12	1.47		0.09	
Yamuna Vihar	10 MGD Phase-I	Inlet	7.5	384	149	897	-	55	6.5
		outlet	7.5	27	17	83	-	50	4
	Real Time Reading at Outlet		7.3	42	37	120		91	
	10 MGD Phase-II	Inlet	7.4	368	147	834	-	45	6
		outlet	7.5	34	13	92	-	35	3.5
	Real Time Reading at Outlet								
25 MGD Phase-III	Inlet	7.5	296	158	740	-	60	4.5	
	outlet	7.6	38	19	110	-	45	1.5	
Real Time Reading at Outlet									
Rithala	40 MGD	Inlet	7	296	173	360	-	31	0.8
		outlet	7.5	31	19	80	-	15	0.6
	Real Time Reading at Outlet		7.31	49.87	15.73	71.3		27.35	
	40 MGD	Inlet	7	296	173	360	-	31	0.8
		Outlet	7.6	17	12	50		11	0.4
Real Time Reading at Outlet		7.15	18.42	12.53	63.09		15.34		
	12 MGD	Inlet	7.3	596	288	-	-	30	2.9
		outlet	7.8	10	7	-	-	7	2.7
	Real Time Reading at Outlet		7.63	7.94	2.47	18.97	-	6.74	

Keshopur	40 MGD	Inlet	7.3	324	232	-	-	29	2.8
		outlet	7.5	98	142	-	-	28	2.6
	Real Time Reading at Outlet		6.52	250.51	99.44	295.32	-	23.5	
	20 MGD	Inlet	7.3	324	232	-	-	29	2.8
		outlet	7.6	68	122	-	-	26	2.7
Real Time Reading at Outlet		7.05	128.52	39.02	158.65	-	25.13		
Nilothi	40 MGD Phase-I	Inlet	7.2	150	108	-	-	25	2.8
		outlet	7.5	30	21	-	-	16	2.5
	Real Time Reading at Outlet		7.52	32.99	22.29	105.33		18.62	
Pappankalan	20 MGD Phase-II	Inlet	7.3	110	105	-	-	36	4
		outlet	7.7	20	18	-	-	18	3.8
	Real Time Reading at Outlet		7.4	27.9	17.95	128.72	-	7.7	
	20 MGD Phase-II	Inlet	7.2	100	103	-	-	40	3.5
		outlet	7.6	6	7	-	-	14	2.2
Real Time Reading at Outlet		6.98	11.21	3.37	27.04	-	1.6		
Najafgarh	5 MGD Phase-II	Inlet	7.3	98	92	-	-	28	3.5
		outlet	7.7	14	12	-	-	10	2
	Real Time Reading at Outlet		7.71	34.5	29.18	85.1	-	18.88	
Corronation pillar	20 MGD Phase-I & II	Inlet	6.9	326	280	426	7.7	37	2.1
		outlet	7.4	70	49	116	2.4	23	1
	Real Time Reading at Outlet		7.4	58	31	131		13	
	10 MGD Phase-III	Inlet	6.8	356	330	454	-	54	2.5
		outlet	7.4	90	64	150	-	37	1.4
Real Time Reading at Outlet		7.5	62	35	117		14		

Dir.(T&QC)









OFFICE OF THE DIRECTOR (T&QC)  
DELHI JAL BOARD: GOVT. OF NCT OF DELHI  
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	10.07.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
		50	30	250
Okhla	12 MGD	39	22	96
	45 MGD	47	25	112
	37 MGD	15	9	40
	16 MGD	26	17	72
Kondli	25 MGD	15	9	-
	45 MGD	27	15	-
Chilla	9 MGD	7	2.9	19
CWG Village	1 MGD	1	0.52	1.6
Yamuna Vihar	10 MGD	27	17	83
	10 MGD	34	13	92
	25 MGD	38	19	110
Rithala	40 MGD	31	19	80
	40 MGD	17	12	50
Keshopur	12 MGD	10	7	-
	40 MGD	98	142	-
	20 MGD	68	122	-
Nilothi	40 MGD	30	21	-
Najafgarh	5 MGD	14	12	-
Pappankalan	20 MGD	20	18	-
	20 MGD	6	7	-
Corronation pillar	20 MGD	70	49	116
	10 MGD	90	64	150



**OFFICE OF THE DIRECTOR (T&QC)**  
**DELHI JAL BOARD: GOVT. OF NCT OF DELHI**  
**WATER WORKS WAZIRABAD:DELHI-110054**



Name of the Plant	Capacity (in MGD)	Parameters of STPs of Delhi as on					11.07.2019		
		Parameter							
		DPPC limits	pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
Okhla	12 MGD	Inlet	7.27	246	170	384	6	42	2.5
		outlet	7.6	38	23	96	4	36	0.5
	Real Time Reading at Outlet								
	45 MGD	Inlet	7.3	232	178	416	5	42	2
		outlet	7.68	41	26	112	2	36	1
	Real Time Reading at Outlet								
	37 MGD	Inlet	7.3	232	178	416	5	42	2
		outlet	7.68	22	13	56	1	33	0.8
	Real Time Reading at Outlet								
	16 MGD	Inlet	7.3	232	178	416	5	42	2
outlet		7.76	23	16	64	1	36	0.5	
Real Time Reading at Outlet									
Kondli	25 MGD Phase-II	Inlet	7.2	254	146	272	-	38	7
		outlet	7.7	18	10	42	-	30	2.6
	Real Time Reading at Outlet		7.4	21	12	43		24.37	
	45 MGD Phase-IV	Inlet	7.2	248	161	254	-	39	6.7
		outlet	7.5	29	16	61	-	31	3.8
Real Time Reading at Outlet		7.7	26	14	39		13.8		
Chilla	9 MGD	Inlet	7.1	128	97	-	-	42	7
		outlet	7.6	9	3.2	-	-	0.3	3.3
	Real Time Reading at Outlet		7.2	20	4.18	21		6.35	
CWG Village	1 MGD	Inlet	7.1	380	215	-	-	21.6	5.1
		outlet	7.7	1	0.36	-	-	0.11	1.7
	Real Time Reading at Outlet		7.6	0.2	0.13	1.5		0.09	
Yamuna Vihar	10 MGD Phase-I	Inlet	7.1	282	190	460	-	35	4.5
		outlet	7.6	39	29	120	-	20	2.5
	Real Time Reading at Outlet		7.3	41	37	126		32	
	10 MGD Phase-II	Inlet	7.6	244	180	680	-	25	6
		outlet	7.8	47	29	140	-	15	2.5
	Real Time Reading at Outlet								
25 MGD Phase-III	Inlet	7.2	296	196	520	-	35	4.5	
	outlet	7.4	44	29	130	-	20	2.5	
Real Time Reading at Outlet		7.2	36	32	90		25		
Rithala	40 MGD	Inlet	7.1	272	166	430	27	32	1.7
		outlet	7.6	32	21	90	5	26	1.2
	Real Time Reading at Outlet		7.2	42.41	15.5	67.33		28.87	
	40 MGD	Inlet	7.1	272	166	430	27	32	1.7
		Outlet	7.7	18	13	60	3	14	0.9
Real Time Reading at Outlet		7.51	18.25	13.5	63.34		15.34		
Rohiini 15 MGD	15 MGD	Inlet	7.3	-	168	592	-	52	7
		Outlet	7.9	-	17	144	-	16	3
	Real Time Reading at Outlet		7.21		8.35	88.24		11.81	

Keshopur	12 MGD	Inlet	7.4	328	218	533	12.6	29	2.9
		outlet	7.7	11	6	26	0.4	6	2.1
	Real Time Reading at Outlet		7.6	14.92	3.2	31.2		6.53	
	40 MGD	Inlet	7.3	356	237	640	17.6	28	3
		outlet	7.5	122	132	304	10	27	2.6
	Real Time Reading at Outlet		6.65	401.73	108.69	378.22		17	
20 MGD	Inlet	7.3	356	237	640	17.6	28	3	
	outlet	7.6	112	113	256	2.8	26	2.5	
Real Time Reading at Outlet		7.4	127.99	57.08	203.64		27.78		
Nilothi	40 MGD Phase-I	Inlet	7.3	172	119	-	-	24	2.8
		outlet	7.5	32	22	-	-	17	2.2
	Real Time Reading at Outlet		7.53	33.09	23.18	107.11		18.93	
Pappankalan	20 MGD Phase-II	Inlet	7.3	364	228	720	16.1	36	3.8
		outlet	7.6	46	33	126	1.7	12	1.8
	Real Time Reading at Outlet		7.27	26.56	25.34	136.82		7.2	
	20 MGD Phase-II	Inlet	7.3	328	240	740	15.2	37	4.5
outlet		7.7	8	8	64	1	10	2.5	
Real Time Reading at Outlet		7.02	12.14	8.11	36.11		1.67		
Najafgarh	5 MGD Phase-II	Inlet	7.3	124	88	-	-	16	2.4
		outlet	7.6	16	10	-	-	12	0.8
	Real Time Reading at Outlet		7.73	34.25	29.45	84.98		19.05	
Corronation pillar	20 MGD Phase-I & II	Inlet	7.1	196	205	375	-	40	2
		outlet	7.4	90	55	138	-	29	0.9
	Real Time Reading at Outlet		7.4	59	31	131		15	
	10 MGD Phase-III	Inlet	7	302	285	462	8.2	53	2.1
		outlet	7.4	110	60	196	3.1	30	1.2
Real Time Reading at Outlet		7.5	78	37	136		19		

Dir.(T&QC)







OFFICE OF THE DIRECTOR (T&QC)  
DELHI JAL BOARD: GOVT. OF NCT OF DELHI  
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	11.07.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
		50	30	250
Okhla	12 MGD	38	23	96
	45 MGD	41	26	112
	37 MGD	22	13	56
	16 MGD	23	16	64
Kondli	25 MGD	18	10	42
	45 MGD	29	16	61
Chilla	9 MGD	9	3.2	-
CWG Village	1 MGD	1	0.36	-
Yamuna Vihar	10 MGD	39	29	120
	10 MGD	47	29	140
	25 MGD	44	29	130
Rithala	40 MGD	32	21	90
	40 MGD	18	13	60
Rohiini	15 MGD	-	17	144
Keshopur	12 MGD	11	6	26
	40 MGD	122	132	304
	20 MGD	112	113	256
Nilothi	40 MGD	32	22	-
Najafgarh	5 MGD	16	10	-
Pappankalan	20 MGD	46	33	126
	20 MGD	8	8	64
Corronation pillar	20 MGD	90	55	138
	10 MGD	110	60	196



**OFFICE OF THE DIRECTOR (T&QC)**  
**DELHI JAL BOARD: GOVT. OF NCT OF DELHI**  
**WATER WORKS WAZIRABAD:DELHI-110054**



Name of the Plant	Capacity (in MGD)	Parameters of STPs of Delhi as on					12.07.2019		
		Parameter							
		DPPC limits	pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
Okhla	12 MGD	Inlet	7.22	154	143	312	2	40	3
		outlet	7.68	33	20	88	Nil	35	0.5
	Real Time Reading at Outlet								
	45 MGD	Inlet	7.24	180	180	344	2	43	3.5
		outlet	7.63	36	24	96	Nil	38	1.8
	Real Time Reading at Outlet								
	37 MGD	Inlet	7.24	180	180	344	2	43	3.5
		outlet	7.72	20	15	56	Nil	30	1.5
	Real Time Reading at Outlet								
	16 MGD	Inlet	7.24	180	180	344	2	43	3.5
outlet		7.8	22	15	56	Nil	38	1	
Real Time Reading at Outlet									
New 30 MGD	Inlet	7.31	186	218	424	4	38	2.4	
	Outlet	7.65	5	4	24	Nil	5	Nil	
Real Time Reading at Outlet									
Mehrauli	5 MGD	Inlet	7.45	306	164	384	4	40	3.5
		outlet	7.69	10	11	40	Nil	7	2.5
Real Time Reading at Outlet									
Vasant Kunj	2.2 MGD	Inlet	7.3	168	152	312	3	35	3.2
		outlet	7.9	26	16	72	Nil	25	1
	Real Time Reading at Outlet								
	3 MGD	Inlet	7.4	404	240	408	5	38	3.8
outlet		7.7	5	6	24	Nil	8	2	
Real Time Reading at Outlet									
Kapashera	5 MGD	Inlet	7.28	662	460	768	4	50	4.5
		outlet	7.78	14	10	40	Nil	38	1.2
Real Time Reading at Outlet									
Kondli	25 MGD Phase-II	Inlet	7.2	314	206	-	-	37	6.9
		outlet	7.7	14	9	-	-	29	3.6
	Real Time Reading at Outlet		7.4	21	18	54		24.88	
	45 MGD Phase-IV	Inlet	7.2	310	175	-	-	38	6.5
outlet		7.6	28	17	-	-	35	4	
Real Time Reading at Outlet		7.8	26	15	38		6.24		
Chilla	9 MGD	Inlet	7.1	144	112	208	-	43	6.6
		outlet	7.6	9	4	23	-	0.27	4.2
Real Time Reading at Outlet		7.1	9	3.3	17		6.1		
CWG Village	1 MGD	Inlet	7.7	352	213	396	-	24	5.4
		outlet	7.7	Bdl	0.76	1.38	-	0.1	1.5
Real Time Reading at Outlet		7.7	0.17	0.12	1.44		0.09		
	10 MGD Phase-I	Inlet	6.9	316	175	636	-	50	7.5
		outlet	7.6	30	21	120	-	35	5.5
Real Time Reading at Outlet									



Yamuna Vihar	10 MGD Phase-II	Inlet	7.4	220	161	626	-	35	7
		outlet	7.7	27	19	90	-	25	3
	Real Time Reading at Outlet								
	25 MGD Phase-III	Inlet	7.2	400	198	658	-	55	8
		outlet	7.5	35	21	115	-	40	6
Real Time Reading at Outlet									
Rithala	40 MGD	Inlet	7	304	184	360	-	31	1
		outlet	7.5	33	19	90	-	20	0.7
	Real Time Reading at Outlet		7.34	72.06	15.11	79.05		25.01	
	40 MGD	Inlet	7	304	184	360	-	31	1
		Outlet	7.6	19	14	70	-	14	0.5
Real Time Reading at Outlet		7.36	36.23	16.4	113.77		15.04		
Keshopur	12 MGD	Inlet	7.2	588	310	-	-	34	3
		outlet	7.7	12	7	-	-	6	2.6
	Real Time Reading at Outlet		7.64	28.82	5.77	61.15		5.37	
	40 MGD	Inlet	7.3	540	265	-	-	32	3.1
		outlet	7.5	108	97	-	-	25	2.8
	Real Time Reading at Outlet		6.7	233.97	101.48	285.98		17.6	
	20 MGD	Inlet	7.3	540	265	-	-	32	3.1
outlet		7.6	90	94	-	-	29	2.9	
Real Time Reading at Outlet		7.5	79.89	52.41	154.76		36.93		
Nilothi	40 MGD Phase-I	Inlet	7.4	170	132	490	-	28	4
		outlet	7.6	29	19	96	-	18	3.2
	Real Time Reading at Outlet		7.6	36.5	24.92	111.18		17.87	
	20 MGD Phase-II	Inlet	7.4	236	156	400	-	29	3.1
		outlet	7.8	10	9	28	-	10	1.8
Real Time Reading at Outlet			8.66	3.11	25.83				
Pappankalan	20 MGD Phase-II	Inlet	7.3	228	178	-	-	36	3.5
		outlet	7.8	36	17	-	-	22	3.2
	Real Time Reading at Outlet		7.51	32.03	21.19	77.24		11.7	
	20 MGD Phase-II	Inlet	7.3	214	187	-	-	38	4
		outlet	7.8	6	7	-	-	5	3.8
Real Time Reading at Outlet		7.03	8.83	4.03	26.63		1.67		
Najafgarh	5 MGD Phase-II	Inlet	7.3	116	82	-	-	18	3
		outlet	7.7	10	8	-	-	14	1.2
	Real Time Reading at Outlet		7.64	33.99	28.74	82.21		19.66	
Corronation pillar	20 MGD Phase-I & II	Inlet	7.2	188	195	344	8.7	42	2.4
		outlet	7.5	78	53	118	2.9	31	1.3
	Real Time Reading at Outlet		7.5	59	31	132		11	
	10 MGD Phase-III	Inlet	7.1	322	295	438	-	50	2.3
		outlet	7.4	84	62	138	-	36	1.1
Real Time Reading at Outlet		7.4	92	39	153		20		
Narela	10 MGD Phase-III	Inlet	7	208	210	298	8	58	2.8
		outlet	7.3	55	46	134	2.7	41	1.8
	Real Time Reading at Outlet		6.8	62	32	115		288	

Dir.(T&QC)







OFFICE OF THE DIRECTOR (T&QC)  
DELHI JAL BOARD: GOVT. OF NCT OF DELHI  
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	12.07.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
		50	30	250
Okhla	12 MGD	33	20	88
	45 MGD	36	24	96
	37 MGD	20	15	56
	16 MGD	22	15	56
	New 30 MGD	5	4	24
Mehrauli	5 MGD	10	11	40
Vasant Kunj	2.2 MGD	26	16	72
	3 MGD	5	6	24
Kapashera	5 MGD	14	10	40
Kondli	25 MGD	14	9	-
	45 MGD	28	17	-
Chilla	9 MGD	9	4	23
CWG Village	1 MGD	Bdl	0.76	1.38
Yamuna Vihar	10 MGD	30	21	120
	10 MGD	27	19	90
	25 MGD	35	21	115
Rithala	40 MGD	33	19	90
	40 MGD	19	14	70
Keshopur	12 MGD	12	7	-
	40 MGD	108	97	-
	20 MGD	90	94	-
Nilothi	40 MGD	29	19	96
	20 MGD	10	9	28
Najafgarh	5 MGD	10	8	-
Pappankalan	20 MGD	36	17	-
	20 MGD	6	7	-
Corronation pillar	20 MGD	78	53	118
	10 MGD	84	62	138
Narela	10 MGD	55	46	134