



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Parameters of STPs of Delhi as on							09.12.2019		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Okhla	12 MGD	Inlet	7.4	192	160	360	3	39	2.1
		outlet	7.7	38	27	104	1	28	0.8
	Real Time Reading at Outlet								
	45 MGD	Inlet	7.6	244	173	376	4	41	2.1
		outlet	7.7	31	28	104	1	32	0.4
	Real Time Reading at Outlet								
	37 MGD	Inlet	7.6	244	173	376	3	41	2.1
		outlet	7.7	21	15	64	1	34	0.6
	Real Time Reading at Outlet								
	16 MGD	Inlet	7.6	240	173	376	4	41	2.1
		outlet	7.7	14	15	56	NIL	32	0.6
	Real Time Reading at Outlet								
Kondli	25 MGD Phase-II	Inlet	7.3	336	196	342	23.5	36	6.6
		outlet	7.7	14	7	32	3.5	25	3
	Real Time Reading at Outlet		7.6	19	10	27	-	2	-
	45 MGD Phase-IV	Inlet	7.3	312	169	328	18.5	37	5.8
		outlet	7.6	28	16	54	4.5	28	3.2
	Real Time Reading at Outlet		7.6	20	17	75	-	5	-
Chilla	9 MGD	Inlet	7	292	163	308	14.5	42	6.8
		outlet	7.4	7	2.6	16	1.5	4	4.2
	Real Time Reading at Outlet		7.4	8	8	32	-	5	-
CWG Village	1 MGD	Inlet	7.2	800	460	834	28	23	5.4
		outlet	7.7	1	0.55	1.6	BDL	NIL	4.2
	Real Time Reading at Outlet		7.2	1.79	1.21	3.56	-	0.5	-
Rithala	40 MGD	Inlet	7.6	29	20	80	-	18	1.2
		outlet	7.5	17	11	60	-	12	1.1
	Real Time Reading at Outlet								
	40 MGD	Inlet	7.6	29	20	80	-	18	1.2
		Real Time Reading at Outlet							
Rohiini 15 MGD	15 MGD	Inlet	7.6	2.4	148	-	-	53	10
		Outlet	7.8	81	45	-	-	18	5
	Real Time Reading at Outlet								
Keshopur	12 MGD	Inlet	7.4	396	180	-	-	31	3
		outlet	7.6	19	10	-	-	2	2.2
	Real Time Reading at Outlet								
	40 MGD	Inlet	7.3	500	233	-	-	32	3.2
		outlet	7.5	96	70	-	-	28	2.6
	Real Time Reading at Outlet								
	20 MGD	Inlet	7.3	500	233	-	-	32	3.2
		outlet	7.5	150	108	-	-	29	2.8
Real Time Reading at Outlet									
	20 MGD	Inlet	7.2	330	200	613	-	38	5

Pappankalan	Phase-I	outlet	7.7	44	20	130	-	22	1
	Real Time Reading at Outlet								
	20 MGD Phase-II	Inlet	7.2	276	192	580	-	36	5.2
		outlet	7.5	5	4	10	-	1.8	2.9
	Real Time Reading at Outlet								
Najafgarh	5 MGD Phase-II	Inlet	7.3	242	170	-	-	35	4.8
		outlet	7.5	20	10	-	-	0.9	1.4
	Real Time Reading at Outlet								
Corronation pillar	20 MGD Phase-I &II	Inlet	6.9	244	195	346	6.6	35	8.4
		outlet	7.5	68	52	128	2.4	23	4.1
	Real Time Reading at Outlet								
	10 MGD Phase-III	Inlet	7.1	290	278	376	-	52	9
		outlet	7.7	88	72	138	-	41	4.7
	Real Time Reading at Outlet								

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	09.12.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC limits	50	30	250
Okhla	12 MGD	38	27	104
	45 MGD	31	28	104
	37 MGD	21	15	64
	16 MGD	14	15	56
Kondli	25 MGD	14	7	32
	45 MGD	28	16	54
Chilla	9 MGD	7	2.6	16
CWG Village	1 MGD	1	0.55	1.6
Rithala	40 MGD	17	11	60
Rohiini	15 MGD	81	45	-
Keshopur	12 MGD	19	10	-
	40 MGD	96	70	-
	20 MGD	150	108	-
Najafgarh	5 MGD	20	10	-
Pappankalan	20 MGD	44	20	130
	20 MGD	5	4	10
Corronation pillar	20 MGD	68	52	128
	10 MGD	88	72	138



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Parameters of STPs of Delhi as on							10.12.2019		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Okhla	12 MGD	Inlet	7.6	294	223	424	3	39	1.6
		outlet	7.8	40	24	96	1	31	0.6
	Real Time Reading at Outlet								
	45 MGD	Inlet	7.6	308	230	440	3	40	1.8
		outlet	7.7	38	26	10	1	34	0.6
	Real Time Reading at Outlet								
	37 MGD	Inlet	7.6	308	230	440	3	40	1.8
		outlet	7.7	15	11	40	1	29	0.7
	Real Time Reading at Outlet								
	16 MGD	Inlet	7.6	308	230	440	3	40	1.8
		outlet	7.7	11	7	32	1	29	0.5
	Real Time Reading at Outlet								
Kondli	25 MGD Phase-II	Inlet	7.3	436	231	442	-	32	6.1
		outlet	7.7	12	6	30	-	22	3.2
	Real Time Reading at Outlet		7.5	18	9	22	-	2	-
	45 MGD Phase-IV	Inlet	7.3	272	166	294	-	33	5.9
		outlet	7.6	27	18	58	-	25	3.3
	Real Time Reading at Outlet		7.6	21	21	97	-	5	-
Chilla	9 MGD	Inlet	7.1	424	225	438	-	38	6.6
		outlet	7.3	8	2.8	18	-	3	3.8
	Real Time Reading at Outlet		7.1	6	7	31	-	3	-
Yamuna Vihar	10 MGD Phase-I	Inlet	7.2	220	166	-	12.4	45	3.5
		outlet	7.5	23	15	-	5.2	25	2.5
	Real Time Reading at Outlet								
	10 MGD Phase-II	Inlet	7.2	172	134	-	10	30	3
		outlet	7.4	21	16	-	3.6	10	2
	Real Time Reading at Outlet								
	25 MGD Phase-III	Inlet	7.1	552	346	-	15.6	35	4
		outlet	7.3	54	38	-	7.2	20	2
Real Time Reading at Outlet									
Rithala	40 MGD	Inlet	7.5	30	21	90	-	15	0.8
		outlet	7.4	18	13	70	-	12	0.5
	Real Time Reading at Outlet								
	40 MGD	Inlet	7.5	30	21	90	-	15	0.8
Real Time Reading at Outlet									
Rohiini 15 MGD	15 MGD	Inlet	7.5	228	158	454	-	48	5
		Outlet	7.5	26	15	96	-	14	2
	Real Time Reading at Outlet								
	12 MGD	Inlet	7.3	412	181	600	-	32	3.3
		outlet	7.6	14	6	32	-	1	2.2
	Real Time Reading at Outlet								
	40 MGD	Inlet	7.3	412	181	613	-	34	34

Keshopur	40 MGD	outlet	7.6	226	160	480	-	31	31
		Real Time Reading at Outlet							
	20 MGD	Inlet	7.3	412	181	613	-	34	34
		outlet	7.5	146	11	356	-	26	2.9
	Real Time Reading at Outlet								
Nilothi	40 MGD Phase-I	Inlet	7.1	334	166	570	8.6	30	3
		outlet	7.3	8	7	20	NIL	10	1.5
	Real Time Reading at Outlet								
	20 MGD	Inlet	7.3	238	133	-	-	28	2.5
	Real Time Reading at Outlet								
Pappankalan	20 MGD Phase-I	Inlet	7.3	337	203	-	-	40	5.2
		outlet	7.8	74	38	-	-	24	1
	Real Time Reading at Outlet								
	20 MGD Phase-II	Inlet	7.2	405	225	-	-	37	5.5
		outlet	7.5	5	3	-	-	1.9	3.1
	Real Time Reading at Outlet								
Najafgarh	5 MGD Phase-II	Inlet	7.2	301	185	-	-	33	4.6
		outlet	7.5	15	9	-	-	0.8	1.6
	Real Time Reading at Outlet								
Corronation pillar	20 MGD Phase-I & II	Inlet	7	238	185	338	-	42	9.2
		outlet	7.5	72	54	132	-	28	4.6
	Real Time Reading at Outlet								
	10 MGD Phase-III	Inlet	7.2	298	280	382	7.4	55	9.5
		outlet	7.6	90	73	142	3.2	39	4.9
	Real Time Reading at Outlet								

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	10.12.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC limits	50	30	250
Okhla	12 MGD	40	24	96
	45 MGD	38	26	10
	37 MGD	15	11	40
	16 MGD	11	7	32
Kondli	25 MGD	12	6	30
	45 MGD	27	18	58
Chilla	9 MGD	8	2.8	18
Yamuna Vihar	10 MGD	23	15	-
	10 MGD	21	16	-
	25 MGD	54	38	-
Rithala	40 MGD	18	13	70
Rohiini	15 MGD	26	15	96
Keshopur	12 MGD	14	6	32
	40 MGD	226	160	480
	20 MGD	146	11	356
Nilothi	40 MGD	8	7	20
Najafgarh	5 MGD	15	9	-
Pappankalan	20 MGD	74	38	-
	20 MGD	5	3	-
Corronation pillar	20 MGD	72	54	132
	10 MGD	90	73	142



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Parameters of STPs of Delhi as on							11.12.2019		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Okhla	12 MGD	Inlet	7.4	270	183	368	3	39	2.1
		outlet	7.7	41	27	96	1	28	0.9
	Real Time Reading at Outlet								
	45 MGD	Inlet	7.5	224	168	384	3	40	2.1
		outlet	7.7	31	17	72	1	31	0.7
	Real Time Reading at Outlet								
	37 MGD	Inlet	7.5	224	168	384	3	40	2.1
		outlet	7.8	17	14	56	NIL	31	0.6
	Real Time Reading at Outlet								
	16 MGD	Inlet	7.5	224	168	384	3	40	2.1
		outlet	7.9	12	12	64	NIL	34	0.5
Kondli	25 MGD Phase-II	Inlet	7.3	372	222	394	20.5	34	6.7
		outlet	7.6	14	8	34	3	22	3.4
	Real Time Reading at Outlet		7.5	19	9	23	-	2	-
	45 MGD Phase-IV	Inlet	7.4	464	233	472	19	34	6.4
		outlet	7.7	25	16	54	3.8	25	3.9
	Real Time Reading at Outlet		7.5	48	25	184	-	5	-
Chilla	9 MGD	Inlet	7.1	300	179	314	15	36	6.4
		outlet	7.2	7	2.9	16	2	3	4.4
	Real Time Reading at Outlet		7.1	5	7	31	-	3	-
Yamuna Vihar	10 MGD Phase-I	Inlet	7.2	344	213	696	-	55	2
		outlet	7.5	23	13	88	-	35	1
	Real Time Reading at Outlet								
	10 MGD Phase-II	Inlet	7.2	344	124	648	-	35	3
		outlet	7.4	27	14	104	-	25	1.5
	Real Time Reading at Outlet								
	25 MGD Phase-III	Inlet	7.2	300	188	736	-	55	3.5
		outlet	7.3	57	30	160	-	45	1.5
Real Time Reading at Outlet									
Rithala	40 MGD	Inlet	7.6	28	18	70	-	17	0.5
		outlet	7.4	17	12	50	-	13	0.4
	Real Time Reading at Outlet								
	40 MGD	Inlet	7.6	28	18	70	-	17	0.5
		Outlet							
Real Time Reading at Outlet									
Rohiini 15 MGD	15 MGD	Inlet	7.2	504	300	-	-	40	5
		Outlet	7.1	34	21	-	-	16	2.5
	Real Time Reading at Outlet								
Kachanpur	12 MGD	Inlet	7.3	196	143	-	-	34	3.5
		outlet	7.6	15	6	-	-	1	2.4
	Real Time Reading at Outlet								
	40 MGD	Inlet	7.3	500	226	-	-	33	3.4
		outlet	7.7	82	83	-	-	31	2.8

Keshinapur	Real Time Reading at Outlet								
	20 MGD	Inlet	7.3	500	226	-	-	33	3.4
		outlet	7.5	156	113	-	-	30	2.9
	Real Time Reading at Outlet								
Nilothe	40 MGD Phase-I	Inlet	7.1	308	158	-	-	30	3.2
		outlet	7.2	12	9	-	-	15	1.4
	Real Time Reading at Outlet								
	20 MGD	Inlet	7.2	254	132	-	-	30	2.8
	Real Time Reading at Outlet								
Pappankalan	20 MGD Phase-II	Inlet	7.4	424	228	-	-	38	5.1
		outlet	7.6	42	29	-	-	22	1.1
	Real Time Reading at Outlet								
	20 MGD Phase-II	Inlet	7.2	354	211	-	-	30	5.4
		outlet	7.5	10	5	-	-	2.8	2.1
	Real Time Reading at Outlet								
Najafgarh	5 MGD Phase-II	Inlet	7.5	379	222	-	-	28	3.2
		outlet	7.4	34	14	-	-	9	4.2
	Real Time Reading at Outlet								
Corronation pillar	20 MGD Phase-I & II	Inlet	6.8	212	178	318	7.2	36	8.6
		outlet	7.4	64	49	128	2.4	22	4.2
	Real Time Reading at Outlet								
	10 MGD Phase-III	Inlet	7	278	268	370	-	48	8.9
		outlet	7.5	86	68	136	-	35	8.9
	Real Time Reading at Outlet								

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	11.12.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC limits	50	30	250
Okhla	12 MGD	41	27	96
	45 MGD	31	17	72
	37 MGD	17	14	56
	16 MGD	12	12	64
Kondli	25 MGD	14	8	34
	45 MGD	25	16	54
Chilla	9 MGD	7	2.9	16
Yamuna Vihar	10 MGD	23	13	88
	10 MGD	27	14	104
	25 MGD	57	30	160
Rithala	40 MGD	17	12	50
Rohiini	15 MGD	34	21	-
Keshopur	12 MGD	15	6	-
	40 MGD	82	83	-
	20 MGD	156	113	-
Nilothi	40 MGD	12	9	-
Najafgarh	5 MGD	34	14	-
Pappankalan	20 MGD	42	29	-
	20 MGD	10	5	-
Corronation pillar	20 MGD	64	49	128
	10 MGD	86	68	136



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Parameters of STPs of Delhi as on							12.12.2019		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Okhla	12 MGD	Inlet	7.5	194	156	384	4	42	3.1
		outlet	7.8	45	28	112	1	30	1.6
	Real Time Reading at Outlet								
	45 MGD	Inlet	7.7	224	165	408	3.5	41	3
		outlet	7.8	30	18	80	1	28	0.8
	Real Time Reading at Outlet								
	37 MGD	Inlet	7.7	224	165	408	3.5	41	3
		outlet	7.9	20	13	64	NIL	32	1.2
	Real Time Reading at Outlet								
	16 MGD	Inlet	7.7	224	165	408	3.5	41	3
		outlet	7.8	8	10	48	1	31	1
	Real Time Reading at Outlet								
Kondli	25 MGD Phase-II	Inlet	7.3	264	171	272	-	38	5.5
		outlet	7.8	12	7	28	-	33	3.2
	Real Time Reading at Outlet		7.5	19	9	25	-	2	-
	45 MGD Phase-IV	Inlet	7.3	260	169	270	-	40	5
		outlet	7.5	24	16	52	-	32	3.5
	Real Time Reading at Outlet		-	-	-	-	-	-	-
Chilla	9 MGD	Inlet	7.1	232	155	244	-	40	6.8
		outlet	7.4	8	4.2	18	-	4	5.2
	Real Time Reading at Outlet		7.1	7	7	31	-	3	-
Yamuna Vihar	10 MGD Phase-I	Inlet	7	408	205	-	-	45	3.5
		outlet	7.4	42	25	-	-	30	1
	Real Time Reading at Outlet								
	10 MGD Phase-II	Inlet	6.8	344	175	-	-	25	3
		outlet	7.3	26	21	-	-	15	1
	Real Time Reading at Outlet								
	25 MGD Phase-III	Inlet	7.2	640	366	-	-	55	3.5
		outlet	7.4	26	21	-	-	10	1.5
Real Time Reading at Outlet									
Rithala	40 MGD	Inlet	7.5	30	17	90	-	16	0.6
		outlet	7.3	18	13	70	-	12	0.5
	Real Time Reading at Outlet								
	40 MGD	Inlet	7.5	30	17	90	-	16	0.6
Real Time Reading at Outlet									
Rohiini 15 MGD	15 MGD	Inlet	7.1	280	185	512	-	52	8
		Outlet	7.4	30	18	115	-	17	3.5
	Real Time Reading at Outlet								
	12 MGD	Inlet	7.3	680	224	-	-	30	3.1
		outlet	7.6	12	5	-	-	1	2.2
	Real Time Reading at Outlet								
	40 MGD	Inlet	7.4	572	210	-	-	31	3

Keshopur	40 MGD	outlet	7.6	134	13	-	-	27	2.8
		Real Time Reading at Outlet							
	20 MGD	Inlet	7.4	572	210	-	-	31	3
		outlet	7.5	160	120	-	-	28	2.6
	Real Time Reading at Outlet								
Nilothe	40 MGD Phase-I	Inlet	7.2	298	164	-	-	32	3
		outlet	7.4	8	7	-	-	12	1.6
	Real Time Reading at Outlet								
	20 MGD Phase-II	Inlet	7.2	282	126	-	-	28	2.5
		outlet							
	Real Time Reading at Outlet								
Pappankalan	20 MGD Phase-II	Inlet	7.4	377	225	-	-	37	5.4
		outlet	7.7	55	26	-	-	20	0.8
	Real Time Reading at Outlet								
	20 MGD Phase-II	Inlet	7.4	315	210	-	-	32	5.6
		outlet	7.6	4	4	-	-	3	4.2
	Real Time Reading at Outlet								
Najafgarh	5 MGD Phase-II	Inlet	7.4	197	145	-	-	22	4.9
		outlet	7.7	27	18	-	-	16	2
	Real Time Reading at Outlet								
Corronation pillar	20 MGD Phase-I & II	Inlet	7	220	180	328	-	40	9
		outlet	7.6	66	51	134	-	31	4.4
	Real Time Reading at Outlet								
	10 MGD Phase-III	Inlet	7.1	332	285	377	7	54	9.6
		outlet	7.7	90	70	146	2.9	37	4.8
	Real Time Reading at Outlet								

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	12.12.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC limits	50	30	250
Okhla	12 MGD	45	28	112
	45 MGD	30	18	80
	37 MGD	20	13	64
	16 MGD	8	10	48
Kondli	25 MGD	12	7	28
	45 MGD	24	16	52
Chilla	9 MGD	8	4.2	18
Yamuna Vihar	10 MGD	42	25	-
	10 MGD	26	21	-
	25 MGD	26	21	-
Rithala	40 MGD	18	13	70
Rohiini	15 MGD	30	18	115
Keshopur	12 MGD	12	5	-
	40 MGD	134	13	-
	20 MGD	160	120	-
Nilothi	40 MGD	8	7	-
Najafgarh	5 MGD	27	18	-
Pappankalan	20 MGD	55	26	-
	20 MGD	4	4	-
Corronation pillar	20 MGD	66	51	134
	10 MGD	90	70	146



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Parameters of STPs of Delhi as on							13.12.2019		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Okhla	12 MGD	Inlet	7.3	448	166	440	-	36	2.8
		outlet	7.7	41	27	112	-	32	0.8
	Real Time Reading at Outlet								
	45 MGD	Inlet	7.5	356	193	424	-	35	3
		outlet	7.7	35	13	96	-	28	0.9
	Real Time Reading at Outlet								
	37 MGD	Inlet	7.5	356	193	424	-	35	3
		outlet	7.8	19	10	48	-	28	0.8
	Real Time Reading at Outlet								
	16 MGD	Inlet	7.5	356	193	424	-	35	3
		outlet	7.8	12	8	32	-	29	1.2
	Real Time Reading at Outlet								
Kondli	25 MGD Phase-II	Inlet	7.2	340	204	358	-	36.18	5.9
		outlet	7.7	22	14	48	-	28.52	2.8
	Real Time Reading at Outlet		7.6	394	36	368	-	2.37	-
	45 MGD Phase-IV	Inlet	7.3	288	178	292	-	35.67	5.4
		outlet	7.6	25	56	56	-	29.84	3.2
	Real Time Reading at Outlet		-	-	-	-	-	-	-
Chilla	9 MGD	Inlet	7	268	171	278	16	39.18	6.6
		outlet	7.5	7	2.8	14	2	2.56	3.4
	Real Time Reading at Outlet								
Rohiini 15 MGD	15 MGD	Inlet	7.2	236	125	-	-	25	5.5
		Outlet	7.5	68	33	-	-	17	4.5
	Real Time Reading at Outlet								
Keshopur	12 MGD	Inlet	7.4	292	142	-	16.8	27	2.9
		outlet	7.6	16	8	-	0	1	2.1
	Real Time Reading at Outlet								
	20 MGD	Inlet	7.4	292	176	-	13.3	29	2.8
		outlet	7.5	138	108	-	4.3	26	2.4
	Real Time Reading at Outlet								
	40 MGD	Inlet	7.4	292	176	-	13.3	29	2.8
		outlet	7.5	128	85	-	1.4	25	2.3
Real Time Reading at Outlet									
Nilothi	40 MGD Phase-	Inlet	7.3	216	116	-	-	30	3
Pappankalan	20 MGD Phase-I	Inlet	7.3	257	178	-	-	28	5.6
		outlet	7.8	60	32	-	-	16	0.6
	Real Time Reading at Outlet								
	20 MGD Phase-II	Inlet	7.3	269	182	-	-	34	5.2
		outlet	7.6	5	4	-	-	3.8	4.8
	Real Time Reading at Outlet								
	5 MGD Phase-	Inlet	7.3	283	191	-	-	26	4.8

Najafgarh	II	outlet	7.5	13	9	-	-	9	1.8
	Real Time Reading at Outlet								
Corronation pillar	20 MGD Phase-I &II	Inlet	6.9	248	190	376	7.6	44	8.6
		outlet	7.5	60	49	116	2.9	34	3.8
	Real Time Reading at Outlet								
	10 MGD Phase-III	Inlet	7	356	305	402	-	49	9
		outlet	7.6	98	75	138	-	30	5
	Real Time Reading at Outlet								
Narela	10 MGD Phase-III	Inlet	6.8	180	170	276	6.9	49	7.8
		outlet	7.4	36	24	82	3	21	4
	Real Time Reading at Outlet								

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	13.12.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC limits	50	30	250
Okhla	12 MGD	41	27	112
	45 MGD	35	13	96
	37 MGD	19	10	48
	16 MGD	12	8	32
Kondli	25 MGD	22	14	48
	45 MGD	25	56	56
Chilla	9 MGD	7	2.8	14
Rohiini	15 MGD	68	33	-
Keshopur	12 MGD	16	8	-
	40 MGD	138	108	-
	20 MGD	128	85	-
Najafgarh	5 MGD	13	9	-
Pappankalan	20 MGD	60	32	-
	20 MGD	5	4	-
Corronation pillar	20 MGD	60	49	116
	10 MGD	98	75	138
Narela	10 MGD	36	24	82



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Parameters of STPs of Delhi as on							14.12.2019		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Okhla	12 MGD	Inlet	7.7	242	215	424	3	39	2.5
		outlet	7.7	39	28	104	1	32	1.5
	Real Time Reading at Outlet								
	45 MGD	Inlet	7.6	212	198	408	4	43	2
		outlet	7.6	19	12	78	NIL	33	1
	Real Time Reading at Outlet								
	37 MGD	Inlet	7.6	212	198	408	4	43	2
		outlet	7.7	15	10	40	1	30	1.2
	Real Time Reading at Outlet								
	16 MGD	Inlet	7.6	212	198	408	4	43	2
		outlet	7.7	8	8	32	1	30	0.6
	Real Time Reading at Outlet								
Kondli	25 MGD Phase-II	Inlet	7.2	360	218	382	19.5	34.57	5.8
		outlet	7.7	17	11	38	3	27.38	2.6
	Real Time Reading at Outlet		7.6	14	9	22	-	2.25	-
	45 MGD Phase-IV	Inlet	7.2	324	182	336	15	36.19	5.6
		outlet	7.6	21	13	48	4.5	28.63	3.4
	Real Time Reading at Outlet		-	-	-	-	-	-	-
Chilla	9 MGD	Inlet	7	204	156	232	-	40.07	6.9
		outlet	7.4	6	2.6	16	-	2.94	3.7
	Real Time Reading at Outlet								
Rohiini 15 MGD	15 MGD	Inlet	7.3	528	273	726	-	38	6
		Outlet	7.8	45	25	102	-	13	5
	Real Time Reading at Outlet								
Keshopur	12 MGD	Inlet	7.4	432	187	596	-	30	3.1
		outlet	7.7	14	6	32	-	1	2.3
	Real Time Reading at Outlet								
	20 MGD	Inlet	7.3	520	206	622	-	30	3.2
		outlet	7.5	132	111	320	-	27	2.6
	Real Time Reading at Outlet								
	40 MGD	Inlet	7.3	520	206	622	-	30	3.2
		outlet	7.5	120	89	280	-	28	2.7
Real Time Reading at Outlet									
	20 MGD Phase-II	Inlet	7.1	312	312	-	-	34	3.2
		outlet	7.3	8	5	-	-	14	1.6
	Real Time Reading at Outlet								
Pappankalan	20 MGD Phase-II	Inlet	7.3	340	192	-	-	30	5.4
		outlet	7.7	65	35	-	-	15	0.8
	Real Time Reading at Outlet								
	20 MGD Phase-II	Inlet	7.2	362	209	-	-	32	5
		outlet	7.5	3	3	-	-	3.4	4.4

	Real Time Reading at Outlet								
Najafgarh	5 MGD Phase-II	Inlet	7.2	374	220	-	-	26	4.6
		outlet	7.4	22	12	-	-	8	1.7
	Real Time Reading at Outlet								
Corronation pillar	20 MGD Phase-I & II	Inlet	7.1	260	205	396	-	46	8.8
		outlet	7.6	76	57	120	-	30	4
	Real Time Reading at Outlet								
	10 MGD Phase-III	Inlet	7.2	376	315	400	7.8	51	9.6
		outlet	7.5	88	73	128	3	34	5.4
	Real Time Reading at Outlet								

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	14.12.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC limits	50	30	250
Okhla	12 MGD	39	28	104
	45 MGD	19	12	78
	37 MGD	15	10	40
	16 MGD	8	8	32
Kondli	25 MGD	17	11	38
	45 MGD	21	13	48
Chilla	9 MGD	6	2.6	16
Rohiini	15 MGD	45	25	102
Keshopur	12 MGD	14	6	32
	40 MGD	132	111	320
	20 MGD	120	89	280
Nilothi	20 MGD	8	5	-
Najafgarh	5 MGD	22	12	-
Pappankalan	20 MGD	65	35	-
	20 MGD	3	3	-
Corronation pillar	20 MGD	76	57	120
	10 MGD	88	73	128



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Parameters of STPs of Delhi as on							15.12.2019		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Okhla	12 MGD	Inlet	7.5	256	208	448	4	39	2.1
		outlet	7.8	31	18	72	1	28	0.9
	Real Time Reading at Outlet								
	45 MGD	Inlet	7.5	226	195	416	3	38	2.1
		outlet	7.6	25	14	56	1	30	1.2
	Real Time Reading at Outlet								
	37 MGD	Inlet	7.5	226	195	416	3	38	2.1
		outlet	7.9	22	13	48	NIL	30	1.2
	Real Time Reading at Outlet								
	16 MGD	Inlet	7.5	226	195	416	3	38	2.1
		outlet	8.1	12	9	32	1	32	NIL
	Real Time Reading at Outlet								
Kondli	25 MGD Phase-II	Inlet	7.2	376	224	384	-	35.67	5.6
		outlet	7.7	15	8	34	-	26.46	2.9
	Real Time Reading at Outlet		7.6	20	13	38	-	2.23	-
	45 MGD Phase-IV	Inlet	7.2	332	173	348	-	37.2	6
		outlet	7.6	24	15	56	-	28.87	3.7
	Real Time Reading at Outlet								
Rohiini 15 MGD	15 MGD	Inlet	7.4	284	273	-	-	56	4.5
		Outlet	7.7	32	25	-	-	15	2
	Real Time Reading at Outlet								
Keshopur	12 MGD	Inlet	7.3	248	169	-	-	27	2.4
		outlet	7.7	15	8	-	-	2	1.7
	Real Time Reading at Outlet								
	20 MGD	Inlet	7.3	300	173	-	-	28	3
		outlet	7.5	108	97	-	-	27	2.7
	Real Time Reading at Outlet								
	40 MGD	Inlet	7.3	300	173	-	-	28	3
		outlet	7.5	94	88	-	-	26	2.6
Real Time Reading at Outlet									
Nilothi	40 MGD Phase-I	Inlet	7.2	204	125	-	-	32	3.4
Pappankalan	20 MGD Phase-II	Inlet	7.3	304	202	-	-	30	5.6
		outlet	7.7	58	32	-	-	14	0.8
	Real Time Reading at Outlet								
	20 MGD Phase-II	Inlet	7.3	310	210	-	-	34	5
		outlet	7.6	5	5	-	-	3.4	4.6
	Real Time Reading at Outlet								
Corronation pillar	20 MGD Phase-I & II	Inlet	6.9	240	195	398	6.8	39	8
		outlet	7.5	70	55	118	2.2	27	3.9
	Real Time Reading at Outlet								
	10 MGD	Inlet	7	312	290	386	-	46	9.5

	Phase-III	outlet	7.6	80	70	120	-	30	5.2
	Real Time Reading at Outlet								

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	15.12.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC limits	50	30	250
Okhla	12 MGD	31	18	72
	45 MGD	25	14	56
	37 MGD	22	13	48
	16 MGD	12	9	32
Kondli	25 MGD	15	8	34
	45 MGD	24	15	56
Rohini	15 MGD	32	25	-
Keshopur	12 MGD	15	8	-
	40 MGD	108	97	-
	20 MGD	94	88	-
Pappankalan	20 MGD	58	32	-
	20 MGD	5	5	-
Corronation pillar	20 MGD	70	55	118
	10 MGD	80	70	120



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Parameters of STPs of Delhi as on							16.12.2019		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Okhla	12 MGD	Inlet	7.6	270	180	432	4	40	2.8
		outlet	7.8	38	28	112	1.5	30	0.8
	Real Time Reading at Outlet								
	45 MGD	Inlet	7.6	198	210	416	4	39	2
		outlet	7.7	35	33	88	NIL	29	0.9
	Real Time Reading at Outlet								
	37 MGD	Inlet	7.6	198	210	416	4	39	2
		outlet	7.8	34	22	88	NIL	32	1.2
	Real Time Reading at Outlet								
	16 MGD	Inlet	7.6	198	210	416	4	39	2
		outlet	7.8	9	9	88	NIL	32	0.4
	Real Time Reading at Outlet								
Kondli	25 MGD Phase-II	Inlet	7.2	384	230	392	20.5	34.79	6.4
		outlet	7.7	12	7	28	3.5	31.98	3.3
	Real Time Reading at Outlet		7.5	18	10	29	-	2.12	-
	45 MGD Phase-IV	Inlet	7.2	288	175	296	22	33.18	5.7
		outlet	7.5	26	16	58	4.5	28.84	3
	Real Time Reading at Outlet		-	-	-	-	-	-	-
Chilla	9 MGD	Inlet	7.1	370	213	384	14.5	43.91	6.7
		outlet	7.4	8	3.1	18	1.6	3.47	4.3
	Real Time Reading at Outlet		-	-	-	-	-	-	-
CWG Village	1 MGD	Inlet	7.2	272	173	288	27.5	21.86	5.4
		outlet	7.7	1	0.5	0.8	NIL	NIL	1.9
	Real Time Reading at Outlet		7.4	1.82	1.21	3.56	-	0.18	-
Rohiini 15 MGD	15 MGD	Inlet	7.1	176	135	499	-	50	9
		Outlet	7.4	28	16	90	-	16	5
	Real Time Reading at Outlet								
Keshopur	12 MGD	Inlet	7.3	732	249	-	-	29	3
		outlet	7.6	16	7	-	-	1	2.1
	Real Time Reading at Outlet								
	20 MGD	Inlet	7.3	388	212	-	-	30	3.1
		outlet	7.5	150	128	-	-	26	2.8
	Real Time Reading at Outlet								
	40 MGD	Inlet	7.3	388	212	-	-	30	3.1
		outlet	7.5	120	91	-	-	28	2.7
Real Time Reading at Outlet									
Nilothi	40 MGD Phase-I	Inlet	7.3	216	114	-	-	28	3
		outlet							
	Real Time Reading at Outlet								
	20 MGD Phase-II	Inlet	7.1	304	166	-	-	32	3
		outlet	7.3	9	6	-	-	15	1.5
Real Time Reading at Outlet									

Pappankalan	20 MGD Phase-II	Inlet	7.4	788	280	-	-	44	6
		outlet	7.6	48	29	-	-	20	0.5
	Real Time Reading at Outlet								
	20 MGD Phase-II	Inlet	7.3	568	250	-	-	42	5.8
		outlet	7.5	5	4	-	-	1	4
	Real Time Reading at Outlet								
Najafgarh	5 MGD Phase-II	Inlet	7.4	351	212	-	14.1	40	5.9
		outlet	7.7	27	20	-	0.2	16	1.4
	Real Time Reading at Outlet								
Corronation pillar	20 MGD Phase-I & II	Inlet	7.1	210	188	368	-	34	8.4
		outlet	7.6	62	59	144	-	21	4.4
	Real Time Reading at Outlet								
	10 MGD Phase-III	Inlet	7.2	354	280	410	7.2	53	8.9
		outlet	7.7	84	90	132	2.6	38	4.8
	Real Time Reading at Outlet								
Narela	10 MGD Phase-III	Inlet	7	280	205	410	7.2	48	7.6
		outlet	7.4	30	22	78	3.2	22	3.8
	Real Time Reading at Outlet								

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	16.12.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC limits	50	30	250
Okhla	12 MGD	38	28	112
	45 MGD	35	33	88
	37 MGD	34	22	88
	16 MGD	9	9	88
Kondli	25 MGD	12	7	28
	45 MGD	26	16	58
Chilla	9 MGD	8	3.1	18
CWG Village	1 MGD	1	0.5	0.8
Rohiini	15 MGD	28	16	90
Keshopur	12 MGD	16	7	-
	40 MGD	150	128	-
	20 MGD	120	91	-
	20 MGD	9	6	-
Najafgarh	5 MGD	27	20	-
Pappankalan	20 MGD	48	29	-
	20 MGD	5	4	-
Corronation pillar	20 MGD	62	59	144
	10 MGD	84	90	132
Narela	10 MGD	30	22	78



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Parameters of STPs of Delhi as on							17.12.2019		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Okhla	12 MGD	Inlet	7.5	260	176	440	5	42	2.5
		outlet	7.6	43	27	112	2	34	0.8
	Real Time Reading at Outlet								
	45 MGD	Inlet	7.5	250	172	416	3	39	2.4
		outlet	7.7	35	22	96	NIL	31	1.2
	Real Time Reading at Outlet								
	37 MGD	Inlet	7.5	250	172	416	3	39	2.4
		outlet	7.7	36	25	96	1	28	0.9
	Real Time Reading at Outlet								
	16 MGD	Inlet	7.5	250	172	416	3	39	2.4
		outlet	7.4	11	7	32	1	30	1.2
	Real Time Reading at Outlet								
Kondli	25 MGD Phase-II	Inlet	7.2	412	237	428	-	38.52	5.9
		outlet	7.6	11	6	24	-	34.13	2.6
	Real Time Reading at Outlet		7.6	14	9	23	-	2.04	-
	45 MGD Phase-IV	Inlet	7.2	308	173	318	-	42.2	6.8
		outlet	7.6	27	18	56	-	36.37	3
	Real Time Reading at Outlet		-	-	-	-	-	-	-
Chilla	9 MGD	Inlet	7	372	220	388	-	48.75	7.1
		outlet	7.5	5	2.3	12	-	4.04	4.2
	Real Time Reading at Outlet								
Yamuna Vihar	10 MGD Phase-I	Inlet	7	304	183	-	-	55	3.5
		outlet	7.5	32	20	-	-	30	1.5
	Real Time Reading at Outlet								
	10 MGD Phase-II	Inlet	7.1	304	176	-	-	35	2.5
		outlet	7.4	40	26	-	-	15	1.5
	Real Time Reading at Outlet								
	25 MGD Phase-III	Inlet	7.2	1068	588	-	-	50	3
outlet		7.5	40	26	-	-	20	2	
Real Time Reading at Outlet									
Rithala	40 MGD	Inlet	7.6	28	18	80	-	18	11
		outlet	7.3	13	10	50	-	10	0.3
	Real Time Reading at Outlet								
Corronation pillar	20 MGD Phase-I & II	Inlet	7.2	246	215	380	7.8	39	7.6
		outlet	7.7	80	70	120	2.9	25	3.8
	Real Time Reading at Outlet								
	10 MGD Phase-III	Inlet	7.1	376	295	416	-	50	9
		outlet	7.6	90	92	136	-	36	4.4
Real Time Reading at Outlet									

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	17.12.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC limits	50	30	250
Okhla	12 MGD	43	27	112
	45 MGD	35	22	96
	37 MGD	36	25	96
	16 MGD	11	7	32
Kondli	25 MGD	11	6	24
	45 MGD	27	18	56
Chilla	9 MGD	5	2.3	12
Yamuna Vihar	10 MGD	32	20	-
	10 MGD	40	26	-
	25 MGD	40	26	-
Rithala	40 MGD	13	10	50
Corronation pillar	20 MGD	80	70	120
	10 MGD	90	92	136



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Parameters of STPs of Delhi as on							18.12.2019		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Okhla	12 MGD	Inlet	7.5	154	165	328	-	42	2.5
		outlet	7.8	45	23	96	-	34	0.8
	Real Time Reading at Outlet								
	45 MGD	Inlet	7.5	120	173	384	-	39	2.4
		outlet	7.9	33	22	88	-	31	1.2
	Real Time Reading at Outlet								
	37 MGD	Inlet	7.5	120	173	384	-	39	2.4
		outlet	7.6	26	18	72	-	28	0.9
	Real Time Reading at Outlet								
	16 MGD	Inlet	7.5	120	173	384	-	39	2.4
		outlet	7.7	14	12	48	-	30	1.2
	Real Time Reading at Outlet								
Kondli	25 MGD Phase-II	Inlet	7.3	356	239	378	18.5	39.28	6
		outlet	7.5	12	7	28	2.5	29.56	2.7
	Real Time Reading at Outlet		7.6	14	9	22	-	2.09	-
	45 MGD Phase-IV	Inlet	7.2	392	246	414	19.5	40.68	6.9
		outlet	7.6	62	30	132	5.5	34.86	3.1
	Real Time Reading at Outlet		-	-	-	-	-	-	-
Chilla	9 MGD	Inlet	7.1	352		368	16.5	42.91	7.2
		outlet	7.4	7	200	16	1.4	4.05	4.1
	Real Time Reading at Outlet		6.9	7	3.8	31	-	3.19	-
CWG Village	1 MGD	Inlet	7	160	7	182	24.5	22.45	5.5
		outlet	7.8	1	110	1.6	BDL	0.02	1.8
	Real Time Reading at Outlet		7.3	1.78	0.46	3.54	-	0.26	-
Yamuna Vihar	10 MGD Phase-I	Inlet	7.2	296	217	-	-	50	3.5
		outlet	7.5	29	20	-	-	30	1.5
	Real Time Reading at Outlet								
	10 MGD Phase-II	Inlet	7.2	164	144	-	-	30	2
		outlet	7.4	24	22	-	-	15	1.5
	Real Time Reading at Outlet								
	25 MGD Phase-III	Inlet	7.2	1088	536	-	-	50	3.5
outlet		7.4	29	21	-	-	35	2.5	
Real Time Reading at Outlet									
Rithala	40 MGD	Inlet	7.7	27	17	70	-	16	0.8
		outlet	7.2	11	9	40	-	6	0.1
	Real Time Reading at Outlet								
	40 MGD	Inlet	7.7	27	17	70	-	16	0.8
Real Time Reading at Outlet									
	12 MGD	Inlet	7.3	416	202	-	-	36	3.2
		outlet	7.6	10	5	-	-	2	3
	Real Time Reading at Outlet								
	20 MGD	Inlet	7.3	404	239	-	-	35	3.3

Keshopur	20 MGD	outlet	7.5	132	89	-	-	32	2.9
	Real Time Reading at Outlet								
	40 MGD	Inlet	7.3	404	239	-	-	35	3.3
		outlet	7.5	130	89	-	-	32	2.6
	Real Time Reading at Outlet								
Nilothi	40 MGD Phase-	Inlet	7.3	254	122	-	-	30	3.2
Pappankalan	20 MGD Phase-I	Inlet	7.3	288	189	-	-	30	5.8
		outlet	7.9	35	23	-	-	28	0.5
	Real Time Reading at Outlet								
Najafgarh	5 MGD Phase-II	Inlet	7.3	485	238	-	-	28	5
		outlet	7.5	20	17	-	-	4	1.6
	Real Time Reading at Outlet								
Corronation pillar	20 MGD Phase-I & II	Inlet	6.9	214	198	316	-	41	9.6
		outlet	7.5	72	65	116	-	29	4.6
	Real Time Reading at Outlet								
	10 MGD Phase-III	Inlet	7.2	384	305	396	6.8	56	9.9
		outlet	7.7	96	89	148	2.4	40	5
	Real Time Reading at Outlet								

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	18.12.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC limits	50	30	250
Okhla	12 MGD	45	23	96
	45 MGD	33	22	88
	37 MGD	26	18	72
	16 MGD	14	12	48
Kondli	25 MGD	12	7	28
	45 MGD	62	30	132
Chilla	9 MGD	7	200	16
CWG Village	1 MGD	1	110	1.6
Yamuna Vihar	10 MGD	29	20	-
	10 MGD	24	22	-
	25 MGD	29	21	-
Rithala	40 MGD	11	9	40
Keshopur	12 MGD	10	5	-
	40 MGD	132	89	-
	20 MGD	130	89	-
Najafgarh	5 MGD	20	17	-
	20 MGD	35	23	-
Corronation pillar	20 MGD	72	65	116
	10 MGD	96	89	148



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Parameters of STPs of Delhi as on							19.12.2019		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Okhla	12 MGD	Inlet	7.5	284	187	464	4	39	3.1
		outlet	7.8	40	25	88	2	30	0.2
	Real Time Reading at Outlet								
	45 MGD	Inlet	7.5	258	165	368	3	39	3
		outlet	7.7	32	20	96	1	33	0.3
	Real Time Reading at Outlet								
	37 MGD	Inlet	7.5	258	165	368	3	39	3
		outlet	7.7	29	18	80	1	30	2.4
	Real Time Reading at Outlet								
	16 MGD	Inlet	7.5	258	165	368	3	39	3
		outlet	7.7	16	9	40	NIL	28	2.8
	Real Time Reading at Outlet								
Kondli	25 MGD Phase-II	Inlet	7.2	308	198	322	-	38.85	5.7
		outlet	7.6	13	7	32	-	27.49	3
	Real Time Reading at Outlet		7.6	20	10	32	-	2.02	-
	45 MGD Phase-IV	Inlet	7.1	252	216	362	-	39.58	6.1
		outlet	7.5	56	27	118	-	29.5	3.8
	Real Time Reading at Outlet		-	-	-	-	-	-	-
Chilla	9 MGD	Inlet	7.1	204	114	218	-	42.29	6.8
		outlet	7.7	8	3.6	18	-	2.87	3.8
	Real Time Reading at Outlet		7.2	9	7	31	-	5.24	-
Yamuna Vihar	10 MGD Phase-I	Inlet	7.2	252	193	536	-	35	4
		outlet	7.4	37	24	110	-	25	2
	Real Time Reading at Outlet								
	10 MGD Phase-II	Inlet	7.1	192	147	-	-	25	3
		outlet	7.3	26	17	-	-	15	1
	Real Time Reading at Outlet								
	25 MGD Phase-III	Inlet	7.2	388	305	544	-	45	3.5
		outlet	7.5	37	25	110	-	10	2
Real Time Reading at Outlet									
Rithala	40 MGD	Inlet	7.6	30	19	90	-	19	0.6
		outlet	7.4	13	11	50	-	7	0.1
	Real Time Reading at Outlet								
	40 MGD	Inlet	7.6	30	19	90	-	19	0.6
Real Time Reading at Outlet									
Keshopur	12 MGD	Inlet	7.3	612	230	-	-	37	3.3
		outlet	7.6	14	9	-	-	1	2.8
	Real Time Reading at Outlet								
	20 MGD	Inlet	7.4	496	222	-	-	34	3.4
		outlet	7.5	138	78	-	-	31	2.8
	Real Time Reading at Outlet								
	40 MGD	Inlet	7.4	496	222	-	-	34	3.4
outlet		7.6	118	78	-	-	32	2.7	

	Real Time Reading at Outlet								
Nilothi	40 MGD Phase-I	Inlet	7.2	236	123	-	-	28	2.8
Pappankalan	20 MGD Phase-II	Inlet	7.3	230	170	-	11.1	32	5.6
		outlet	7.8	66	32	-	2.9	24	0.5
	Real Time Reading at Outlet								
Najafgarh	5 MGD Phase-II	Inlet	7.4	237	172	-	-	28	5.8
		outlet	7.7	24	12	-	-	6	1.4
	Real Time Reading at Outlet								
Corronation pillar	20 MGD Phase-I & II	Inlet	7.1	227	205	310	7	38	9
		outlet	7.6	92	75	120	2.6	26	5.2
	Real Time Reading at Outlet								
	10 MGD Phase-III	Inlet	7.2	388	310	400	-	50	10.2
		outlet	7.7	112	92	142	-	38	5.6
	Real Time Reading at Outlet								

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	19.12.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC limits	50	30	250
Okhla	12 MGD	40	25	88
	45 MGD	32	20	96
	37 MGD	29	18	80
	16 MGD	16	9	40
Kondli	25 MGD	13	7	32
	45 MGD	56	27	118
Chilla	9 MGD	8	3.6	18
Yamuna Vihar	10 MGD	37	24	110
	10 MGD	26	17	-
	25 MGD	37	25	110
Rithala	40 MGD	13	11	50
Keshopur	12 MGD	14	9	-
	40 MGD	138	78	-
	20 MGD	118	78	-
Najafgarh	5 MGD	24	12	-
Pappankalan	20 MGD	66	32	-
Corronation pillar	20 MGD	92	75	120
	10 MGD	112	92	142