



DELHI JAL BOARD
DAILY ANALYSIS REPORT OF ALL SEWAGE TREATMENT PLANT
DATE OF ANALYSIS : 01.09.2025

S.No.	Lab	Sewage Treatment Plant (Operator) Technology	Capacity (MGD)	DPCC Parameter (mg/l) (TSS:10,BOD:10, COD:50, (NH4-N:5,P04-P:2, Oil & grease : 10)	Average Daily Flow (MGD)	pH		TSS		BOD (3 DAYS at 27.0 C)		COD		Ammonical nitrogen		Dissolve phosphate		Oil & Grease		Fecal Coliform (72 hrs)		Remarks
					Outlet (F.Coli) Limit	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	
			(MGD)		MPN/100ml	-	-	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	MPN/100ml	MPN/100ml	
1		Keshopur Ph-I (VA-TECH WABAG LTD.) ASP	12	30/20/250/50/5	230	7.11	7.40	282	5	110	3	240	16	12	2.0	3	2.6	-	46x10^8	160		
2		Keshopur Ph-II (Ayaappa Pvt.Ltd) ASP (IFAS)	20	10/10/50/5/1	230	7.15	7.50	330	6	185	4	380	24	18	8.5	4.2	1.2	-	-	-	-	sample collected on alternate days
3		Keshopur Ph-III (Ayaappa Pvt.Ltd) ASP	60	10/10/50/5/1	230	7.32	7.57	421	4	205	5	510	21	13	6.1	3.8	3.2	-	-	-	-	sample collected on alternate days
4		Kapashera (Triveni Pvt. Ltd) SBR	5	10/10/50/5/2	230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	sample collected on weekly basis
5		Kondli Ph-I (Triveni Pvt. Ltd) ASP	10	10/10/50/5/2	230	7.00	7.60	272	7	132	8	358	14	30	2.0	3	1	-	1100x10^14	7.3		
6		Kondli Ph-II (Triveni Pvt. Ltd) ASP	25	10/10/50/5/2	230	7.00	7.60	272	9	132	6	358	15	30	2.5	3	0.8	-	1100x10^14	6.1		
7		Kondli Ph-III (Triveni Pvt. Ltd) ASP	10	10/10/50/5/2	230	7.00	7.60	272	9	132	6	358	15	30	2.5	3	0.8	-	1100x10^14	6.1		
8		Kondli Ph-IV (Ayaappa Pvt.Ltd) ASP (IFAS)	45	10/10/50/5/2	230	6.90	7.50	292	7	138	6	376	11	30	2.5	3.5	1	-	250x10^14	7.2		
9		Chilla (HHB Engineers) C-ISBR	9	10/10/50/5/2	230	7.00	7.60	282.00	9.00	160.00	7.00	438.00	8.00	32.00	0.80	3.00	0.80	10.50	160x10^14	11.00		
10		CMG (M/s Toshiba Water Soluti on Pvt. Ltd.) MBR	1	10/10/50/5/2	230	7.00	7.50	264.00	6.00	155.00	5.00	366.00	4.00	28.00	1.00	2.50	Nil	12.80	210x10^14	20.00		
11		Coronation Pillar Ph-II (DRA Infracom Pvt.Ltd.) ASP (IFAS)	20	50/30/250/50/5	230	7.10	7.60	106	6	53	3	189	13	18	0.8	1.3	0.7	1.2	BDL	24X10^11	93	
12		Coronation Pillar Ph-III (DRA Infracom Pvt.Ltd.) ASP (IFAS)	10	10/10/50/5/2	230	7.20	7.50	66	8	41	5	78	15	20	0.7	1.3	1	0.9	BDL	43X10^4	75	
13		Coronation New (L&T Construction and PASSAVANT (JV)) ASP	70	10/10/50/5/2	230	7.10	7.60	216	10	122	6	306	19	24	1.0	2.5	1.7	-	11X10^5	75		
14		Narela (DRA Infracom Pvt.Ltd.) ASP (IFAS)	10	10/10/50/5/2	230	7.10	7.60	214	9	111	7	450	18	30	1.0	3.4	1	-	73X10^11	93		
15		Nilothi Ph-I (SUBHASH INFRA PVT. LTD) ASP (IFAS)	60	10/10/50/5/1	230	6.96	7.87	118	10	90	3	-	-	20	1.2	2.6	1.4	-	-	-	-	
16		Nilothi Ph-II (VEOLIA INDIA) ASP	20	10/10/50/5/2	230	7.32	7.67	154	8	108	8	-	-	23	12.0	3	2.6	-	-	-	-	
17		Okhla Ph-V (DIB) ASP	16	50/30/250/50/5	-	7.30	7.50	168	10	220	7.4	438	26	46	0.6	2.8	2.4	4	ND			
18		Okhla Ph-VI (SUEZ India Pvt. Ltd.) ASP	30	10/10/50/5/2	230	7.30	7.50	300	12	270	7.2	528	42	48	0.36	3.4	2.2	5	ND	-	-	



DELHI JAL BOARD
DAILY ANALYSIS REPORT OF ALL SEWAGE TREATMENT PLANT

DATE OF ANALYSIS : 01.09.2025

S.No.	Lab	Sewage Treatment Plant (Operator) Technology	Capacity (MGD)	DPCC Parameter (mg/l) (TSS:10,BOD:10, COD:50, NH4-N:5, PO4-P:2, Oil& grease : 10)	Outlet (F-Coli) Limit	Average Daily Flow (MGD)	pH		TSS		BOD (3 DAYS at 27.0 C)		COD		Ammonical nitrogen		Dissolve phosphate		Oil & Grease		Fecal Coliform (72 hrs)		Remarks		
							INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET		MPN/100ml	MPN/100ml
19	Okhla	Okhla New (SUEZ India Pvt. Ltd.) ASP	124	10/10/50/5/2	230		7.40	7.50	170	3	130	7.2	359	37	48	0.2	2.8	2.6	5	ND	-	-			
20		Mehrauli (DIB) E.A	5	50/30/250/50/5	-		-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
21		Molar band (DIB)	0.66	50/30/250/50/5	-		7.00	7.30	330	26	440	24	775	79	72	48.0	3.2	3.8	-	-	-	-			
22		Ghitorini (DIB) ASP	5	50/30/250/50/5	-		-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
23		Vasant Kunj Ph-I (DIB) E.A	2.2	50/30/250/50/5	-		-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
24		Vasant Kunj Ph-II (DIB) E.A	3	50/30/250/50/5	-		-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
25		Delhi Gate Ph-I (Degramont) B & D	2.2	10/10/50/5/2	230		7.10	7.40	136	9	113	8	224	39	42	28.0	2.8	2.4	4	ND	-	-			
26		Delhi Gate Ph-II (Degramont) B & D	15	10/10/50/5/2	230		7.00	7.60	226	8	210	5.2	327	25	40	4.8	2.6	2.2	-	-	-	-			
27	Pappankalan	SNH drain (Degramont) B & D	2.2	10/10/50/5/2	230		-	-	-	-	-	-	-	-	-	-	-	-	-	-	-				
28		Phappankalan Ph-I (SUBHASH INFRA PVT. LTD) ASP	20	10/10/50/5/1	-		7.20	7.40	296	8	165	4	338	13	50	0.1	4	1.8	-	93*10^10	230				
29		Phappankalan Ph-II (VA*TECH WABAG LTD.) ASP	20	10/10/50/5/1	230		7.20	7.70	296	9	165	6	338	24	50	14.0	4	2.6	-	93*10^10	1100				
30	Rithala	Najafgarh (Ayaappa Pvt.Ltd.) ASP	5	10/10/50/5/2	230		-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	sample collected on weekly basis			
31		Rithala Ph-I (MS WA TECH BABAG LTD.) ASP	40	10/10/50/5/2	100	45.92	7.27	7.51	248	5	140	5	344	20	20	0.9	3.6	1	11	1	24x10^13	93			
32		Rithala Ph-II (SUEZ India Pvt. Ltd.) ASP	40	10/10/50/5/2	230	38.89	7.30	7.59	316	6	170	5	416	24	21	4.0	3.9	0.4	10	1	24x10^13	95			
33	Rohini Sec-25	Rohini (MS Dinesh Chandra Rohini project pvt. Ltd.) ASP(IFAS)	25	10/10/50/5/1	230	27.19	7.35	7.36	316	12	160	9	384	32	18	0.2	1.8	0.8			11x10^13	210			
34		Yamuna Vihar Ph-I (DIB) ASP	10	30/20/250/50/5	-	9.99	7.30	7.50	264	24	158	16	357	50	38	28.0	4.2	2.2	-	-	20*10^11	16*10^5			
35	Vihar	Yamuna Vihar Ph-II (M/S SIPL-RKC IV) ASP(IFAS)	15	10/10/50/5/1	100	15.99	7.30	7.60	356	8	230	5	446	16	30	4.0	2.8	0.6	-	-	34*10^10	21*10^3			



DELHI JAL BOARD
DAILY ANALYSIS REPORT OF ALL SEWAGE TREATMENT PLANT

DATE OF ANALYSIS : 01.09.2025

[illegible]

[illegible]

S.No.	Lab	Sewage Treatment Plant (Operator) Technology	Capacity (MGD)	DPCC Parameter (mg/l) (TSS:10,800;10, COD:50, NH4-N:5,POL-P:2, Oil: grease :10)	Outlet (F:Coli) Limit MPN /100ml	Average Daily Flow (MGD)	pH		TSS		BOD (3 DAYS at 27.0 C)		COD		Ammonical nitrogen		Dissolve phosphate		Oil & Grease		Fecal Coliform (72 hrs)		Remarks		
							INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET		INLET	OUTLET
1	Keshonpur	Keshonpur PH-I (V&T-TECH WABAG LTD.) ASP	12	30/10/250/50/5	230		7.27	7.29	179	3	115	3	286	20	6	2.5	2	2.5	-	-	-	-			
2		Keshonpur PH-II (Ayaappa Pvt.Ltd) ASP(IPAS)	20	10/10/50/5/1	230		7.29	7.24	221	2	155	2	399	13	7	1.2	2.5	2	-	-	24x10^7+	150			
3		Keshonpur PH-III (Ayaappa Pvt.Ltd) ASP	60	10/10/50/5/1	230		7.35	7.20	287	2	165	2	406	12	6	0.8	3	0.5	-	-	-	-			
4		Kapashera (Triveni Pvt. Ltd) SBR	5	10/10/50/5/2	230		7.30	7.50	682	6	325	5.8	771	20	50	8.0	6	2.2	-	-	-	11*10^+12	2900		
5	Kondili	Kondili PH-I (Triveni Pvt. Ltd) ASP	10	10/10/50/5/2	230		6.90	7.20	258	8	128	6	376	15	28	1.5	2.5	0.8	-	-	-	44x10^+14	6.1		
6		Kondili PH-II (Triveni Pvt. Ltd) ASP	25	10/10/50/5/2	230		6.90	7.50	258	9	128	8	376	16	28	2.0	2.5	1	-	-	-	44x10^+14	7.2		
7		Kondili PH-III (Triveni Pvt. Ltd) ASP	10	10/10/50/5/2	230		6.90	7.50	258	9	128	8	376	16	28	2.0	2.5	1	-	-	-	44x10^+14	7.2		
8		Kondili PH-IV (Ayaappa Pvt.Ltd) ASP(IPAS)	45	10/10/50/5/2	230		7.10	7.60	274	8	135	9	392	14	30	1.5	2.8	1	-	-	-	210x10^+14	11	once in a week	
9	N.S.P.C.Pillar	Chilla (HNS Engineers) C-ISR	9	10/10/50/5/2	230		-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	once in a week		
10		OWG (M/S Toshiba Water Solut on Pvt. Ltd.) MBR	1	10/10/50/5/2	230		-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	once in a week		
11		Coronation Pillar Ph-II (DRA Infracom Pvt.Ltd.) ASP(IPAS)	20	50/30/250/50/5	230	20		7.10	7.60	114	5	61	3	153	10	15	0.5	1.4	0.5	-	-	-	-		
12		Coronation Pillar Ph-III (DRA Infracom Pvt.Ltd.) ASP(IPAS)	10	10/10/50/5/2	230	10		7.20	7.60	76	7	47	4	88	15	18	0.5	1.2	1	-	-	-	-		
13	N.S.I.P.C.Pillar	Coronation New (L&T Construction and PASSAVANT (JV))	70	10/10/50/5/2	230	70	7.00	7.70	140	5	97	3	223	11	22	0.7	2.5	2	2.2	BDL					
14		Nareila (DRA Infracom Pvt.Ltd.) ASP(IPAS)	10	10/10/50/5/2	230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
15		Nilothi PH-I (SUBHASH INFRA PVT. LTD) ASP(IPAS)	60	10/10/50/5/1	230		7.54	7.72	232	5	130	4	-	-	11	0.5	2.2	4	-	-	-	46 x 10^+10	2400+		
16		Nilothi PH-II (VEOLIA INDIA) ASP	20	10/10/50/5/2	230		7.26	7.56	366	24	173	15	-	-	15	6.5	2.4	1.8	-	-	-	11 x 10^+11	2400+		
17	Nilothi	Okhla Ph-V (DIB) ASP	16	50/30/250/50/5	-		7.20	7.50	202	20	240	6.3	1423	18	48	0.16	2.8	2.6	4	ND					
18		Okhla Ph-VI (SUZJ India Pvt. Ltd.) ASP	30	10/10/50/5/2	230		7.20	7.40	230	18	370	4.1	1385	31	46	0.52	2.4	1	5	ND					
19		Okhla New (SUZJ India Pvt. Ltd.) ASP	124	10/10/50/5/2	230		7.30	7.50	176	14	155	5.1	1500	17	48.0	0.48	2.6	2.4	6	ND					
20		Mehrauli (DIB) E.A	5	50/30/250/50/5	-		7.20	7.40	138	50	268	27	924	72	44	35.0	3.8	2.8	4	2					
21	Okhla	Molar band (DIB)	0.66	50/30/250/50/5	-		-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	sample not collected due to power failure		
22		Ghitorini (DIB) ASP	5	50/30/250/50/5	-		-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		

[illegible][illegible]



DAILY ANALYSIS REPORT OF ALL SEWAGE TREATMENT PLANT


DATE OF ANALYSIS : 03.09.2025					
-------------------------------	--	--	--	--	--

[illegible]




DATE OF ANALYSIS : 05.09.2025

[illegible]

[illegible]

DATE OF ANALYSIS : 05.09.2025

[illegible]

[illegible][illegible]

S.No.	Lab	Sewage Treatment Plant (Operator) Technology	Capacity (MGD)	DPPC Parameter (mg/l) (TSS,10,BOD,10, COD,50, NH4-N,5,POM-4,5)	Outlet (F.Coll) Limit	Average Daily Flow (MGD)	pH			TSS			BOD (3 DAYS at 27.0 C)			COD			Ammonical nitrogen			Dissolve phosphate			Oil & Grease		Fecal Coliform (72 hrs)		Remarks		
							INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET		INLET	OUTLET
		Keshopur Ph-I (VA-TECH VABAG LTD.) ASP	12	30/20/250/50/5	230	-	7.20	7.21	313	4	156	3	315	14	19	1.3	4	3.5	-	-	-	-	-	-	-	-	-				
1	Keshonpur	Keshopur Ph-II (Ayaappa Pvt.Ltd) ASP (IFAS)	20	10/10/50/5/1	230	-	7.20	7.48	376	6	232	7	432	22	20	6.0	4.5	2.5	-	-	-	-	-	-	-	-	-				
2		Keshopur Ph-III (Ayaappa Pvt.Ltd) ASP	60	10/10/50/5/1	230	-	7.21	7.51	288	6	230	5	403	24	16	2.0	3.5	2.8	-	-	-	-	-	-	-	-	-				
3		Kapashera (Triveni Pvt. Ltd) SBR	5	10/10/50/5/2	230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-				
4		Kondli Ph-I (Triveni Pvt. Ltd) ASP	10	10/10/50/5/2	230	-	7.00	7.60	282	8	145	6	366	14	30	4.0	2.8	1	-	-	-	-	-	-	-	-	-				
5	Kondli	Kondli Ph-II (Triveni Pvt. Ltd) ASP	25	10/10/50/5/2	230	-	7.00	7.50	282	8	145	8	366	17	30	3.0	2.8	1.5	-	-	-	-	-	-	-	-	-				
6		Kondli Ph-III (Triveni Pvt. Ltd) ASP	10	10/10/50/5/2	230	-	7.00	7.50	282	8	145	8	366	17	30	3.0	2.8	1.5	-	-	-	-	-	-	-	-	-				
7		Kondli Ph-IV (Ayaappa Pvt.Ltd) ASP (IFAS)	45	10/10/50/5/2	230	-	6.90	7.60	280	9	140	8	394	16	28	2.0	3	1.2	-	-	-	-	-	-	-	-	-				
8		Omni Engineers) C-SSBR	9	10/10/50/5/2	230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-				
9	N.S.T.P.C.Pillar	CMG (M/S Toshiba Water Solution Pvt. Ltd.)	1	10/10/50/5/2	230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-				
10		MBR																													
11		Coronation Pillar Ph-II (DRA Infracore Pvt.Ltd.) ASP (IFAS)	20	50/30/250/50/5	230	18.66	7.30	7.70	144	7	71	5	214	15	9	0.2	1	0.9	-	-	-	-	-	-	-	-	-				
12		Coronation Pillar Ph-III (DRA Infracore Pvt.Ltd.) ASP (IFAS)	10	10/10/50/5/2	230	8.61	7.20	7.60	100	7	53	4	210	17	10	0.4	1	0.7	1.2	BDL	BDL	BDL	BDL	BDL	BDL	BDL	BDL				
13	N.S.T.P.C.Pillar	Coronation New (LL&T Construction and PASSAVANT (JV)) ASP	70	10/10/50/5/2	230	60.24	7.20	7.70	150	5	67	3	170	10	12	0.2	1.2	1	1.5	BDL	BDL	BDL	BDL	BDL	BDL	BDL	BDL				
14		Narela (DRA Infracore Pvt.Ltd.) ASP (IFAS)	10	10/10/50/5/2	230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-				
15		Nicithi Ph-I (SUEZHASH INFRA PVT. LTD) ASP (IFAS)	60	10/10/50/5/1	230	30.67	7.72	8.05	314	2	140	4	-	-	20	0.5	1.5	2	-	-	-	-	-	-	-	-	-				
16		Nicithi Ph-II (SUEZ India PVT. LTD) ASP	20	10/10/50/5/2	230	-	7.52	7.88	196	8	120	6	-	-	20	1.5	2	0.8	-	-	-	-	-	-	-	-	-	-			
17	Nobleth	Okhla Ph-V (DIB) ASP	16	50/30/250/50/5	-	-	7.20	7.60	210	10	100	2.2	416	38	48	0.04	2	2.6	2	ND	ND	ND	ND	ND	ND	ND	ND				
18		Okhla Ph-VI (SUEZ India Pvt. Ltd.) ASP	30	10/10/50/5/2	230	-	7.10	7.50	250	9	123	2	375	20	46	0.04	2.6	ND	3	ND	ND	ND	ND	ND	ND	ND	ND				
19		Okhla New (SUEZ India Pvt. Ltd.) ASP	124	10/10/50/5/2	230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-				
20		Mehtaurli (DIB) E.A	5	50/30/250/50/5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-				
21	Okhla	Molar band (DIB)	0.66	50/30/250/50/5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-					
22		Ghitorini (DIB) ASP	5	50/30/250/50/5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-				

[illegible]



DATE OF ANALYSIS : 07.09.2025

S.No.	Lab	Sewage Treatment Plant (Operator) Technology	Capacity	DPCC Parameter (mg/l) (TSS:10,BOD:10, COD:50, NH4-N:5,P04-P:2, Oil& grease : 10)	Outlet (F.Coli) Limit	Average Daily Flow (MGD)	pH		TSS		BOD (3 DAYS at 27 0 C)		COD		Ammonical nitrogen		Dissolve phosphate		Oil & Grease		Fecal Coliform (72 hrs)		Remarks		
			(MGD)	Design Parameter (mg/l) TSS/BOD/COD/ Ammonical nitrogen/Ortho phosphate	MPN /100ml		INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET		INLET	OUTLET
							-	-	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l		MPN/100ml	MPN/100ml
1	Keshapur	Keshapur Ph-I (VA-TECH WABAG LTD.) ASP	12	30/20/250/50/5	230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	Lab close on sunday			
2		Keshapur Ph-II (Ayaappa Pvt.Ltd) ASPI(FAS)	20	10/10/50/5/1	230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	Lab close on sunday			
3		Keshapur Ph-III (Ayaappa Pvt.Ltd) ASP	60	10/10/50/5/1	230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	Lab close on sunday			
4		Kapashera (Triveni P.td) SBR	5	10/10/50/5/2	230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	Lab close on sunday			
5	Kondli	Kondli Ph-I (Triveni Pvt. Ltd) ASP	10	10/10/50/5/2	230	10	7.1	7.6	302	9	142	7	401	12	28	3	3.2	1.2							
6		Kondli Ph-II (Triveni Pvt. Ltd) ASP	25	10/10/50/5/2	230	25	7.1	7.5	302	9	142	8	401	15	28	3.2	3.2	1.2							
7		Kondli Ph-III (Triveni Pvt. Ltd) ASP	10	10/10/50/5/2	230	10	7.1	7.5	302	9	142	8	401	15	28	3.2	3.2	1.2							
8		Kondli Ph-IV (Ayaappa Pvt.Ltd.) ASPI(IFAS)	45	10/10/50/5/2	230	45	7	7.4	298	7	152	6	423	14	30	2	3	1							
9		Chilla (HNB Engineers) C-SBR	9	10/10/50/5/2	230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	Sample collection on Weekly basis		
10		CWG (M&A Toshiba Water Soluti on Pvt. Ltd.) MBR	1	10/10/50/5/2	230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	Sample collection on Weekly basis		
11	N.S.T.P.C.Pillar	Coronation Pillar Ph-II (DRA Infracom Pvt.Ltd.) ASPI(IFAS)	20	50/30/250/50/5	230	18.37	7.2	7.5	136	08	69	05	157	14	10	0.3	1	0.9	NA	NA					
12		Coronation Pillar Ph-III (DRA Infracom Pvt.Ltd.) ASPI(IFAS)	10	10/10/50/5/2	230	8.31	7.2	7.6	116	06	58	03	142	10	12	0.2	1.2	0.8	NA	NA					
13		Coronation New (L&T Construction and PASSAVANT (JV)) ASP	70	10/10/50/5/2	230	47.29	7.3	7.6	190	06	109	04	196	12	15	0.4	1.5	1	NA	NA					
14		Narela (DRA Infracom Pvt.Ltd.) ASPI(IFAS)	10	10/10/50/5/2	230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	Sample collection on Weekly basis		
15	Nilothi	Nilothi Ph-I (SUBHASH INFRA PVT. LTD) ASPI(IFAS)	60	10/10/50/5/1	230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	Lab close on sunday			
16		Nilothi Ph-II (VEOLIA INDIA) ASP	20	10/10/50/5/2	230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	Lab close on sunday			
17	Okhla	Okhla Ph-V (DIB) ASP	16	50/30/250/50/5	-		7.2	7.4	272	7	210	3.2	440	17	42	0.5	2	1.8	4	ND					
18		Okhla Ph-VI (SUEZ India Pvt. Ltd.) ASP	30	10/10/50/5/2	230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
19		Okhla New (SUEZ India Pvt.Ltd.) ASP	124	10/10/50/5/2	230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
20		Mehrauli (DIB) E.A	5	50/30/250/50/5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
21		Molar band (DIB)	0.66	50/30/250/50/5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
22		Okhlorini (DIB) ASP	5	50/30/250/50/5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
23		Vasant Kunj Ph-I (DIB) E.A	2.2	50/30/250/50/5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
24		Vasant Kunj Ph-II (DIB) E.A	3	50/30/250/50/5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
25		Delhi Gate Ph-I (Degramont) B & D	2.2	10/10/50/5/2	230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
26		Delhi Gate Ph-II (Degramont) B & D	15	10/10/50/5/2	230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
27	SNH drain (Degramont) B & D	2.2	10/10/50/5/2	230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
28	Pappankalan	Phappankalan Ph-I (SUBHASH INFRA PVT. LTD) ASP	20	10/10/50/5/1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
29		Phappankalan Ph-II (VA-TECH WABAG LTD.) ASP	20	10/10/50/5/1	230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
30		Najafgarh (Ayaappa Pvt.Ltd.) ASP	5	10/10/50/5/2	230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
31	Rithala	Rithala Ph-I (R&S WA TECH BABAG LTD.) ASP	40	10/10/50/5/2	100	45.14	7.18	7.48	22	5	120	4	296	24	21	1.6	3.3	0.7	-	1					
32		Rithala Ph-II (SUEZ India Pvt. Ltd.) ASP	40	10/10/50/5/2	230	35.78	7.27	7.62	280	5	157	4	384	20	23	4	3.4	0.6	-	1					
33	Rohini Sec-25	Rohini (R&S Dinesh Chandra Rohini project pvt. Ltd .) ASPI(IFAS)	25	10/10/50/5/1	230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
34		Yamuna Vihar Ph-I (DIB) ASP	10	30/20/250/50/5	-	10.12	7.2	7.4	244	25	154	18	458	50	34	21	4	1.4	-	-					

35	Yamuna Vihar	Yamuna Vihar Ph-II (M/s SIPI- RKC JV) ASP(IFAS)	15	10/10/50/5/1	100	16.67	7.3	7.5	232	07	148	04	426	16	30	04	3.6	0,6	-	-			
36		Yamuna Vihar Ph-III (M/s joly & joly) ASP	25	30/20/250/50/5	-	27.93	7.3	7.6	328	23	237	13	516	62	39	24	4.5	2	-	-			
37		Sonia Vihar (Ayaappa PvtLtd.) ASP	7	10/10/50/5/2		-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
			Total Treatment	799.26																			
		ASP	Activated Sludge Process																				
		ASP(IFAS)	Activated Sludge Process with Integrated Fixed-film Activated Sludge																				
		E.A	Extended Aeration																				
		FAB	Fluidized Aerobic Bed																				
		B & D	Biofor and dansadeg																				
		C-ISBR	Combitreat-ISBR																				
		W	Waiting																				
		ND	Not Detectable																				
		BDL	Bellow Detection Limit																				



DATE OF ANALYSIS : 08.09.2025


STATE OF HARYANA - CONTINUED																									
S.No.	Lab	Sewage Treatment Plant (Operator) Technology	Capacity		DPPC Parameter (mg/l) (TSS:10,BOD:10, COD:50, NH4-N:5,P04-P:2, Oil& grease : 10)	Outlet (F.Coli) Limit	Average Daily Flow (MGD)	pH		TSS		BOD (3 DAYS at 27 O C)		COD		Ammonical nitrogen		Dissolve phosphate		Oil & Grease		Fecal Coliform (72 hrs)		Remarks	
			(MGD)	Design Parameter (mg/l) TSS/BOD/COD/ Ammonical nitrogen/Oilko phosphate	MPN /100ml	INLET		OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET		OUTLET
						-		-	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l		MPN/100ml
1	Keshopur	Keshopur Ph-I (VA-TECH WABAG LTD.) ASP	12	30/20/250/50/5	230	--	7.14	7.44	279	2	171	2	352	23	18	1.5	2.5	3	-	-	93*10^9	120			
2		Keshopur Ph-II (Ayaappa Pvt.Ltd) ASPI(IFS)	20	10/10/50/5/1	230	-	7.19	7.47	298	4	172	9	344	38	22	6	4	0.8	-	-	-	-			
3		Keshopur Ph-III (Ayaappa Pvt.Ltd) ASP	60	10/10/50/5/1	230	-	7.24	7.38	240	2	160	3	337	28	22	2	3.5	0.5	-	-	-	-			
4		Kapashera (Triveni Pvt. Ltd) SBR	5	10/10/50/5/2	230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
5	Kondli	Kondli Ph-I (Triveni Pvt. Ltd) ASP	10	10/10/50/5/2	230	-	7.1	7.5	288	8	135	8	426	18	32	6	2.5	0.8	8.8	N.D.	150X10^14	73			
6		Kondli Ph-II (Triveni Pvt. Ltd) ASP	25	10/10/50/5/2	230	-	7.1	7.5	288	9	135	7	426	17	32	5	2.5	1	8.8	0.8	150X10^14	91			
7		Kondli Ph-III (Triveni Pvt. Ltd) ASP	10	10/10/50/5/2	230	-	7.1	7.5	288	9	135	7	426	17	32	5	2.5	1	8.8	0.8	150X10^14	91			
8		Kondli Ph-IV (Ayaappa Pvt.Ltd) ASPI(IFS)	45	10/10/50/5/2	230	-	6.9	7.6	294	9	130	8	440	21	35	4.2	2.8	1	9.3	0.8	290X10^14	73			
9		Chilla (HNB Engineers) C-ISBR	9	10/10/50/5/2	230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	Sample collection on Weekly basis		
10		CWG (M/s-Toshiba Water Solutn on Pvt. Ltd.) MBR	1	10/10/50/5/2	230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	Sample collection on Weekly basis		
11	N.S.T.P.C Pillar	Coronation Pillar Ph-II (DR& Infracom Pvt.Ltd.) ASPI(IFS)	20	50/30/250/50/5	230	18.46	7.2	7.5	128	7	47	5	207	15	15	0.4	1.2	0.5	1.4	bdl	73x10^4	43			
12		Coronation Pillar Ph-III (DR& Infracom Pvt.Ltd.) ASPI(IFS)	10	10/10/50/5/2	230	8.69	7.2	7.4	160	7	57	5	172	17	18	0.6	1.5	0.7	1.7	bdl	15x10^10	75			
13		Coronation New (L&I Construction and PASSAVANT JV)) ASP	70	10/10/50/5/2	230	41.809	7.2	7.6	120	6	38	4	76	13	22	0.7	2	1	1.2	bdl	15x10^9	23			
14		Narela (DR& Infracom Pvt.Ltd.) ASPI(IFS)	10	10/10/50/5/2	230	12.76	7.4	7.6	48	7	23	4	59	15	15	0.4	0.5	0.8	-	-	15x10^8	43			
15	Nilothi	Nilothi Ph-I (SUBHASH INFRA PVT. LTD) ASPI(IFS)	60	10/10/50/5/1	230	-	7.64	7.9	176	4	105	4	-	-	15	0.5	1.5	1.7	-	-	-	-			
16		Nilothi Ph-II (VEOLIA INDIA) ASP	20	10/10/50/5/2	230	-	7.41	7.58	286	13	150	14	-	-	10	6	1.9	1.2	-	-	-	-			
17	Okhla	Okhla Ph-V (DIB) ASP	16	50/30/250/50/5	-	-	7.2	7.5	208	6	308	4.1	379	20	42	0.2	2.3	1	5	ND	15 X 10^11	9.1 X 10^3			
18		Okhla Ph-VI (SUEZ India Pvt. Ltd.) ASP	30	10/10/50/5/2	230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
19		Okhla New (SUEZ India Pvt. Ltd.) ASP	124	10/10/50/5/2	230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
20		Mehrauli (DIB) E.A	5	50/30/250/50/5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
21		Molar band (DIB)	0.66	50/30/250/50/5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
22		Chitorini (DIB) ASP	5	50/30/250/50/5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
23		Vasant Kunj Ph-I (DIB) E.A	2.2	50/30/250/50/5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
24		Vasant Kunj Ph-II (DIB) E.A	3	50/30/250/50/5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
25		Delhi Gate Ph-I (Degramont) B & D	2.2	10/10/50/5/2	230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
26		Delhi Gate Ph-II (Degramont) B & D	15	10/10/50/5/2	230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
27	SNH drain (Degramont) B & D	2.2	10/10/50/5/2	230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-				
28	Peppankalan	Phappankalan Ph-I (SUBHASH INFRA PVT. LTD) ASP	20	10/10/50/5/1	-	-	7.3	7.7	430	10	210	7	590	25	45	0.2	4.2	2.2	-	-	46*10^11	73			
29		Phappankalan Ph-II (VA-TECH WABAG LTD.) ASP	20	10/10/50/5/1	230	-	7.3	7.8	430	9	210	5	590	18	45	4.4	4.2	3	-	-	46*10^11	340			
30		Najafgarh (Ayaappa Pvt.Ltd.) ASP	5	10/10/50/5/1	230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
31	Rithala	Rithala Ph-I (Ms WA TECH BABAG LTD.) ASP	40	10/10/50/5/2	100	44.24	7.23	7.55	460	8	202	7	520	32	29	1.9	3.4	0.9	11	2	24 x 10^12	75			
32		Rithala Ph-II (SUEZ India Pvt. Ltd.) ASP	40	10/10/50/5/2	230	38.89	7.31	7.57	448	7	200	6	512	28	29	6	4.1	0.5	10	2	24 x 10^13	64			
33	Rohtli S&P-25	Rohtli (Ms Dinesh Chandra Rohtli project Pvt. Ltd.) ASPI(IFS)	25	10/10/50/5/1	230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	11 x 10^12	210	-		
34	Vihar	Yamuna Vihar Ph-I (DIB) ASP	10	30/20/250/50/5	-	9.98	7.2	7.4	284	29	188	19	442	44	34	24	3	0.8	8	1.8	14x10^10	29x10^5			
35		Yamuna Vihar Ph-II (M/s-SIN_R&C JV) ASPI(IFS)	15	10/10/50/5/1	100	15.86	7.3	7.5	404	6	250	4	562	10	32	3	5.4	0.2	7.2	0.8	42x10^10	23x10^3			

36	Yamun: Sonia Vihar (Ayaappa Pvt.Ltd.) ASP	25	30/20/250/50/5	-	28,09	7.4	7.6	332	23	230	18	576	56	38	26	4.2	1.8	9.4	2	93×10^12	43×10^6	
37		7	10/10/50/5/2		-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
		Total Treatment	799.26																			
	ASP	Activated Sludge Process																				
	ASP(IFAS)	Activated Sludge Process with Integrated Fixed-film Activated Sludge																				
	E.A	Extended Aeration																				
	FAB	Fluidized Aerobic Bed																				
	B & D	Biofor and dansadeg																				
	C-ISBR	Combitreat-ISBR																				
	W	Waiting																				
	ND	Not Detectable																				
	BDL	Bellow Detection Limit																				

--	--

S.No.	Sewage Treatment Plant (Operator) Technology	Capacity	DPCC Parameter (mg/l) (TSS:10,BOD:10, COD:50, NH4-N:5,PO4-P:2, Oil& grease : 10)	Outlet (F.Coli) Limit	Average Daily Flow (MGD)	pH		TSS		BOD (3 DAYS at 27 0 C)		COD		Ammonical nitrogen		Dissolve phosphate		Oil & Grease		Fecal Coliform (72 hrs)		Remarks		
						INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET		INLET	OUTLET
						-	-	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	MPN/100ml		MPN/100ml	
1	Keshopur Ph-I (VA-TECH WABAG LTD.) ASP	12	30/20/250/50/5	230	-	7.2	7.52	273	5	122	4	231	22	24	4	4	4.5	-	-	-	-			
2	Keshopur Ph-II (Ayaappa Pvt.Ltd) ASP(IFAS)	20	10/10/50/5/1	230	-	7.27	7.54	375	4	212	5	518	29	21	6.5	3.5	1.7	-	-	24*10^9	210			
3	Keshopur Ph-III (Ayaappa Pvt.Ltd) ASP	60	10/10/50/5/1	230	-	7.32	7.36	334	12	205	8	470	38	15	2	3.5	2.7	-	-	-	-			
4	Kapashera (Triveni Pvt. Ltd) SBR	5	10/10/50/5/2	230	-	7.3	7.7	412	13	258	9	640	32	35	12	4.5	0.6	-	-	36*10^11	2400+			
5	Kondli Ph-I (Triveni Pvt. Ltd) ASP	10	10/10/50/5/2	230	10	7	7.5	310	9	138	7	432	18	30	5	3	0.8			210*10^14	110			
6	Kondli Ph-II (Triveni Pvt. Ltd) ASP	25	10/10/50/5/2	230	25	7	7.5	310	8	138	5	432	15	30	4	3	1.2			210*10^14	73			
7	Kondli Ph-III (Triveni Pvt. Ltd) ASP	10	10/10/50/5/2	230	10	7	7.5	310	8	138	5	432	15	30	4	3	1.2			210*10^14	73			
8	Kondli Ph-IV (Ayaappa Pvt.Ltd) ASP(IFAS)	45	10/10/50/5/2	230	45	7.1	7.6	318	9	135	9	462	16	28	3.5	3	0.8			150*10^14	91			
9	Chilla (HNB Engineers) C-SSR	9	10/10/50/5/2	230	9	7	7.5	274	7	155	5	444	11	35	N.D	2.8	0.5	9.8	NII	1100*10^14	73			
10	CWIS (M/s Toshiba Water Soluti on Pvt. Ltd.) MBR	1	10/10/50/5/2	230	1	7.1	7.6	306	5	160	3	428	6	35	N.D	3	N.D	12	NII	290*10^14	15			
11	Coronation Pillar Ph-II (DRA Infracom Pvt.Ltd.) ASP(IFAS)	20	50/30/250/50/5	230	18.17	7.2	7.6	132	5	84	3	227	12	20	0.8	1.8	0.9			-	-			
12	Coronation Pillar Ph-III (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	10/10/50/5/2	230	8.28	7.2	7.6	66	8	38	5	88	14	19	0.5	1.6	1	1.2	bdl	-	-			
13	Coronation New (L&T Construction and PASSAVANT (P)) ASP	70	10/10/50/5/2	230	38,605	7.3	7.7	210	6	79	4	187	14	24	0.7	2	1.2	1.8	bdl	-	-			
14	Narela (DRA Infracom Pvt.Ltd.) ASP(IFAS)	10	10/10/50/5/2	230	-															-	-	sample not collected due to non availability of vehicles		
15	Nilothi Ph-I (SUBHASH INFRA PVT. LTD) ASP(IFAS)	60	10/10/50/5/1	230	-	7.54	7.83	288	2	133	5	-	-	27.5	9	2.5	2	-	-	-	-			
16	Nilothi Ph-II (VEOLIA INDIA) ASP	20	10/10/50/5/2	230	-	7.53	7.56	372	7	155	9	-	-	32.5	10	2.8	1.6	-	-	-	-			
17	Okhla Ph-V (CIB) ASP	16	50/30/250/50/5	-	-	7.2	7.5	226	5	288	4.2	770	22	38	0.6	1.9	1.9	5	ND	-	-			
18	Okhla Ph-VI (SUEZ India Pvt. Ltd.) ASP	30	10/10/50/5/2	230	-	7.3	7.6	200	5	320	2.7	641	27	41	0.4	2.4	1.1	4	ND	-	-			
19	Okhla New (SUEZ India Pvt. Ltd.) ASP	124	10/10/50/5/2	230	-	7.3	7.6	312	5	298	5.1	457	5.1	46	0.4	2.8	2	-	-	-	-			
20	Mehrauli (CIB) E.A	5	50/30/250/50/5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
21	Molar band (CIB)	0.66	50/30/250/50/5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
22	Ghitorini (CIB) ASP	5	50/30/250/50/5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
23	Vasant Kunj Ph-I (CIB) E.A	2.2	50/30/250/50/5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
24	Vasant Kunj Ph-II (CIB) E.A	3	50/30/250/50/5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
25	Delhi Gate Ph-I (Degramont) B & D	2.2	10/10/50/5/2	230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
26	Delhi Gate Ph-II (Degramont) B & D	15	10/10/50/5/2	230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
27	SNH drain (Degramont) B & D	2.2	10/10/50/5/2	230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
28	Phappankalan Ph-I (SUBHASH INFRA PVT. LTD) ASP	20	10/10/50/5/1	-	-	7.4	7.6	294	10	180	6	450	23	30	0.1	2.8	0.7	-	-	35*10^11	93			
29	Phappankalan Ph-II (VA-TECH WABAG LTD.) ASP	20	10/10/50/5/2	230	-	7.4	7.7	294	12	180	6.8	450	26	30	10	2.8	2.5	-	-	35*10^11	1100			
30	Najafgarh (Ayaappa Pvt.Ltd.) ASP	5	10/10/50/5/1	230	-	7.3	7.6	370	12	230	6	580	27	40	0.1	3.7	1.7	-	-	15*10^11	93			
31	Rithala Ph-I (MS WA TECH BABAG LTD.) ASP	40	10/10/50/5/2	100	45.91	7.26	7.53	240	9	138	8	336	36	24	0.6	3.1	1.1	-	1	11*10^12	93			
32	Rithala Ph-II (SUEZ India Pvt. Ltd.) ASP	40	10/10/50/5/2	230	39.68	7.29	7.6	316	8	168	7	416	32	27	3	3.3	0.5	-	1	11*10^12	95			
33	Rohini (Ms Dinesh Chandra Rohini project pvt. Ltd) ASP(IFAS)	25	10/10/50/5/1	230	26.88	7.1	7.17	172	10	123	8	280	32	25	0.5	3.5	1	-	-	-	-			
34	Yamuna Vihar Ph-I (CIB) ASP	10	30/20/250/50/5	-	10.05	7.3	7.6	264	28	190	16	408	50	44	28	4.6	1.6	-	-	20*10^10	11*10^5			

35	Yamuna Vihar Ph-II (M/s SIPR-RKC JV) ASP(IFAS)	15	10/10/50/5/1	100	15.79	7.2	7.6	380	5	223	3	578	10	30	5	3.8	0.4	-	-	19×10^9	15×10^3	
36	Yamuna Vihar Ph-III (M/s Joly & Joly) ASP	25	30/20/250/50/5	-	27.39	7.3	7.5	460	21	310	15	618	48	46	30	5	2.2	-	-	43×10^12	23×10^6	
37	Sonia Vihar (Ayanappa Pvt.Ltd.) ASP	7	10/10/50/5/2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
Total Treatment		799.26																				
ASP		Activated Sludge Process																				
ASP(IFAS)		Activated Sludge Process with Integrated Fixed-film Activated Sludge																				
E.A		Extended Aeration																				
FAB		Fluidized Aerobic Bed																				
B & D		Biofor and dansadeg																				
C-ISBR		Combitreat-ISBR																				
W		Waiting																				
ND		Not Detectable																				
BDL		Bellow Detection Limit																				



DATE OF ANALYSIS : 10.09.2023																									
S.No.	Lab	Sewage Treatment Plant (Operator) Technology	Capacity	DPPC Parameter (mg/l) (TSS:10,BOD:10, COD:50, NH4-N:5,PO4-P:2, Oil& grease : 10)	Outlet (F.Coli) Limit	Average Daily Flow (MGD)	pH		TSS		BOD (3 DAYS at 27 o C)		COD		Ammonical nitrogen		Dissolve phosphate		Oil & Grease		Fecal Collform (72 hrs)		Remarks		
							INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET		INLET	OUTLET
			(MGD)	Design Parameter (mg/l) TSS/BOD/COD/ Ammoniacal nitrogen/Oilho phosphate	MPN /100ml		-	-	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l		mg/l	MPN/100ml
1	Keshapur	Keshapur Ph-I (VA-TECH WABAG LTD.) ASP	12	30/20/250/50/5	230		7.2	7.57	994	6	177	5	473	17	23	6	6	5	-	-	-	-			
2		Keshapur Ph-II (Ayaappa Pvt.Ltd) ASPI(RAS)	20	10/10/50/5/1	230		7.23	7.52	516	10	210	6	486	25	20	9	4	1.7	-	-	-	-			
3		Keshapur Ph-III (Ayaappa Pvc.Ltd) ASP	60	10/10/50/5/1	230		7.28	7.39	427	6	215	4	510	27	16	2	4.5	2.8	-	-	11*10^10	150			
4		Rasvishera (Triveni Pvt. Ltd) SBR	5	10/10/50/5/2	230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
5	Kondili	Kondili Ph-I (Triveni Pvt. Ltd) ASP	10	10/10/50/5/2	230	10	7	7.5	270	7	133	6	412	15	28	4.5	3	0.8			1100X10^14	91			
6		Kondili Ph-II (Triveni Pvt. Ltd) ASP	25	10/10/50/5/2	230	25	7	7.6	270	9	133	8	412	20	28	3.5	3	1			1100X10^14	150			
7		Kondili Ph-III (Triveni Pvt. Ltd) ASP	10	10/10/50/5/2	230	10	7	7.6	270	9	133	8	412	20	28	3.5	3	1			1100X10^14	150			
8		Kondili Ph-IV (Ayaappa Pvc.Ltd) ASPI(RAS)	45	10/10/50/5/2	230	45	7.1	7.5	290	8	130	5	436	18	32	3.2	3.2	1			210X10^14	73			
9		Chilla (HNB Engineers) C-ISBR	9	10/10/50/5/2	230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
10		CWSG (M/S Toshiba Water Solutn on Pvt. Ltd.) MBR	1	10/10/50/5/2	230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
11		N.S.T.P.C Pillar	Coronation Pillar Ph-II (DRA Infracom Pvt.Ltd.) ASPI(RAS)	20	50/30/250/50/5	230	18.52	7.1	7.6	182	5	120	3	244	12	21	0.5	1.2	0.9	2.1	bdl	21X10^3	93		
12			Coronation Pillar Ph-III (DRA Infracom Pvt.Ltd.) ASPI(RAS)	10	10/10/50/5/2	230	9.38	7.2	7.6	72	5	44	2	87	14	16	0.7	1.8	1	1	BDL	43X10^2	93		
13			Coronation New (JAT Construction and PASSAWANT (JV)) ASP	70	10/10/50/5/2	230	37.026	7.2	7.7	114	6	91	3	165	12	20	0.4	2.1	0.6	1.1	0.09	15X10^3	23		
14			Narela (DRA Infracom Pvt.Ltd.) ASPI(RAS)	10	10/10/50/5/2	230	12.12	7.4	7.6	50	5	32	3	65	11	10	0.5	0.5	0.8	1	BDL	11X10^7	150		
15	Nitrochi	Nitrochi Ph-I (SUBHASH INFRA PVT. LTD) ASPI(RAS)	60	10/10/50/5/1	230		7.84	7.99	182	4	83	3	-	-	27.5	5	1.8	1.5			-	-			
16		Nitrochi Ph-II (VCOIA INDIA) ASP	20	10/10/50/5/2	230		7.62	7.87	290	8	130	7	-	-	25	8	2.2	8			-	-			
17	Oikhla	Oikhla Ph-V (DJB) ASP	16	50/30/250/50/5	-	-	7.1	7.4	248	7	248	3.6	3	612	18	48	3.2	2.8	2.6	5	ND	-	-		
18		Oikhla Ph-VI (SUEZ India Pvt. Ltd.) ASP	30	10/10/50/5/2	230	-	7	7.5	264	5	238	4.1	630	16	46	0.8	2.4	1.4	4	ND	-	-			
19		Oikhla New (SUEZ India Pvt. Ltd.) ASP	124	10/10/50/5/2	230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
20		Mehrauli (DJB) E.A	5	50/30/250/50/5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
21		Molar band (DJB)	0.66	50/30/250/50/5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
22		Ghitorini (DJB) ASP	5	50/30/250/50/5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
23		Vasant Kunj Ph-I (DJB) E.A	2.2	50/30/250/50/5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
24		Vasant Kunj Ph-II (DJB) E.A	3	50/30/250/50/5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
25		Delhi Gate Ph-I (Degramont) B & D	2.2	10/10/50/5/2	230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
26		Delhi Gate Ph-II (Degramont) B & D	15	10/10/50/5/2	230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
27	SNH drain (Degramont) B & D	2.2	10/10/50/5/2	230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
28	Pappankalan	Phappankalan Ph-I (SUBHASH INFRA PVT. LTD) ASP	20	10/10/50/5/1	-		7.3	7.7	320	10	195	7.3	400	26	40	0.3	3.8	1.5	-	-	43*10^13	210			
29		Phappankalan Ph-II (VA-TECH WABAG LTD.) ASP	20	10/10/50/5/2	230		7.3	7.8	320	6	195	6	400	20	40	12	3.8	2.7	-	-	43*10^13	2000			
30		Najafgarh (Ayaappa Pvc.Ltd.) ASP	5	10/10/50/5/1	230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
31	Rithala	Rithala Ph-I (Ms WA TECH BARAG LTD.) ASP	40	10/10/50/5/2	100	44.17	7.29	7.62	316	10	178	9	440	40	23	0.8	3.4	0.8	-	2	24x10^13	75			
32		Rithala Ph-II (SUEZ India Pvt. Ltd.) ASP	40	10/10/50/5/2	230	38.05	7.35	7.69	400	7	205	6	520	28	24	3	3.5	0.3	-	1	24x10^13	64			
33	Rohini Sec-25	Rohini (Ms Dinash Chandra Rohini project pvt. Ltd.) ASPI(RAS)	25	10/10/50/5/1	230	25.15	7.22	7.04	408	8	215	6	512	24	20	0.4	3.8	0.8	-	-	-	-			
34	Yamuna Vihar	Yamuna Vihar Ph-I (DJB) ASP	10	30/20/250/50/5	-	9.95	7.2	7.5	328	37	208	23	528	59	35	22	3.4	1.2	10	2.4	43*10^10	23*10^5			
35		Yamuna Vihar Ph-II (M/S SIPL-RCC JV) ASPI(RAS)	15	10/10/50/5/1	100	15.66	7.3	7.6	408	7	239	4	654	14	32	4	3.8	0.2	10.8	1.2	39*10^9	36*10^3			
36		Yamuna Vihar Ph-III (M/S Joly & Joly) ASP	25	30/20/250/50/5	-	27.02	7.3	7.4	448	22	255	15	720	38	40	23	4.4	2	11.6	2	29*10^12	44*10^6			

[illegible]

DELHI JAL BOARD																							
DAILY ANALYSIS REPORT OF ALL SEWAGE TREATMENT PLANT																							
DATE OF ANALYSIS : 11.09.2025																							
S.No.	Sewage Treatment Plant (Operator) Technology	Capacity	DPPCC Parameter (mg/l) (TSS:10,BOD:10, COD:50, NH4-N:5,PO4-P:2, Oil& grease : 10)	Outlet (F.Coli) Limit	Average Daily Flow (MGD)	pH		TSS		BOD (3 DAYS at 27 0 C)		COD		Ammonical nitrogen		Dissolve phosphate		Oil & Grease		Fecal Coliform (72 hrs)		Remarks	
			Design Parameter (mg/l) TSS/BOD/COD/ Ammonical nitrogen/Ortho phosphate			INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET		
		(MGD)				-	-	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	MPN/100ml	MPN/100ml		
1	Keshapur Ph-I (VA-TECH WABAG (TD.) ASP	12	30/20/250/50/5	230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	Lab Close on Sunday	
	Keshapur Ph-II (Ayaappa Pvt.Ltd) ASPI(FAS)	20	10/10/50/5/1	230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	Lab Close on Sunday	
2	Keshapur Ph-III (Ayaappa Pvt.Ltd) ASP	60	10/10/50/5/1	230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	Lab Close on Sunday	
3	Kapashera (Trivent Pvt. Ltd) SBR	5	10/10/50/5/2	230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	Lab Close on Sunday	
4	Kondli Ph-I (Trivent Pvt. Ltd) ASP	10	10/10/50/5/2	230	10	7	7.4	282	7	140	5	378	16	30	4	2.8	1	8.1	Nil	2.1 X 10^16	73		
	Kondli Ph-II (Trivent Pvt. Ltd) ASP	25	10/10/50/5/2	230	25	7	7.5	282	8	140	6	378	14	30	2.5	2.8	0.8	8.1	Nil	2.1 X 10^16	73		
	Kondli Ph-III (Trivent Pvt. Ltd) ASP	10	10/10/50/5/2	230	10	7	7.5	282	8	140	6	378	14	30	2.5	2.8	0.8	8.1	Nil	2.1 X 10^16	73		
	Kondli Ph-IV (Ayaappa Pvt.Ltd) ASPI(FAS)	45	10/10/50/5/2	230	45	6.9	7.5	295	8	145	7	422	15	30	3.5	3	0.8	8.5	0.5	1.5 X 10^16	93		
	Chilla (HNB Engineers) C-SSR	9	10/10/50/5/2	230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	Sample collected on weekly basis	
	CWG (M/s Toshiba Water Solutn on Pvt. Ltd.) MBR	1	10/10/50/5/2	230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	Sample collected on weekly basis	
	Coronation Pillar Ph-II (DRA Infracore Pvt.Ltd.) ASPI(FAS)	20	50/30/250/50/5	230	18,09	6,9	7,3	180	5	105	3	182	11	17	0,7	1,4	0,8	1,8	bdl	-	-		
	Coronation Pillar Ph-III (DRA Infracore Pvt.Ltd.) ASPI(FAS)	10	10/10/50/5/2	230	8,6	7	7,6	80	5	39	3	90	13	15	0,5	1,9	1	1,5	bdl	-	-		
	Coronation New (L&T Construction and PASS/AVANT JV) ASP	70	10/10/50/5/2	230	42,41	7,2	7,6	190	7	72	4	180	16	14	0,6	2,2	0,8	-	-	-	-		
	Narela (DRA Infracore Pvt.Ltd.) ASPI(FAS)	10	10/10/50/5/2	230	-														-	-			
3	Nilothi Ph-I (SUSHASH INFRA PVT. LTD) ASPI(FAS)	60	10/10/50/5/1	230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	Lab Close on Sunday	
4	Nilothi Ph-II (VEOLIA INDIA) ASP	20	10/10/50/5/2	230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	Lab Close on Sunday	
	Okhla Ph-V (DIB) ASP	16	50/30/250/50/5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
	Okhla Ph-VI (SUEZ India Pvt. Ltd.) ASP	30	10/10/50/5/2	230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
	Okhla New (SUEZ India Pvt. Ltd.) ASP	124	10/10/50/5/2	230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
	Mehrauli (DIB) EA	5	50/30/250/50/5	-	-	7.2	7.4	252	56	200	36	502	158	48	76	3.8	3.8	8	2	-	-	-	
	Molar band (DIB)	0.66	50/30/250/50/5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
	Ghitorini (DIB) ASP	5	50/30/250/50/5	-	-	7.2	7.5	316	38	255	24	859	98	92	92	3.8	2.6	6	2	-	-	-	
	Vasant Kunj Ph-I (DIB) EA	2.2	50/30/250/50/5	-	-	7.4	7.5	1056	28	670	16	877	59	34	30	3.4	0.6	7	1	-	-	-	
	Vasant Kunj Ph-II (DIB) EA	3	50/30/250/50/5	-	-	7.2	7.5	370	32	300	20	994	82	48	72	3.4	3.8	4	2	-	-	-	
	Delhi Gate Ph-I (Degramont) B & D	2.2	10/10/50/5/2	230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
	Delhi Gate Ph-II (Degramont) B & D	15	10/10/50/5/2	230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
	SNH drain (Degramont) B & D	2.2	10/10/50/5/2	230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
5	Phappankalan Ph-I (SUSHASH INFRA PVT. LTD) ASP	20	10/10/50/5/1	-		7.3	7.45	484	9	-	-	-	-	40	0.1	3.2	1.7	-	-	-	-	-	
6	Phappankalan Ph-II (VA-TECH WABAG (TD.) ASP	20	10/10/50/5/2	230		7.3	8.04	484	10	-	-	-	-	40	5	3.2	2	-	-	-	-	-	
9	Najafgarh (Ayaappa Pvt.Ltd.) ASP	5	10/10/50/5/1	230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
	Rithala Ph-I (M& WA TECH BABAG (TD.) ASP	40	10/10/50/5/2	100	-	7.27	7.56	280	8	157	7	392	32	29	0.9	3.1	0.9	-	1	-	-	-	
10	Rithala Ph-II (SUEZ India Pvt. Ltd.) ASP	40	10/10/50/5/2	230	-	7.33	7.64	368	5	193	4	480	20	26	7	3.3	0.5	-	1	-	-	-	
	Rohini (M/s Dinesh Chandra Rohini project pvt. Ltd.) ASPI(FAS)	25	10/10/50/5/1	230	24,77	6,95	7,15	128	9	101	7	232	32	25	0,2	5,8	1	6	0,8	-	-	-	
7	Yamuna Vihar Ph-I (DIB) ASP	10	30/20/250/50/5	-	9.98	7.2	7.4	276	29	152	19	480	58	32	24	4	1	-	-	16×10^10	11×10^5	-	
8	Yamuna Vihar Ph-II (M/s SIPL-RKC JV) ASPI(FAS)	15	10/10/50/5/1	100	15.94	7.2	7.4	324	7	201	4	550	16	30	6	5.2	0.5	-	-	19×10^9	23×10^2	-	

[illegible]



DELHI JAL BOARD
DAILY ANALYSIS REPORT OF ALL SEWAGE TREATMENT PLANT
DATE OF ANALYSIS : 12.09.2025

S.No.	Lab	Sewage Treatment Plant (Operator) Technology	Capacity	DPCC Parameter (mg/l) (TSS:10,BOD:10, COD:50, NH4-N:5,PO4-P:2, Oil& grease : 10)	Outlet (F.Coli) Limit	Average Daily Flow (MGD)	pH		TSS		BOD (3 DAYS at 27 0 C)		COD		Ammonical nitrogen		Dissolve phosphate		Oil & Grease		Fecal Coliform (72 hrs)		Remarks
							INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	
			(MGD)	Design Parameter (mg/l) TSS/BOD/COD/ Ammonical nitrogen/Ortho phosphate	MPN /100ml		-	-	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	MPN/100ml	MPN/100ml	
1	Keshopur	Keshopur Ph-I (VA-TECH WABAG LTD.) ASP	12	30/20/250/50/5	230	-	7.18	7.55	383	3	177	3	489	23	25	7	4	6	-	-	-	-	
2		Keshopur Ph-II (Avasappa Pvt.Ltd) ASP(IFS)	20	10/10/50/5/1	230	-	7.31	7.61	428	10	215	7	569	31	26	6.5	3.7	1.8	-	-	11*10^10	150	
3		Keshopur Ph-III (Avasappa Pvt.Ltd) ASP	60	10/10/50/5/1	230	-	7.23	7.51	368	12	185	8	465	39	20	1.8	3.5	2.2	-	-	-	-	
4		Kapashera (Triveni Pvt. Ltd) SBR	5	10/10/50/5/2	230	-	7.2	7.3	156	8	190	5.8	320	28	50	12	2.2	1	-	-	91*10^11	1100	
5	Kondli	Kondli Ph-I (Triveni Pvt. Ltd) ASP	10	10/10/50/5/2	230	10	7	7.5	264	9	142	5	393	20	32	2.5	3.5	0.5	7.9	Nil	210X10^14	91	
6		Kondli Ph-II (Triveni Pvt. Ltd) ASP	25	10/10/50/5/2	230	25	7	7.4	264	8	142	6	393	12	32	4.5	3.5	1.5	7.9	0.8	210X10^14	72	
7		Kondli Ph-III (Triveni Pvt. Ltd) ASP	10	10/10/50/5/2	230	10	7	7.4	264	8	142	6	393	12	32	4.5	3.5	1.5	7.9	0.8	210X10^14	72	
8		Kondli Ph-IV (Avasappa Pvt.Ltd) ASP(IFS)	45	10/10/50/5/2	230	45	7	7.5	282	9	150	6	415	16	30	3	3	1.2	8.3	Nil	1100X10^14	35	
9		Chilla (INB Engineers) C-SSBR	9	10/10/50/5/2	230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
10		CWG (M/A Toshiba Water Soluti on Pvt. Ltd.) MBR	1	10/10/50/5/2	230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
11	N.S.T.P.C. Pillar	Coronation Pillar Ph-II (DRA Infracom Pvt.Ltd.) ASP(IFS)	20	50/30/250/50/5	230	18.48	7.1	7.6	166	6	70	4	203	13	12	0.3	1.5	0.8	1.5	bdl	-	-	
12		Coronation Pillar Ph-III (DRA Infracom Pvt.Ltd.) ASP(IFS)	10	10/10/50/5/2	230	8.28	7.2	7.5	54	6	25	4	85	11	12	0.4	1.5	1.3	-	-	-	-	
13		Coronation New (L&T Construction and PASSAVANT (JV) ASP	70	10/10/50/5/2	230	42.05	7.2	7.6	130	8	64	5	305	17	20	0.4	1	0.4	1.7	bdl	-	-	
14		Narela (DRA Infracom Pvt.Ltd.) ASP(IFS)	10	10/10/50/5/2	230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
15	Nilothi	Nilothi Ph-I (SUBHASH INFRA PVT. LTD) ASP(IFS)	60	10/10/50/5/1	230	-	7.68	7.94	280	7	150	5	-	-	20	2	1.7	2.2	-	-	-	-	
16		Nilothi Ph-II (VEOLA INDIA) ASP	20	10/10/50/5/2	230	-	7.45	7.56	170	16	95	8	-	-	20	10	1.9	1.8	-	-	-	-	
17		Okhla Ph-V (DIB) ASP	16	50/30/250/50/5	-	-	7.2	7.5	186	6	265	5.9	-	-	48	0.68	2.8	2.6	5	RD	-	-	
18		Okhla Ph-VI (SUEZ India Pvt. Ltd.) ASP	30	10/10/50/5/2	230	-	7.2	7.4	288	8	270	3.8	-	-	48	0.08	3	2	6	ND	-	-	
19	Okhla	Okhla New (SUEZ India Pvt. Ltd.) ASP	124	10/10/50/5/2	230	-	7.2	7.3	198	7	240	4.5	-	-	46	2.6	3	2.6	5	ND	-	-	
20		Mehrauli (DIB) E.A	5	50/30/250/50/5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
21		Molar band (DIB)	0.66	50/30/250/50/5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
22		Ghitorini (DIB) ASP	5	50/30/250/50/5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
23		Vasant Kunj Ph-I (DIB) E.A	2.2	50/30/250/50/5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
24		Vasant Kunj Ph-II (DIB) E.A	3	50/30/250/50/5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
25		Delhi Gate Ph-I (Degramont) B & D	2.2	10/10/50/5/2	230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
26		Delhi Gate Ph-II (Degramont) B & D	15	10/10/50/5/2	230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
27	Pappankalan	RNH drain (Degramont) B & D	2.2	10/10/50/5/2	230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
28		Phappankalan Ph-I (SUBHASH INFRA PVT. LTD) ASP	20	10/10/50/5/1	-	--	7.4	7.5	270	12	240	7	560	28	40	0.2	4.5	1.8	-	-	15*10^12	200	
29		Phappankalan Ph-II (VA-TECH WABAG LTD.) ASP	20	10/10/50/5/2	230	-	7.4	7.9	270	6	240	5	560	22	40	14	4.5	2	-	-	15*10^12	2100	
30	Rithala	Najafgarh (Avasappa Pvt.Ltd.) ASP	5	10/10/50/5/1	230	-	7.5	7.6	178	10	205	6	480	24	35	0.3	3.8	1.5	-	-	15*10^12	230	
31		Rithala Ph-I (VA-TECH BABAG LTD.) ASP	40	10/10/50/5/2	100	43.32	7.27	7.56	280	8	157	7	392	32	29	0.9	3.1	0.9	-	1	24x10^13	95	
32		Rithala Ph-II (SUEZ India Pvt. Ltd.) ASP	40	10/10/50/5/2	230	44.46	7.32	7.67	360	6	192	5	472	24	27	4	3.6	0.4	8	1	24x10^13	120	
33	Rohini Sec-25	Rohini (Ms Dinesh Chandra Rohini project pvt. Ltd.) ASP(IFS)	25	10/10/50/5/1	230	25.83	7.22	7.36	484	10	243	7	592	32	23	0.2	5	0.9	-	-	-	-	
34	Yamuna Vihar	Yamuna Vihar Ph-I (DIB) ASP	10	30/20/250/50/5	-	10.08	7.4	7.3	364	28	225	19	408	50	40	25	4.2	1.4	10.8	2	20*10^10	23*10^5	
35		Yamuna Vihar Ph-II (M/A SIPL-RCC JV) ASP(IFS)	15	10/10/50/5/1	100	15.89	7.1	7.2	472	6	267	4	578	10	34	4	3.8	0.4	11.6	1.6	42*10*11	21*10^3	
36		Yamuna Vihar Ph-III (M/A Joly & joly) ASP	25	30/20/250/50/5	-	28.31	7.3	7.4	424	22	280	17	618	48	42	26	5	2.2	12.8	2.4	93*10^12	39*10^5	

[illegible]

 DELHI JAL BOARD DAILY ANALYSIS REPORT OF ALL SEWAGE TREATMENT PLANT DATE OF ANALYSIS : 13.09.2025																								
S.No.	Lab	Sewage Treatment Plant (Operator) Technology	Capacity	DPCC Parameter (mg/l) (TSS:10,BOD:10, COD:50, NH4-N:5,PO4-P:2, Oil& grease : 10)	Outlet (F.Coli) Limit	Average Daily Flow (MGD)	pH		TSS		BOD (3 DAYS at 27 0 C)		COD		Ammonical nitrogen		Dissolve phosphate		Oil & Grease		Fecal Coliform (72 hrs)		Remarks	
			(MGD)	Design Parameter (mg/l) TSS/BOD/COD/ Ammonical nitrogen/Ortho phosphate	MPN /100ml		INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET	INLET	OUTLET		
							-	-	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	MPN/100ml	MPN/100ml		
				No any compliance																				
1	Keshopur	Keshopur Ph-I (VA TECH WABAG LTD.) ASP	12	30/20/250/50/5	230	-	7.18	7.58	277	5	175	5	473	19	24	10	4.5	5	-	-	-	-		
2		Keshopur Ph-II (Ayaappa Pvt.Ltd) ASP(IAS)	20	10/10/50/5/1	230	-	7.28	7.55	387	15	217	13	542	38	23	10	5	2.7	-	-	-	-		
3		Keshopur Ph-III (Ayaappa Pvt.Ltd) ASP	60	10/10/50/5/1	230	-	7.31	7.58	453	8	285	6	646	22	20	1.8	4.5	2.3	-	-	24*10^8	120		
4		Kapashera (Triveni Pvt. Ltd) SBR	5	10/10/50/5/2	230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
5	Kondli	Kondli Ph-I (Triveni Pvt. Ltd) ASP	10	10/10/50/5/2	230	10	7	7.6	272	8	147	7	415	18	30	3	2.5	0.6			1100X10^11	110		
6		Kondli Ph-II (Triveni Pvt. Ltd) ASP	25	10/10/50/5/2	230	25	7	7.5	272	9	147	5	415	17	30	3.5	2.5	1			1100X10^11	150		
7		Kondli Ph-III (Triveni Pvt. Ltd) ASP	10	10/10/50/5/2	230	10	7	7.5	272	9	147	5	415	17	30	3.5	2.5	1			1100X10^11	150		
8		Kondli Ph-IV (Ayaappa Pvt.Ltd) ASP(IAS)	45	10/10/50/5/2	230	45	7	7.6	302	8	155	6	446	15	35	2	3	0.8			290X10^11	91		
9		Chilla (HNS Engineers) C-15BR	9	10/10/50/5/2	230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
10		CWG (M/A Toshiba Water Soluti on Pvt. Ltd.) MBR	1	10/10/50/5/2	230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
11	N.S.T.P.C.Pillar	Coronation Pillar Ph-II (DRA Infracom Pvt.Ltd.) ASP(IAS)	20	50/30/250/50/5	230	18.08	7	7.5	148	5	84	3	225	11	17	0.4	2	0.6	-	-	15x10^13	460		
12		Coronation Pillar Ph-III (DRA Infracom Pvt.Ltd.) ASP(IAS)	10	10/10/50/5/2	230	8.32	7	7.5	66	8	25	5	92	19	15	0.4	1.2	0.9	-	-	93x10^6	150		
13		Coronation New (L&T Construction and PASSAVANT (JV)) ASP	70	10/10/50/5/2	230	36,568	7.1	7.6	230	9	121	6	331	20	2.1	0.3	1.4	0.2	2	bdl	21x10^14	460		
14		Narela (DRA Infracom Pvt.Ltd.) ASP(IAS)	10	10/10/50/5/2	230	12.16	7.3	7.7	54	5	29	3	63	11	8	0.3	1.4	0.7	1	bdl	11x10^10	150		
15	Nilothi	Nilothi Ph-I (S-UBHASH INFRA PVT. LTD) ASP(IAS)	60	10/10/50/5/1	230	-	7.7	7.76	244	5	130	4	-	-	17.5	0.3	2.2	1.6			-	-		
16		Nilothi Ph-II (VEDOLA INDIA) ASP	20	10/10/50/5/2	230	-	7.36	7.64	170	14	90	11	-	-	20	9	2	1.2			-	-		
17		Okhla Ph-V (DJB) ASP	16	50/30/250/50/5	-	-	7.2	7.5	280	6	290	3.9	561	32	46	2.4	2.8	2.6	5	1	-	-		
18		Okhla Ph-VI (SUEZ India Pvt. Ltd.) ASP	30	10/10/50/5/2	230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
19	Okhla	Okhla New (SUEZ India Pvt. Ltd.) ASP	124	10/10/50/5/2	230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
20		Mehrauli (DJB) E.A	5	50/30/250/50/5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
21		Molar band (DJB)	0.66	50/30/250/50/5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
22		Ghitorini (DJB) ASP	5	50/30/250/50/5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
23		Vasant Kunj Ph-I (DJB) E.A	2.2	50/30/250/50/5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
24		Vasant Kunj Ph-II (DJB) E.A	3	50/30/250/50/5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
25		Delhi Gate Ph-I (Degramont) B & D	2.2	10/10/50/5/2	230	-	7.2	7.4	262	7	170	6.5	382	16	46	4.8	2.8	1.6	6	ND	-	-		
26		Delhi Gate Ph-II (Degramont) B & D	15	10/10/50/5/2	230	-	7.3	7.4	210	4	165	7	335	31	48	30	2.8	1.6	7	ND	-	-		
27		SNH drain (Degramont) B & D	2.2	10/10/50/5/2	230	-	7.2	7.5	310	8	200	8	335	40	48	32	3	2	8	ND	-	-		
28		Phappankalan Ph-I (SUBHASH INFRA PVT. LTD) ASP	20	10/10/50/5/1	-	-	7.31	7.52	136	10	160	6.5	380	24	30	0.3	4	2	-	-	12*10^12	150		
29	Papankalan	Phappankalan Ph-II (VA TECH WABAG LTD.) ASP	20	10/10/50/5/2	230	-	7.31	8.26	136	4	160	5	380	16	30	15	4	2.7	-	-	12*10^12	1600		
30		Najafgarh (Ayaappa Pvt.Ltd.) ASP	5	10/10/50/5/1	230	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
31		Rithala Ph-I (Ms WA TECH BABAG LTD.) ASP	40	10/10/50/5/2	100	44.03	7.25	7.52	376	9	195	8	488	36	23	0.7	3.5	0.6	-	2	24x10^12	93		
32	Rithala	Rithala Ph-II (SUEZ India Pvt. Ltd.) ASP	40	10/10/50/5/2	230	81.57	7.35	7.69	332	10	182	9	448	40	27	5	3.7	0.5	-	2	24x10^13	210		
33		Rohini (Ms Dinesh Chandra Rohini project Pvt. Ltd.) ASP(IAS)	25	10/10/50/5/1	230	25.55	7.34	7.45	552	9	255	6	648	32	22	0.4	4	1	-	-	-	-		
34	Behini Sec-25	Yamuna Vihar Ph-I (DJB) ASP	10	30/20/250/50/5	-	9.95	7.4	7.5	332	38	169	19	524	66	30	21	3.4	1.3	-	-	14x10^10	11x10^5		

35	Yamuna Vihar	Yamuna Vihar Ph-II (M/s SUP, INC JV) ASP(IFAS)	15	10/10/50/5/1	100	15.96	7.3	7.3	452	7	238	3	734	10	29	5	3.2	0.3	-	-	39×10^10	23×10^3	
36		Yamuna Vihar Ph-III (M/s Joly & Joly) ASP	25	30/20/250/50/5	-	28.55	7.3	7.5	548	23	216	17	816	58	32	22	3.8	1.6	-	-	44×10^12	23×10^6	
37		Sonia Vihar (Ayaappa Pvt.,Ltd.) ASP	7	10/10/50/5/2		-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
		Total Treatment	799.26																				
	ASP	Activated Sludge Process																					
	ASP(IFAS)	Activated Sludge Process with Integrated Fixed-film Activated Sludge																					
	E.A	Extended Aeration																					
	FAB	Fluidized Aerobic Bed																					
	B & D	Biofor and dansadeg																					
	C-ISBR	Combitreat-ISBR																					
	W	Waiting																					
	ND	Not Detectable																					
	BDL	Bellow Detection Limit																					