



Total No of operational plant	38	%BTL	15.8%
Total No of Plant under rehabilitation	4		
Total No of Outlet Sample collected	38		
Total No of plant Under Unit	9		
Total No of plant Under Ft	30		
%Unit	16		
%Ft	84	%BTL	84.2%

BDL: Below detection limit
ND: Not Detectable

Plant not meeting standard as per the design parameter	
Plant under D/B (O&M)	10
Plant under P/vt (O&M)	28



Total No of operational plant	38	Not meeting standard as per the design parameter Plant under OJB (OSM) Plant under P+G (OSM)
Total No of Plant under rehabilitation	4	
Total No of Outlet Sample collected	38	
Total No of plant Under fits	7	
Total No of plant under fit	31	
%fit	81.58%	
%fit	81.58%	



DELHI JAL BOARD

DAILY ANALYSIS REPORT OF ALL SEWAGE TREATMENT PLANT


DATE OF ANALYSIS : 03.12.2024

S.No.	Lab	Plant	Technology	Operator	Tertiary System	Disinfectant Type	Design Parameter(mg/l)				Outlet MPN (100ml)	Date of Analysis	Average Daily Flow (MGD)	pH (inlet)	pH (outlet)	TSS (inlet)	TSS (outlet)	BOD (inlet)	BOD (outlet)	COD (inlet)	COD (outlet)	Ammoniac Nitrogen (inlet)	Ammoniac Nitrogen (outlet)	Ortho phosphate (inlet)	Ortho phosphate (outlet)	Sulphide (inlet)	Sulphide (outlet)	Inlet SPS (l/cat)	Outlet SPS (l/cat)	Inlet SPS (l/cat)	Outlet SPS (l/cat)	Remarks	Feed SPS	Command Area			
							TSS	BOD	COD	Ammoniac Nitrogen																											
1	Keshopur	12 MGD Ph-I STP Keshopur	ASP	VA-TECH WABAG LTD.	-	Chlorination	-	-	-	-	-	03.12.2024	-	7.24	7.67	261	18	160	4	304	-	25.5	5	3	4	2.39	0.13					Under rehabilitation state and running with 50% capacity	Shree Nagar SPS, Pappankalan SPS, Keshopur SPS	Shree Nagar SPS, Pappankalan SPS, Keshopur SPS			
2	Keshopur	20MGD Ph-II STP Keshopur	ASP	Ayazappa Pvt.Ltd	-	-	50	30	250	50	5	-	03.12.2024	-	7.39	7.46	389	9	272	15	460	-	24	8	4	2	1.2	Nil	24x10 ⁹	11x10 ⁴	24x10 ⁸	46000	Under rehablitation SPS	Under rehablitation SPS	Under rehablitation SPS		
3	Keshopur	40MGD Ph-III STP Keshopur	ASP	Ayazappa Pvt.Ltd	-	-	50	30	250	50	5	-	03.12.2024	-	7.35	7.49	655	7	310	5	676	-	16.5	2	4	3	2.92	0.13	24*10 ¹¹	24*10 ⁵	24*10 ⁹	11*10 ⁴	Under rehablitation SPS	Under rehablitation SPS	Under rehablitation SPS		
4	Keshopur	9 MGD STP Keshopur	SRB	TRIVENI	-	UV	10	10	50	5	2	230	30.11.2024	-	6.98	7.27	781	11	450	13	869	-	35	6	6	4	3.7	Nil					Under rehablitation SPS	Under rehablitation SPS	Under rehablitation SPS		
5	Kondli	16MGD Phase-I STP Kondli	ASP	Triveni Pvt. Ltd	RGF	Chlorination	10	10	50	5	2	230	03.12.2024	10	7.00	7.60	310	8	135	5	395	18	33	1	4	1	5.8	Nil					Under rehablitation SPS	Under rehablitation SPS	Under rehablitation SPS		
6	Kondli	25 MGD Phase-II STP Kondli	ASP	Triveni Pvt. Ltd	RGF	Chlorination	10	10	50	5	2	230	03.12.2024	25	7.00	7.50	310	8	135	5	395	16	32	3	4	1	5.8	Nil					Under rehablitation SPS	Under rehablitation SPS	Under rehablitation SPS		
7	Kondli	10 MGD Phase-III STP Kondli	ASP	Triveni Pvt. Ltd	RGF	Chlorination	10	10	50	5	2	230	03.12.2024	10	7.00	7.50	310	8	135	5	395	16	32	3	4	1	5.8	Nil					Under rehablitation SPS	Under rehablitation SPS	Under rehablitation SPS		
8	Kondli	45 MGD Phase-IV STP Kondli	ASP(FAS)	Ayazappa Pvt.Ltd	Disc Filter	UV	30	20	250	50	5	230	03.12.2024	45	7.10	7.50	304	12	140	9	405	20	30	8	4	2	6.4	Nil					Under rehablitation SPS	Under rehablitation SPS	Under rehablitation SPS		
9	Kondli	9 MGD STP Chilla	Combiteat-SBR	HNB Engineers	-	Chlorination	10	10	50	5	2	230	07.10.2024	9	6.80	7.30	354	8	138	0.8	424	14	35	1	4	2	6.8	Nil					Under rehablitation SPS	Under rehablitation SPS	Under rehablitation SPS		
10	Kondli	18MGD STP Akhandam	MBR	M/A Toshiba Water Solution Pvt. Ltd.	Membrane Filtration	Chlorination	1	2	50	5	2	230	16.09.2024	1	6.90	7.60	310	BOL	140	BOL	390	6	32	Nil	3	Nil	6.4	Nil	11x10 ¹⁷	150			Under rehablitation SPS	Under rehablitation SPS	Under rehablitation SPS		
11	N.S.T.P.C.Pillar	20MGD Phase-I NESTPC Pillar	ASP	DRA Infracon Pvt.Ltd.	-	UV (Not Started)	50	30	250	50	5	-	03.12.2024	4	7.20	7.50	226	18	148	13	386	22	16	1	2	1	2	0.7					Under rehablitation SPS	Under rehablitation SPS	Under rehablitation SPS		
12	N.S.T.P.C.Pillar	16MGD Phase-II NESTPC Pillar	ASP	DRA Infracon Pvt.Ltd.	-	UV (Not Started)	50	30	250	50	5	-	03.12.2024	2.5	7.30	7.40	180	22	91	12	358	39	21	1	3	1	1.8	1.2					Under rehablitation SPS	Under rehablitation SPS	Under rehablitation SPS		
13	N.S.T.P.C.Pillar	70MGD NESTPC Pillar	ASP	L&T Construction and PASSAVANT (JV)	-	Chlorination	10	10	50	5	2	230	03.12.2024	35.267	7.20	7.50	256	11	147	06	421	19	32	1	4	2	3.2	0.6					Under rehablitation SPS	Under rehablitation SPS	Under rehablitation SPS		
14	N.S.T.P.C.Pillar	10MGD STP Navia	ASP	DRA Infracon Pvt. Ltd.	-	UV (Not Started)	50	30	250	50	5	-	02.12.2024	2.08	7.40	7.70	156	15	73	07	267	27	35	1	4	3	4.3	2.2					Under rehablitation SPS	Under rehablitation SPS	Under rehablitation SPS		
15	Nilothi	40MGD Ph-I STP Nilothi	ASP	SURSHASH INFRA PVT. LTD	-	-	50	30	250	50	5	-	03.12.2024	-	7.50	8.03	296	11	183	16	719	-	32	24	4	2	1.6	Nil					Under rehablitation SPS	Under rehablitation SPS	Under rehablitation SPS		
16	Nilothi	38MGD Ph-II STP Nilothi	ASP	VEDULA INDIA	Disc Filter	Chlorination	10	10	50	5	2	230	03.12.2024	-	7.50	7.80	254	8	173	6	632	-	28	14	3	2	1	Nil					Under rehablitation SPS	Under rehablitation SPS	Under rehablitation SPS		
17	Okhla	12 MGD STP Okhla	ASP	DIB	-	-	50	30	250	50	5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	Plant not in operation	Plant not in operation	Plant not in operation		
18	Okhla	45 MGD STP Okhla	ASP	DIB	-	-	50	30	250	50	5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	Plant not in operation	Plant not in operation	Plant not in operation		
19	Okhla	37 MGD STP Okhla	ASP	DIB	-	-	50	30	250	50	5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	Plant not in operation	Plant not in operation	Plant not in operation		
20	Okhla	16 MGD STP Okhla	ASP	DIB	-	-	50	30	250	50	5	-	22.11.2024	-	7.10	7.50	170	24	220	20.5	-	-	42	32	2	1		28x10 ¹⁰					PAC Dosing	PAC Dosing	PAC Dosing		
21	Okhla	New 35 MGD STP Okhla	ASP	SUEZ India Pvt. Ltd.	-	-	10	10	50	5	2	-	21.11.2024	-	6.90	7.60	220	4	100	4.3	-	-	401	1	3	0		35x10 ¹²	<1.8					Plant not in operation	Plant not in operation	Plant not in operation	
22	Okhla	9 MGD STP Mahauli	Extended Aeration	DIB	-	-	50	30	250	50	5	-	11.10.2024	-	7.30	7.60	490	44	260	28	690	110	21	24	2	1	2.8	1.2	24x10 ¹⁸	24x10 ¹⁰			Under rehablitation SPS	Under rehablitation SPS	Under rehablitation SPS		
23	Okhla	0.66MGD STP Mahauli	Fluidized Aerobic Bed	-	-	-	30	20	250	50	5	-	15.08.2024	-	7.20	7.40	556	19	320	11	770	45	43	34	2	1	6.8	0.4	24x10 ¹⁸	93			Under rehablitation SPS	Under rehablitation SPS	Under rehablitation SPS		
24	Okhla	9 MGD STP Ghisruvi	ASP	DIB	-	-	30	20	250	50	5	-	17.10.2024	-	7.60	7.30	284	19	260	10	519	46	200	0	3	1	2.4	0.4					Under rehablitation SPS	Under rehablitation SPS	Under rehablitation SPS		
25	Okhla	2.2 MGD STP Vasant Kunj(Old)	Extended Aeration	DIB	-	-	50	30	250	50	5	-	11.10.2024	-	7.40	7.60	408	25	230	10.8	698	62	71	1	2	1	2.4	0.8	24x10 ¹⁸	11x10 ⁸			Under rehablitation SPS	Under rehablitation SPS	Under rehablitation SPS		
26	Okhla	38MGD STP Vasant Kunj(New)	Extended Aeration	DIB	-	-	30	20	250	50	5	-	11.10.2024	-	7.30	7.30	370	20	365	12	633	53	89	5	2	1	2	0.4	24x10 ¹⁸				Under rehablitation SPS	Under rehablitation SPS	Under rehablitation SPS		
27	Okhla	2.2 MGD STP Delhi Gazi-3	Biofor and dandage	Degraoment	-	-	15	10	50	5	2	-	17.10.2024	-	7.20	7.40	240	8	225	10.3	472	39	42	3	2	1	2.4	0	24x10 ¹⁸	24x10 ⁶			Under rehablitation SPS	Under rehablitation SPS	Under rehablitation SPS		
28	Okhla	15 MGD STP Delhi Gazi-4	Biofor and dandage	Degraoment	-	Chlorination	10	10	50	5	2	230	17.10.2024	-	7.50	7.60	268	6	300	6	394	30	38	2	2	0	2	0	24x10 ¹⁸	2400			Under rehablitation SPS	Under rehablitation SPS	Under rehablitation SPS		
29	Okhla	2.2 MGD STP S.H.N	Biofor and dandage	Degraoment	-	-	15	10	50	5	2	-	17.10.2024	-	7.30	7.20	284	7	219	6.3	520	54	44	4	3	0	2.8	0	24x10 ¹⁸	35x10 ⁵			Under rehablitation SPS	Under rehablitation SPS	Under rehablitation SPS		
30	Pappankalan	20MGD Ph-I STP Pappankalan	ASP	SURSHASH INFRA PVT. LTD	-	-	50	30	250	50	5	-	03.12.2024	-	7.65	7.82	324	16	185	15.5	519	66	35	2	3	1	3.4	Nil					Under rehablitation SPS	Under rehablitation SPS	Under rehablitation SPS		
31	Pappankalan	20MGD Ph-II STP Pappankalan	ASP	VA-TECH WABAG LTD.	-	Media Filtration	10	10	50	5	2	230	03.12.2024	-	7.65	7.90	324	5	185	4	519	28	35	3	3	2	3.4	Nil					Under rehablitation SPS	Under rehablitation SPS	Under rehablitation SPS		
32	Pappankalan	18MGD STP Naglaugh	ASP	Ayazappa Pvt.Ltd.	-	-	50	30	250	50	5	-	30.11.2024	-	7.31	7.80	585	2	350	2	860	-	45	1	5	3	1.86	Nil					Under rehablitation SPS	Under rehablitation SPS	Under rehablitation SPS		
33	Rithala	45MGD Ph-I STP Rithala	ASP	M/s WA-TECH BARAG LTD.	Disc Filter	UV	10	10	50	5	2	100	03.12.2024	34.46	7.48	7.69	380	8	190	7	478	31	30	2	4	1	3.6	0.4	-	-	24x10 ⁷⁺	460	Plant Under not	Plant Under not	Plant Under not		
34	Rithala	45MGD Ph-II STP Rithala	ASP	SUEZ India Pvt. Ltd.	Disc Filter	UV	10	10	50	5	2	230	03.12.2024	39.03	7.50	7.68	352	10	185	9	456	33	27	8	4	1	2.4	0.8	-	-	24 X 10 ⁷⁺	120			Plant Under not	Plant Under not	Plant Under not
35	Rohini	15MGD STP Sec-25 Rohini	ASP	M/s Dinesh Chandra Rulliet project Pvt. Ltd.	-	-	50	30	250	50	5	-	03.12.2024	7.77	7.32	7.38	332	30	181	18	456	80	38	0	6	5	-	-	-	-	-	-	-	Plant Under not	Plant Under not	Plant Under not	
36	Yamuna Vihar	10MGD Phase-I Yamuna Vihar	ASP	DIB	-	-	50	30	250	50	5	-	03.12.2024	10.05	7.20	7.40	252	21	155	12	460	40	35	22	4	1	4.8	1.8	21x10 ¹²	15x10 ⁶	14x10 ¹¹	11x10 ⁵	Under rehablitation SPS	Under rehablitation SPS	Under rehablitation SPS		
37	Yamuna Vihar	10MGD Phase-II Yamuna Vihar	ASP(FAS)	M/A SPL-RCC JV	Disc Filter	UV	50	30	250	50	5	230	03.12.2024	15.17	7.30	7.50	260	08	160	6	464	14	34	15	4	1	4.4	1.4	21x10 ¹²	210	11x10 ¹¹	75	Under rehablitation SPS	Under rehablitation SPS	Under rehablitation SPS		
38	Yamuna Vihar	25 MGD Phase-III Yamuna Vihar	ASP	M/s Joly & Joly	-	-	30	20	250	50	5	-	03.12.2024	27.27	7.40	7.60	396	24	246	16	649	50	40	25	5	2	6.2	3	29x10 ¹⁴	21x10 ⁷	21x10 ¹³	11x10 ⁶	Under rehablitation SPS	Under rehablitation SPS	Under rehablitation SPS		

Operational plant	38
Plant Under rehabilitation	4
Plant out of order	3
Outlet Sample collected	35
Plant Under Unfit	8
Plant Under fit	27
%Unfit	23
%Fit	77



BDL: Below detection limit	
ND: Not Detectable	
Plant not meeting standard as per the design parameter	
Plant under DJB (O&M)	10
Plant under Pvt. (O&M)	28




% Fit & unfit report %Fit 77.1% %Unfit 22.9%		Outlet TSS & BOD Profile Sewage Treatment Plant, Dehli Jal Board		WQA, Review detection limit NO: Not Detectable Plant not meeting standard Plant under O&M (O&M) 10 Plant under Pre- (O&M) 28
Operational plant	38			
Plant Under rehabilitation	4			
Plant out of order	3			
Outlet Sample collected	35			
Plant Under Unfit	9			
Plant Under fit	27			
Unfits	23			
Total	77			



DATE OF ANALYSIS : 05.12.2024

Operational plant	38
Plant Under rehabilitation	4
Plant out of order	3
Outlet Sample collected	35
Plant Under Unfit	4
Plant Under fit	31
%Unfit	11
%fit	89






DATE OF ANALYSIS : 06.12.2024

Operational plant	38
Plant Under rehabilitation	4
Plant out of order	3
Outlet Sample collected	35
Plant Under Unfit	6
Plant Under fit	29
%Unfit	17
%fit	83




DATE OF ANALYSIS : 07.12.2024

	Plant not meeting standard as per plant perimeter	BDL: Below detection limit
	Plant not meeting standard as per DPCP norms	ND: Not Detectable
Operational plant	36	Plant under D/B (O&M)
Plant Under rehabilitation	4	Plant under P/vt. (O&M)
Plant out of order	3	
Outlet Sample collected	36	
Plant Under Units	6	
Plant Under fit	29	
Plant unfit as per DPCP norms	11	
%Unfit	17	
%fit	83	



%Unfit
17.1%



%fit
82.9%







DATE OF ANALYSIS : 08.12.2024


	Plant not meeting standard as per plant per-minute	IDL: Below detection limit
	Plant not meeting standard as per DPCP norms	ND: Not Detectable
Operational plant	36	Plant under D/JB (OSM)
Plant Under rehabilitation	4	Plant under Pvt. (OSM)
Plant out of order	3	
Outlet Sample collected	35	
Plant Under Unit	2	
Plant Under fit	33	
Plant unfit as per DCPF norms	11	
%Unfit	6	
%fit	94	





	Plant not meeting standard as per point parameter	BGL: Below detection limit	% Fit & Unfit report (As per DPCC limit)		% Fit & Unfit report (As per design parameter)	
	Plant not meeting standard as per DPCC limit	ND: Not Detectable				
Operational plant	58	Plant under O&M	10	% Fit 85.7% % Unfit 14.3%	% Fit 94.3% % Unfit 5.7%	Outlet TSS & BOD Profile TSS (blue) BOD (red)
Plant Under rehabilitation	4	Plant under Pcs (O&M)	20			
Plant out of order	3	Plant Under Unfit (As per DPCC)	3			
Outlet Sample collected	35	Plant Under Fit	16			
Plant Under Unfit (As per design)	2	% Unfit	54			
Plant Under Fit	53	% Unfit	46			
% Unfit	6	% Unfit				
% Fit	94	% Fit				



[illegible]

Plant not meeting standard as per plant parameter	35	WOL: Below detection limit
Plant not meeting standard as per DPCC criteria	0	ND: Not Detectable
Operational plant	38	Plant under O&M (O&M)
Plant Under rehabilitation	4	Plant under Per. (O&M)
Plant out of order	3	Plant out of order
Outlet Sample collected	35	Outlet Sample collected
Plant Under Unfit (As per design)	11	Plant Under Unfit (As per DPCC)
Plant Under fit	24	Plant Under fit
%Unfit	31	%Unfit
%fit	69	%fit

% Fit/BODT report(As per DPCC limit)
per 6.4.3 TSS <10 mg, BOD5 <10 mg, COD <50 mg, NH3-N <5 mg/L, PO4-P <2 mg/L, FC-TSS MPN/100 ml



%Fit: 69.7%
%Unfit: 30.3%


% Fit & unfit report (As per design parameter)

%Fit: 65.6%
%Unfit: 34.4%

Outlet TSS & BOD Profile

Sewage Treatment Plant, Delhi Jal Board





S.No.	Lab	Plant	Technology	Operator	Tertiary System	Disinfectant Type	Design Parameter(mg/l)						Outlet MPN (I/Coll)	Date of Analysis	Average Daily Flow (MGD)	pH (Inlet)	pH (Outlet)	TSS (Inlet)	TSS (Outlet)	BOD (Inlet)	BOD (Outlet)	COD (Inlet)	COD (Outlet)	Ammoniacal nitrogen (Inlet)	Ammoniacal nitrogen (Outlet)	Ortho phosphate (Inlet)	Ortho phosphate (Outlet)	Sulphate (Inlet)	Sulphate (Outlet)	Inlet MPN (T.Coll)	Outlet MPN (T.Coll)	Inlet MPN (F.Coll)	Outlet MPN (F.Coll)	Remarks	Feed SPS	Command Area		
							TSS	BOD	COD	Ammoniacal nitrogen	Ortho phosphate	100ml			-	-	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	100ml	100ml	100ml	100ml					
1	Kashipur	12 MGD Ph-I STP Kashipur	ASP	VA-TECH WABAG LTD.	-	Chlorination	30	20	250	50	5	-	27.12.2024	-	7.35	7.30	326	8	172	6	476	23	17	1.5	2.0	4.2	1.3	Nil							Uttam Nagar SPS Ranwarpur SPS Panrampur SP	Hill Dalhi, Patel Nagar, Main Nagar, Rajnagar, Gopal Nagar, Panchsathi Bapla, Dahi Cantt, Joraha		
2		20MGD Ph-II STP Kashipur	ASP	Ayaappa Pvt.Ltd	-	-	30	20	250	50	5	-	27.12.2024	-	7.40	7.31	589	15	250	31	615	42	17.5	4.1	1.8	1.3	1.1	Nil	24x10 ⁸	24000	24x10 ⁷	21000	Plant is under rehabilitation and running with 50% capacity.					
3		4MGD Ph-III STP Kashipur	ASP	Ayaappa Pvt.Ltd	-	-	30	20	250	50	5	-	27.12.2024	-	7.33	7.37	420	4	210	2.1	574	26	132	1.8	2.0	3.0	0.7	Nil								under rehabilitation state and running with 50% capacity.		
4		5 MGD STP Kapashera	SBR	TRIVENI	-	UV	10	10	50	5	2	230	24.12.2024	-	7.34	7.35	691	16	390	6	720	42	53	1.2	4.2	1.8	0.5	Nil								Rajapur SPS, Panrampur SPS, Rasthapura SPS, Chandrahat SPS		
5	Kondli	10MGD Phase-I STP Kondli	ASP	Triveni Pvt. Ltd	ROF	Chlorination	10	10	50	5	2	230	27.12.2024	10	7.00	7.60	282	12	135	8	360	36	28.0	4.0	3.2	1.0	6	1.2								Plant Under Trial		
6		25 MGD Phase-II STP Kondli	ASP	Triveni Pvt. Ltd	ROF	Chlorination	10	10	50	5	2	230	27.12.2024	25	7.00	7.30	282	7	135	5	360	18	28.0	1.2	3.2	1.5	6	Nil								Plant Under Trial		
7		10 MGD Phase-III STP Kondli	ASP	Triveni Pvt. Ltd	ROF	Chlorination	10	10	50	5	2	230	27.12.2024	10	7.00	7.30	282	7	135	5	360	18	28.0	1.2	3.2	1.5	6	Nil								Plant Under Trial		
8		45 MGD Phase-IV STP Kondli	ASPI(HAS)	Ayaappa Pvt.Ltd	Disc Filter	UV	10	10	50	5	2	230	27.12.2024	45	7.00	7.50	298	9	138	7	390	20	30.0	3.0	3.5	1.2	5.6	Nil								Plant Under Trial		
9	N.B.T.P.C.Pillar	9 MGD STP Chilla	Combireact-HSR	NHB Engineers	-	Chlorination	10	10	50	5	2	230	10.07.2024	9	6.80	7.30	354	8	138	6	424	14	35.0	0.6	3.8	1.5	6.8	Nil								Chhapra area		
10		1MGD STP Alambahar	MBR	M/S Yoshida Water Solution Pvt. Ltd.	Membrane Filtration	Chlorination	1	2	50	5	2	230	16.09.2024	1	6.90	7.60	310	BDL	140	BDL	390	6	32.0	Nil	2.5	Nil	6.4	Nil	11x10 ¹⁷	150						Alambahar SPS	Sports Complex	
11		20MGD Phase-I NESTPC Pillar	ASP	DRA Infrahcom Pvt.Ltd.	-	UV (Not Started)	50	30	250	50	5	-	27.12.2024	4	7.30	7.50	330	20	161	10	418	29	22.0	0.4	2.1	2.5	1.3	0.7								Half stream of plant is Under Rehabilitation		
12		10MGD Phase-II NESTPC Pillar	ASP	DRA Infrahcom Pvt.Ltd.	-	UV (Not Started)	50	30	250	50	5	-	27.12.2024	2.5	7.30	7.60	170	12	81	07	272	18	19.0	0.5	2.0	1.7	1.7	0.5								Poly dosing		
13	Nishithi	70MGD NESTPC Pillar	ASP	J&T Construction and PASSAUNAV (JV)	-	Chlorination	10	10	50	5	2	230	27.12.2024	38.4	7.10	7.50																						

	Plant not meeting standard as per plant parameters	BOL - Below detection limit	% F8 Unfit report(As per DPCC limit) pre 0.0-0.150 mg/l, BOD5(mg/l) Color (mg/l) NH3-N(mg/l) NO3-N (<0. mg/l) PO4-P (<0. mg/l) FC (<0.50 MPN/100 ml)	% F8 & unfit report (As per design parameter)	Outlet TSS & BOD Profile TSS (Outlet) & BOD (Outlet)
	Plant not meeting standard as per DPCC norms	ND - Not Detectable			
Operational plant	38	Plant under O&M (O&M)	10		
Plant Under rehabilitation	4	Plant under P&C (P&C)	25		
Plant out of order	3	Plant out of order	3		
Outlet Sample collected	35	Outlet Sample collected	35		
Plant Under Unfit (As per design)	10	Plant Under Unfit (As per DPCC)	23		
Plant Under fit	25	Plant Under fit	12		
%Unfit	29	%Unfit	66		
%Fit	71	%Fit	34		



DATE OF ANALYSIS : 28.12.2024

Outlet TSS & BOD Profile

Legend: TSS (Outlet) (Blue), BOD (Outlet) (Red)

Sewage Treatment Plant	TSS (Outlet) (mg/l)	BOD (Outlet) (mg/l)
Chandigarh	28	18
Connaught Place	36	20
Connaught Place	28	17
Connaught Place	11	9
Connaught Place	9	10
Connaught Place	7	7
Connaught Place	15	7
Connaught Place	27	10
Connaught Place	2	4
Connaught Place	2	4
Connaught Place	6	9
Connaught Place	20	19
Connaught Place	26	19
Connaught Place	13	19
Connaught Place	45	20
Connaught Place	8	10
Connaught Place	15	10
Connaught Place	45	10
Connaught Place	15	10
Connaught Place	20	10
Connaught Place	15	10
Connaught Place	8	9
Connaught Place	9	9
Connaught Place	9	9
Connaught Place	16	10
Connaught Place	4	10
Connaught Place	28	10
Connaught Place	12	10

Sewage Treatment Plant, Delhi Jal Board



DATE OF ANALYSIS : 29.12.2024

[illegible]



DATE OF ANALYSIS : 30.12.2024

[illegible]

