



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Parameters of STPs of Delhi as on							14.05.2019		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Okhla	12 MGD	Inlet	7.3	220	180	432	3	43	1.2
		outlet	7.6	43	28	104	1	40	1.1
	Real Time Reading at Outlet								
	45 MGD	Inlet	7.3	260	195	464	-	40	1.8
		outlet	7.7	21	9.6	56	-	36	1
	Real Time Reading at Outlet								
	37 MGD	Inlet	7.3	260	195	464	-	40	1.8
		outlet	7.6	29	12.4	64	-	38	1.2
	Real Time Reading at Outlet								
	16 MGD	Inlet	7.3	260	195	464	-	40	1.8
		outlet	7.8	9	7.3	24	-	39	1.5
	Real Time Reading at Outlet								
Mehrauli	5 MGD	Inlet	7.3	186	145	264	3	35	2.5
		outlet	8	5	4.8	24	Nil	32	1.8
	Real Time Reading at Outlet								
Vasant Kunj	2.2 MGD	Inlet	7.1	324	180	432	4	38	2.8
		outlet	7.9	6	5	24	Nil	32	2.2
	Real Time Reading at Outlet								
	3 MGD	Inlet	7	544	270	576	7	37	2.8
		outlet	7.5	4	4.2	16	Nil	35	2.2
Real Time Reading at Outlet									
Kondli	25 MGD Phase-II	Inlet	7.2	340	188	304	18	39.67	6.7
		outlet	7.6	16	12	32	3	27.81	2.8
	Real Time Reading at Outlet		7.3	24	19	44		33.62	
	45 MGD Phase-IV	Inlet	7.2	364	209	352	25	40.93	6.9
		outlet	7.5	30	17	64	5	32.08	3.4
Real Time Reading at Outlet		6.7	26	16	39		32.12		
Chilla	9 MGD	Inlet	7.2	136	86	144	16	42.18	7.1
		outlet	7.7	9	6	22	2	0.24	4.4
	Real Time Reading at Outlet		7.8	10	4	25		7.45	
CWG Village	1 MGD	Inlet	7.1	536	380	544	22	22.68	4.9
		outlet	7.7	1	0.61	Bdl	Bdl	0.05	1.3
	Real Time Reading at Outlet		7.4	0.13	0.47	2		0.11	
Yamuna Vihar	10 MGD Phase-I	Inlet	7.2	364	236	768	-	40	4.5
		outlet	7.5	40	24	128	-	20	2
	Real Time Reading at Outlet								
	10 MGD Phase-II	Inlet	7.3	284	188	530	-	30	5
		outlet	7.5	23	15	160	-	15	1.5
	Real Time Reading at Outlet								
	25 MGD Phase-III	Inlet	7.2	268	267	723	-	55	5.5
outlet		7.5	28	21	112	-	35	2.5	
Real Time Reading at Outlet									

Rithala	40 MGD	Inlet	7.2	252	167	410	-	40	1
		outlet	7.8	36	25	100	-	24	0.8
	Real Time Reading at Outlet						-		
	40 MGD	Inlet	7.2	252	167	410	-	40	1
		Outlet	7.7	17	14	70	-	14	0.4
	Real Time Reading at Outlet								
Keshopur	12 MGD	Inlet	7.3	260	229	680	-	31	3.4
		outlet	7.7	12	7	34	-	16	2
	Real Time Reading at Outlet								
	40 MGD	Inlet	7.4	440	247	720	-	33	3.6
		outlet	7.6	108	99	276	-	28	2.6
	Real Time Reading at Outlet								
	20 MGD	Inlet	7.4	440	247	720	-	33	3.6
		outlet	7.5	150	141	412	-	36	3.2
Real Time Reading at Outlet									
Nilothi	40 MGD Phase-I	Inlet	7.3	182	153	480	-	26	3.5
		outlet	7.5	64	36	124	-	21	2.6
	Real Time Reading at Outlet								
	20 MGD Phase-II	Inlet	7.3	260	173	560	8.8	28	3
		outlet	7.3	8	8	32	Nil	8	2
	Real Time Reading at Outlet								
Najafgarh	5 MGD Phase-II	Inlet	7.3	314	150	-	-	30	3
		outlet	7.7	14	13	-	-	16	2
	Real Time Reading at Outlet								
Pappankalan	20 MGD Phase-II	Inlet	7.3	419	270	-	-	32	3.2
		outlet	7.7	19	16	-	-	24	1
	Real Time Reading at Outlet								
	20 MGD Phase-II	Inlet	7.3	419	270	-	-	32	3.2
		outlet	7.7	17	12	-	-	-	-
	Real Time Reading at Outlet								
Corronation pillar	20 MGD Phase-I &II	Inlet	7	280	275	386	8.5	40	2.5
		outlet	7.5	62	32	104	2.8	23	1.5
	Real Time Reading at Outlet								
	10 MGD Phase-III	Inlet	7	420	305	426	-	54	2.4
		outlet	7.4	82	37	112	-	39	1.4
	Real Time Reading at Outlet		7.3	51	35	126	-	18	
Narela	10 MGD Phase-III	Inlet	7.2	194	208	304	7.9	55	2.7
		outlet	7.5	102	40	96	3	37	1.6
	Real Time Reading at Outlet		6.8	66	32	102	-	118	-

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	14.05.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC limits	50	30	250
Okhla	12 MGD	43	28	104
	45 MGD	21	9.6	56
	37 MGD	29	12.4	64
	16 MGD	9	7.3	24
Mehrauli	5 MGD	5	4.8	24
Vasant Kunj	2.2 MGD	6	5	24
	3 MGD	4	4.2	16
Kondli	25 MGD	16	12	32
	45 MGD	30	17	64
Chilla	9 MGD	9	6	22
CWG Village	1 MGD	1	0.61	Bdl
Yamuna Vihar	10 MGD	40	24	128
	10 MGD	23	15	160
	25 MGD	28	21	112
Rithala	40 MGD	36	25	100
	40 MGD	17	14	70
Keshopur	12 MGD	12	7	34
	40 MGD	108	99	276
	20 MGD	150	141	412
Nilothi	40 MGD	64	36	124
	20 MGD	8	8	32
Najafgarh	5 MGD	14	13	-
Pappankalan	20 MGD	19	16	-
	20 MGD	17	12	-
Corronation pillar	20 MGD	62	32	104
	10 MGD	82	37	112
Narela	10 MGD	102	40	96



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Parameters of STPs of Delhi as on							15.05.2019		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Okhla	12 MGD	Inlet	7.2	280	188	400	3	44	2
		outlet	7.6	27	18	72	2	40	1.8
	Real Time Reading at Outlet								
	45 MGD	Inlet	7.3	324	200	432	4	42	2.8
		outlet	7.7	14	9	40	1	34	2.2
	Real Time Reading at Outlet								
	37 MGD	Inlet	7.3	324	200	432	4	42	2.8
		outlet	7.6	17	11	48	1	36	2.8
	Real Time Reading at Outlet								
	16 MGD	Inlet	7.3	324	200	432	4	42	2.8
		outlet	7.8	8	6	32	Nil	5	2.2
	Real Time Reading at Outlet								
Kondli	25 MGD Phase-II	Inlet	7.4	368	208	357	-	38	6.6
		outlet	7.7	17	11	35	-	30	2.7
	Real Time Reading at Outlet		7.3	24	31	47		35	
	45 MGD Phase-IV	Inlet	7.3	346	186	306	-	40	6.7
		outlet	7.6	30	16	61	-	31	3.1
	Real Time Reading at Outlet		6.7	27	16	41		26	
Chilla	9 MGD	Inlet	7.3	144	99	176	-	39	6.5
		outlet	7.7	10	5	26	-	0.24	4.5
	Real Time Reading at Outlet		7.6	9	4	25		7	
CWG Village	1 MGD	Inlet	7.4	752	523	568	-	20	4.4
		outlet	7.8	1	0.54	0.8	-	0.02	1
	Real Time Reading at Outlet		7.4	0.95	1.22	4		0.24	
Yamuna Vihar	10 MGD Phase-I	Inlet	7.1	428	251	1036	-	35	5
		outlet	7.6	52	29	158	-	10	2
	Real Time Reading at Outlet								
	10 MGD Phase-II	Inlet	7.2	308	181	670	-	30	3
		outlet	7.6	55	31	168	-	10	1
	Real Time Reading at Outlet								
	25 MGD Phase-III	Inlet	7.2	496	295	1108	-	40	3.5
outlet		7.6	35	21	146	-	15	1.5	
Real Time Reading at Outlet									
Rithala	40 MGD	Inlet	7	240	157	380	-	42	1.3
		outlet	7.6	37	24	90	-	26	0.9
	Real Time Reading at Outlet								
	40 MGD	Inlet	7	240	157	380	-	42	1.3

	40 MGD		Outlet	7.5	19	13	50	-	16	0.5
	Real Time Reading at Outlet									
Keshopur	12 MGD	Inlet	7.3	380	227	-	17	30	3.4	
		outlet	7.6	12	6	-	-	12	1.8	
	Real Time Reading at Outlet									
	40 MGD	Inlet	7.3	464	261	-	16	32	3.3	
		outlet	7.5	142	106	-	2.4	28	2.9	
	Real Time Reading at Outlet									
	20 MGD	Inlet	7.3	464	261	-	16	32	3.3	
		outlet	7.5	334	154	-	6.8	29	3.1	
Real Time Reading at Outlet										
Nilothi	40 MGD Phase-I	Inlet	7.2	296	156		4.6	25	3	
		outlet	7.5	56	36		0.9	20	2	
	Real Time Reading at Outlet									
Najafgarh	5 MGD Phase-II	Inlet	7.3	209	120	-	-	28	3	
		outlet	7.7	29	15	-	-	14	2	
	Real Time Reading at Outlet									
Pappankalan	20 MGD Phase-II	Inlet	7.3	344	230	-	-	34	3.2	
		outlet	7.6	25	19	-	-	20	0.8	
	Real Time Reading at Outlet									
	20 MGD Phase-II	Inlet	7.3	344	230	-	-	34	3.2	
		outlet	7.7	23	16	-	-	28	1.4	
	Real Time Reading at Outlet									
Corronation pillar	20 MGD Phase-I & II	Inlet	6.8	330	285	285	-	44	2.3	
		outlet	7.2	112	52	138	-	25	1.4	
	Real Time Reading at Outlet									
	10 MGD Phase-III	Inlet	7	408	315	516	8.4	58	2.5	
		outlet	7.4	116	45	128	3.5	41	1.5	
	Real Time Reading at Outlet			7.1	55	33	137		20	

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	15.05.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC limits	50	30	250
Okhla	12 MGD	27	18	72
	45 MGD	14	9	40
	37 MGD	17	11	48
	16 MGD	8	6	32
Kondli	25 MGD	17	11	35
	45 MGD	30	16	61
Chilla	9 MGD	10	5	26
CWG Village	1 MGD	1	0.54	0.8
Yamuna Vihar	10 MGD	52	29	158
	10 MGD	55	31	168
	25 MGD	35	21	146
Rithala	40 MGD	37	24	90
	40 MGD	19	13	50
Keshopur	12 MGD	12	6	-
	40 MGD	142	106	-
	20 MGD	334	154	-
Nilothi	40 MGD	56	36	-
Najafgarh	5 MGD	29	15	-
Pappankalan	20 MGD	25	19	-
	20 MGD	23	16	-
Corronation pillar	20 MGD	112	52	138
	10 MGD	116	45	128



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Parameters of STPs of Delhi as on							16.05.2019		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Okhla	12 MGD	Inlet	7.3	232	190	400	3	38	2
		outlet	7.6	33	22	88	2	35	1
	Real Time Reading at Outlet								
	45 MGD	Inlet	7.3	230	170	384	3	38	2.2
		outlet	7.6	27	18	72	Nil	35	1.5
	Real Time Reading at Outlet								
	37 MGD	Inlet	7.3	230	170	384	3	38	2.2
		outlet	7.6	26	18	72	Nil	34	0.8
	Real Time Reading at Outlet								
	16 MGD	Inlet	7.3	230	170	384	3	38	2.2
		outlet	7.6	22	15	56	Nil	32	0.5
	Real Time Reading at Outlet								
Kondli	25 MGD Phase-II	Inlet	7.3	322	178	302	16	41	7.2
		outlet	7.7	19	12	43	3	33	3.3
	Real Time Reading at Outlet		7.3	25	50	53		35	
	45 MGD Phase-IV	Inlet	7.2	276	162	264	24	41	7.3
		outlet	7.6	30	18	74	5	35	3.8
	Real Time Reading at Outlet		7	27	15	40		8	
Yamuna Vihar	10 MGD Phase-I	Inlet	7.1	256	191	52	-	35	4
		outlet	7.6	31	21	80	-	25	2
	Real Time Reading at Outlet								
	10 MGD Phase-II	Inlet	7.3	452	270	680	-	35	3.5
		outlet	7.6	27	14	88	-	20	1.5
	Real Time Reading at Outlet								
	25 MGD Phase-III	Inlet	7.3	392	246	596	-	40	5.5
		outlet	7.6	38	21	112	-	35	3
Real Time Reading at Outlet									
Rithala	40 MGD	Inlet	7	308	164	360	-	28	0.9
		outlet	7.6	48	26	110	-	17	0.6
	Real Time Reading at Outlet								
	40 MGD	Inlet	7	308	164	360	-	28	0.9
		Outlet	7.3	17	11	60	-	13	0.4
Real Time Reading at Outlet									
	12 MGD	Inlet	7.4	272	193	400	-	32	3.3
		outlet	7.7	15	8	36	-	14	2
	Real Time Reading at Outlet								
	40 MGD	Inlet	7.3	700	296	800	-	34	3.6

Keshopur	40 MGD	outlet	7.5	136	97	240	-	29	3
		Real Time Reading at Outlet							
	20 MGD	Inlet	7.3	700	296	800	-	34	3.6
		outlet	7.5	282	133	280	-	31	3
	Real Time Reading at Outlet								
Nilothe	40 MGD Phase-I	Inlet	7.3	198	152	-	-	28	2.8
		outlet	7.5	48	34	-	-	24	2
	Real Time Reading at Outlet								
Pappankalan	20 MGD Phase-II	Inlet	7.3	338	218	-	-	42	3.2
		outlet	7.6	26	17	-	-		1
	Real Time Reading at Outlet								
	20 MGD Phase-II	Inlet	7.3	338	218	-	-	42	3.2
		outlet	7.5	12	9	-	-	32	1.9
	Real Time Reading at Outlet								
Corronation pillar	20 MGD Phase-I & II	Inlet	6.8	264	245	392	7.8	40	2.2
		outlet	7.3	74	35	128	3.2	22	1.2
	Real Time Reading at Outlet								
	10 MGD Phase-III	Inlet	6.9	396	310	426	-	56	3.2
		outlet	7.3	94	39	122	-	37	2
	Real Time Reading at Outlet		7.2	56	33	140		20	
Narela	10 MGD Phase-III	Inlet	6.7	165	175	262	8	60	3.4
		outlet	7.1	54	33	96	3.4	42	2.1
	Real Time Reading at Outlet		6.8	89	30	30		87	

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	16.05.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC limits	50	30	250
Okhla	12 MGD	33	22	88
	45 MGD	27	18	72
	37 MGD	26	18	72
	16 MGD	22	15	56
Kondli	25 MGD	19	12	43
	45 MGD	30	18	74
Yamuna Vihar	10 MGD	31	21	80
	10 MGD	27	14	88
	25 MGD	38	21	112
Rithala	40 MGD	48	26	110
	40 MGD	17	11	60
Keshopur	12 MGD	15	8	36
	40 MGD	136	97	240
	20 MGD	282	133	280
Nilothi	40 MGD	48	34	-
Pappankalan	20 MGD	26	17	-
	20 MGD	12	9	-
Corronation pillar	20 MGD	74	35	128
	10 MGD	94	39	122
Narela	10 MGD	54	33	96



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Parameters of STPs of Delhi as on							17.05.2019		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Okhla	12 MGD	Inlet	7.3	208	163	352	3	38	1.8
		outlet	7.6	32	23	88	2	36	1.3
	Real Time Reading at Outlet								
	45 MGD	Inlet	7.3	214	183	400	3	39	1.7
		outlet	7.6	24	15	56	Nil	35	0.8
	Real Time Reading at Outlet								
	37 MGD	Inlet	7.3	214	183	400	3	39	1.7
		outlet	7.7	36	22	88	Nil	34	0.6
	Real Time Reading at Outlet								
	16 MGD	Inlet	7.3	214	183	400	3	39	1.7
		outlet	7.7	12	9	40	Nil	33	0.4
	Real Time Reading at Outlet								
	New 30 MGD	Inlet	7.4	314	180	400	4	40	2.4
		Outlet	7.8	10	6	24	Nil	2	Nil
	Real Time Reading at Outlet								
Molarbund	0.66 MGD	Inlet	7.3	552	430	1040	4	38	1.6
		outlet	7.7	18	10	40	2	8	0.6
	Real Time Reading at Outlet								
Delhi Gate-I	2.2 MGD	Inlet	7.5	202	173	416	2	25	1.6
		outlet	7.9	4	4	16	Nil	5	0.8
	Real Time Reading at Outlet								
Delhi Gate-II	15 MGD	Inlet	7.5	238	193	456	1.2	26	1.2
		outlet	7.8	5	5	16	Nil	4	0.5
	Real Time Reading at Outlet								
Sen Nursing Home	2.2 MGD	Inlet	7.4	260	212	472	0	27	1.4
		outlet	7.8	8	6	24	Nil	3	0.4
	Real Time Reading at Outlet								
Kondli	25 MGD Phase-II	Inlet	7.2	220	185	248	-	39	6.7
		outlet	7.6	15	12	34	-	29	3.1
	Real Time Reading at Outlet		7.3	20	10	42		34	
	45 MGD Phase-IV	Inlet	7.2	238	176	272	-	40	7
		outlet	7.5	29	18	64	-	32	3.9
Real Time Reading at Outlet		7.1	27	16	41		23		

Chilla	9 MGD	Inlet	7.2	164	96	173	18	43	7.2
		outlet	7.7	7	3.5	16	3	0.35	4.7
	Real Time Reading at Outlet		7.6	15	4.74	28		6	
CWG Village	1 MGD	Inlet	7.1	504	290	536	24	27	4.1
		outlet	7.7	Bdl	Bdl	Bdl	Bdl	0.05	1
	Real Time Reading at Outlet								
Yamuna Vihar	10 MGD Phase-I	Inlet	7.2	400	240	840	16	30	4
		outlet	7.6	42	30	124	8	10	1.5
	Real Time Reading at Outlet								
	10 MGD Phase-II	Inlet	7.2	396	228	780	17.6	25	3
		outlet	7.5	28	18	88	8.4	10	1
	Real Time Reading at Outlet								
	25 MGD Phase-III	Inlet	7.2	412	248	580	15.2	40	4.5
		outlet	7.5	29	20	120	5.2	20	2
	Real Time Reading at Outlet								
Rithala	40 MGD	Inlet	7.1	264	153	370	-	29	0.8
		outlet	7.8	43	29	110	-	27	0.8
	Real Time Reading at Outlet								
	40 MGD	Inlet	7.1	264	153	370	-	29	0.8
		Outlet	7.9	19	13	60	-	12	0.4
	Real Time Reading at Outlet								
Keshopur	12 MGD	Inlet	7.4	408	224	-	18.6	33	3.2
		outlet	7.6	14	6	-	0	15	1.9
	Real Time Reading at Outlet								
	40 MGD	Inlet	7.3	388	200	-	14.2	34	3.5
		outlet	7.6	124	82	-	2.1	30	3.2
	Real Time Reading at Outlet								
	20 MGD	Inlet	7.3	388	200	-	14.2	34	3.5
		outlet	7.5	196	109	-	5.8	31	3
	Real Time Reading at Outlet								
Nilothi	40 MGD Phase-I	Inlet	7.3	150	140	460	5.2	26	2.5
		outlet	7.5	40	30	108	0.8	0.8	2
	Real Time Reading at Outlet								
Najafgarh	5 MGD Phase-II	Inlet	7.3	878	295	-	-	28	3
		outlet	7.7	14	11	-	-	11	2
	Real Time Reading at Outlet								
Pappankalan	20 MGD Phase-II	Inlet	7.3	364	243	800	-	38	3.2
		outlet	7.8	32	22	72	-	18	1
	Real Time Reading at Outlet								
	20 MGD Phase-II	Inlet	7.3	308	183	820	-	38	3.4
		outlet	7.7	14	10	60	-	28	1.9
	Real Time Reading at Outlet								

Corronation pillar	20 MGD Phase-I &II	Inlet	6.6	288	255	304	-	38	2.4
		outlet	7.2	48	29	98	-	20	1.4
	Real Time Reading at Outlet		7.4	48	28	28		26	
	10 MGD Phase-III	Inlet	6.9	450	350	502	7.7	54	2.6
		outlet	7.3	102	54	148	3.3	40	1.6
	Real Time Reading at Outlet		7	58	33	145	-	2	

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	17.05.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC limits	50	30	250
Okhla	12 MGD	32	23	88
	45 MGD	24	15	56
	37 MGD	36	22	88
	16 MGD	12	9	40
	New 30 MGD	10	6	24
Molarbund	0.66 MGD	18	10	40
Delhi Gate-I	2.2 MGD	4	4	16
Delhi Gate-II	15 MGD	5	5	16
Sen Nursing Home	2.2 MGD	8	6	24
Kondli	25 MGD	15	12	34
	45 MGD	29	18	64
Chilla	9 MGD	7	3.5	16
CWG Village	1 MGD	Bdl	Bdl	Bdl
Yamuna Vihar	10 MGD	42	30	124
	10 MGD	28	18	88
	25 MGD	29	20	120
Rithala	40 MGD	43	29	110
	40 MGD	19	13	60
Keshopur	12 MGD	14	6	-
	40 MGD	124	82	-
	20 MGD	196	109	-
Nilothi	40 MGD	40	30	108
Najafgarh	5 MGD	14	11	-
Pappankalan	20 MGD	32	22	72
	20 MGD	14	10	60
Corronation pillar	20 MGD	48	29	98
	10 MGD	102	54	148