

OFFICE OF THE DIRECTOR (T&QC)									
DELHI JAL BOARD: GOVT. OF NCT OF DELHI									
WATER WORKS WAZIRABAD:DELHI-110054									
Parameters of STPs of Delhi as on							17.02.2020		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Yamuna Vihar	10 MGD Phase-I	Inlet	7.2	312	206		17.2	55	5
		outlet	7.8	61	31		8.4	35	2.5
	Real Time Reading at Outlet		7	30	16	58		21	
	10 MGD Phase-II	Inlet	7.4	432	233		13.6	40	3.5
		outlet	8	31	21		8.8	20	2.5
	Real Time Reading at Outlet								
	25 MGD Phase-III	Inlet	7.5	748	385		21.2	50	4
		outlet	7.9	44	30		9.6	30	2
Real Time Reading at Outlet		7.6	25	20	82		15		
Rithala	40 MGD	Inlet	7.2	256	169	330	nd	24	1.4
		outlet	7.8	43	25	90	nd	20	1.1
	Real Time Reading at Outlet		nd	nd	nd	nd		nd	
	40 MGD	Inlet	7.2	256	169	330	nd	24	1.4
		Outlet	7.7	16	11	50	nd	19	1
	Real Time Reading at Outlet		7.88	18.23	14	57.77		6.61	
Corronation Pillar	20 MGD Phase-I & II	Inlet	7	338	233	464	36	12.8	6.8
		outlet	7.6	68	66	116	20	8.8	3.6
	Real Time Reading at Outlet		7.9	308	102	293	15		
	10 MGD Phase-III	Inlet	7.2	474	318	602	50	11.8	8.6
		outlet	7.5	132	110	176	28	8.2	3.5
	Real Time Reading at Outlet		6.9	116	51	66	5		
Rohini	15 MGD	Inlet	7.1	256	158			53	5
		Outlet	7.5	35	21			13	2.5
	Real Time Reading at Outlet								
Keshopur	12 MGD	Inlet	7.3	492	227	729	-	33	3.1
	(PH-I)	Outlet	7.6	30	14	38	-	3	3.5
	Real time reading at OUTLET(online)		7.17	2	2.09	20.05	-	1.02	-
	20 MGD	Inlet	7.3	460	235	693	-	32	3.4
	(PH-II)	Outlet	7.5	70	93	298	-	31	3
	Real Time Reading at Outlet								
	40 MGD	Inlet	7.3	460	235	693	-	32	3.4
	(PH-III)	Outlet	7.5	128	117	364	-	29	3.2
	Real Time Reading at Outlet								
Nilothi	40 MGD	Inlet	7.2	350	154	-	-	30	-
	(PH-I)	Outlet	7.5	58	34	-	-	12	-
	Real Time Reading at Outlet		7.75	37.26	17.27	117.48	-	21.18	-
	20 MGD	Inlet	7.2	290	168	-	-	35	3

	(PH-II)	Outlet	7.4	8	7	-	-	8	1.5
	Real Time Reading at Outlet								
Pappankalan	(20 MGD)	Inlet	7.3	443	226	-	-	40	6
	PH-I	Outlet	7.5	73	48	-	-	22	1
	Real Time Reading at Outlet		7.61	93	61.63	171.06	-	5.35	-
	(20 MGD)	Inlet	7.4	418	245	620	-	42	6.4
	PH-II	Outlet	7.7	6	5	30	-	13	1.2
	Real Time Reading at Outlet		7.88	17.32	10.21	33.67	-	5.54	-
Najafgarh	(05 MGD)	Inlet	7.4	1010	252	-	-	42	5.7
		Outlet	7.6	56	32	-	-	6	0.9
	Real Time Reading at Outlet		7.3	39.77	22.52	78.81	-	6.38	-
Okhla	45 MGD	Inlet	7.5	254	197	424	-	39	1.8
		outlet	7.6	43	29	112	-	35	1
	Real Time Reading at Outlet								
	37 MGD	Inlet	7.5	254	197	424	-	39	1.8
		outlet	7.4	41	26	104	-	32	0.9
	Real Time Reading at Outlet								
	16 MGD	Inlet	7.5	254	197	424	-	39	1.8
		outlet	7.7	37	25	96	-	30	0.5
	Real Time Reading at Outlet								
	New 30 MGD	Inlet	7.5	326	285	472	5	44	1.5
		Outlet	7.4	9	5	24	1	4	1
	Real Time Reading at Outlet								

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Name of the Plant	Capacity (in MGD)	17.02.2020		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC Limit	50	30	250
Yamuna Vihar	10 MGD Phase-I	61	31	-
	10 MGD Phase-II	31	21	-
	25 MGD Phase-III	44	30	-
Rithala	40 MGD	43	25	90
	40 MGD	16	11	50
Corronation pillar	20 MGD Phase-I &II	68	66	116
	10 MGD Phase-III	132	110	176
Rohini	15 MGD	35	21	-
Keshopur	12 MGD	30	14	38
	20 MGD	70	93	298
	40 MGD	128	117	364
Nilothe	40 MGD	58	34	-
	20 MGD	8	7	-
Pappankalan	(20 MGD)	73	48	-
	(20 MGD)	6	5	30
Najafgarh	05 MGD	56	32	-
Okhla	45 MGD	43	29	112
	37 MGD	41	26	104
	16 MGD	37	25	96
	New 30 MGD	9	5	24

OFFICE OF THE DIRECTOR (T&QC)									
DELHI JAL BOARD: GOVT. OF NCT OF DELHI									
WATER WORKS WAZIRABAD:DELHI-110054									
Parameters of STPs of Delhi as on							18.02.2020		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Yamuna Vihar	10 MGD Phase-I	Inlet	7.2	364	183	672		50	4
		outlet	7.5	40	27	120		30	2
	Real Time Reading at Outlet		7.1	35	16	65		20	
	10 MGD Phase-II	Inlet	7.2	360	240	664		40	3.5
		outlet	7.4	31	22	88		20	1.5
	Real Time Reading at Outlet								
	25 MGD Phase-III	Inlet	7.2	516	302	968		45	3.5
		outlet	7.5	38	22	120		25	1.5
Real Time Reading at Outlet		7.9	36	24	76		10		
Rithala	40 MGD	Inlet	7.1	244	165	350	nd	32	1.7
		outlet	7.6	40	22	100	nd	19	0.9
	Real Time Reading at Outlet		nd	nd	nd	nd		nd	
	40 MGD	Inlet	7.1	244	165	350	nd	32	1.7
		Outlet	7.7	17	12	60	nd	15	0.6
Real Time Reading at Outlet		7.96	17.99	14.09	57.91		6.67		
Corronation Pillar	20 MGD Phase-I &II	Inlet	7	338	233	464	36	12.8	6.8
		outlet	7.6	68	66	116	20	8.8	3.6
	Real Time Reading at Outlet		7.9	308	102	293	15		
	10 MGD Phase-III	Inlet	7.2	474	318	602	50	11.8	8.6
		outlet	7.5	132	110	176	28	8.2	3.5
Real Time Reading at Outlet		6.9	116	51	66	5			
Rohini	15 MGD	Inlet	7.1	268	155	672		48	9
		Outlet	7.4	32	20	112		16	3.5
	Real Time Reading at Outlet								
Keshopur	12 MGD	Inlet	7.2	1116	329	-	-	32	3.3
	(PH-I)	Outlet	7.5	57	27	-	-	3	3.7
	Real time reading at OUTLET(online)		7.15	5.01	6.78	23	-	1.08	-
	20 MGD	Inlet	7.3	400	192	-	-	34	3.5
	(PH-II)	Outlet	7.5	84	81	-	-	30	3.2
	Real Time Reading at Outlet								
	40 MGD	Inlet	7.3	400	192	-	-	34	3.5
	(PH-III)	Outlet	7.5	118	111	-	-	30	3.1
Real Time Reading at Outlet									
Nilothi	40 MGD	Inlet	7.1	328	158	580	-	32	3.2
	(PH-I)	Outlet	7.4	54	38	138	-	14	2.5
	Real Time Reading at Outlet		7.75	30.98	20.51	117.82	-	20.71	-
	20 MGD	Inlet	7.2	228	161	570	-	30	3.2

	(PH-II)	Outlet	7.3	7	5	32	-	10	1.8
	Real Time Reading at Outlet								
Pappankalan	(20 MGD)	Inlet	7.2	479	230	-	-	39	6.4
	PH-I	Outlet	7.5	73	46	-	-	23	1.2
	Real Time Reading at Outlet		7.64	80.48	55.11	156.89	-	4.25	-
	(20 MGD)	Inlet	7.4	428	238	-	18.6	42	6.3
	PH-II	Outlet	7.7	7	6	-	0	13	1.4
	Real Time Reading at Outlet		7.88	16.34	12.5	35.06	-	5.67	-
Okhla	45 MGD	Inlet	7.6	226	208	440	4	38	2.2
		outlet	7.8	45	29	112	1	35	1.5
	Real Time Reading at Outlet								
	37 MGD	Inlet	7.6	226	208	440	4	38	2.2
		outlet	7.7	48	24	112	1	32	1
	Real Time Reading at Outlet								
	16 MGD	Inlet	7.6	226	208	440	4	38	2.2
		outlet	7.8	47	29	120	1	35	1.5
	Real Time Reading at Outlet								

OFFICE OF THE DIRECTOR (T&QC)				
DELHI JAL BOARD: GOVT. OF NCT OF DELHI				
WATER WORKS WAZIRABAD:DELHI-110054				
Name of the Plant	Capacity (in MGD)	18.02.2020		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC Limit	50	30	250
Yamuna Vihar	10 MGD Phase-I	40	27	120
	10 MGD Phase-II	31	22	88
	25 MGD Phase-III	38	22	120
Rithala	40 MGD	40	22	100
	40 MGD	17	12	60
Corronation pillar	20 MGD Phase-I &II	68	66	116
	10 MGD Phase-III	132	110	176
Rohini	15 MGD	32	20	112
Keshopur	12 MGD	57	27	-
	20 MGD	84	81	-
	40 MGD	118	111	-
Nilothi	40 MGD	54	38	138
	20 MGD	7	5	32
Pappankalan	(20 MGD)	73	46	-
	(20 MGD)	7	6	-
Okhla	45 MGD	45	29	112
	37 MGD	48	24	112
	16 MGD	47	29	120

OFFICE OF THE DIRECTOR (T&QC)									
DELHI JAL BOARD: GOVT. OF NCT OF DELHI									
WATER WORKS WAZIRABAD:DELHI-110054									
Parameters of STPs of Delhi as on							19.02.2020		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Yamuna Vihar	10 MGD Phase-I	Inlet	7.1	320	206			50	4
		outlet	7.4	23	16			30	2.5
	Real Time Reading at Outlet								
	10 MGD Phase-II	Inlet	7	280	212			45	3.5
		outlet	7.5	22	15			20	1
	Real Time Reading at Outlet								
	25 MGD Phase-III	Inlet	7.3	460	244			55	3
		outlet	7.3	41	27			25	1.5
Real Time Reading at Outlet		7.9	24	24	69		10		
Rithala	40 MGD	Inlet	7	252	173	390	nd	34	1.5
		outlet	7.5	46	24	110	nd	18	1.2
	Real Time Reading at Outlet		nd	nd	nd	nd		nd	
	40 MGD	Inlet	7	252	173	390	nd	34	1.5
		Outlet	7.6	16	12	60	nd	13	0.6
Real Time Reading at Outlet		7.97	17.49	14.35	58.58		6.68		
Corronation Pillar	20 MGD Phase-I & II	Inlet	7	304	220	498	32	8.2	
		outlet	7.4	94	73	138	18	5	
	Real Time Reading at Outlet		79	388	118	321	15		
	10 MGD Phase-III	Inlet	7.1	544	328	638	43	6.4	
		outlet	7.5	184	128	202	25	3.8	
Real Time Reading at Outlet		7.4	120	20	98	7			
Rohini	15 MGD	Inlet	7.3	236	153			55	12.5
		Outlet	7.6	30	19			17	5
	Real Time Reading at Outlet								
Keshopur	12 MGD	Inlet	7.3	340	196	-	12.7	29	3.3
	(PH-I)	Outlet	7.5	14	5	-	0.8	3	3.6
	Real time reading at OUTLET(online)		7.32	5.89	9.08	22.88	-	0.63	-
	20 MGD	Inlet	7.3	628	251	-	9.9	32	3.4
	(PH-II)	Outlet	7.5	122	112	-	3.3	28	3.1
	Real Time Reading at Outlet								
	40 MGD	Inlet	7.3	628	251	-	9.9	32	3.4
	(PH-III)	Outlet	7.5	136	119	-	3.8	29	3
Real Time Reading at Outlet									
Nilothi	40 MGD	Inlet	7.1	354	155	-	6.2	30	-
	(PH-I)	Outlet	7.4	56	34	-	1.4	12	-
	Real Time Reading at Outlet		7.78	31.68	22.19	118.68	-	20.73	-
	(20 MGD)	Inlet	7.2	500	250	-	-	38	6.3

Pappankalan	PH-I	Outlet	7.7	54	32	-	-	25	1.1
	Real Time Reading at Outlet		7.62	80.81	54.72	157.17	-	4.3	-
	(20 MGD)	Inlet	7.3	481	225	-	-	40	6.2
	PH-II	Outlet	7.5	7	6	-	-	12	1.6
	Real Time Reading at Outlet		8.07	17.61	13.34	36.59	-	5.51	-
Najafgarh	(05 MGD)	Inlet	7.5	344	205	-	-	25	5.6
		Outlet	7.5	74	35	-	-	10	1
	Real Time Reading at Outlet		7.4	166.5	36.22	127.94	-	6.65	-
Okhla	45 MGD	Inlet	7.3	250	185	424	-	40	1.5
		outlet	7.4	40	26	104	-	36	1
	Real Time Reading at Outlet								
	37 MGD	Inlet	7.3	250	185	424	-	40	1.5
		outlet	7.5	43	28	112	-	32	0.9
	Real Time Reading at Outlet								
	16 MGD	Inlet	7.3	250	185	424	-	40	1.5
		outlet	7.5	48	29	120	-	29	1.2
	Real Time Reading at Outlet								

OFFICE OF THE DIRECTOR (T&QC)				
DELHI JAL BOARD: GOVT. OF NCT OF DELHI				
WATER WORKS WAZIRABAD:DELHI-110054				
Name of the Plant	Capacity (in MGD)	19.02.2020		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC Limit	50	30	250
Yamuna Vihar	10 MGD Phase-I	23	16	-
	10 MGD Phase-II	22	15	-
	25 MGD Phase-III	41	27	-
Rithala	40 MGD	46	24	110
	40 MGD	16	12	60
Corronation pillar	20 MGD Phase-I &II	94	73	138
	10 MGD Phase-III	184	128	202
Rohini	15 MGD	30	19	-
Keshopur	12 MGD	14	5	-
	20 MGD	122	112	-
	40 MGD	136	119	-
Nilothi	40 MGD	56	34	-
Pappankalan	(20 MGD)	54	32	-
	(20 MGD)	7	6	-
Najafgarh	05 MGD	74	35	-
Okhla	45 MGD	40	26	104
	37 MGD	43	28	112
	16 MGD	48	29	120

OFFICE OF THE DIRECTOR (T&QC)									
DELHI JAL BOARD: GOVT. OF NCT OF DELHI									
WATER WORKS WAZIRABAD:DELHI-110054									
Parameters of STPs of Delhi as on							20.02.2020		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Yamuna Vihar	10 MGD Phase-I	Inlet	7.2	384	196			55	4
		outlet	7.5	20	19			25	2
		Real Time Reading at Outlet		6.9	58	41	100		10
	10 MGD Phase-II	Inlet	7.2	544	244			35	2.5
		outlet	7.5	60	39			25	1.5
		Real Time Reading at Outlet							
	25 MGD Phase-III	Inlet	7.2	448	257			40	3.5
		outlet	7.5	31	22			15	2
Real Time Reading at Outlet		7.9	26	22	64		10		
Rithala	40 MGD	Inlet	7	272	166	410	nd	29	1.1
		outlet	7.9	43	27	100	nd	20	1
	Real Time Reading at Outlet		nd	nd	nd	nd		nd	
	40 MGD	Inlet	7	272	166	410	nd	29	1.1
		Outlet	7.8	18	13	70	nd	15	0.7
Real Time Reading at Outlet		8.06	17.52	13.82	57.11		6.75		
Corronation Pillar	20 MGD Phase-I & II	Inlet	7.2	300	228	482	35	10	6.2
		outlet	7.6	98	74	142	22	5.9	3
	Real Time Reading at Outlet		7.8	445	129	381	15		
	10 MGD Phase-III	Inlet	7	400	315	602	39	11.8	
		outlet	7.6	178	133	224	28	8	
Real Time Reading at Outlet		7.6	128	49	135	8			
Rohini	15 MGD	Inlet	7.1	264	163	496		52	7
		Outlet	7.5	29	18	112		16	3.5
	Real Time Reading at Outlet								
Keshopur	12 MGD (PH-I)	Inlet	7.5	424	167	-	-	34	3.2
		Outlet	7.8	12	9	-	-	1	3.4
	Real time reading at OUTLET(online)		7.04	4.63	4.5	27.04	-	0.95	-
	20 MGD (PH-II)	Inlet	7.5	820	213	-	-	32	3.4
		Outlet	7.7	92	87	-	-	28	3
	Real Time Reading at Outlet								
	40 MGD (PH-III)	Inlet	7.5	820	213	-	-	32	3.4
		Outlet	7.7	132	113	-	-	30	3.1
Real Time Reading at Outlet									
Nilothi	40 MGD (PH-I)	Inlet	7.1	328	176	-	-	30	-
		Outlet	7.5	46	33	-	-	15	-
	Real Time Reading at Outlet		7.79	32.34	21.4	118.41	-	21.68	-
	20 MGD	Inlet	7.2	346	168	-	8	35	3.2

	(PH-II)	Outlet	7.4	9	8	-	0	10	1.5
	Real Time Reading at Outlet								
Pappankalan	(20 MGD)	Inlet	7.3	820	245	-	16.4	40	6.7
	PH-I	Outlet	7.7	64	34	-	2.2	30	1.3
	Real Time Reading at Outlet		7.66	81.52	54.82	157.39	-	4.35	-
	(20 MGD)	Inlet	7.3	386	223	-	14	38	6.5
	PH-II	Outlet	7.6	8	5	-	0	15	2
	Real Time Reading at Outlet		7.96	18.43	14.33	37.75	-	5.55	-
Najafgarh	(05 MGD)	Inlet	7.3	319	204	-	-	32	4.8
		Outlet	7.5	38	22	-	-	12	1.2
	Real Time Reading at Outlet		7.43	27.65	19.36	72.41	-	6.56	-
Okhla	45 MGD	Inlet	7.3	206	178	440	4	41	1.8
		outlet	7.7	39	25	96	1	35	1
	Real Time Reading at Outlet								
	37 MGD	Inlet	7.3	206	178	440	4	41	1.8
		outlet	7.6	45	28	112	1	32	0.7
	Real Time Reading at Outlet								
	16 MGD	Inlet	7.3	206	178	440	4	41	1.8
		outlet	7.7	43	27	104	NIL	30	0.5
	Real Time Reading at Outlet								

OFFICE OF THE DIRECTOR (T&QC)				
DELHI JAL BOARD: GOVT. OF NCT OF DELHI				
WATER WORKS WAZIRABAD:DELHI-110054				
Name of the Plant	Capacity (in MGD)	20.02.2020		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC Limit	50	30	250
Yamuna Vihar	10 MGD Phase-I	20	19	-
	10 MGD Phase-II	60	39	-
	25 MGD Phase-III	31	22	-
Rithala	40 MGD	43	27	100
	40 MGD	18	13	70
Corronation pillar	20 MGD Phase-I &II	98	74	142
	10 MGD Phase-III	178	133	224
Rohini	15 MGD	29	18	112
Keshopur	12 MGD	12	9	-
	20 MGD	92	87	-
	40 MGD	132	113	-
Nilothi	40 MGD	46	33	-
	20 MGD	9	8	-
Pappankalan	(20 MGD)	64	34	-
	(20 MGD)	8	5	-
Najafgarh	05 MGD	38	22	-
Okhla	45 MGD	39	25	96
	37 MGD	45	28	112
	16 MGD	43	27	104

OFFICE OF THE DIRECTOR (T&QC)									
DELHI JAL BOARD: GOVT. OF NCT OF DELHI									
WATER WORKS WAZIRABAD:DELHI-110054									
Parameters of STPs of Delhi as on							21.02.2020		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Yamuna Vihar	10 MGD Phase-I	Inlet	7.2	476	219			50	5.0
		outlet	7.4	34	22			30	4.0
	Real Time Reading at Outlet								
	10 MGD Phase-II	Inlet	7.0	332	198			35	4.0
		outlet	7.5	15	14			20	3.0
	Real Time Reading at Outlet								
	25 MGD Phase-III	Inlet	7.2	672	390			55	4.5
		outlet	7.5	22	18			30	2.5
Real Time Reading at Outlet		8.0	29	20	60		10		
Rithala	40 MGD	Inlet	7.1	284	162	430	nd	38	1.4
		outlet	7.6	55	28	120	nd	21	1.3
	Real Time Reading at Outlet		nd	nd	nd	nd		nd	
	40 MGD	Inlet	7.1	284	162	430	nd	38	1.4
		Outlet	7.5	17	13	60	nd	17	1.1
Real Time Reading at Outlet									
Corronation Pillar	20 MGD Phase-I & II	Inlet	7.2	356	235	474	22	7.6	5.8
		outlet	7.5	88	69	118	17	3.4	3.2
	Real Time Reading at Outlet								
	10 MGD Phase-III	Inlet	7	400	315	602	39	11.8	
		outlet	7.6	178	133	224	28	8	
Real Time Reading at Outlet									
Narela	10 MGD Phase-III	Inlet	7.3	260	223	364	38	10.4	9.8
		outlet	7.6	26	21	94	25	4.3	3
	Real Time Reading at Outlet								
Rohini	15 MGD	Inlet	7.2	296	208			45	6.5
		Outlet	7.5	36	22			14	4.5
	Real Time Reading at Outlet								
Keshopur	12 MGD	Inlet	7.4	328	214	806	-	32	3.3
	(PH-I)	Outlet	7.7	15	6	28	-	1	3.4
	Real time reading at OUTLET(online)		7.33	7.26	3.4	26.23	-	0.71	-
	20 MGD	Inlet	7.4	500	249	876	-	31	3.2
	(PH-II)	Outlet	7.6	76	84	274	-	27	3.1
	Real Time Reading at Outlet								
	40 MGD	Inlet	7.4	500	249	876	-	31	3.2
	(PH-III)	Outlet	7.6	126	117	352	-	28	3
	Real Time Reading at Outlet								
	40 MGD	Inlet	7.1	316	168	-	-	32	3

Nilothi	(PH-I)	Outlet	7.5	57	35	-	-	18	2.6
	Real Time Reading at Outlet		7.8	29.07	20.79	117.67	-	22.88	-
	20 MGD	Inlet	7.2	336	171	-	-	34	3.2
	(PH-II)	Outlet	7.4	8	7	-	-	10	1.8
	Real Time Reading at Outlet		7.31	6.06	6.6	23.66	-	1.98	-
Pappankalan	(20 MGD)	Inlet	7.3	410	198	-	-	42	6.6
	PH-I	Outlet	7.7	66	50	-	-	28	1.2
	Real Time Reading at Outlet		7.6	77.69	53.75	154.22	-	4.45	-
	(20 MGD)	Inlet	7.3	385	189	560	-	40	6.4
	PH-II	Outlet	7.6	7	6	20	-	14	2
	Real Time Reading at Outlet		8.04	18.81	15.94	39.53	-	5.54	-
Najafgarh	(05 MGD)	Inlet	7.3	325	186	580	-	34	4.8
		Outlet	7.5	24	20	80	-	14	1.4
	Real Time Reading at Outlet		7.37	64.15	23.92	83.73	-	7.25	-
Okhla	45 MGD	Inlet	7.3	262	203	432	-	39	1.5
		outlet	7.6	42	26	104	-	35	1
	Real Time Reading at Outlet								
	37 MGD	Inlet	7.3	262	203	432	-	39	1.5
		outlet	7.6	43	28	112	-	33	0.9
	Real Time Reading at Outlet								
	16 MGD	Inlet	7.3	262	203	432	-	39	1.5
		outlet	7.7	45	29	120	-	29	0.5
	Real Time Reading at Outlet								

OFFICE OF THE DIRECTOR (T&QC)				
DELHI JAL BOARD: GOVT. OF NCT OF DELHI				
WATER WORKS WAZIRABAD:DELHI-110054				
Name of the Plant	Capacity (in MGD)	21.02.2020		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC Limit	50	30	250
Yamuna Vihar	10 MGD Phase-I	34	22	-
	10 MGD Phase-II	15	14	-
	25 MGD Phase-III	22	18	-
Rithala	40 MGD	55	28	120
	40 MGD	17	13	60
Corronation pillar	20 MGD Phase-I &II	88	69	118
	10 MGD Phase-III	178	133	224
Narela	10 MGD Phase-III	26	21	94
Rohini	15 MGD	36	22	-
Keshopur	12 MGD	15	6	28
	20 MGD	76	84	274
	40 MGD	126	117	352
Nilothi	40 MGD	57	35	-
	20 MGD	8	7	-
Pappankalan	(20 MGD)	66	50	-
	(20 MGD)	7	6	20
Najafgarh	05 MGD	24	20	80
Okhla	45 MGD	42	26	104
	37 MGD	43	28	112
	16 MGD	45	29	120

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Parameters of STPs of Delhi as on

22.02.2020

Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Yamuna Vihar	10 MGD Phase-I	Inlet	7.2	364	216	592		45	5.0
		outlet	8.1	30	24	110		20	1.5
		Real Time Reading at Outlet	6.9	71	43	104		8	
	10 MGD Phase-II	Inlet	7.3	264	185	660		50	4.5
		outlet	8.1	33	22	130		25	2.0
		Real Time Reading at Outlet							
	25 MGD Phase-III	Inlet	7.3	420	360	810		55	5.0
		outlet	8.1	27	20	104		25	3.5
		Real Time Reading at Outlet							
Rithala	40 MGD	Inlet	7	268	152	380	17	32	1.2
		outlet	7.7	57	29	70	11	28	1.2
		Real Time Reading at Outlet	7.16	28.85	17.1	69.96		27.41	
	40 MGD	Inlet	7	268	152	380	17	32	1.2
		Outlet	7.6	18	14	70	5	21	0.9
		Real Time Reading at Outlet	8.11	16.53	13.21	54.95		6.8	
Corronation Pillar	20 MGD Phase-I & II	Inlet	7.1	340	228	498	24	10.5	
		outlet	7.4	96	72	186	18	4.5	
		Real Time Reading at Outlet	7.8	474	138	398	15		
	10 MGD Phase-III	Inlet	7.2	450	318	5.4	38	9.3	7.4
		outlet	7.6	128	118	196	27	5	4.2
		Real Time Reading at Outlet	7.7	113	31	71	0		
Rohini	15 MGD	Inlet	7.1	404	235	749		52	9
		Outlet	7.5	28	17	106		15	3
		Real Time Reading at Outlet							
Keshopur	12 MGD (PH-I)	Inlet	7.4	292	192	-	-	33	2.9
		Outlet	7.6	9	6	-	-	2	3
		Real time reading at OUTLET(online)	7.3	60.38	37.43	118.3	-	9.08	-
	20 MGD (PH-II)	Inlet	7.4	548	240	-	-	32	3.1
		Outlet	7.6	92	102	-	-	28	2.7
		Real Time Reading at Outlet							
	40 MGD (PH-III)	Inlet	7.4	548	240	-	-	32	3.1
		Outlet	7.5	150	129	-	-	29	3
		Real Time Reading at Outlet							
Nilothi	40 MGD (PH-I)	Inlet	7.2	336	164	-	-	30	3.2
		Outlet	7.4	59	34	-	-	22	2.6
		Real Time Reading at Outlet	7.81	28.43	16.2	115.47	-	22.98	-

	20 MGD	Inlet	7.2	344	176	-	-	34	3.4
	(PH-II)	Outlet	7.4	7	7	-	-	9	1.8
	Real Time Reading at Outlet								
Pappankalan	(20 MGD)	Inlet	7.2	387	203	-	-	43	6
	PH-I	Outlet	7.6	56	32	-	-	26	1.2
	Real Time Reading at Outlet		7.63	80.67	55.94	158.62	-	4.55	-
	(20 MGD)	Inlet	7.2	328	185	-	13.6	38	5.8
	PH-II	Outlet	7.5	6	5	-	0	15	3.2
	Real Time Reading at Outlet		8.04	17.31	16.42	39.09	-	5.63	-
Najafgarh	(05 MGD)	Inlet	7.3	387	218	-	15.8	36	7
		Outlet	7.6	29	22	-	0.2	12	2
	Real Time Reading at Outlet		7.31	34.89	21.56	78.15	-	6.99	-
Okhla	45 MGD	Inlet	7.4	218	195	392	3	41	2.2
		outlet	7.7	45	29	120	1	35	1.3
	Real Time Reading at Outlet								
	37 MGD	Inlet	7.4	218	196	392	3	41	2.2
		outlet	7.6	43	26	112	1	33	0.9
	Real Time Reading at Outlet								
	16 MGD	Inlet	7.4	218	196	392	3	41	2.2
		outlet	7.6	46	27	120	1	29	0.5
	Real Time Reading at Outlet								
	New 30 MGD	Inlet	7.6	322	200	456	4	43	1.8
		Outlet	7.8	10	8	32	NIL	5	NIL
	Real Time Reading at Outlet								
Mehrauli	5 MGD	Inlet	7.4	280	293	472	3	42	3.2
		outlet	7.6	25	15	56	1	39	1
	Real Time Reading at Outlet								
Vasant Kunj	2.2 MGD	Inlet	7.5	260	288	448	4	30	2.6
		outlet	7.8	16	11	48	1	28	1
	Real Time Reading at Outlet								
	3 MGD	Inlet	7.7	274	215	456	3	38	3.5
		outlet	7.6	14	8	40	1	30	1.2
	Real Time Reading at Outlet								
Ghitorni	5 MGD	Inlet	7.4	288	233	472	4	43	3
		outlet	7.6	40	25	96	2	40	1.5
	Real Time Reading at Outlet								

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Name of the Plant	Capacity (in MGD)	22.02.2020		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC Limit	50	30	250
Yamuna Vihar	10 MGD Phase-I	30	24	110
	10 MGD Phase-II	33	22	130
	25 MGD Phase-III	27	20	104
Rithala	40 MGD	57	29	70
	40 MGD	18	14	70
Corronation pillar	20 MGD Phase-I &II	96	72	186
	10 MGD Phase-III	128	118	196
Rohini	15 MGD	28	17	106
Keshopur	12 MGD	9	6	-
	20 MGD	92	102	-
	40 MGD	150	129	-
Nilothi	40 MGD	59	34	-
	20 MGD	7	7	-
Pappankalan	(20 MGD)	56	32	-
	(20 MGD)	6	5	-
Najafgarh	05 MGD	29	22	-
Okhla	45 MGD	45	29	120
	37 MGD	43	26	112
	16 MGD	46	27	120
	New 30 MGD	10	8	32
Mehrauli	5 MGD	25	15	56
Vasant Kunj	2.2 MGD	16	11	48
	3 MGD	14	8	40
Ghitorni	5 MGD	40	25	96

OFFICE OF THE DIRECTOR (T&QC)									
DELHI JAL BOARD: GOVT. OF NCT OF DELHI									
WATER WORKS WAZIRABAD:DELHI-110054									
Parameters of STPs of Delhi as on							23.02.2020		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Yamuna Vihar	10 MGD Phase-I	Inlet	7.2	424	268			45	5.5
		outlet	7.5	36	23			20	3.0
	Real Time Reading at Outlet								
	10 MGD Phase-II	Inlet	7.2	676	375			50	4.5
		outlet	7.5	35	21			25	1.5
	Real Time Reading at Outlet								
	25 MGD Phase-III	Inlet	7.2	692	402			40	3.5
		outlet	7.4	38	27			20	1.0
Real Time Reading at Outlet									
Rithala	40 MGD	Inlet	7.2	252	151	350		37	1.7
		outlet	7.6	48	22	100		32	1.2
	Real Time Reading at Outlet		7.2	28.99	17.27	70.18		26.17	
	40 MGD	Inlet	7.2	252	151	350		37	1.7
		Outlet	7.5	19	14	60		17	0.7
Real Time Reading at Outlet		8.11	21.34	15.7	62.97		6.8		
Corronation Pillar	20 MGD Phase-I & II	Inlet	6.8	334	223	418	32	10.2	
		outlet	7.2	92	68	140	23	5.2	
	Real Time Reading at Outlet		7.8	562	159	452	14		
	10 MGD Phase-III	Inlet	7	456	323	496	38	10.9	
		outlet	7.6	122	115	202	29	6	
Real Time Reading at Outlet		7.8	142	50	139	33			
Rohini	15 MGD	Inlet	7.2	520	345			53	8
		Outlet	7.5	30	19			16	4.5
	Real Time Reading at Outlet								
Keshopur	12 MGD	Inlet	7.4	340	189	-	-	30	3.4
	(PH-I)	Outlet	7.5	15	6	-	-	2	3
	Real time reading at OUTLET(online)		7.3	60.62	37.41	114.89	-	9.14	-
	20 MGD	Inlet	7.4	388	198	-	-	32	3.7
	(PH-II)	Outlet	7.6	84	91	-	-	29	2.4
	Real Time Reading at Outlet								
	40 MGD	Inlet	7.4	388	198	-	-	32	3.7
	(PH-III)	Outlet	7.5	134	117	-	-	29	3.2
Real Time Reading at Outlet									
Nilothi	40 MGD	Inlet	7.2	280	158	-	-	30	3.4
	(PH-I)	Outlet	7.4	54	33	-	-	24	2.6
	Real Time Reading at Outlet		7.81	27.86	16.7	115.56	-	22.64	-
	(20 MGD)	Inlet	7.3	435	210	-	-	44	6.4

Pappankalan	PH-I	Outlet	7.7	58	33	-	-	24	1.4
	Real Time Reading at Outlet		7.61	78.88	57.31	159.15	-	4.2	-
	(20 MGD)	Inlet	7.3	380	192	-	-	40	6
	PH-II	Outlet	7.5	7	6	-	-	14	3.4
	Real Time Reading at Outlet		8.18	18.36	18.37	41.47	-	5.83	-
Okhla	45 MGD	Inlet	7.5	264	230	456	4	40	1.6
		outlet	7.6	35	24	88	1	30	0.8
	Real Time Reading at Outlet								
	37 MGD	Inlet	7.5	264	230	456	4	40	1.6
		outlet	7.6	38	25	96	1	36	0.9
	Real Time Reading at Outlet								
	16 MGD	Inlet	7.5	264	230	456	4	40	1.6
		outlet	7.9	39	26	96	1	32	1
	Real Time Reading at Outlet								

OFFICE OF THE DIRECTOR (T&QC)				
DELHI JAL BOARD: GOVT. OF NCT OF DELHI				
WATER WORKS WAZIRABAD:DELHI-110054				
Name of the Plant	Capacity (in MGD)	23.02.2020		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC Limit	50	30	250
Yamuna Vihar	10 MGD Phase-I	36	23	-
	10 MGD Phase-II	35	21	-
	25 MGD Phase-III	38	27	-
Rithala	40 MGD	48	22	100
	40 MGD	19	14	60
Corronation pillar	20 MGD Phase-I &II	92	68	140
	10 MGD Phase-III	122	115	202
Rohini	15 MGD	30	19	-
Keshopur	12 MGD	15	6	-
	20 MGD	84	91	-
	40 MGD	134	117	-
Nilothi	40 MGD	54	33	-
Pappankalan	(20 MGD)	58	33	-
	(20 MGD)	7	6	-
Okhla	45 MGD	35	24	88
	37 MGD	38	25	96
	16 MGD	39	26	96

OFFICE OF THE DIRECTOR (T&QC)									
DELHI JAL BOARD: GOVT. OF NCT OF DELHI									
WATER WORKS WAZIRABAD:DELHI-110054									
Parameters of STPs of Delhi as on							24.02.2020		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Yamuna Vihar	10 MGD Phase-I	Inlet	7.2	324	234	800		50	4.5
		outlet	7.5	42	26	96		30	2.5
	Real Time Reading at Outlet		7.0	61	49	106		10	
	10 MGD Phase-II	Inlet	7.0	428	327	896		45	3.0
		outlet	7.5	35	23	100		25	1.5
	Real Time Reading at Outlet								
	25 MGD Phase-III	Inlet	7.0	416	235	960		55	4.0
		outlet	7.5	49	26	112		30	2.5
Real Time Reading at Outlet		8.2	15	18	44		10		
Rithala	40 MGD	Inlet	7.1	248	145	370	nd	36	1.3
		outlet	7.5	52	24	110	nd	29	1.1
	Real Time Reading at Outlet		7.16	29.25	17.41	70.42		25.9	
	40 MGD	Inlet	7.1	248	145	370	nd	36	1.3
		Outlet	7.6	18	13	60	nd	12	0.7
Real Time Reading at Outlet		8.26	19.15	15.88	62.69		6.92		
Corronation Pillar	20 MGD Phase-I & II	Inlet	7	316	248	408	29	9.4	
		outlet	7.4	84	56	130	19	4.3	
	Real Time Reading at Outlet								
	10 MGD Phase-III	Inlet	7.1	428	316	502	36	10.2	
		outlet	7.4	118	110	204	31	7.5	
Real Time Reading at Outlet									
Narela	10 MGD Phase-III	Inlet	7.2	246	218	374	42	8.4	6.2
		outlet	7.5	32	21	72	28	5	3
	Real Time Reading at Outlet								
Rohini	15 MGD	Inlet	7.1	248	155	618		44	6.5
		Outlet	7.5	27	15	122		15	4
	Real Time Reading at Outlet								
Keshopur	12 MGD	Inlet	7.3	504	226	-	-	32	3.1
	(PH-I)	Outlet	7.6	10	5	-	-	1	3
	Real time reading at OUTLET(online)		7.28	60.89	38	113.8	-	8.67	-
	20 MGD	Inlet	7.3	532	234	-	-	30	3.2
	(PH-II)	Outlet	7.5	104	98	-	-	28	2.8
	Real Time Reading at Outlet								
	40 MGD	Inlet	7.3	532	234	-	-	30	3.2
	(PH-III)	Outlet	7.5	156	129	-	-	29	3
	Real Time Reading at Outlet		6.4	167.43	142.03	563.21	-	89.19	-
	40 MGD	Inlet	7.1	288	154	-	7.2	32	3

Nilothi	(PH-I)	Outlet	7.3	46	30	-	1	24	2.2
	Real Time Reading at Outlet		7.82	32.58	18.04	116.9	-	23.36	-
	20 MGD	Inlet	7.2	316	176	-	8.6	34	3.2
	(PH-II)	Outlet	7.4	7	7	-	0	12	1.8
	Real Time Reading at Outlet								
Pappankalan	(20 MGD)	Inlet	7.4	402	192	-	13.2	36	-
	PH-I	Outlet	7.8	50	29	-	0.2	28	-
	Real Time Reading at Outlet		7.71	81.51	60.59	164.32	-	3.55	-
	(20 MGD)	Inlet	7.4	388	196	-		37	-
	PH-II	Outlet	7.6	5	4	-		22	-
	Real Time Reading at Outlet		8.24	22.95	20.37	45.98	-	5.94	-
Najafgarh	(05 MGD)	Inlet	7.4	368	202	560	9.2	35	-
		Outlet	7.8	17	11	54	0	4	-
	Real Time Reading at Outlet		7.13	44.41	50.86	231.48	-	6.99	-
Okhla	45 MGD	Inlet	7.5	216	195	432	-	40	1.5
		outlet	7.7	44	28	112	-	36	1
	Real Time Reading at Outlet								
	37 MGD	Inlet	7.5	216	195	432	-	40	1.5
		outlet	7.7	47	29	120	-	32	0.9
	Real Time Reading at Outlet								
	16 MGD	Inlet	7.5	216	195	432	-	40	1.5
		outlet	7.7	30	21	80	-	29	1.2
	Real Time Reading at Outlet								
	New 30 MGD	Inlet	7.5	152	177	416	4	41	1.1
		Outlet	7.5	9	8	32	1	3	0.8
	Real Time Reading at Outlet								
Delhi Gate-I	2.2 MGD	Inlet	7.4	300	215	480	3	38	1.6
		outlet	7.4	3	5	16	NIL	35	1.2
	Real Time Reading at Outlet								
Delhi Gate-II	15 MGD	Inlet	7.6	252	198	456	3	37	0.9
		outlet	7.5	17	10	40	1	32	0.7
	Real Time Reading at Outlet								
Sen Nursing Home	2.2 MGD	Inlet	7.6	264	205	464	4	29	1.6
		outlet	7.6	19	12	48	NIL	28	1
	Real Time Reading at Outlet								

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Name of the Plant	Capacity (in MGD)	24.02.2020		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC Limit	50	30	250
Yamuna Vihar	10 MGD Phase-I	42	26	96
	10 MGD Phase-II	35	23	100
	25 MGD Phase-III	49	26	112
Rithala	40 MGD	52	24	110
	40 MGD	18	13	60
Corronation pillar	20 MGD Phase-I &II	84	56	130
	10 MGD Phase-III	118	110	204
Narela	10 MGD Phase-III	32	21	72
Rohini	15 MGD	27	15	122
Keshopur	12 MGD	10	5	-
	20 MGD	104	98	-
	40 MGD	156	129	-
Nilothi	40 MGD	46	30	-
	20 MGD	7	7	-
Pappankalan	(20 MGD)	50	29	-
	(20 MGD)	5	4	-
Najafgarh	05 MGD	17	11	54
Okhla	45 MGD	44	28	112
	37 MGD	47	29	120
	16 MGD	30	21	80
	New 30 MGD	9	8	32
Delhi Gate-I	2.2 MGD	3	5	16
Delhi Gate-II	15 MGD	17	10	40
Sen Nursing Home	2.2 MGD	19	12	48

OFFICE OF THE DIRECTOR (T&QC)									
DELHI JAL BOARD: GOVT. OF NCT OF DELHI									
WATER WORKS WAZIRABAD:DELHI-110054									
Parameters of STPs of Delhi as on							25.02.2020		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Yamuna Vihar	10 MGD Phase-I	Inlet	7.2	264	225			50	4.5
		outlet	7.6	34	22			30	2.5
	Real Time Reading at Outlet		7.0	53	46	103		10	
	10 MGD Phase-II	Inlet	7.2	344	269			45	3.0
		outlet	7.5	26	19			20	1.0
	Real Time Reading at Outlet								
	25 MGD Phase-III	Inlet	7.0	392	266			55	3.5
		outlet	7.4	33	22			30	2.0
Real Time Reading at Outlet									
Rithala	40 MGD	Inlet	7.2	232	149	330	nd	40	1.8
		outlet	7.7	47	21	100	nd	31	1.4
	Real Time Reading at Outlet		7.19	29.35	14.47	70.55		25.16	
	40 MGD	Inlet	7.2	232	149	330	nd	40	1.8
		Outlet	7.6	17	12	50	nd	20	1.1
Real Time Reading at Outlet		8.31	17.12	15.04	59.17		6.96		
Corronation Pillar	20 MGD Phase-I & II	Inlet	7.1	244	228	388	40	8.4	7.8
		outlet	7.5	98	72	138	20	4.5	3.2
	Real Time Reading at Outlet		7.8	115	67	190	15		
	10 MGD Phase-III	Inlet	7.2	516	350	638	44	9.6	
		outlet	7.5	150	50	144	13		
Real Time Reading at Outlet									
Rohini	15 MGD	Inlet	7.2	196	153			53	10
		Outlet	7.4	30	19			17	4
	Real Time Reading at Outlet								
Keshopur	12 MGD	Inlet	7.4	440	246	720	13.6	35	3.8
	(PH-I)	Outlet	7.7	11	5	30	0	2	3.8
	Real time reading at OUTLET(online)		7.31	59.47	36.25	114.66	-	7.97	-
	20 MGD	Inlet	7.3	424	250	800	10	32	3.5
	(PH-II)	Outlet	7.6	94	111	320	2.6	31	3.3
	Real Time Reading at Outlet								
	40 MGD	Inlet	7.3	424	250	800	10	32	3.5
	(PH-III)	Outlet	7.5	138	130	380	3.2	30	3
Real Time Reading at Outlet		6.44	241.91	156.38	652.48	-	82.31	-	
Nilothi	40 MGD	Inlet	7.1	276	159	-	-	30	3.2
	(PH-I)	Outlet	7.3	55	34	-	-	22	2.4
	Real Time Reading at Outlet								
	20 MGD	Inlet	7.2	308	174	-	-	34	3.4

	(PH-II)	Outlet	7.4	13	9	-	-	14	2
	Real Time Reading at Outlet								
Pappankalan	(20 MGD)	Inlet	7.3	372	190	-	-	37	6.6
	PH-I	Outlet	7.8	82	35	-	-	32	1.6
	Real Time Reading at Outlet		7.62	84.87	66.33	172.16	-	4.15	-
	(20 MGD)	Inlet	7.4	305	196	-	-	37	6.2
	PH-II	Outlet	7.7	6	7	-	-	18	3.2
	Real Time Reading at Outlet		8.27	24.14	24.91	50.61	-	6.44	-
Najafgarh	(05 MGD)	Inlet	7.3	438	200	-	-	35	5
		Outlet	7.8	40	23	-	-	6	0.9
	Real Time Reading at Outlet		7.35	48.11	59.79	287.25	-	6.98	-
Okhla	12 MGD	Inlet	7.4	246	205	424	-	32	2
		outlet	7.7	48	30	120	-	30	1.8
	Real Time Reading at Outlet								
	45 MGD	Inlet	7.6	176	198	400	-	39	1.5
		outlet	7.4	42	27	112	-	35	1
	Real Time Reading at Outlet								
	37 MGD	Inlet	7.6	176	198	400	-	39	1.5
		outlet	7.4	40	25	104	-	35	1
	Real Time Reading at Outlet								
	16 MGD	Inlet	7.6	176	198	400	-	39	1.5
		outlet	7.7	38	23	96	-	33	1
	Real Time Reading at Outlet								

OFFICE OF THE DIRECTOR (T&QC)				
DELHI JAL BOARD: GOVT. OF NCT OF DELHI				
WATER WORKS WAZIRABAD:DELHI-110054				
Name of the Plant	Capacity (in MGD)	25.02.2020		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC Limit	50	30	250
Yamuna Vihar	10 MGD Phase-I	34	22	-
	10 MGD Phase-II	26	19	-
	25 MGD Phase-III	33	22	-
Rithala	40 MGD	47	21	100
	40 MGD	17	12	50
Corronation pillar	20 MGD Phase-I &II	98	72	138
	10 MGD Phase-III	150	50	144
Rohini	15 MGD	30	19	-
Keshopur	12 MGD	11	5	30
	20 MGD	94	111	320
	40 MGD	138	130	380
Nilothi	40 MGD	55	34	-
	20 MGD	13	9	-
Pappankalan	(20 MGD)	82	35	-
	(20 MGD)	6	7	-
Najafgarh	05 MGD	40	23	-
Okhla	12 MGD	48	30	120
	45 MGD	42	27	112
	37 MGD	40	25	104
	16 MGD	38	23	96

OFFICE OF THE DIRECTOR (T&QC)									
DELHI JAL BOARD: GOVT. OF NCT OF DELHI									
WATER WORKS WAZIRABAD:DELHI-110054									
Parameters of STPs of Delhi as on							26.02.2020		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Yamuna Vihar	10 MGD Phase-I	Inlet	7.2	284	209			55	4.5
		outlet	7.5	33	22			30	2.0
	Real Time Reading at Outlet								
	10 MGD Phase-II	Inlet	7.1	356	231			40	3.5
		outlet	7.6	31	19			15	1.0
	Real Time Reading at Outlet								
	25 MGD Phase-III	Inlet	7.1	488	269			60	3.5
		outlet	7.5	37	24			35	1.5
Real Time Reading at Outlet									
Rithala	40 MGD	Inlet	7.1	252	143	350	nd	36	1.3
		outlet	7.7	45	22	110	nd	30	1.2
	Real Time Reading at Outlet		7.2	29.37	17.59	70.63		23.75	
	40 MGD	Inlet	7.1	252	143	350	nd	36	1.3
		Outlet	7.6	18	13	70	nd	18	0.6
	Real Time Reading at Outlet		8.37	19.15	16.13	63.33		7.01	
Corronation Pillar	20 MGD Phase-I & II	Inlet	7	430	275	492	28	6.4	
		outlet	7.4	88	68	126	20	4	
	Real Time Reading at Outlet		7.8	163	78	214	15		
	10 MGD Phase-III	Inlet	7.3	484	338	506	33	8.2	7.4
		outlet	7.6	144	123	184	24	5.4	4
	Real Time Reading at Outlet		7.5	173	50	149	13		
Rohini	15 MGD	Inlet	7.2	416	243	762		55	10
		Outlet	7.6	34	21	90		15	4.5
	Real Time Reading at Outlet								
Keshopur	12 MGD	Inlet	7.3	464	203	-	-	33	3.6
	(PH-I)	Outlet	7.7	11	6	-	-	2	3.5
	Real time reading at OUTLET(online)		7.25	60.01	37.89	115.37	-	9.43	-
	20 MGD	Inlet	7.3	744	254	-	-	32	3.4
	(PH-II)	Outlet	7.6	86	94	-	-	30	3.2
	Real Time Reading at Outlet								
	40 MGD	Inlet	7.3	744	254	-	-	32	3.4
	(PH-III)	Outlet	7.6	142	121	-	-	29	3.2
	Real Time Reading at Outlet		6.58	173.19	145.55	573.3	-	61.24	-
Nilothi	40 MGD	Inlet	7.2	260	164	520	6.4	30	3.2
	(PH-I)	Outlet	7.4	44	29	126	0.8	22	2
	Real Time Reading at Outlet								
	20 MGD	Inlet	7.1	284	168	590	-	32	3.4

	(PH-II)	Outlet	7.3	18	12	48	-	16	1.8
	Real Time Reading at Outlet								
Pappankalan	(20 MGD)	Inlet	7.3	385	225	710	14.4	38	6.8
	PH-I	Outlet	7.7	76	28	120	0.4	28	1.4
	Real Time Reading at Outlet		7.58	87.89	79.27	186.56	-	4.35	-
	(20 MGD)	Inlet	7.3	400	230	740	14.6	40	6.4
	PH-II	Outlet	7.6	12	10	20	0	20	3.4
	Real Time Reading at Outlet		8.29	30.09	24.64	53.28	-	6.58	-
Najafgarh	(05 MGD)	Inlet	7.3	429	222	-	-	36	5.2
		Outlet	7.8	48	28	-	-	10	1
	Real Time Reading at Outlet		7.42	39.5	50.44	168.65	-	6.83	-
Okhla	12 MGD	Inlet	7.5	396	190	464	6	36	1.6
		outlet	7.5	48	25	112	3	32	1.4
	Real Time Reading at Outlet								
	45 MGD	Inlet	7.5	290	208	416	-	34	1
		outlet	7.5	47	27	120	-	32	0.8
	Real Time Reading at Outlet								
	37 MGD	Inlet	7.7	290	208	416	-	34	1
		outlet	7.7	46	25	104	-	27	0.5
	Real Time Reading at Outlet								
	16 MGD	Inlet	7.5	290	208	416	-	34	1
		outlet	7.5	28	20	80	-	31	0.5
	Real Time Reading at Outlet								
Kondli	25 MGD Phase-II	Inlet	7.3	456	218	464	-	33	5.9
		outlet	7.7	15	8	32	-	20	2.7
	Real Time Reading at Outlet								
	45 MGD Phase-IV	Inlet	7.2	436	218	452	-	34	5.7
		outlet	7.5	64	27	132	-	22	3.1
	Real Time Reading at Outlet								
Chilla	9 MGD	Inlet	7.1	636	238	568	-	35	5.7
		outlet	7.6	8	3.5	18	-	3	3.2
	Real Time Reading at Outlet								

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Name of the Plant	Capacity (in MGD)	26.02.2020		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC Limit	50	30	250
Yamuna Vihar	10 MGD Phase-I	33	22	-
	10 MGD Phase-II	31	19	-
	25 MGD Phase-III	37	24	-
Rithala	40 MGD	45	22	110
	40 MGD	18	13	70
Corronation pillar	20 MGD Phase-I &II	88	68	126
	10 MGD Phase-III	144	123	184
Rohini	15 MGD	34	21	90
Keshopur	12 MGD	11	6	-
	20 MGD	86	94	-
	40 MGD	142	121	-
Nilothi	40 MGD	44	29	126
	20 MGD	18	12	48
Pappankalan	(20 MGD)	76	28	120
	(20 MGD)	12	10	20
Najafgarh	05 MGD	48	28	-
Okhla	12 MGD	48	25	112
	45 MGD	47	27	120
	37 MGD	46	25	104
	16 MGD	28	20	80
Kondli	25 MGD Phase-II	15	8	32
	45 MGD Phase-IV	64	27	132
Chilla	9 MGD	8	3.5	18

OFFICE OF THE DIRECTOR (T&QC)									
DELHI JAL BOARD: GOVT. OF NCT OF DELHI									
WATER WORKS WAZIRABAD:DELHI-110054									
Parameters of STPs of Delhi as on							27.02.2020		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Yamuna Vihar	10 MGD Phase-I	Inlet	7.0	248	215	552		45	2.5
		outlet	7.5	35	21	100		35	1.5
	Real Time Reading at Outlet		7.0	53	43	100		10	
	10 MGD Phase-II	Inlet	7.1	204	183	528		30	4.0
		outlet	7.5	28	19	88		25	2.0
	Real Time Reading at Outlet								
	25 MGD Phase-III	Inlet	7.0	240	182	592		35	5.0
		outlet	7.4	33	20	100		25	3.0
Real Time Reading at Outlet		7.1	14	18	45		10		
Rithala	40 MGD	Inlet	7.1	264	149	340	nd	38	1.6
		outlet	7.8	46	21	110	nd	27	1.3
	Real Time Reading at Outlet		7.08	29.33	17.36	70.4		30.13	
	40 MGD	Inlet	7.1	264	149	340	nd	38	1.6
		Outlet	7.7	16	12	60	nd	19	1.1
Real Time Reading at Outlet		8.5	18.22	14.91	59.86		7.12		
Corronation Pillar	20 MGD Phase-I & II	Inlet	7.1	328	238	456	27	7	6
		outlet	7.5	90	70	138	23	3.8	2.4
	Real Time Reading at Outlet		7.7	194	90	237	16		
	10 MGD Phase-III	Inlet	7.3	512	368	564	36	10.8	
		outlet	7.7	168	128	192	29	6.6	
Real Time Reading at Outlet		7.5	197	50	154	12			
Rohini	15 MGD	Inlet	7.6	268	168			45	7.5
		Outlet	7.8	33	21			14	5
	Real Time Reading at Outlet								
Keshopur	12 MGD	Inlet	7.4	428	213	-	-	34	3.7
	(PH-I)	Outlet	7.6	13	9	-	-	1	3.4
	Real time reading at OUTLET(online)		7.09	58.51	37.77	117.92	-	12.25	-
	20 MGD	Inlet	7.4	436	223	-	-	33	3.5
	(PH-II)	Outlet	7.6	104	105	-	-	29	3.1
	Real Time Reading at Outlet								
	40 MGD	Inlet	7.4	436	223	-	-	33	3.5
	(PH-III)	Outlet	7.5	134	124	-	-	30	3.3
Real Time Reading at Outlet		6.63	375.34	101.1	426.72	-	819.67	-	
Nilothi	40 MGD	Inlet	7.1	306	156	-	-	32	2.8
	(PH-I)	Outlet	7.4	52	32	-	-	20	2
	Real Time Reading at Outlet		7.83	32.54	17.73	116.85	-	24.27	-
	20 MGD	Inlet	7.2	294	169	-	-	35	3

	(PH-II)	Outlet	7.4	16	14	-	-	15	2
	Real Time Reading at Outlet		7.18	30.02	7.98	25.79	-	3.25	-
Pappankalan	(20 MGD)	Inlet	7.3	898	320	-	17.6	38	6.5
	PH-I	Outlet	7.8	54	25	-	0	28	1.2
	Real Time Reading at Outlet		7.55	88.35	82.45	189.9	-	5.95	-
	(20 MGD)	Inlet	7.3	519	200	-	-	32	6.4
	PH-II	Outlet	7.6	68	34	-	-	28	3.2
	Real Time Reading at Outlet		8.36	29.58	23.93	52.43	-	7.45	-
Okhla	12 MGD	Inlet	7.7	274	187	424	3	38	1.5
		outlet	7.5	27	18	88	1	35	0.4
	Real Time Reading at Outlet								
	45 MGD	Inlet	7.7	260	182	440	3	39	1.3
		outlet	7.6	29	19	72	1	32	0.8
	Real Time Reading at Outlet								
	37 MGD	Inlet	7.7	260	182	440	3	39	1.3
		outlet	7.7	23	18	88	1	35	1.2
	Real Time Reading at Outlet								
	16 MGD	Inlet	7.7	260	182	440	3	39	1.3
		outlet	7.7	26	17	80	1	31	NIL
	Real Time Reading at Outlet								
Kondli	25 MGD Phase-II	Inlet	7.2	384	231	396	-	35	5.1
		outlet	7.6	8	4	20	-	18	4.7
	Real Time Reading at Outlet								
	45 MGD Phase-IV	Inlet	7.1	380	201	396	-	33	5.7
		outlet	7.7	136	72	278	-	22	5.4
	Real Time Reading at Outlet								
Chilla	9 MGD	Inlet	7.1	544	186	568	-	38	4.6
		outlet	7.6	7	0.56	16	-	2.46	3.6
	Real Time Reading at Outlet								

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Name of the Plant	Capacity (in MGD)	27.02.2020		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC Limit	50	30	250
Yamuna Vihar	10 MGD Phase-I	35	21	100
	10 MGD Phase-II	28	19	88
	25 MGD Phase-III	33	20	100
Rithala	40 MGD	46	21	110
	40 MGD	16	12	60
Corronation pillar	20 MGD Phase-I &II	90	70	138
	10 MGD Phase-III	168	128	192
Rohini	15 MGD	33	21	-
Keshopur	12 MGD	13	9	-
	20 MGD	104	105	-
	40 MGD	134	124	-
Nilothi	40 MGD	52	32	-
	20 MGD	16	14	-
Pappankalan	(20 MGD)	54	25	-
	(20 MGD)	68	34	-
Okhla	12 MGD	27	18	88
	45 MGD	29	19	72
	37 MGD	23	18	88
	16 MGD	26	17	80
Kondli	25 MGD Phase-II	8	4	20
	45 MGD Phase-IV	136	72	278
Chilla	9 MGD	7	0.56	16

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Parameters of STPs of Delhi as on

28.02.2020

Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Yamuna Vihar	10 MGD Phase-I	Inlet	7.0	272	224		11.6	45	3.5
		outlet	7.5	29	20		2.0	30	1.5
	Real Time Reading at Outlet								
	10 MGD Phase-II	Inlet	7.1	256	187		6.0	35	4.0
		outlet	7.5	31	21		2.4	25	2.0
	Real Time Reading at Outlet								
	25 MGD Phase-III	Inlet	7.0	336	280		26.4	40	5.5
		outlet	7.5	36	23		3.6	20	3.0
Real Time Reading at Outlet		7.1	13	22			10		
Rithala	40 MGD	Inlet	7.2	260	149	360	nd	39	1.9
		outlet	7.8	48	25	110	nd	30	1.5
	Real Time Reading at Outlet		7.04	30.44	17.24	70.66		30.03	
	40 MGD	Inlet	7.2	260	149	360	nd	39	1.9
		Outlet	7.9	16	11	50	nd	21	1.1
Real Time Reading at Outlet		8.51	16.71	13.71	56.8		7.13		
Corronation Pillar	20 MGD Phase-I & II	Inlet	7.1	340	240	438	30	7	
		outlet	7.5	112	80	142	19	5.2	
	Real Time Reading at Outlet		7.7	196	90	237	16		
	10 MGD Phase-III	Inlet	7.2	468	338	688	32	10.8	8
		outlet	7.5	124	110	208	26	6.5	3.2
Real Time Reading at Outlet		7.4	213	50	161	12			
Narela	10 MGD Phase-III	Inlet	7.2	216	220	394	40	11.2	7
		outlet	7.5	28	19	68	21	4.4	2.8
	Real Time Reading at Outlet								
Rohini	15 MGD	Inlet	7.1	532	360	848		56	7.5
		Outlet	7.5	30	19	112		16	3.5
	Real Time Reading at Outlet								
Keshopur	12 MGD	Inlet	7.2	288	202	-	-	34	3.2
	(PH-I)	Outlet	7.6	15	7	-	-	2	3.4
	Real time reading at OUTLET(online)		7.29	59.31	43.78	114.68	-	8.91	-
	20 MGD	Inlet	7.3	496	229	-	-	33	3.5
	(PH-II)	Outlet	7.6	96	89	-	-	32	3
	Real Time Reading at Outlet								
	40 MGD	Inlet	7.3	496	229	-	-	33	3.5
	(PH-III)	Outlet	7.5	136	125	-	-	30	3.2
Real Time Reading at Outlet		6.65	319.12	111.5	423.21	-	0	-	

Nilothi	40 MGD	Inlet	7.2	288	148	-	-	28	3.2
	(PH-I)	Outlet	7.5	46	27	-	-	18	2.5
	Real Time Reading at Outlet		7.84	34.78	21.86	119.19	-	24.45	-
	20 MGD	Inlet	7.1	308	176	-	-	30	3.5
	(PH-II)	Outlet	7.3	18	16	-	-	18	2.2
	Real Time Reading at Outlet		7.23	18.53	7.45	21.62	-	3.22	-
Pappankalan	(20 MGD)	Inlet	7.2	528	194	-	-	32	6.8
	PH-I	Outlet	7.3	74	32	-	-	23	1.2
	Real Time Reading at Outlet		7.91	43.77	33.68	105.56	-	9.85	-
	(20 MGD)	Inlet	7.3	492	188	-	-	32	6.4
	PH-II	Outlet	7.6	67	38	-	-	25	3.4
	Real Time Reading at Outlet		8.39	23.09	24.21	49.89	-	7.8	-
Okhla	12 MGD	Inlet	7.5	260	225	424	4	39	1.8
		outlet	7.7	43	26	104	1	35	1
	Real Time Reading at Outlet								
	45 MGD	Inlet	7.6	316	220	448	4	40	1.7
		outlet	7.6	26	18	72	1	33	1
	Real Time Reading at Outlet								
	37 MGD	Inlet	7.6	316	220	448	4	40	1.7
		outlet	7.5	26	17	72	1	32	0.8
	Real Time Reading at Outlet								
	16 MGD	Inlet	7.6	316	220	448	4	40	1.7
		outlet	7.8	28	21	80	NIL	29	0.5
	Real Time Reading at Outlet								
Kondli	25 MGD Phase-II	Inlet	7.2	436	235	448	-	35	5.9
		outlet	7.7	12	7	28	-	23	3.7
	Real Time Reading at Outlet								
	45 MGD Phase-IV	Inlet	7.2	348	215	358	-	32	5.8
		outlet	7.6	64	25	132	-	24	4
	Real Time Reading at Outlet								
Chilla	9 MGD	Inlet	7.2	460	246	476	-	38	5.7
		outlet	7.5	5	2	12	-	2.68	3.4
	Real Time Reading at Outlet								
Molarbund	0.66 MGD	Inlet	7.6	436	260	528	4	42	2
		outlet	7.4	18	13	48	1.2	39	0.9
	Real Time Reading at Outlet								
Mehrauli	5 MGD	Inlet	7.6	284	233	456	-	39	1.5
		outlet	7.7	21	17	64	-	35	0.8
	Real Time Reading at Outlet								
Vasant Kunj	2.2 MGD	Inlet	7.6	274	283	448	4	35	2.8
		outlet	7.8	13	10	40	1	29	1.7
	Real Time Reading at Outlet								
	3 MGD	Inlet	7.5	256	233	432	4	39	3

Ghitorni	5 MGD	outlet	7.6	14	11	48	1	32	2.1
		Real Time Reading at Outlet							
	5 MGD	Inlet	7.5	312	245	472	4	41	2.2
		outlet	7.7	48	29	120	1.5	37	1.2
		Real Time Reading at Outlet							

OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054

Name of the Plant	Capacity (in MGD)	28.02.2020		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC Limit	50	30	250
Yamuna Vihar	10 MGD Phase-I	29	20	-
	10 MGD Phase-II	31	21	-
	25 MGD Phase-III	36	23	-
Rithala	40 MGD	48	25	110
	40 MGD	16	11	50
Corronation pillar	20 MGD Phase-I &II	112	80	142
	10 MGD Phase-III	124	110	208
Narela	10 MGD Phase-III	28	19	68
Rohini	15 MGD	30	19	112
Keshopur	12 MGD	15	7	-
	20 MGD	96	89	-
	40 MGD	136	125	-
Nilothi	40 MGD	46	27	-
	20 MGD	18	16	-
Pappankalan	(20 MGD)	74	32	-
	(20 MGD)	67	38	-
Okhla	12 MGD	43	26	104
	45 MGD	26	18	72
	37 MGD	26	17	72
	16 MGD	28	21	80
	New 30 MGD	10	8	32
Kondli	25 MGD Phase-II	12	7	28
	45 MGD Phase-IV	64	25	132
Chilla	9 MGD	5	2	12
Molarbund	0.66 MGD	18	13	48
Mehrauli	5 MGD	21	17	64
Vasant Kunj	2.2 MGD	13	10	40
	3 MGD	14	11	48
Ghitorni	5 MGD	48	29	120

OFFICE OF THE DIRECTOR (T&QC)									
DELHI JAL BOARD: GOVT. OF NCT OF DELHI									
WATER WORKS WAZIRABAD:DELHI-110054									
Parameters of STPs of Delhi as on							29.02.2020		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Yamuna Vihar	10 MGD Phase-I	Inlet	7.2	192	157			55	6.5
		outlet	7.5	24	19			30	4.0
	Real Time Reading at Outlet		7.0	43	39	95		11	
	10 MGD Phase-II	Inlet	7.1	324	253			40	6.0
		outlet	7.4	22	17			25	3.0
	Real Time Reading at Outlet								
	25 MGD Phase-III	Inlet	7.2	272	244			50	6.5
		outlet	7.5	29	20			35	2.5
Real Time Reading at Outlet									
Rithala	40 MGD	Inlet	7.1	244	151	370	nd	38	2.1
		outlet	7.7	48	24	100	nd	29	1.6
	Real Time Reading at Outlet		7.04	29.84	17.23	70.42		30.86	
	40 MGD	Inlet	7.1	244	151	370	nd	38	2.1
		Outlet	7.6	17	12	60	nd	18	1.3
	Real Time Reading at Outlet		8.54	18.39	15.08	60.07		7.16	
Corronation Pillar	20 MGD Phase-I &II	Inlet	7.2	292	213	392	28	6.8	5.8
		outlet	7.5	94	73	118	16	4.3	2.8
	Real Time Reading at Outlet		7.7	194	90	237	16		
	10 MGD Phase-III	Inlet	7.2	452	328	508	34	76	
		outlet	7.5	132	115	178	25	5	
	Real Time Reading at Outlet		7.5	230	50	50	166	11	
Rohini	15 MGD	Inlet	6.9	276	215			54	8
		Outlet	7.6	35	22			17	5.5
	Real Time Reading at Outlet								
Keshopur	12 MGD	Inlet	7.3	740	271	963	-	34	3.4
	(PH-I)	Outlet	7.6	13	7	34	-	1	3.6
	Real time reading at OUTLET(online)								
	20 MGD	Inlet	7.3	492	254	897	-	33	3.2
	(PH-II)	Outlet	7.6	114	107	348	-	30	3.1
	Real Time Reading at Outlet								
	40 MGD	Inlet	7.3	492	254	897	-	33	3.2
	(PH-III)	Outlet	7.6	144	126	394	-	31	3
	Real Time Reading at Outlet		6.43	166.29	101.01	370.78	-	0	-
Nilothi	40 MGD	Inlet	7.1	272	153	510	-	32	-
	(PH-I)	Outlet	7.4	42	27	112	-	20	-
	Real Time Reading at Outlet		7.86	33.08	23.88	119.9	-	24.83	-
	20 MGD	Inlet	7.2	310	166	560	-	32	-

	(PH-II)	Outlet	7.4	16	12	44	-	18	-
	Real Time Reading at Outlet		7.38	11.05	6.56	17.59	-	3.14	-
Pappankalan	(20 MGD)	Inlet	7.2	368	228	560	-	40	7
	PH-I	Outlet	7.4	57	30	86	-	30	1.4
	Real Time Reading at Outlet		7.74	41.38	47.84	135.22	-	15.15	-
	(20 MGD)	Inlet	7.3	311	216	-	-	44	6.6
	PH-II	Outlet	7.6	96	36	-	-	26	3
	Real Time Reading at Outlet		8.36	23.02	23.19	48.98	-	7.4	-
Najafgarh	(05 MGD)	Inlet	7.3	455	227	640	-	47	5.8
		Outlet	7.7	22	17	58	-	9	1
	Real Time Reading at Outlet		7.36	35.78	44.38	111.14	-	7	-
Okhla	12 MGD	Inlet	7.3	264	203	432	9	39	2.5
		outlet	7.4	41	26	104	3	36	1.5
	Real Time Reading at Outlet								
	45 MGD	Inlet	7.2	284	210	464	6	41	2.2
		outlet	7.4	35	24	96	1	32	1
	Real Time Reading at Outlet								
	37 MGD	Inlet	7.2	284	210	464	6	41	2.2
		outlet	7.7	33	23	96	1	31	0.8
	Real Time Reading at Outlet								
	16 MGD	Inlet	7.2	284	210	464	6	41	2.2
		outlet	7.8	30	20	80	NIL	28	NIL
	Real Time Reading at Outlet								

OFFICE OF THE DIRECTOR (T&QC)				
DELHI JAL BOARD: GOVT. OF NCT OF DELHI				
WATER WORKS WAZIRABAD:DELHI-110054				
Name of the Plant	Capacity (in MGD)	29.02.2020		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC Limit	50	30	250
Yamuna Vihar	10 MGD Phase-I	24	19	-
	10 MGD Phase-II	22	17	-
	25 MGD Phase-III	29	20	-
Rithala	40 MGD	48	24	100
	40 MGD	17	12	60
Corronation pillar	20 MGD Phase-I &II	94	73	118
	10 MGD Phase-III	132	115	178
Rohini	15 MGD	35	22	-
Keshopur	12 MGD	13	7	34
	20 MGD	114	107	348
	40 MGD	144	126	394
Nilothi	40 MGD	42	27	112
	20 MGD	16	12	44
Pappankalan	(20 MGD)	57	30	86
	(20 MGD)	96	36	-
Najafgarh	05 MGD	22	17	58
Okhla	12 MGD	41	26	104
	45 MGD	35	24	96
	37 MGD	33	23	96
	16 MGD	30	20	80