



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Parameters of STPs of Delhi as on							18.05.2019		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Okhla	12 MGD	Inlet	7.4	230	174	432	3	35	1.5
		outlet	7.6	28	18	64	1	28	0.8
	Real Time Reading at Outlet								
	45 MGD	Inlet	7.4	236	167	424	3	36	1.6
		outlet	7.7	26	16	56	1	25	0.6
	Real Time Reading at Outlet								
	37 MGD	Inlet	7.4	236	167	424	3	36	1.6
		outlet	7.7	30	16	64	1	27	0.5
	Real Time Reading at Outlet								
	16 MGD	Inlet	7.4	236	167	424	3	36	1.6
		outlet	7.8	10	8	32	Nil	24	0.4
	Real Time Reading at Outlet								
Mehrauli	5 MGD	Inlet	7.4	224	210	416	4	33	2
		outlet	7.9	10	9	32	1	26	1.2
	Real Time Reading at Outlet								
Vasant Kunj	2.2 MGD	Inlet	7.5	254	215	432	4	35	2
		outlet	7.7	12	8	32	1	26	1.5
	Real Time Reading at Outlet								
	3 MGD	Inlet	7.4	264	195	408	3	33	2.2
		outlet	7.6	10	8	32	Nil	24	1.1
	Real Time Reading at Outlet								
Ghitorni	5 MGD	Inlet	7.4	312	285	512	4	33	1.8
		outlet	7.8	28	19	72	1	20	1.1
	Real Time Reading at Outlet								
Kondli	25 MGD Phase-II	Inlet	7.3	382	177	392	18	36	7.3
		outlet	7.6	22	13	48	3	27	2.7
	Real Time Reading at Outlet		7.3	20	21	45		34	
	45 MGD Phase-IV	Inlet	7.3	274	170	296	23	38	7.1
		outlet	7.5	29	19	68	4.8	31	3.4
	Real Time Reading at Outlet		7.1	27	15	41		5	
Chilla	9 MGD	Inlet	7.2	136	78	160	-	40	6.9
		outlet	7.7	8	3	19	-	0.24	4.7
	Real Time Reading at Outlet		7.2	9	2	20		6	
CWG Village	1 MGD	Inlet	7.2	816	275	776	-	19	4.6
		outlet	7.7	1	Bdl	Bdl	-	0.12	1
	Real Time Reading at Outlet		7.4	0.4	0.53	2		0.14	
Yamuna Vihar	10 MGD Phase-I	Inlet	7.2	388	244	892	-	55	6
		outlet	7.5	45	29	158	-	35	3.5
	Real Time Reading at Outlet								
	10 MGD Phase-II	Inlet	7.3	452	288	1129	-	30	4
		outlet	7.5	49	30	142	-	10	1.5
	Real Time Reading at Outlet								
25 MGD Phase-	Inlet	7.2	264	163	681	-	50	5.5	

	III		outlet	7.5	27	17	117	-	30	2.5
	Real Time Reading at Outlet									
Rithala	40 MGD	Inlet	7.2	236	143	290	29	30	0.7	
		outlet	7.9	44	29	100	8	21	0.6	
	Real Time Reading at Outlet									
	40 MGD	Inlet	7.2	236	143	290	29	30	0.7	
		Outlet	7.8	16	11	50	3	13	0.3	
	Real Time Reading at Outlet									
Keshopur	12 MGD	Inlet	7.4	384	213	-	-	32	3.4	
		outlet	7.6	15	8	-	-	13	2	
	Real Time Reading at Outlet		7.5	5.3	4	23		7.4	-	
	40 MGD	Inlet	7.4	432	247	-	-	34	3.6	
		outlet	7.6	128	90	-	-	29	3.1	
	Real Time Reading at Outlet		7.8	62	51	137		21		
	20 MGD	Inlet	7.4	432	247	-	-	34	3.6	
		outlet	7.5	220	119	-	-	30	3.2	
	Real Time Reading at Outlet		6.3	104	102	223		36		
Nilothi	40 MGD Phase-I	Inlet	7.3	172	145	-	-	28	2.8	
		outlet	7.5	42	29	-	-	24	2	
	Real Time Reading at Outlet		7.4	43	32	107		27		
Pappankalan	20 MGD Phase-II	Inlet	7.3	334	220	-	10	40	3.2	
		outlet	7.8	35	15	-	2	16	1	
	Real Time Reading at Outlet					-				
	20 MGD Phase-II	Inlet	7.3	334	220	-	-	40	3.2	
		outlet	7.7	11	10	-	-	28	2.2	
	Real Time Reading at Outlet									
Corronation pillar	20 MGD Phase-I & II	Inlet	6.7	270	230	316	7.2	37	2.2	
		outlet	7.1	47	28	96	3.1	22	1.2	
	Real Time Reading at Outlet		7.4	47	28	101	-	26		
	10 MGD Phase-III	Inlet	6.8	480	355	508	-	53	2.4	
		outlet	7.2	94	48	138	-	38	1.7	
	Real Time Reading at Outlet		7	57	33	143	-	23		

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	18.05.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC limits	50	30	250
Okhla	12 MGD	28	18	64
	45 MGD	26	16	56
	37 MGD	30	16	64
	16 MGD	10	8	32
Mehrauli	5 MGD	10	9	32
Vasant Kunj	2.2 MGD	12	8	32
	3 MGD	10	8	32
Ghitorni	5 MGD	28	19	72
Kondli	25 MGD	22	13	48
	45 MGD	29	19	68
Chilla	9 MGD	8	3	19
CWG Village	1 MGD	1	Bdl	Bdl
Yamuna Vihar	10 MGD	45	29	158
	10 MGD	49	30	142
	25 MGD	27	17	117
Rithala	40 MGD	44	29	100
	40 MGD	16	11	50
Keshopur	12 MGD	15	8	-
	40 MGD	128	90	-
	20 MGD	220	119	-
Nilothi	40 MGD	42	29	-
Pappankalan	20 MGD	35	15	-
	20 MGD	11	10	-
Corronation pillar	20 MGD	47	28	96
	10 MGD	94	48	138



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Parameters of STPs of Delhi as on							19.05.2019		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Okhla	12 MGD	Inlet	7.5	210	158	424	3	33	1.2
		outlet	7.6	30	17	72	1	26	0.6
	Real Time Reading at Outlet								
	45 MGD	Inlet	7.4	312	223	464	3	34	1.2
		outlet	7.7	30	16	72	1	25	0.5
	Real Time Reading at Outlet								
	37 MGD	Inlet	7.4	312	223	464	3	34	1.2
		outlet	7.8	20	15	56	1	26	0.6
	Real Time Reading at Outlet								
	16 MGD	Inlet	7.4	312	223	464	3	34	1.2
		outlet	7.8	15	10	40	Nil	24	0.5
	Real Time Reading at Outlet								
Kondli	25 MGD Phase-II	Inlet	7.3	300	164	335	-	40	6.8
		outlet	7.6	15	11	32	-	31	3.2
	Real Time Reading at Outlet		7.3	20	14	43		35	
	45 MGD Phase-IV	Inlet	7.3	276	200	294	-	42	6.9
		outlet	7.5	28	17	64	-	33	3.5
	Real Time Reading at Outlet		6.7	29	49	49		47	
Yamuna Vihar	10 MGD Phase-I	Inlet	7	272	196	683	-	45	4
		outlet	7.6	38	23	111	-	20	2
	Real Time Reading at Outlet								
	10 MGD Phase-II	Inlet	7.2	260	179	652	-	35	5
		outlet	7.7	39	25	120	-	15	2.5
	Real Time Reading at Outlet								
	25 MGD Phase-III	Inlet	7.3	428	269	1063	-	50	5.5
		outlet	7.6	26	15	129	-	25	2.5
Real Time Reading at Outlet									
Rithala	40 MGD	Inlet	7.2	256	156	360	-	28	1
		outlet	7.7	40	28	110	-	20	0.7
	Real Time Reading at Outlet								
	40 MGD	Inlet	7.2	256	156	360	-	28	1
		Outlet	7.3	17	12	60	-	14	0.6
	Real Time Reading at Outlet								
Keshopur	12 MGD	Inlet	7.2	288	215	-	-	28	2.7
		outlet	7.5	18	8	-	-	12	2
	Real Time Reading at Outlet		7.4	5.3	4.8	23.16		7.6	
	40 MGD	Inlet	7.2	320	283	-	-	27	2.6
		outlet	7.4	94	58	-	-	24	2.2
	Real Time Reading at Outlet		7.7	73.4	51.9	148.4		76.5	
	20 MGD	Inlet	7.2	320	283	-	-	27	2.6
outlet		7.4	170	138	-	-	28	1.9	
Real Time Reading at Outlet		6.4	167.1	103.5	256.8		64.7		
	40 MGD Phase-	Inlet	7.2	208	149	-	-	26	2.2

Nilothe	I	outlet	7.4	40	29	-	-	24	1.8
	Real Time Reading at Outlet		7.2	46	34	110		26	
Pappankalan	20 MGD Phase-II	Inlet	7.3	348	259	-	11	42	3.4
		outlet	7.7	30	16	-	2	14	1
	Real Time Reading at Outlet								
	20 MGD Phase-II	Inlet	7.3	348	259	-	11	42	3.4
		outlet	7.6	12	11	-	-	28	2.2
	Real Time Reading at Outlet								
Corronation pillar	20 MGD Phase-I &II	Inlet	6.5	228	205	305	-	39	2.3
		outlet	7.1	44	29	88	-	23	1.4
	Real Time Reading at Outlet								
	10 MGD Phase-III	Inlet	7.1	520	360	616	7.9	54	22.5
		outlet	7.4	66	38	126	3.4	36	1.9
	Real Time Reading at Outlet								

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	19.05.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC limits	50	30	250
Okhla	12 MGD	30	17	72
	45 MGD	30	16	72
	37 MGD	20	15	56
	16 MGD	15	10	40
Kondli	25 MGD	15	11	32
	45 MGD	28	17	64
Yamuna Vihar	10 MGD	38	23	111
	10 MGD	39	25	120
	25 MGD	26	15	129
Rithala	40 MGD	40	28	110
	40 MGD	17	12	60
Keshopur	12 MGD	18	8	-
	40 MGD	94	58	-
	20 MGD	170	138	-
Nilothi	40 MGD	40	29	-
Pappankalan	20 MGD	30	16	-
	20 MGD	12	11	-
Corronation pillar	20 MGD	44	29	88
	10 MGD	66	38	126



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Parameters of STPs of Delhi as on							20.05.2019		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Okhla	12 MGD	Inlet	7.3	246	200	440	5	42	1.8
		outlet	7.7	31	22	80	2	32	0.5
	Real Time Reading at Outlet								
	45 MGD	Inlet	7.4	378	258	488	6	44	2.5
		outlet	7.9	17	14	48	2	33	0.5
	Real Time Reading at Outlet								
	37 MGD	Inlet	7.4	378	258	488	6	44	2.5
		outlet	7.8	35	23	96	2	35	1.2
	Real Time Reading at Outlet								
	16 MGD	Inlet	7.4	378	258	488	6	44	2.5
outlet		7.8	15	11	48	1	30	0.8	
Real Time Reading at Outlet									
Kondli	25 MGD Phase-II	Inlet	7.1	270	169	312	18	41	7.4
		outlet	7.6	12	8	27	2.5	33	2.7
	Real Time Reading at Outlet								
	45 MGD Phase-IV	Inlet	7.1	276	180	320	24	41	7
		outlet	7.5	30	19	68	4	31	3
	Real Time Reading at Outlet								
Chilla	9 MGD	Inlet	7.1	116	94	152	18	39	6.7
		outlet	7.5	10	4	24	2	0.34	4.7
	Real Time Reading at Outlet								
CWG Village	1 MGD	Inlet	7.2	484	308	520	26	29	5.2
		outlet	7.6	1	0.54	1	Bdl	0.12	1
	Real Time Reading at Outlet								
Yamuna Vihar	10 MGD Phase-I	Inlet	7.4	376	261	-	-	35	4
		outlet	7.6	45	28	-	-	10	2
	Real Time Reading at Outlet								
	10 MGD Phase-II	Inlet	7.4	444	300	-	-	30	4.5
		outlet	7.6	44	25	-	-	10	2.5
	Real Time Reading at Outlet								
	25 MGD Phase-III	Inlet	7.2	436	235	-	-	40	3.5
outlet		7.6	30	18	-	-	20	2	
Real Time Reading at Outlet									
Rithala	40 MGD	Inlet	7.3	284	162	380		42	2.3
		outlet	8	39	26	100		32	1.7
	Real Time Reading at Outlet								
	40 MGD	Inlet	7.3	284	162	380	0	42	2.3
		Outlet	7.9	18	13	70		21	1.2
Real Time Reading at Outlet									
	12 MGD	Inlet	7.3	236	189	422	-	31	3
		outlet	7.6	14	11	38	-	12	1.9
	Real Time Reading at Outlet		7.6	5.31	4.94	23.41		7.5	

Keshopur	40 MGD	Inlet	7.3	372	251	727	-	34	3.1
		outlet	7.6	114	83	208	-	28	2.4
	Real Time Reading at Outlet		7.7	87.04	55.72	182.56		43.14	
	20 MGD	Inlet	7.3	372	251	727	-	34	3.1
		outlet	7.5	108	133	280	-	30	2.4
	Real Time Reading at Outlet		6.3	203.91	118.94	304.14		40.6	
Nilothi	40 MGD Phase-I	Inlet	7.3	210	155	-	4.6	27	2.5
		outlet	7.4	38	28	-	0.4	25	2
	Real Time Reading at Outlet		7.2	44	33	109	-	26	-
	20 MGD Phase-II	Inlet	-	-	-	-	-	-	-
		outlet	-	-	-	-	-	-	-
	Real Time Reading at Outlet		6.8	4.98	2.6	15.82	-	1.34	-
Najafgarh	5 MGD Phase-II	Inlet	7.3	393	160	-	-	30	3
		outlet	7.7	13	7	-	-	10	1.8
	Real Time Reading at Outlet		7.7	85.6	41.8	-	-	21.08	-
Pappankalan	20 MGD Phase-II	Inlet	7.4	293	190	268.34	-	40	3.2
		outlet	7.6	39	11		-	16	0.8
	Real Time Reading at Outlet		7.3	19.8	26.5	135.7	-	16.95	-
	20 MGD Phase-II	Inlet	7.3	341	-	268.34	-	42	3.2
		outlet	7.6	17	9		-	-	-
	Real Time Reading at Outlet		6.8	23.5	8.16	35.4	-	11.31	-
Corronation pillar	20 MGD Phase-I & II	Inlet	6.7	260	220	328	7.7	35	2.6
		outlet	7.2	41	27	86	3.3	20	1.6
	Real Time Reading at Outlet		-	-	-	-	-	-	-
	10 MGD Phase-III	Inlet	7	300	310	486	-	56	2.3
		outlet	7.5	68	39	122	-	34	1.3
	Real Time Reading at Outlet								

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	20.05.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC limits	50	30	250
Okhla	12 MGD	31	22	80
	45 MGD	17	14	48
	37 MGD	35	23	96
	16 MGD	15	11	48
Kondli	25 MGD	12	8	27
	45 MGD	30	19	68
Chilla	9 MGD	10	4	24
CWG Village	1 MGD	1	0.54	1
Yamuna Vihar	10 MGD	45	28	-
	10 MGD	44	25	-
	25 MGD	30	18	-
Rithala	40 MGD	39	26	100
	40 MGD	18	13	70
Keshopur	12 MGD	14	11	38
	40 MGD	114	83	208
	20 MGD	108	133	280
Nilothi	40 MGD	38	28	-
Najafgarh	5 MGD	13	7	-
Pappankalan	20 MGD	39	11	-
	20 MGD	17	9	-
Corronation pillar	20 MGD	41	27	86
	10 MGD	68	39	122



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Parameters of STPs of Delhi as on							21.05.2019		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Okhla	12 MGD	Inlet	7.3	194	218	424	4	48	1.8
		outlet	7.8	37	23	96	2	28	0.5
	Real Time Reading at Outlet								
	45 MGD	Inlet	7.3	220	163	432	4	45	1.8
		outlet	7.8	23	18	64	1	28	0.5
	Real Time Reading at Outlet								
	37 MGD	Inlet	7.3	220	163	432	4	45	1.8
		outlet	7.8	42	27	96	2	30	0.5
	Real Time Reading at Outlet								
	16 MGD	Inlet	7.3	220	163	432	4	45	1.8
		outlet	7.9	20	15	56	Nil	25	0.8
	Real Time Reading at Outlet								
Kondli	25 MGD Phase-II	Inlet	7.1	352	205	392	-	43	7.4
		outlet	7.6	11	8	24	-	35	2.9
	Real Time Reading at Outlet								
	45 MGD Phase-IV	Inlet	7.1	342	173	384	-	42	7.3
		outlet	7.5	30	18	72	-	37	3.5
	Real Time Reading at Outlet								
Chilla	9 MGD	Inlet	7.1	116	90	152	-	43	7.2
		outlet	7.6	9	4	22	-	0.38	5
	Real Time Reading at Outlet								
CWG Village	1 MGD	Inlet	7.1	824	456	561	-	29	5.4
		outlet	7.7	Bdl	Bdl	Bdl	-	0.12	1.2
	Real Time Reading at Outlet								
Yamuna Vihar	10 MGD Phase-I	Inlet	7.3	344	221	656	-	40	4.5
		outlet	7.6	37	23	120	-	20	2
	Real Time Reading at Outlet								
	10 MGD Phase-II	Inlet	7.4	280	183	672	-	35	4
		outlet	7.7	27	17	96	-	15	2
	Real Time Reading at Outlet								
	25 MGD Phase-III	Inlet	7.4	320	186	608	-	35	3.5
outlet		7.7	28	18	112	-	20	2	
Real Time Reading at Outlet									
Rithala	40 MGD	Inlet	7.1	268	163	360	18	34	1.4
		outlet	7.8	41	27	120	9	23	1.1
	Real Time Reading at Outlet								
	40 MGD	Inlet	7.1	268	163	360	18	34	1.4
		Outlet	7.7	20	15	60	5	15	0.8
Real Time Reading at Outlet									
	12 MGD	Inlet	7.3	328	230	-	-	29	3.2
		outlet	7.7	11	7	-	-	10	1.8
	Real Time Reading at Outlet		7.7	5.4	5.1	24.2		6.3	

Keshopur	40 MGD	Inlet	7.3	440	287	-	-	32	3
		outlet	7.5	104	101	-	-	26	2.7
	Real Time Reading at Outlet		7.7	79.67	53.2	158.6		55.3	
	20 MGD	Inlet	7.3	440	287	-	-	32	3
		outlet	7.5	112	111	-	-	30	2.9
	Real Time Reading at Outlet		6.4	248.6	109.9	304.3		35	
Nilothi	40 MGD Phase-I	Inlet	7.3	240	141	-	-	30	3.5
		outlet	7.5	44	27	-	-	25	2.8
	Real Time Reading at Outlet		7.3	50	36	116	-	24	
	20 MGD Phase-II	Inlet	7.3	264	153	496	6.8	30	3
		outlet	7.4	6	6	28	0	7	2
	Real Time Reading at Outlet		7.5	4	3	17.8	-	0.82	
Najafgarh	5 MGD Phase-II	Inlet	7.3	180	102	200	-	28	3
		outlet	7.8	11	10	108	-	14	2
	Real Time Reading at Outlet		7.6	33.5	19.7	56.8	-	22.8	
Pappankalan	20 MGD Phase-II	Inlet	7.3	429	243	660	-	38	3
		outlet	7.8	31	22	92	-	14	0.1
	Real Time Reading at Outlet		7.3	22.5	18.3	127.5	-	11.1	-
	20 MGD Phase-II	Inlet	7.3	365	210	-	-	38	3.4
		outlet	7.7	14	9	-	-	28	1.4
	Real Time Reading at Outlet		6.6	26.3	10.1	41.8	-	10.3	-
Corronation pillar	20 MGD Phase-I & II	Inlet	6.6	248	215	318	-	37	2.3
		outlet	7.3	45	29	92	-	22	1.3
	Real Time Reading at Outlet		7.6	48	28	102	-	26	-
	10 MGD Phase-III	Inlet	7	472	345	504	8.3	54	2.4
		outlet	7.3	74	41	138	3.5	42	1.8
	Real Time Reading at Outlet		7	57.6	33	143	-	23	-

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	21.05.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC limits	50	30	250
Okhla	12 MGD	37	23	96
	45 MGD	23	18	64
	37 MGD	42	27	96
	16 MGD	20	15	56
Kondli	25 MGD	11	8	24
	45 MGD	30	18	72
Chilla	9 MGD	9	4	22
CWG Village	1 MGD	Bdl	Bdl	Bdl
Yamuna Vihar	10 MGD	37	23	120
	10 MGD	27	17	96
	25 MGD	28	18	112
Rithala	40 MGD	41	27	120
	40 MGD	20	15	60
Keshopur	12 MGD	11	7	-
	40 MGD	104	101	-
	20 MGD	112	111	-
Nilothi	40 MGD	44	27	-
	20 MGD	6	6	28
Najafgarh	5 MGD	11	10	108
Pappankalan	20 MGD	31	22	92
	20 MGD	14	9	-
Corronation pillar	20 MGD	45	29	92
	10 MGD	74	41	138



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Parameters of STPs of Delhi as on							22.05.2019		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Okhla	12 MGD	Inlet	7.3	292	187	440	6	38	2.2
		outlet	7.6	39	22	96	2	29	0.8
	Real Time Reading at Outlet								
	45 MGD	Inlet	7.2	310	235	472	6	37	1.9
		outlet	7.6	21	16	-	3	30	0.7
	Real Time Reading at Outlet								
	37 MGD	Inlet	7.2	310	235	472	6	37	1.9
		outlet	7.8	30	18	-	1	31	0.6
	Real Time Reading at Outlet								
	16 MGD	Inlet	7.2	310	235	472	6	37	1.9
outlet		7.8	18	12	-	Nil	28	0.4	
Real Time Reading at Outlet									
Kondli	25 MGD Phase-II	Inlet	7.1	292	200	328	18	40	7
		outlet	7.6	14	9	32	3.2	33	3
	Real Time Reading at Outlet		7.3	18	4.8	39		35	
	45 MGD Phase-IV	Inlet	7.1	286	199	376	24	39	7.1
		outlet	7.5	29	19	64	4	34	3.4
	Real Time Reading at Outlet		6.8	26	15	38		17	
Chilla	9 MGD	Inlet	7.1	128	98	158	-	40	7.1
		outlet	7.6	8	3.8	18	-	0.34	4.9
	Real Time Reading at Outlet		7.2	10	2.5	21		6.2	
CWG Village	1 MGD	Inlet	7.1	548	350	584	-	23	5.1
		outlet	7.6	Bdl	0.57	Bdl	-	0.14	1.6
	Real Time Reading at Outlet		7.4	0.15	0.12	1.39		0.09	
Yamuna Vihar	10 MGD Phase-I	Inlet	7.4	220	170	566	28	40	4.4
		outlet	7.8	40	32	121	14	20	2
	Real Time Reading at Outlet								
	10 MGD Phase-II	Inlet	7.4	224	177	573	10.8	35	5.5
		outlet	7.8	28	18	85	4.4	15	3.5
	Real Time Reading at Outlet								
	25 MGD Phase-III	Inlet	7.3	316	218	805	14.4	45	5
outlet		7.7	24	18	70	6.4	25	2.5	
Real Time Reading at Outlet									
Rithala	40 MGD	Inlet	7.2	280	161	340	-	28	1.6
		outlet	7.3	39	25	100	-	26	0.7
	Real Time Reading at Outlet						-		
	40 MGD	Inlet	7.2	280	161	340	-	28	1.6
		Outlet	7.8	17	12	50	-	15	0.4
Real Time Reading at Outlet									
	12 MGD	Inlet	7.5	316	215	-	15.8	28	3.7
		outlet	7.8	10	9	-	-	9	1.1
	Real Time Reading at Outlet		7.5	5.34	5.4	25.14		7.54	

Keshopur	40 MGD	Inlet	7.3	532	253	-	18	33	3.9
		outlet	7.6	86	89	-	2.1	24	3.5
	Real Time Reading at Outlet		7.5	79.58	41.3	130.7		32.2	
	20 MGD	Inlet	7.3	532	253	-	18	33	3.9
		outlet	7.4	136	125	-	5.6	31	3.8
	Real Time Reading at Outlet		6.3	242.1	123.4	336.7		32.05	
Nilothi	40 MGD Phase-I	Inlet	7.2	204	153	480	5.2	28	2.5
		outlet	7.4	48	27	110	0.2	24	2
	Real Time Reading at Outlet		7.3	61	43	131		25	
	20 MGD Phase-II	Inlet	-	-	-	-	-	-	-
		outlet	-	-	-	-	-	-	-
	Real Time Reading at Outlet		7.5	4.9	2.7	18.3		0.91	
Najafgarh	5 MGD Phase-II	Inlet	7.2	253	175	-	-	28	3.5
		outlet	7.7	16	9	-	-	10	2.8
	Real Time Reading at Outlet		7.6	33.8	20.6	59.8		24.9	
Pappankalan	20 MGD Phase-II	Inlet	7.3	342	215	-	-	36	3.6
		outlet	7.7	29	13	-	-	16	0.6
	Real Time Reading at Outlet		7.3	21.95	23.88	133.45		13.05	
	20 MGD Phase-II	Inlet	7.1	335	230	-	-	38	3.6
		outlet	7.6	12	8	-	-	20	1
	Real Time Reading at Outlet		6.5	26.46	13.5	45.62		9.7	
Corronation pillar	20 MGD Phase-I & II	Inlet	6.6	252	220	356	7.9	39	2.2
		outlet	7	58	36	106	3.4	24	1.1
	Real Time Reading at Outlet		7.4	48	28	102		26	
	10 MGD Phase-III	Inlet	7	336	310	470	-	56	2.5
		outlet	7.4	78	42	110	-	40	1.7
	Real Time Reading at Outlet		7	57	33	143		23	

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	22.05.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC limits	50	30	250
Okhla	12 MGD	39	22	96
	45 MGD	21	16	-
	37 MGD	30	18	-
	16 MGD	18	12	-
Kondli	25 MGD	14	9	32
	45 MGD	29	19	64
Chilla	9 MGD	8	3.8	18
CWG Village	1 MGD	Bdl	0.57	Bdl
Yamuna Vihar	10 MGD	40	32	121
	10 MGD	28	18	85
	25 MGD	24	18	70
Rithala	40 MGD	39	25	100
	40 MGD	17	12	50
Keshopur	12 MGD	10	9	-
	40 MGD	86	89	-
	20 MGD	136	125	-
Nilothi	40 MGD	48	27	110
Najafgarh	5 MGD	16	9	-
Pappankalan	20 MGD	29	13	-
	20 MGD	12	8	-
Corronation pillar	20 MGD	58	36	106
	10 MGD	78	42	110



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Parameters of STPs of Delhi as on							23.05.2019		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Okhla	12 MGD	Inlet	7.4	230	163	416	4	42	2.8
		outlet	7.7	49	28	112	1	38	2.2
	Real Time Reading at Outlet								
	45 MGD	Inlet	7.4	254	175	432	4	45	2.5
		outlet	7.8	27	18	72	1	38	0.5
	Real Time Reading at Outlet								
	37 MGD	Inlet	7.4	254	175	432	4	45	2.5
		outlet	7.8	39	24	88	1	35	2
	Real Time Reading at Outlet								
	16 MGD	Inlet	7.4	254	175	432	4	45	2.5
		outlet	7.9	15	11	40	Nil	35	0.5
	Real Time Reading at Outlet								
Kondli	25 MGD Phase-II	Inlet	7.1	296	177	328	-	39	6.9
		outlet	7.7	21	15	43	-	32	2.8
	Real Time Reading at Outlet		7.3	19	10	41		36	
	45 MGD Phase-IV	Inlet	7.2	232	170	264	-	40	6.8
		outlet	7.5	50	32	120	-	33	3.1
	Real Time Reading at Outlet		6.8	26	15	38		22	
Chilla	9 MGD	Inlet	7	132	146	160	-	41	6.7
		outlet	7.6	9	3	19	-	0.32	4.6
	Real Time Reading at Outlet		7.3	10	2.6	21		6.2	
CWG Village	1 MGD	Inlet	-	-	-	-	-	-	-
		outlet	-	-	-	-	-	-	-
	Real Time Reading at Outlet		7.5	0.15	0.12	1.4		0.09	
Yamuna Vihar	10 MGD Phase-I	Inlet	7.4	304	184	769	-	35	4
		outlet	7.8	37	16	114	-	15	1.5
	Real Time Reading at Outlet								
	10 MGD Phase-II	Inlet	7.5	264	193	675	-	30	35
		outlet	7.8	49	28	149	-	10	1
	Real Time Reading at Outlet								
	25 MGD Phase-III	Inlet	7.4	268	202	693	-	40	5.5
outlet		7.7	20	15	62	-	20	2	
Real Time Reading at Outlet									
Rithala	40 MGD	Inlet	7	256	162	380	-	26	0.9
		outlet	7.7	40	25	100	-	19	0.7
	Real Time Reading at Outlet								
	40 MGD	Inlet	7	256	162	380	-	26	0.9
		Outlet	7.6	18	13	60	-	12	0.5
Real Time Reading at Outlet									
	12 MGD	Inlet	7.4	284	233	613	-	30	3.6
		outlet	7.7	12	8	36	-	10	1.4
	Real Time Reading at Outlet		7.6	5.3	5.8	26.5		7.4	

Keshopur	40 MGD	Inlet	7.3	528	281	853	-	34	3.7
		outlet	7.5	98	96	256	-	26	3.4
	Real Time Reading at Outlet		7.7	72	52.7	150.4		37.7	
	20 MGD	Inlet	7.3	528	281	853	-	34	3.7
		outlet	7.6	104	130	384	-	32	3.6
	Real Time Reading at Outlet		6.4	219.5	122.1	324.8		38.9	
Nilothe	40 MGD Phase-I	Inlet	7.3	198	147	-	-	29	2.2
		outlet	7.5	46	27	-	-	25	1.5
	Real Time Reading at Outlet		7.3	55.8	43.4	130.8		24.18	
Najafgarh	5 MGD Phase-II	Inlet	7.3	122	108	-	-	28	3.6
		outlet	7.6	16	11	-	-	10	2.8
	Real Time Reading at Outlet		7.7	37.43	22.5	75.7		14.3	
Pappankalan	20 MGD Phase-II	Inlet	7.3	275	207	620	10	40	3.6
		outlet	7.5	25	13	84	2	16	0.6
	Real Time Reading at Outlet		7.3	19.9	17	125.9		14.9	-
	20 MGD Phase-II	Inlet	7.4	253	237	-	-	42	3.6
		outlet	7.6	10	8	-	-	22	1
	Real Time Reading at Outlet		6.6	26.8	10.6	43.4		9.7	
Corronation pillar	20 MGD Phase-I & II	Inlet	6.7	274	230	362	-	36	2
		outlet	7.2	54	32	88	-	24	1
	Real Time Reading at Outlet		7.5	48	28	102	-	31	-
	10 MGD Phase-III	Inlet	6.6	436	340	510	8.1	52	2.3
		outlet	7.1	64	37	96	3.3	38	1.5
	Real Time Reading at Outlet		7	57	33	143		23	

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	23.05.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC limits	50	30	250
Okhla	12 MGD	49	28	112
	45 MGD	27	18	72
	37 MGD	39	24	88
	16 MGD	15	11	40
Kondli	25 MGD	21	15	43
	45 MGD	50	32	120
Chilla	9 MGD	9	3	19
Yamuna Vihar	10 MGD	37	16	114
	10 MGD	49	28	149
	25 MGD	20	15	62
Rithala	40 MGD	40	25	100
	40 MGD	18	13	60
Keshopur	12 MGD	12	8	36
	40 MGD	98	96	256
	20 MGD	104	130	384
Nilothi	40 MGD	46	27	-
Najafgarh	5 MGD	16	11	-
Pappankalan	20 MGD	25	13	84
	20 MGD	10	8	-
Corronation pillar	20 MGD	54	32	88
	10 MGD	64	37	96



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



		Parameters of STPs of Delhi as on					24.05.2019		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Okhla	12 MGD	Inlet	7.3	318	218	464	3	42	3
		outlet	7.8	48	29	112	Nil	38	2.4
	Real Time Reading at Outlet								
	45 MGD	Inlet	7.4	282	193	440	2	46	2.8
		outlet	7.8	22	15	56	Nil	28	0.4
	Real Time Reading at Outlet								
	37 MGD	Inlet	7.4	282	193	440	2	46	2.8
		outlet	7.7	32	16	72	Nil	35	1.8
	Real Time Reading at Outlet								
	16 MGD	Inlet	7.4	282	193	440	2	46	2.8
		outlet	7.8	15	9	40	Nil	33	1.6
	Real Time Reading at Outlet								
	New 30 MGD	Inlet	7.3	288	197	432	4	46	2.8
		Outlet	7.4	5	4	16	Nil	8	1.5
Real Time Reading at Outlet									
Mehrauli	5 MGD	Inlet	7.5	298	228	480	3	40	2
		outlet	8.1	13	10	40	Nil	30	1
	Real Time Reading at Outlet								
Vasant Kunj	2.2 MGD	Inlet	7.5	910	510	688	8	45	1.5
		outlet	7.8	18	14	-	Nil	22	0.5
	Real Time Reading at Outlet								
	3 MGD	Inlet	7.5	162	143	-	6	42	2.2
		outlet	8	5	2	-	Nil	15	1.8
	Real Time Reading at Outlet								
Ghitorni	5 MGD	Inlet	7.3	204	400	600	4	60	2.2
		outlet	8.1	61	45	176	7	55	1.8
	Real Time Reading at Outlet								
Kondli	25 MGD Phase-II	Inlet	7.2	336	223	328	-	38	7.4
		outlet	7.7	14	9	32	-	29	3
	Real Time Reading at Outlet		7.3	19	9	33		39	
	45 MGD Phase-IV	Inlet	7.2	316	163	302	-	39	7.3
		outlet	7.4	68	39	139	-	32	3.8
	Real Time Reading at Outlet		6.8	26	15	39		22	
Chilla	9 MGD	Inlet	7.1	200	108	232	-	40	7.2
		outlet	7.7	8	2.9	16	-	0.28	5.4
	Real Time Reading at Outlet		7.3	11	2.7	22		7	
CWG Village	1 MGD	Inlet	7.1	264	181	306	-	22	7
		outlet	7.7	1	0.76	0.8	-	0.08	1.2
	Real Time Reading at Outlet		7.4	0	0.12	1.3		0.08	
	10 MGD Phase-I	Inlet	7.4	316	163	-	-	50	4.5
		outlet	7.7	43	25	-	-	30	2
	Real Time Reading at Outlet								

Yamuna Vihar	10 MGD Phase-II	Inlet	7.4	260	161	660	-	45	4
		outlet	7.6	27	20	89	-	20	1.5
	Real Time Reading at Outlet								
	25 MGD Phase-III	Inlet	7.5	276	156	702	-	55	5.5
		outlet	7.6	26	19	79	-	25	2.5
	Real Time Reading at Outlet								
Rithala	40 MGD	Inlet	7.1	352	163	320	-	24	0.7
		outlet	7.8	38	25	100	-	20	0.7
	Real Time Reading at Outlet								
	40 MGD	Inlet	7.1	352	163	320	-	24	0.7
		Outlet	7.7	17	12	60	-	14	0.4
	Real Time Reading at Outlet								
Keshopur	12 MGD	Inlet	7.4	488	221	-	14.6	30	3.6
		outlet	7.7	14	8	-	-	12	1.3
	Real Time Reading at Outlet		7.5	5.3	5.9	25.9	-	7.3	
	40 MGD	Inlet	7.3	604	239	-	16	31	3.8
		outlet	7.5	104	101	-	6.2	27	3.2
	Real Time Reading at Outlet		7.4	75	52	52	-	28	
	20 MGD	Inlet	7.3	604	239	-	16	31	3.8
		outlet	7.6	112	121	-	8	29	3.4
Nilothi	Real Time Reading at Outlet		6.6	182.4	110	274	-	27.6	
	40 MGD Phase-I	Inlet	7.4	210	155	-	-	29	3
		outlet	7.5	42	26	-	-	24	2
	Real Time Reading at Outlet		7.4	55.4	22	106	-	24	
	20 MGD Phase-II	Inlet	7.3	324	160	520	7.8	30	3.5
		outlet	7.4	12	7	30	0	8	1.8
Najafgarh	Real Time Reading at Outlet		7.4	5.8	2.8	20.1	-	4.5	
	5 MGD Phase-II	Inlet	7.3	300	178	-	-	28	3.6
		outlet	7.7	22	17	-	-	10	2.8
Pappankalan	Real Time Reading at Outlet		7.6	36.5	20.3	68.07	-	26.2	
	20 MGD Phase-II	Inlet	7.3	402	256	-	36	3.6	-
		outlet	7.7	28	16	-	14	0.6	-
	Real Time Reading at Outlet		7.4	22.3	17.5	126.78		15.9	
	20 MGD Phase-II	Inlet	7.2	298	265	-	-	38	3.6
		outlet	7.6	11	10	-	-	22	1
Corronation pillar	Real Time Reading at Outlet		6.6	26.9	11.6	40.36	-	9.9	
	20 MGD Phase-I & II	Inlet	7	224	215	324	8.2	38	2.5
		outlet	7.3	47	27	86	3.1	24	1.5
	Real Time Reading at Outlet		7.4	48	28	102		31	
	10 MGD Phase-III	Inlet	6.8	320	275	468	-	58	2.4
		outlet	7.3	82	37	118	-	41	1.8
	Real Time Reading at Outlet		6.9	75	38	141		30	

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	24.05.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC limits	50	30	250
Okhla	12 MGD	48	29	112
	45 MGD	22	15	56
	37 MGD	32	16	72
	16 MGD	15	9	40
	New 30 MGD	5	4	16
Mehrauli	5 MGD	13	10	40
Vasant Kunj	2.2 MGD	18	14	-
	3 MGD	5	2	-
Ghitorni	5 MGD	61	45	176
Kondli	25 MGD	14	9	32
	45 MGD	68	39	139
Chilla	9 MGD	8	2.9	16
CWG Village	1 MGD	1	0.76	0.8
Yamuna Vihar	10 MGD	43	25	-
	10 MGD	27	20	89
	25 MGD	26	19	79
Rithala	40 MGD	38	25	100
	40 MGD	17	12	60
Keshopur	12 MGD	14	8	-
	40 MGD	104	101	-
	20 MGD	112	121	-
Nilothi	40 MGD	42	26	-
	20 MGD	12	7	30
Najafgarh	5 MGD	22	17	-
Pappankalan	20 MGD	28	16	-
	20 MGD	11	10	-
Corronation pillar	20 MGD	47	27	86
	10 MGD	82	37	118



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Parameters of STPs of Delhi as on							25.05.2019		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Okhla	12 MGD	Inlet	7.5	172	148	376	3	40	2.5
		outlet	7.9	46	28	112	1	35	2
	Real Time Reading at Outlet								s
	45 MGD	Inlet	7.4	224	203	400	3	40	2.3
		outlet	7.7	36	22	88	Nil	33	2
	Real Time Reading at Outlet								
	37 MGD	Inlet	7.4	224	203	400	3	40	2.3
		outlet	7.7	33	20	80	Nil	35	2
	Real Time Reading at Outlet								
	16 MGD	Inlet	7.4	224	203	400	3	40	2.3
		outlet	7.8	16	13	48	Nil	30	1.8
	Real Time Reading at Outlet								
Kondli	25 MGD Phase-II	Inlet	7.1	394	180	348	-	37	6.7
		outlet	7.7	14	8	34	-	34	1.3
	Real Time Reading at Outlet		7.3	19	11	38		38	
	45 MGD Phase-IV	Inlet	7.1	336	185	322	-	37	6.9
		outlet	7.5	43	29	106	-	31	3.5
	Real Time Reading at Outlet		6.7	28	16	43		111	
Chilla	9 MGD	Inlet	7.1	292	95	254	-	40	6.7
		outlet	7.7	9	3	22	-	0.3	4.9
	Real Time Reading at Outlet		7.2	12	3	22		6.21	
CWG Village	1 MGD	Inlet	7.1	672	338	453	-	25	6.8
		outlet	7.7	Bdl	Bdl	Bdl	-	0.28	1.4
	Real Time Reading at Outlet		7.5	0.16	0.12			0.09	
Yamuna Vihar	10 MGD Phase-I	Inlet	7.3	332	201	-	-	50	4
		outlet	7.6	34	21	-	-	35	2
	Real Time Reading at Outlet								
	10 MGD Phase-II	Inlet	7.3	300	199	-	-	40	4
		outlet	7.6	26	20	-	-	35	1.5
	Real Time Reading at Outlet								
	25 MGD Phase-III	Inlet	7.2	328	204	-	-	50	5
outlet		7.6	28	19	-	-	45	2.5	
Real Time Reading at Outlet									
Rithala	40 MGD	Inlet	7.1	260	156	340	21	32	1
		outlet	7.7	35	25	110	5	28	0.9
	Real Time Reading at Outlet								
	40 MGD	Inlet	7.1	260	156	340	21	32	1
		Outlet	7.6	18	13	60	3	14	0.5
Real Time Reading at Outlet									
	12 MGD	Inlet	7.4	192	164	-	-	29	3.5
		outlet	7.7	10	8	-	-	10	1.4
	Real Time Reading at Outlet		7.7	5.4	6.3	28.1		6.4	

Keshopur	40 MGD	Inlet	7.3	560	271	-	-	34	3.6
		outlet	7.5	110	94	-	-	27	3.1
	Real Time Reading at Outlet		7.7	67.2	50.1	143		26.9	
	20 MGD	Inlet	7.3	560	261	-	-	34	3.6
		outlet	7.6	128	116	-	-	30	3.2
	Real Time Reading at Outlet		6.5	151	103.9	249		26.7	
Nilothi	40 MGD Phase-I	Inlet	7.4	196	142	-	-	28	3.8
		outlet	7.5	44	24	-	-	22	3
	Real Time Reading at Outlet		7.3	40.2	24.2	108.8		22.4	
	20 MGD Phase-II	Inlet	-	-	-	-	-	-	-
		outlet	-	-	-	-	-	-	-
	Real Time Reading at Outlet		7.4	8.5	2.9	22.3		4.6	
Najafgarh	5 MGD Phase-II	Inlet	7.3	191	162	-	-	22	3.6
		outlet	7.7	14	9	-	-	4	2.8
	Real Time Reading at Outlet		7.7	42.8	21.4	88.5		13.8	
Pappankalan	20 MGD Phase-II	Inlet	7.3	275	200	-	-	26	3.6
		outlet	7.6	27	17	-	-	16	0.6
	Real Time Reading at Outlet		7.3	15.9	11.3	117.5		25.5	
	20 MGD Phase-II	Inlet	7.3	399	212	-	-	26	3.6
		outlet	7.7	7	5	-	-	20	1
	Real Time Reading at Outlet		6.6	27.5	8.6	40.6		10.2	
Corronation pillar	20 MGD Phase-I & II	Inlet	6.9	320	205	382	-	40	2.7
		outlet	7.4	60	34	112	-	22	1.6
	Real Time Reading at Outlet								
	10 MGD Phase-III	Inlet	7	450	338	526	8.4	54	2.5
		outlet	7.5	74	38	114	3.6	35	1.4
	Real Time Reading at Outlet								

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	25.05.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC limits	50	30	250
Okhla	12 MGD	46	28	112
	45 MGD	36	22	88
	37 MGD	33	20	80
	16 MGD	16	13	48
Kondli	25 MGD	14	8	34
	45 MGD	43	29	106
Chilla	9 MGD	9	3	22
CWG Village	1 MGD	Bdl	Bdl	Bdl
Yamuna Vihar	10 MGD	34	21	-
	10 MGD	26	20	-
	25 MGD	28	19	-
Rithala	40 MGD	35	25	110
	40 MGD	18	13	60
Keshopur	12 MGD	10	8	-
	40 MGD	110	94	-
	20 MGD	128	116	-
Nilothi	40 MGD	44	24	-
Najafgarh	5 MGD	14	9	-
Pappankalan	20 MGD	27	17	-
	20 MGD	7	5	-
Corronation pillar	20 MGD	60	34	112
	10 MGD	74	38	114