



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



		Parameters of STPs of Delhi as on					20.04.2019			
Name of the Plant	Capacity (in MGD)	Parameter								
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4	
		DPPC limits	5.5-9.0	50	30	250	10	50	5	
Okhla	12 MGD	Inlet	7.3	210	185	360	4	45	2	
		outlet	7.4	25	15	56	1	40	1.3	
	45 MGD	Inlet	7.3	248	213	400	4	44	2.2	
		outlet	7.5	13	12	48	Nil	39	0.4	
	37 MGD	Inlet	7.3	248	213	400	4	44	2.2	
		outlet	7.6	32	20	80	1	36	0.6	
	16 MGD	Inlet	7.3	248	213	400	4	44	2.2	
		outlet	7.5	12	11	40	Nil	36	0.5	
Kondli	25 MGD Phase-II	Inlet	7.3	284	210	296	14	39	6.8	
		outlet	7.7	20	14	44	3	29	2.7	
	45 MGD Phase-IV	Inlet	7.2	430	256	392	26	41	6.9	
		outlet	7.5	44	26	96	5	34	3.4	
Chilla	9 MGD	Inlet	7.1	244	102	280	12	40	6.9	
		outlet	7.6	9	5	22	2	0.24	4.7	
CWG Village	1 MGD	Inlet	7.2	1172	512	717	28	24	4.8	
		outlet	7.7	1	Bdl	Bdl	Bdl	0.14	1.6	
Yamuna Vihar	10 MGD Phase-I	Inlet	7.3	292	222	528	-	55	7	
		outlet	7.7	21	14	104	-	30	2.5	
	Phase-II	Inlet	7.3	340	239	576	-	35	5.5	
		outlet	7.7	23	16	68	-	20	3.5	
	25 MGD Phase-III	Inlet	7.2	244	168	659	-	45	7.5	
		outlet	7.7	27	17	109	-	30	4.5	
Rithala	40 MGD	Inlet	7.2	276	165	340		30	0.9	
		outlet	7.7	28	18	80		16	0.6	
	40 MGD	Inlet	7.2	276	165	340	0	30	0.9	
		Outlet	7.6	17	12	50		12	0.4	
	Keshopur	12 MGD	Inlet	7.4	480	180	-	-	33	4.3
			outlet	7.6	11	7	-	-	6	1.4
40 MGD		Inlet	7.4	512	187	-	-	34	5.7	
		outlet	7.6	100	65	-	-	28	3.6	
20 MGD	Inlet	7.4	512	187	-	-	34	5.7		
	outlet	7.5	142	99	-	-	32	2.6		
Nilothi	40 MGD Phase-I	Inlet	7.3	216	145	240	4.2	28	2.6	
		outlet	7.5	34	24	96	0.8	22	2	
Nazafgarh	5 MGD	Inlet	7.3	228	168	-	-	22	2	
		outlet	7.6	25	14	-	-	6	1.2	
PappanKalan	20 MGD Phase-I	Inlet	7.4	409	198	580	-	38	3	
		outlet	7.7	26	13	90	-	16	0.4	
	20 MGD Phase-II	Inlet	7.4	409	198	580	-	38	3	
		outlet	7.6	26	20	80	-	28	1.8	
Corronation pillar	20 MGD Phase-I & II	Inlet	6.9	220	195	344	-	35	1.9	
		outlet	7.4	52	31	88	-	25	0.9	
	10 MGD Phase-III	Inlet	7	456	320	456	6.9	54	2.6	
		outlet	7.5	72	35	132	2.1	33	1.5	
Narela	10 MGD	Inlet	7.4	200	185	352	7.7	58	2.4	
		outlet	7.7	64	39	110	2.8	36	1.5	

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	20.04.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
		50	30	250
Okhla	12 MGD	25	15	56
	45 MGD	13	12	48
	37 MGD	32	20	80
	16 MGD	12	11	40
Kondli	25 MGD Pahse-II	20	14	44
	45 MGD Phase-IV	44	26	96
Chilla	9 MGD	9	5	22
CWG Village	1 MGD	1	Bdl	Bdl
Yamuna Vihar	10 MGD Phase-I	21	14	104
	Phase-II	23	16	68
	25 MGD Phase-III	27	17	109
Rithala	40 MGD Phase-I	28	18	80
	40 MGD Phase-II	17	12	50
Keshopur	12 MGD	11	7	-
	40 MGD	100	65	-
	20 MGD	142	99	-
Nilothi	40 MGD Pahse-I	34	24	96
Nazafgarh	5 MGD	25	14	-
PappanKalan	20 MGD Phase-I	26	13	90
	20 MGD Phase-II	26	20	80
Corronation pillar	20 MGD Pahse-I & II	52	31	88
	10 MGD Pahse-III	72	35	132
Narela	10 MGD	64	39	110



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	Parameters of STPs of Delhi as on					21.04.2019		
		DPPC limits	Parameter						
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		5.5-9.0	50	30	250	10	50	5	
Okhla	12 MGD	Inlet	7.3	208	223	400	4	44	2.4
		outlet	7.8	40	24	96	2	40	1.2
	45 MGD	Inlet	7.4	230	245	432	4	42	2.6
		outlet	7.6	36	18	72	2	35	0.8
	37 MGD	Inlet	7.4	230	245	432	4	42	2.6
		outlet	7.6	38	21	80	2	36	0.8
	16 MGD	Inlet	7.4	230	245	432	4	42	2.6
		outlet	7.7	12	11	40	1	30	0.4
Kondli	25 MGD Phase-II	Inlet	7.3	296	156	308	-	38	6.8
		outlet	7.7	13	7	32	-	30	2.5
	45 MGD Phase-IV	Inlet	7.2	268	137	280	-	43	6.9
		outlet	7.6	30	16	68	-	36	3.2
Yamuna Vihar	10 MGD Phase-I	Inlet	7.2	260	128	493	-	50	6
		outlet	7.6	34	21	96	-	20	3
	Phase-II	Inlet	7.4	252	192	456	-	40	5.5
		outlet	7.7	38	17	80	-	15	2
	25 MGD Phase-III	Inlet	7.3	288	181	552	-	60	6
		outlet	7.7	28	19	120	-	35	3.5
Rithala	40 MGD	Inlet	7	232	163	340	-	33	1.4
		outlet	7.8	30	19	80	-	27	1
	40 MGD	Inlet	7	232	163	340	-	33	1.4
		Outlet	7.5	18	14	60	-	17	0.6
Keshopur	12 MGD	Inlet	7.3	376	228	-	-	32	3.9
		outlet	7.6	10	7	-	-	7	1.5
	40 MGD	Inlet	7.3	392	241	-	-	35	4.4
		outlet	7.5	92	75	-	-	29	3.2
	20 MGD	Inlet	7.3	392	241	-	-	35	4.4
		outlet	7.4	132	121	-	-	30	2.8
Nilothi	40 MGD Phase-I	Inlet	7.3	236	139	-	-	28	2.8
		outlet	7.5	38	23	-	-	22	2.2
PappanKalan	20 MGD Phase-I	Inlet	7.3	412	206	-	-	38	3.2
		outlet	7.6	30	16	-	-	16	0.4
	20 MGD Phase-II	Inlet	7.3	412	206	-	-	38	3.2
		outlet	7.6	25	21	-	-	28	1.8
Corronation pillar	20 MGD Phase-I & II	Inlet	6.9	240	225	358	7.5	38	1.6
		outlet	7.3	58	34	115	2.2	24	0.7
	10 MGD Phase-III	Inlet	7	470	340	526	-	58	2.3
		outlet	7.5	64	36	138	-	36	1.3

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	21.04.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
		50	30	250
Okhla	12 MGD	40	24	96
	45 MGD	36	18	72
	37 MGD	38	21	80
	16 MGD	12	11	40
Kondli	25 MGD Pahse-II	13	7	32
	45 MGD Phase-IV	30	16	68
Yamuna Vihar	10 MGD Phase-I	34	21	96
	Phase-II	38	17	80
	25 MGD Phase-III	28	19	120
Rithala	40 MGD Phase-I	30	19	80
	40 MGD Phase-II	18	14	60
Keshopur	12 MGD	10	7	-
	40 MGD	92	75	-
	20 MGD	132	121	-
Nilothi	40 MGD Pahse-I	38	23	-
PappanKalan	20 MGD Phase-I	30	16	-
	20 MGD Phase-II	25	21	-
Corronation pillar	20 MGD Pahse-I & II	58	34	115
	10 MGD Pahse-III	64	36	138



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



		Parameters of STPs of Delhi as on					22.04.2019			
Name of the Plant	Capacity (in MGD)	Parameter								
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4	
		DPPC limits	5.5-9.0	50	30	250	10	50	5	
Okhla	12 MGD	Inlet	7	398	240	458	5	38	2.2	
		outlet	7.8	26	18	72	3	33	1	
	45 MGD	Inlet	7.4	326	265	448	3	38	2	
		outlet	7.7	25	16	64	1	35	0.8	
	37 MGD	Inlet	7.4	326	265	448	3	38	2	
		outlet	7.5	35	24	96	2	36	0.6	
	16 MGD	Inlet	7.4	326	265	448	3	38	2	
		outlet	7.7	14	13	48	Nil	35	0.5	
	New 30 MGD	Inlet	7.7	376	245	-	3	40	2.4	
		Outlet	7.7	10	8	-	Nil	5	1	
Mehrauli	5 MGD	Inlet	7.3	390	268	496	5	40	1.2	
		outlet	8	16	12	48	Nil	23	-	
Vasant Kunj	2.2 MGD	Inlet	7.4	466	263	512	-	48	0.8	
		outlet	8	9	10	40	-	43	0.6	
	3 MGD	Inlet	7.7	130	205	360	-	49	1.5	
		outlet	7.6	7	8	32	-	10	0.9	
Kondli	25 MGD Phase-II	Inlet	7.3	306	214	312	17	42	6.9	
		outlet	7.7	17	11	38	4	35	3.3	
	45 MGD Phase-IV	Inlet	7.3	348	233	352	25	40	6.8	
		outlet	7.5	30	18	62	5	33	3.5	
Chilla	9 MGD	Inlet	7.1	208	134	256	14	40	6.7	
		outlet	7.7	8	5	18	2	0.32	4.5	
CWG Village	1 MGD	Inlet	7.2	456	238	560	30	22	4.7	
		outlet	7.7	Bdl	Bdl	Bdl	Bdl	0.14	1	
Yamuna Vihar	10 MGD Phase-I	Inlet	7.4	372	257	552	-	50	7	
		outlet	7.9	38	21	109	-	20	3	
	Phase-II	Inlet	7.4	388	251	548	-	30	6	
		outlet	7.9	20	13	62	-	15	2.5	
	25 MGD Phase-III	Inlet	7.3	328	221	512	-	55	7.5	
		outlet	7.8	24	15	80	-	25	4	
Rithala	40 MGD	Inlet	7.3	276	174	330	-	38	2.2	
		outlet	7.6	31	19	90	-	24	1.2	
	40 MGD	Inlet	7.3	276	174	330	-	38	2.2	
		Outlet	7.8	17	12	60	-	17	0.8	
Keshopur	12 MGD	Inlet	7.4	492	260	-	13	28	3.1	
		outlet	7.7	12	6	-	Nil	8	1.8	
	40 MGD	Inlet	7.4	420	228	-	18.2	32	3.4	
		outlet	7.5	72	47	-	2.2	24	2.9	
	20 MGD	Inlet	7.4	420	228	-	18.2	32	3.4	
		outlet	7.6	142	118	-	6	30	2.8	
Nilothi	40 MGD Phase-I	Inlet	7.3	176	119	-	5.9	26	2.4	
		outlet	7.4	40	27	-	0.6	22	2	
	20 MGD Phase-II	Inlet	7.3	360	178	560	8.8	29	3	
		outlet	7.2	10	7	30	Nil	3	1.8	
Nazafgarh	5 MGD	Inlet	7.4	291	192	-	-	24	2.2	
		outlet	7.7	21	15	-	-	6	1	
PappanKalan	20 MGD Phase-I	Inlet	7.3	328	197	-	-	42	3.2	
		outlet	7.9	19	15	-	-	14	0.4	
	20 MGD Phase-II	Inlet	7.3	328	197	-	-	42	3.2	
		outlet	7.5	22	21	-	-	38	2	
Corronation pillar	20 MGD Phase-I & II	Inlet	7	266	230	394	-	36	1.4	
		outlet	7.5	55	33	104	-	23	0.8	
	10 MGD Phase-III	Inlet	7.2	314	305	468	7	56	2.5	
		outlet	7.5	61	35	128	3	32	1.4	
Narela	10 MGD	Inlet	6.9	198	180	376	8.4	60	2.9	
		outlet	7.4	58	36	102	3.3	38	1.8	

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	22.04.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
		50	30	250
Okhla	12 MGD	26	18	72
	45 MGD	25	16	64
	37 MGD	35	24	96
	16 MGD	14	13	48
	New 30 MGD	10	8	-
Mehrauli	5 MGD	16	12	48
Vasant Kunj	2.2 MGD	9	10	40
	3 MGD	7	8	32
Kondli	25 MGD Pahse-II	17	11	38
	45 MGD Phase-IV	30	18	62
Chilla	9 MGD	8	5	18
CWG Village	1 MGD	Bdl	Bdl	Bdl
Yamuna Vihar	10 MGD Phase-I	38	21	109
	Phase-II	20	13	62
	25 MGD Phase-III	24	15	80
Rithala	40 MGD Phase-I	31	19	90
	40 MGD Phase-II	17	12	60
Keshopur	12 MGD	12	6	-
	40 MGD	72	47	-
	20 MGD	142	118	-
Nilothi	40 MGD Pahse-I	40	27	-
	20 MGD Phase-II	10	7	30
Nazafgarh	5 MGD	21	15	-
PappanKalan	20 MGD Phase-I	19	15	-
	20 MGD Phase-II	22	21	-
Corronation pillar	20 MGD Pahse-I & II	55	33	104
	10 MGD Pahse-III	61	35	128
Narela	10 MGD	58	36	102



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



		Parameters of STPs of Delhi as on					23.04.2019		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPPC limits	5.5-9.0	50	30	250	10	50	5
Okhla	12 MGD	Inlet	7.4	256	235	416	4	40	2
		outlet	7.6	43	28	104	2	36	0.5
	45 MGD	Inlet	7.5	276	215	432	4	42	2.2
		outlet	7.7	34	22	80	1	36	0.8
	37 MGD	Inlet	7.5	276	215	432	4	42	2.2
		outlet	7.8	31	21	80	1	37	0.5
16 MGD	Inlet	7.5	276	215	432	4	42	2.2	
	outlet	7.8	14	10	40	Nil	35	1	
Kondli	25 MGD Phase-II	Inlet	7.3	286	230	296	15	39	7.1
		outlet	7.7	14	8	32	3	34	2.4
	45 MGD Phase-IV	Inlet	7.2	334	256	344	24	41	7
		outlet	7.5	29	19	59	5	30	3.2
Chilla	9 MGD	Inlet	7.2	204	129	216	15	42	6.7
		outlet	7.6	8	4.8	18	3	0.29	4.4
CWG Village	1 MGD	Inlet	7.2	852	348	616	26	26	4.6
		outlet	7.7	1	Bdl	Bdl	Bdl	0.17	1.4
Yamuna Vihar	10 MGD Phase-I	Inlet	7.3	300	181	448	22.4	45	5
		outlet	7.6	43	24	104	12	15	2
	Phase-II	Inlet	7.3	456	305	360	21.2	30	6
		outlet	7.8	18	10	56	10.4	10	3
	25 MGD Phase-III	Inlet	7.2	288	213	520	33.2	50	7.5
		outlet	7.9	22	14	70	15.6	20	3.5
Rithala	40 MGD	Inlet	7	292	178	410	-	33	1.2
		outlet	7.6	29	18	80	-	19	0.7
	40 MGD	Inlet	7	292	178	410	-	33	1.2
		Outlet	7.7	16	11	50	-	14	0.4
Keshopur	12 MGD	Inlet	7.4	268	188	580	-	27	3
		outlet	7.7	9	9	36	-	9	1.7
	40 MGD	Inlet	7.4	256	229	667	-	30	3.2
		outlet	7.6	86	76	280	-	26	2.7
	20 MGD	Inlet	7.4	256	229	667	-	30	3.2
		outlet	7.5	136	154	422	-	29	2.8
Nilothi	40 MGD Phase-I	Inlet	7.4	160	138	-	-	24	3
		outlet	7.5	32	27	-	-	19	2
	20 MGD Phase-II	Inlet	7.3	324	171	-	7.8	30	3.5
		outlet	7.4	10	7	-	Nil	2	1.8
Nazafgarh	5 MGD	Inlet	7.3	245	165	-	-	26	
		outlet	7.8	33	19	-	-	4	
PappanKalan	20 MGD Phase-I	Inlet	7.4	430	190	-	10	30	3.2
		outlet	7.8	47	28	-	-	20	0.4
	20 MGD Phase-II	Inlet	7.4	430	190	-	10	30	3.2
		outlet	7.6	29	16	-	-	28	1.6
Corronation pillar	20 MGD Phase-I & II	Inlet	7.1	304	285	416	9.3	34	1.7
		outlet	7.5	62	34	128	3.4	20	0.9
	10 MGD Phase-III	Inlet	7.4	440	345	482	-	52	2
		outlet	7.6	66	36	132	-	34	1

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	23.04.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
		50	30	250
Okhla	12 MGD	43	28	104
	45 MGD	34	22	80
	37 MGD	31	21	80
	16 MGD	14	10	40
Kondli	25 MGD Pahse-II	14	8	32
	45 MGD Phase-IV	29	19	59
Chilla	9 MGD	8	4.8	18
CWG Village	1 MGD	1	Bdl	Bdl
Yamuna Vihar	10 MGD Phase-I	43	24	104
	Phase-II	18	10	56
	25 MGD Phase-III	22	14	70
Rithala	40 MGD Phase-I	29	18	80
	40 MGD Phase-II	16	11	50
Keshopur	12 MGD	9	9	36
	40 MGD	86	76	280
	20 MGD	136	154	422
Nilothi	40 MGD Pahse-I	32	27	-
	20 MGD Phase-II	10	7	-
Nazafgarh	5 MGD	33	19	-
PappanKalan	20 MGD Phase-I	47	28	-
	20 MGD Phase-II	29	16	-
Corronation pillar	20 MGD Pahse-I & II	62	34	128
	10 MGD Pahse-III	66	36	132



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



		Parameters of STPs of Delhi as on					24.04.2019		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Okhla	12 MGD	Inlet	7.3	266	198	400	4	40	2
		outlet	7.6	86	36	160	4	42	0.5
	45 MGD	Inlet	7.3	322	238	432	4	44	2.5
		outlet	7.7	32	23	80	2	40	1
	37 MGD	Inlet	7.3	322	238	432	4	44	2.5
		outlet	7.7	16	11	40	1	38	0.8
16 MGD	Inlet	7.3	322	238	432	4	44	2.5	
	outlet	7.7	15	11	40	1	40	0.5	
Kondli	25 MGD Phase-II	Inlet	7.3	322	230	348	18	41	6.8
		outlet	7.7	12	8	26	3	32	2.9
	45 MGD Phase-IV	Inlet	7.3	282	184	288	22	42	6.6
		outlet	7.5	30	18	62	5	35	3.7
Chilla	9 MGD	Inlet	7.1	348	148	360	18	43	6.7
		outlet	7.6	7	4	16	3	0.32	4.5
CWG Village	1 MGD	Inlet	7.2	372	270	396	24	28.64	4.7
		outlet	7.7	1	0.45	0.8	Bdl	0.14	1.2
Yamuna Vihar	10 MGD Phase-I	Inlet	7.5	552	338	1097	-	55	6
		outlet	7.8	35	22	103	-	30	3.5
	Phase-II	Inlet	7.3	372	270	718	-	35	7
		outlet	7.8	25	17	75	-	15	4
	25 MGD Phase-III	Inlet	7.2	324	210	456	-	60	6.5
		outlet	7.7	26	16	80	-	35	3.5
Rithala	40 MGD	Inlet	7.2	264	179	-	-	38	1.4
		outlet	7.8	35	23	-	-	25	0.8
	40 MGD	Inlet	7.2	264	179	-	-	38	1.4
		Outlet	7.6	17	12	-	-	16	0.5
Keshopur	12 MGD	Inlet	7.4	348	192	-	-	30	3.4
		outlet	7.8	10	6	-	-	8	1.8
	40 MGD	Inlet	7.4	644	261	-	-	32	3.6
		outlet	7.9	112	74	-	-	28	2.9
	20 MGD	Inlet	7.4	644	261	-	-	32	3.6
		outlet	7.6	130	106	-	-	31	3.1
Nilothi	40 MGD Phase-I	Inlet	7.3	212	147	-	5.8	26	3.8
		outlet	7.4	30	24	-	0.3	20	2.6
	20 MGD Phase-II	Inlet	7.2	348	158	580	8	28	3
		outlet	7.2	13	8	32	Nil	3	2
Nazafgarh	5 MGD	Inlet	7.2	259	180	-	-	14	-
		outlet	7.6	20	15	-	-	6	-
PappanKalan	20 MGD Phase-I	Inlet	7.3	600	208	720	-	38	3.2
		outlet	7.8	57	24	136	-	14	0.4
	20 MGD Phase-II	Inlet	7.3	600	208	720	-	38	3.2
		outlet	7.6	31	19	50	-	36	1.6
Corronation pillar	20 MGD Phase-I & II	Inlet	7.2	324	305	446	7.8	38	2.2
		outlet	7.5	78	38	124	3.2	24	1
	10 MGD Phase-III	Inlet	7.3	530	350	640	9.5	56	2.4
		outlet	7.7	82	43	128	3.4	32	1.3

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	24.04.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
		50	30	250
Okhla	12 MGD	86	36	160
	45 MGD	32	23	80
	37 MGD	16	11	40
	16 MGD	15	11	40
Kondli	25 MGD Pahse-II	12	8	26
	45 MGD Phase-IV	30	18	62
Chilla	9 MGD	7	4	16
CWG Village	1 MGD	1	0.45	0.8
Yamuna Vihar	10 MGD Phase-I	35	22	103
	Phase-II	25	17	75
	25 MGD Phase-III	26	16	80
Rithala	40 MGD Phase-I	35	23	-
	40 MGD Phase-II	17	12	-
Keshopur	12 MGD	10	6	-
	40 MGD	112	74	-
	20 MGD	130	106	-
Nilothi	40 MGD Pahse-I	30	24	-
	20 MGD Phase-II	13	8	32
Nazafgarh	5 MGD	20	15	-
PappanKalan	20 MGD Phase-I	57	24	136
	20 MGD Phase-II	31	19	50
Corronation pillar	20 MGD Pahse-I & II	78	38	124
	10 MGD Pahse-III	82	43	128



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



		Parameters of STPs of Delhi as on					25.04.2019		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
	45 MGD	Inlet	7.5	284	180	424	2	40	2.8
		outlet	7.8	42	24	104	Nil	33	0.5
	37 MGD	Inlet	7.5	284	180	424	2	40	2.8
		outlet	7.8	33	20	88	Nil	34	1
	16 MGD	Inlet	7.5	284	180	424	2	40	2.8
		outlet	7.9	22	14	56	Nil	32	0.5
Kondli	25 MGD Phase-II	Inlet	7.3	262	137	298	15	42	7
		outlet	7.7	14	8	32	3	35	3.3
	45 MGD Phase-IV	Inlet	7.3	268	143	280	20	41	6.9
		outlet	7.6	30	16	64	5	34	3.5
Chilla	9 MGD	Inlet	7.2	244	128	256	15	41	7.1
		outlet	7.7	10	5.5	22	2	0.38	4.4
CWG Village	1 MGD	Inlet	7.2	656	330	664	28	28	5.2
		outlet	7.7	Bdl	0.54	Bdl	Bdl	0.02	1.4
Yamuna Vihar	10 MGD Phase-I	Inlet	7.3	432	256	942	-	50	8
		outlet	7.7	42	28	122	-	25	4
	Phase-II	Inlet	7.3	416	277	862	-	25	6.5
		outlet	7.7	35	20	108	-	10	3.5
	25 MGD Phase-III	Inlet	7.1	472	305	920	-	50	7
		outlet	7.5	27	19	114	-	30	3
Rithala	40 MGD	Inlet	7	256	183	460	-	32	0.9
		outlet	7.7	35	23	90	-	26	0.8
	40 MGD	Inlet	7	256	183	460	-	32	0.9
		Outlet	7.5	16	13	60	-	12	0.7
Keshopur	12 MGD	Inlet	7.4	292	191	-	-	32	3.6
		outlet	7.6	12	6	-	-	9	2.1
	40 MGD	Inlet	7.4	564	212	-	-	34	4.3
		outlet	7.5	88	81	-	-	29	3.3
	20 MGD	Inlet	7.4	564	212	-	-	34	4.3
		outlet	7.5	136	117	-	-	30	3.6
Nilothi	40 MGD Phase-I	Inlet	7.3	196	126	-	-	25	3.5
		outlet	7.5	32	22	-	-	21	2.5
Nazafgarh	5 MGD	Inlet	7.3	353	168	-	-	14	3.6
		outlet	7.7	24	17	-	-	6	1.2
PappanKalan	20 MGD Phase-I	Inlet	7.4	434	207	-	-	42	3.2
		outlet	7.7	62	31	-	-	14	0.4
	20 MGD Phase-II	Inlet	7.4	434	207	-	-	42	3.2
		outlet	7.7	27	20	-	-	38	2.2
Corronation pillar	20 MGD Phase-I & II	Inlet	7	320	295	394	8.7	34	2
		outlet	7.4	59	36	116	3.3	20	0.9
	10 MGD Phase-III	Inlet	7.2	510	345	644	-	54	2.2
		outlet	7.6	98	48	192	-	30	1.1

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	25.04.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
		50	30	250
	45 MGD	42	24	104
	37 MGD	33	20	88
	16 MGD	22	14	56
Kondli	25 MGD Pahse-II	14	8	32
	45 MGD Phase-IV	30	16	64
Chilla	9 MGD	10	5.5	22
CWG Village	1 MGD	Bdl	0.54	Bdl
Yamuna Vihar	10 MGD Phase-I	42	28	122
	Phase-II	35	20	108
	25 MGD Phase-III	27	19	114
Rithala	40 MGD Phase-I	35	23	90
	40 MGD Phase-II	16	13	60
Keshopur	12 MGD	12	6	-
	40 MGD	88	81	-
	20 MGD	136	117	-
Nilothi	40 MGD Pahse-I	32	22	-
Nazafgarh	5 MGD	24	17	-
PappanKalan	20 MGD Phase-I	62	31	-
	20 MGD Phase-II	27	20	-
Corronation pillar	20 MGD Pahse-I & II	59	36	116
	10 MGD Pahse-III	98	48	192



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



		Parameters of STPs of Delhi as on					26.04.2019		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
	45 MGD	Inlet	7.3	282	184	392	-	38	2.8
		outlet	7.7	28	21	72	-	35	0.5
	37 MGD	Inlet	7.3	282	184	392	-	38	2.8
		outlet	7.5	22	22	56	-	33	0.8
	16 MGD	Inlet	7.3	282	184	392	-	38	2.8
		outlet	7.8	15	15	48	-	36	0.5
Kondli	25 MGD Phase-II	Inlet	7.4	330	278	352	18	40	6.8
		outlet	7.7	13	10	28	3	34	2.9
	45 MGD Phase-IV	Inlet	7.3	282	198	296	23	40	6.9
		outlet	7.6	30	19	68	5	35	3.2
Yamuna Vihar	10 MGD Phase-I	Inlet	7.6	328	242	-	-	40	5
		outlet	7.8	45	26	-	-	20	2
	Phase-II	Inlet	7.5	284	201	-	-	30	6.5
		outlet	7.8	16	9	-	-	15	3
	25 MGD Phase-III	Inlet	7.5	464	259	-	-	55	7.5
		outlet	7.5	29	17	-	-	30	4
Rithala	40 MGD	Inlet	7.2	268	181	480	-	37	1.6
		outlet	8	44	23	90	-	28	1.4
	40 MGD	Inlet	7.2	268	181	480	-	37	1.6
		Outlet	7.8	18	14	60	-	19	0.8
Keshopur	12 MGD	Inlet	7.4	448	211	620	-	30	3.4
		outlet	7.6	10	7	36	-	8	2
	40 MGD	Inlet	7.3	512	319	906	-	31	3.9
		outlet	7.6	84	83	272	-	27	3.2
	20 MGD	Inlet	7.3	512	319	906	-	31	3.9
		outlet	7.5	134	115	312	-	28	3.5
Nilothi	40 MGD Phase-I	Inlet	7.3	224	136	-	-	28	3
		outlet	7.5	39	22	-	-	22	2.4
Nazafgarh	5 MGD	Inlet	7.3	168	105	-	-	14	3.6
		outlet	7.7	12	9	-	-	6	1.2
PappanKalan	20 MGD Phase-I	Inlet	7.4	198	152	-	-	42	3.2
		outlet	7.7	28	14	-	-	14	0.4
	20 MGD Phase-II	Inlet	7.4	198	152	-	-	42	3.2
		outlet	7.7	20	12	-	-	36	2
Corronation pillar	20 MGD Phase-I & II	Inlet	7.3	294	275	386	8.3	37	8.3
		outlet	7.7	62	37	112	3.5	22	3.5
	10 MGD Phase-III	Inlet	7	416	310	520	8.6	52	2.4
		outlet	7.6	82	42	124	3.7	32	1.2

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	26.04.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
		50	30	250
	45 MGD	28	21	72
	37 MGD	22	22	56
	16 MGD	15	15	48
Kondli	25 MGD Pahse-II	13	10	28
	45 MGD Phase-IV	30	19	68
Yamuna Vihar	10 MGD Phase-I	45	26	-
	Phase-II	16	9	-
	25 MGD Phase-III	29	17	-
Rithala	40 MGD Phase-I	44	23	90
	40 MGD Phase-II	18	14	60
Keshopur	12 MGD	10	7	36
	40 MGD	84	83	272
	20 MGD	134	115	312
Nilothi	40 MGD Pahse-I	39	22	-
Nazafgarh	5 MGD	12	9	-
PappanKalan	20 MGD Phase-I	28	14	-
	20 MGD Phase-II	20	12	-
Corronation pillar	20 MGD Pahse-I & II	62	37	112
	10 MGD Pahse-III	82	42	124



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



		Parameters of STPs of Delhi as on					27.04.2019			
Name of the Plant	Capacity (in MGD)	Parameter								
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4	
		DPCC limits	5.5-9.0	50	30	250	10	50	5	
	45 MGD	Inlet	7.3	254	225	408	3	40	2.5	
		outlet	7.6	21	15	56	1	36	1.5	
	37 MGD	Inlet	7.3	254	225	408	3	40	2.5	
		outlet	7.6	34	23	88	2	36	2	
	16 MGD	Inlet	7.3	254	225	408	3	40	2.5	
		outlet	7.8	19	12	48	Nil	34	0.5	
Kondli	25 MGD Phase-II	Inlet	7.3	356	247	386	16	42	7.1	
		outlet	7.6	26	17	54	3	32	3	
	45 MGD Phase-IV	Inlet	7.2	320	269	348	24	41	7	
		outlet	7.5	30	18	64	5	35	3.3	
Chilla	9 MGD	Inlet	7.2	196	120	212	18	39	6.8	
		outlet	7.6	8	5	18	3	0.3	4.3	
CWG Village	1 MGD	Inlet	7.2	612	362	618	28	26	5.1	
		outlet	7.7	1	0.38	Bdl	Bdl	0.05	1.3	
Yamuna Vihar	10 MGD Phase-I	Inlet	7.3	356	233	-	-	55	6.5	
		outlet	7.7	47	25	-	-	40	2.5	
	Phase-II	Inlet	7.4	372	258	-	-	40	7	
		outlet	7.8	35	23	-	-	25	4	
	25 MGD Phase-III	Inlet	7.2	728	370	-	-	60	8	
		outlet	7.8	28	18	-	-	35	5.5	
Rithala	40 MGD	Inlet	7.2	272	165	430	24	38	2	
		outlet	7.8	45	25	110	6	24	0.9	
	40 MGD	Inlet	7.2	272	165	430	24	38	2	
		Outlet	7.6	18	13	60	4	17	0.4	
	Keshopur	12 MGD	Inlet	7.4	240	211	-	12	33	3.2
			outlet	7.7	17	10	-	0.4	2	2.1
40 MGD		Inlet	7.4	540	256	-	16.2	34	3.5	
		outlet	7.6	116	98	-	2.3	32	3.1	
20 MGD	Inlet	7.4	540	256	-	16.2	34	3.5		
	outlet	7.5	146	107	-	6.1	30	3		
Nilothi	40 MGD Phase-I	Inlet	7.3	208	138	-	-	26	3	
		outlet	7.5	42	25	-	-	22	2.2	
	20 MGD Phase-II	Inlet	7.3	260	165	-	-	28	3.6	
		outlet	7.5	7	8	-	-	4	2	
Nazafgarh	5 MGD	Inlet	7.3	204	95	-	-	26	3.4	
		outlet	7.8	40	25	-	-	6	1.2	
PappanKalan	20 MGD Phase-I	Inlet	7.4	60	193	-	-	34	3.2	
		outlet	7.8	37	20	-	-	16	0.4	
	20 MGD Phase-II	Inlet	7.4	60	193	-	-	34	3.2	
		outlet	7.8	29	21	-	-	28	2	
Corronation pillar	20 MGD Phase-I & II	Inlet	7.2	290	270	396	-	36	2.2	
		outlet	7.4	76	40	116	-	23	1.2	
	10 MGD	Inlet	7.3	490	335	537	-	54	2.3	

	Phase-III	outlet	7.6	98	46	196	-	36	1.4
--	-----------	--------	-----	----	----	-----	---	----	-----

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	27.04.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
		50	30	250
	45 MGD	21	15	56
	37 MGD	34	23	88
	16 MGD	19	12	48
Kondli	25 MGD Pahse-II	26	17	54
	45 MGD Phase-IV	30	18	64
Chilla	9 MGD	8	5	18
CWG Village	1 MGD	1	0.38	Bdl
Yamuna Vihar	10 MGD Phase-I	47	25	-
	Phase-II	35	23	-
	25 MGD Phase-III	28	18	-
Rithala	40 MGD Phase-I	45	25	110
	40 MGD Phase-II	18	13	60
Keshopur	12 MGD	17	10	-
	40 MGD	116	98	-
	20 MGD	146	107	-
Nilothi	40 MGD Pahse-I	42	25	-
	20 MGD Phase-II	7	8	-
Nazafgarh	5 MGD	40	25	-
PappanKalan	20 MGD Phase-I	37	20	-
	20 MGD Phase-II	29	21	-
Corronation pillar	20 MGD Pahse-I & II	76	40	116
	10 MGD Pahse-III	98	46	196



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



		Parameters of STPs of Delhi as on					28.04.2019		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
	45 MGD	Inlet	7.2	258	215	416	3	42	2.4
		outlet	7.5	32	19	72	2	35	1
	37 MGD	Inlet	7.2	258	215	416	3	42	2.4
		outlet	7.6	25	15	56	2	32	0.6
	16 MGD	Inlet	7.2	258	215	416	3	42	2.4
		outlet	7.6	20	11	48	2	30	0.6
Kondli	25 MGD Phase-II	Inlet	7.2	222	114	264	-	40	6.9
		outlet	7.6	13	7	28	-	30	2.8
	45 MGD Phase-IV	Inlet	7.2	254	134	284	-	43	6.8
		outlet	7.5	29	16	60	-	34	3.1
Yamuna Vihar	10 MGD Phase-I	Inlet	7.2	192	161	-	-	50	7
		outlet	7.6	36	20	-	-	30	3
	Phase-II	Inlet	7.4	252	186	-	-	40	6.5
		outlet	7.6	28	20	-	-	20	3
	25 MGD Phase-III	Inlet	7.4	528	307	-	-	55	7.5
		outlet	7.5	25	15	-	-	30	3.5
Keshopur	12 MGD	Inlet	7.3	296	206	-	-	30	3.2
		outlet	7.6	14	9	-	-	7	1.9
	40 MGD	Inlet	7.4	356	216	-	-	32	3.4
		outlet	7.6	104	86	-	-	29	2.8
	20 MGD	Inlet	7.4	356	216	-	-	32	3.4
		outlet	7.5	140	111	-	-	27	2.9
Nilothi	40 MGD Phase-I	Inlet	7.4	196	124	-	6.8	25	2.8
		outlet	7.5	34	23	-	0.4	19	2.2
PappanKalan	20 MGD Phase-I	Inlet	7.4	340	205	-	-	36	3.2
		outlet	7.7	30	18	-	-	14	0.4
	20 MGD Phase-II	Inlet	7.4	340	205	-	-	36	3.2
		outlet	7.4	28	20	-	-	28	2
Corronation pillar	20 MGD Phase-I & II	Inlet	7.1	340	305	458	7.9	38	2.3
		outlet	7.4	84	42	129	3.3	24	1.3
	10 MGD Phase-III	Inlet	7.2	460	350	544	-	58	2.4
		outlet	7.6	72	41	188	-	34	1.3

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	28.04.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
		50	30	250
	45 MGD	32	19	72
	37 MGD	25	15	56
	16 MGD	20	11	48
Kondli	25 MGD Pahse-II	13	7	28
	45 MGD Phase-IV	29	16	60
Yamuna Vihar	10 MGD Phase-I	36	20	-
	Phase-II	28	20	-
	25 MGD Phase-III	25	15	-
Keshopur	12 MGD	14	9	-
	40 MGD	104	86	-
	20 MGD	140	111	-
Nilothi	40 MGD Pahse-I	34	23	-
PappanKalan	20 MGD Phase-I	30	18	-
	20 MGD Phase-II	28	20	-
Corronation pillar	20 MGD Pahse-I & II	84	42	129
	10 MGD Pahse-III	72	41	188



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



		Parameters of STPs of Delhi as on					29.04.2019		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPPC limits	5.5-9.0	50	30	250	10	50	5
Okhla	45 MGD	Inlet	7.4	342	235	-	4	44	1.5
		outlet	7.6	32	22	-	2	36	1
	37 MGD	Inlet	7.4	342	235	-	4	44	1.5
		outlet	7.6	19	12	-	1	35	1.2
	16 MGD	Inlet	7.4	342	235	-	4	44	1.5
		outlet	7.7	20	13	-	1	36	0.6
Kondli	25 MGD Phase-II	Inlet	7.2	230	118	256	15	40	6.9
		outlet	7.6	16	8	42	3	33	3.4
	45 MGD Phase-IV	Inlet	7.2	218	117	234	22	40	6.7
		outlet	7.5	28	15	70	4	34	4.3
Chilla	9 MGD	Inlet	7.2	280	144	234	20	41	6.5
		outlet	7.6	7	4	18	3	0.28	4.2
CWG Village	1 MGD	Inlet	7.3	292	148	306	22	21	4.8
		outlet	7.7	Bdl	0.36	Bdl	Bdl	0.03	1.4
Delhi Gate Nallah	2.2 MGD	Inlet	7.5	82	138	264	7	45	1.2
		outlet	7.7	5	6	24	Nil	26	0.4
	15 MGD	Inlet	7.5	96	125	272	7	48	1.5
		outlet	7.6	6	7	24	Nil	30	0.4
Sen Nursing Home	2.2 MGD	Inlet	7.5	258	218	392	6	46	1.5
		outlet	7.6	6	8	32	Nil	32	0.3
Yamuna Vihar	10 MGD Phase-I	Inlet	7.1	320	213	-	-	40	5
		outlet	7.7	40	25	-	-	15	2.5
	Phase-II	Inlet	7.5	304	193	-	-	30	6
		outlet	7.8	20	13	-	-	10	3
	25 MGD Phase-III	Inlet	7.5	604	346	-	-	45	5.5
		outlet	7.7	24	17	-	-	25	2
Rithala	40 MGD	Inlet	7.1	276	164	380	-	39	1.5
		outlet	7.7	46	27	100	-	31	1.1
	40 MGD	Inlet	7.1	276	164	380	-	39	1.5
		Outlet	7.6	16	11	60	-	17	0.6
Keshopur	12 MGD	Inlet	7.3	292	220	-	-	31	3.1
		outlet	7.5	12	7	-	-	8	1.7
	40 MGD	Inlet	7.3	712	300	-	-	34	3.2
		outlet	7.7	100	71	-	-	27	2.9
	20 MGD	Inlet	7.3	712	300	-	-	34	3.2
		outlet	7.4	124	140	-	-	29	3
Nilothi	40 MGD Phase-I	Inlet	7.4	284	146	-	-	26	4
		outlet	7.5	32	25	-	-	20	2.8
	20 MGD Phase-II	Inlet	7.3	312	176	510	8.7	28	3.5
		outlet	7.3	14	9	38	Nil	6	2
Nazafgarh	5 MGD	Inlet	7.3	234	165	-	-	26	3.4
		outlet	7.6	25	23	-	-	4	1.2
PappanKalan	20 MGD Phase-I	Inlet	7.4	2808	-	-	-	42	3.2
		outlet	7.6	26	20	-	-	14	0.4
	20 MGD Phase-II	Inlet	7.4	2808	-	-	-	42	3.2
		outlet	7.7	25	21	-	-	28	2
Corronation pillar	20 MGD Phase-I & II	Inlet	7	352	310	436	-	36	2
		outlet	7.4	96	44	132	-	22	0.9
	10 MGD Phase-III	Inlet	7.2	536	355	486	7.6	56	2.1
		outlet	7.5	90	43	114	2.9	32	1.2
Narela	10 MGD	Inlet	7	188	200	352	8.2	47	2.5
		outlet	7.5	54	38	108	3.1	34	1.3

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	29.04.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
		50	30	250
	45 MGD	32	22	-
	37 MGD	19	12	-
	16 MGD	20	13	-
Kondli	25 MGD Pahse-II	16	8	42
	45 MGD Phase-IV	28	15	70
Chilla	9 MGD	7	4	18
CWG Village	1 MGD	Bdl	0.36	Bdl
Delhi Gate Nallah	2.2 MGD Pahse-I	5	6	24
	15 MGD Pahse-II	6	7	24
Sen Nursing Home	2.2 MGD	6	8	32
Yamuna Vihar	10 MGD Phase-I	40	25	-
	Phase-II	20	13	-
	25 MGD Phase-III	24	17	-
Rithala	40 MGD Phase-I	46	27	100
	40 MGD Phase-II	16	11	60
Keshopur	12 MGD	12	7	-
	40 MGD	100	71	-
	20 MGD	124	140	-
Nilothi	40 MGD Pahse-I	32	25	-
	20 MGD Phase-II	14	9	38
Nazafgarh	5 MGD	25	23	-
PappanKalan	20 MGD Phase-I	26	20	-
	20 MGD Phase-II	25	21	-
Corronation pillar	20 MGD Pahse-I & II	96	44	132
	10 MGD Pahse-III	90	43	114
Narela	10 MGD	54	38	108