



**OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054**



Name of the Plant	Capacity (in MGD)	Parameters of STPs of Delhi as on					24.07.2019		
		Parameter							
		DPPC limits	pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
Okhla	12 MGD	Inlet	7.2	300	193	384	2	42	1.2
		outlet	7.5	32	22	80	1	40	0.2
	Real Time Reading at Outlet								
	45 MGD	Inlet	7.2	264	230	-	1	41	1
		outlet	7.6	29	21	-	Nil	36	0.2
	Real Time Reading at Outlet								
	37 MGD	Inlet	7.2	264	230	-	1	41	1
		outlet	7.7	32	23	-	1	34	0.8
	Real Time Reading at Outlet								
	16 MGD	Inlet	7.2	264	230	-	1	41	1
outlet		7.7	19	15	-	Nil	35	0.5	
Real Time Reading at Outlet									
Kondli	25 MGD Phase-II	Inlet	7.2	230	154	272	-	41	7.2
		outlet	7.6	16	12	34	-	33	4.2
	Real Time Reading at Outlet		7.3	19	29	86		26.77	
	45 MGD Phase-IV	Inlet	7.2	282	211	312	-	43	6.9
		outlet	7.5	29	18	59	-	34	4.8
Real Time Reading at Outlet		7.7	10	16	39		23.14		
Chilla	9 MGD	Inlet	7.1	148	116	-	-	44	7.3
		outlet	7.5	6	3.3	-	-	0.32	4.7
	Real Time Reading at Outlet		7.1	23	5	23		5.58	
CWG Village	1 MGD	Inlet	7.1	1068	424	-	-	26	5.8
		outlet	7.8	1	Bdl	-	-	Nil	1.2
	Real Time Reading at Outlet			0.16	0.13	1.43			
Yamuna Vihar	10 MGD Phase-I	Inlet	7.5	284	182	-	-	35	7
		outlet	7.7	38	19	-	-	25	4.5
	Real Time Reading at Outlet		7.3	40	30	94		20	
	10 MGD Phase-II	Inlet	7.3	332	240	-	-	30	6
		outlet	7.6	31	12	-	-	15	2.5
	Real Time Reading at Outlet		7.3	23	11	50		8	
	25 MGD Phase-III	Inlet	7.6	484	233	-	-	45	7
outlet		7.5	40	17	-	-	35	5	
Real Time Reading at Outlet		7.6	25	14	40		25		
Rithala	40 MGD	Inlet	7	280	168	390	-	33	1.2
		outlet	7.7	27	16	90	-	21	0.8
	Real Time Reading at Outlet		7.38	361.94	52.62	266.63		19.66	
	40 MGD	Inlet	7	280	168	390	-	33	1.2
		Outlet	7.5	19	14	70	-	15	0.6
Real Time Reading at Outlet		7.38	17.72	12.77	61.25		15.08		
Rohiini 15 MGD	15 MGD	Inlet	7.4	300	185	-	-	55	5
		Outlet	7.8	23	14	-	-	15	2.5
	Real Time Reading at Outlet		7.01	36.06	13.51	152.67		12.26	

Keshopur	40 MGD	Inlet	7.2	332	217	560	-	34	3.2
		outlet	7.5	94	86	320	-	29	2.5
	Real Time Reading at Outlet		6.49	201.17	103.22	268.2	-	48.8	-
	20 MGD	Inlet	7.2	332	217	560	-	34	3.2
		outlet	7.6	80	91	304	-	31	2.7
Real Time Reading at Outlet		NA	NA	NA	NA	NA	NA	NA	
Nilothi	40 MGD Phase-I	Inlet	7.3	284	128	-	5.8	25	3
		outlet	7.4	22	19	-	0	16	2.4
	Real Time Reading at Outlet		7.46	31.26	21.49	97.43	-	17.69	-
Pappankalan	20 MGD Phase-II	Inlet	7.3	262	180	520	-	45	3.5
		outlet	7.8	22	20	60	-	22	0.1
	Real Time Reading at Outlet		7.31	19.99	28.29	73.65	-	13.6	-
	20 MGD Phase-II	Inlet	7.3	384	203	500	-	43	3
		outlet	7.7	6	5	40	-	2	1.3
Real Time Reading at Outlet		NA	NA	NA	NA	NA	NA	NA	
Najafgarh	5 MGD Phase-II	Inlet	7.2	151	141	-	-	29	2.8
		outlet	7.6	17	15	-	-	6	0.6
	Real Time Reading at Outlet		7.57	33.88	29.48	83.87	-	19.34	-
Corronation pillar	20 MGD Phase-I & II	Inlet	6.9	290	210	318	8.4	38	2.2
		outlet	7.3	61	48	104	3.3	22	1
	Real Time Reading at Outlet		7.3	58.6	30.9	131.7		24	
	10 MGD Phase-III	Inlet	7.2	304	290	484	-	58	2.5
		outlet	7.4	86	59	142	-	35	1.2
Real Time Reading at Outlet		7.2	202	57	293		23		

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	24.07.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
		50	30	250
Okhla	12 MGD	32	22	80
	45 MGD	29	21	-
	37 MGD	32	23	-
	16 MGD	19	15	-
Kondli	25 MGD	16	12	34
	45 MGD	29	18	59
Chilla	9 MGD	6	3.3	-
CWG Village	1 MGD	1	Bdl	-
Yamuna Vihar	10 MGD	38	19	-
	10 MGD	31	12	-
	25 MGD	40	17	-
Rithala	40 MGD	27	16	90
	40 MGD	19	14	70
Rohiini	15 MGD	23	14	-
Keshopur	40 MGD	94	86	320
	20 MGD	80	91	304
Nilothi	40 MGD	22	19	-
Najafgarh	5 MGD	17	15	-
Pappankalan	20 MGD	22	20	60
	20 MGD	6	5	40
Corronation pillar	20 MGD	61	48	104
	10 MGD	86	59	142



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	Parameters of STPs of Delhi as on					25.07.2019		
		Parameter							
		DPPC limits	pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
Okhla	12 MGD	Inlet	7.2	236	162	336	2	38	1.8
		outlet	7.7	42	26	88	Nil	32	1.5
	Real Time Reading at Outlet								
	45 MGD	Inlet	7.3	254	172	352	3	40	2
		outlet	7.8	25	16	64	Nil	32	Nil
	Real Time Reading at Outlet								
	37 MGD	Inlet	7.3	254	172	352	3	40	2
		outlet	7.7	27	17	72	Nil	30	0.5
	Real Time Reading at Outlet								
	16 MGD	Inlet	7.3	254	172	352	3	40	2
outlet		7.8	15	10	48	Nil	30	Nil	
Real Time Reading at Outlet									
Kondli	25 MGD Phase-II	Inlet	7.3	300	165	-	-	41	5.2
		outlet	7.7	18	11	-	-	33	4
	Real Time Reading at Outlet		7.3	16	42	108		26.69	
	45 MGD Phase-IV	Inlet	7.2	270	154	-	-	42	6.5
		outlet	7.5	28	16	-	-	32	3.8
Real Time Reading at Outlet		7.8	16	16	48		12.06		
Chilla	9 MGD	Inlet	7.1	116	108	144	15	48	7.1
		outlet	7.4	8	3	21	2	0.44	4
	Real Time Reading at Outlet		7.1	9	3.2	17		5.62	
CWG Village	1 MGD	Inlet	7.2	704	369	712	28	26	5.2
		outlet	7.7	1	0.38	0.8	Bdl	0.11	1.3
	Real Time Reading at Outlet		7.5	0.16	0.11	1.44		0.02	
Yamuna Vihar	10 MGD Phase-I	Inlet	7.5	340	213	-	-	55	4.5
		outlet	7.6	21	17	-	-	25	3
	Real Time Reading at Outlet		7.3	41	46	148		30	
	10 MGD Phase-II	Inlet	7.6	420	232	-	-	40	4
		outlet	7.7	23	17	-	-	15	1
	Real Time Reading at Outlet		8.1	32	33	79		9	
25 MGD Phase-III	Inlet	7.5	548	241	-	-	45	3.5	
	outlet	7.6	23	18	-	-	15	1.5	
Real Time Reading at Outlet		7.4	26	18	45		25		
Rithala	40 MGD	Inlet	7.1	288	143	360	-	35	1
		outlet	7.6	29	18	80	-	24	1
	Real Time Reading at Outlet		7.37	26.63	16.29	64.09		23.46	
	40 MGD	Inlet	7.1	288	143	360	-	35	1
		Outlet	7.7	17	13	50	-	17	0.6
Real Time Reading at Outlet		7.38	19.87	18.07	72.48		15.58		
Rohiini 15 MGD	15 MGD	Inlet	7.6	308	183	560	-	54	8
		Outlet	7.9	25	15	74	-	17	3
	Real Time Reading at Outlet		7.05	24.6	11.88	105.96	-	11.89	

Keshopur	12 MGD	Inlet	7.4	232	211	-	-	29	3
		outlet	7.6	9	6	-	-	5	1.5
	Real Time Reading at Outlet						-		
	40 MGD	Inlet	7.3	404	339	-	-	32	3.1
		outlet	7.5	116	127	-	-	30	2.8
	Real Time Reading at Outlet		6.54	214.91	104.63	276.72		32.5	
	20 MGD	Inlet	7.3	404	339	-	-	32	3.1
outlet		7.5	90	125	-	-	31	2.5	
Real Time Reading at Outlet		6.5	122.46	51.79	183.25		61.78		
Nilothi	40 MGD Phase-I	Inlet	7.3	202	118	-	-	26	2.3
		outlet	7.5	24	18	-	-	17	1.7
	Real Time Reading at Outlet		7.4	30.1	21.29	96.83		19.78	
Pappankalan	20 MGD Phase-II	Inlet	7.2	284	175	-	-	46	4.2
		outlet	7.5	41	32	-	-	25	0.4
	Real Time Reading at Outlet								
	20 MGD Phase-II	Inlet	7.2	391	210	-	21	45	4.4
		outlet	7.7	6	5	-	0.4	0.6	2.6
Real Time Reading at Outlet		7.03	9.2	3.32	26.17		1.44		
Najafgarh	5 MGD Phase-II	Inlet	7.3	136	105	310	12	30	3.8
		outlet	7.5	12	9	41	Nil	8	1.2
	Real Time Reading at Outlet		7.6	33.91	29.6	84.24		18.46	
Corronation pillar	20 MGD Phase-I & II	Inlet	7.2	268	220	356	-	40	2
		outlet	7.5	78	56	122	-	24	0.9
	Real Time Reading at Outlet		7.2	59	31	132		23	
	10 MGD Phase-III	Inlet	7.2	324	295	442	7.8	52	2.3
		outlet	7.6	82	58	158	2.4	33	1.4
Real Time Reading at Outlet		7.4	211	60	312		22		

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	25.07.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
		50	30	250
Okhla	12 MGD	42	26	88
	45 MGD	25	16	64
	37 MGD	27	17	72
	16 MGD	15	10	48
Kondli	25 MGD	18	11	-
	45 MGD	28	16	-
Chilla	9 MGD	8	3	21
CWG Village	1 MGD	1	0.38	0.8
Yamuna Vihar	10 MGD	21	17	-
	10 MGD	23	17	-
	25 MGD	23	18	-
Rithala	40 MGD	29	18	80
	40 MGD	17	13	50
Rohiini	15 MGD	25	15	74
Keshopur	12 MGD	9	6	-
	40 MGD	116	127	-
	20 MGD	90	125	-
Nilothi	40 MGD	24	18	-
Najafgarh	5 MGD	12	9	41
Pappankalan	20 MGD	41	32	-
	20 MGD	6	5	-
Corronation pillar	20 MGD	78	56	122
	10 MGD	82	58	158



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	Parameters of STPs of Delhi as on					26.07.2019		
		Parameter							
		DPPC limits	pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
Okhla	12 MGD	Inlet	7.2	222	168	360	3	36	1.6
		outlet	7.6	28	19	72	Nil	30	0.8
	Real Time Reading at Outlet								
	45 MGD	Inlet	7.3	218	178	352	4	35	1.7
		outlet	7.7	27	16	72	1	29	0.8
	Real Time Reading at Outlet								
	37 MGD	Inlet	7.3	218	178	352	4	35	1.7
		outlet	7.6	28	20	80	1	30	0.4
	Real Time Reading at Outlet								
	16 MGD	Inlet	7.3	218	178	352	4	35	1.7
		outlet	7.7	20	15	56	1	29	0.4
	Real Time Reading at Outlet								
New 30 MGD	Inlet	7.3	284	198	400	4	35	2	
	Outlet	7.6	5	6	24	Nil	4	0.8	
Real Time Reading at Outlet									
Delhi Gate-I	2.2 MGD	Inlet	7.1	146	167	240	6	35	3.5
		outlet	7.5	5	6	24	Nil	5	0.5
Real Time Reading at Outlet									
Delhi Gate-II	15 MGD	Inlet	7.2	264	213	400	3	30	2
		outlet	7.6	14	9	40	Nil	6	1.5
Real Time Reading at Outlet									
Sen Nursing Home	2.2 MGD	Inlet	7.2	528	250	520	5	38	2.8
		outlet	7.6	6	6	24	Nil	6	0.5
Real Time Reading at Outlet									
Kondli	25 MGD Phase-II	Inlet	7.2	326	167	356	-	40	6.2
		outlet	7.6	17	10	42	-	30	3.4
	Real Time Reading at Outlet		7.3	16	12	37		26.7	
	45 MGD Phase-IV	Inlet	7.3	266	159	304	-	40	7.1
outlet		7.7	29	17	64	-	32	4	
Real Time Reading at Outlet		7.8	28	21	56		59.65		
Chilla	9 MGD	Inlet	7.2	136	89	-	-	43	5.2
		outlet	7.5	5	3	-	-	0.38	3.8
Real Time Reading at Outlet		7	9	3.25	17		5.63		
CWG Village	1 MGD	Inlet	7.2	372	192	-	-	27	4.7
		outlet	7.7	Bdl	0.68	-	-	0.08	1.8
Real Time Reading at Outlet		7.3	0.08	0.1	1.25		0.31		
	10 MGD Phase-I	Inlet	7.2	332	190	768	-	40	4
		outlet	7.8	37	24	112	-	15	3.5
	Real Time Reading at Outlet		7.3	177	66	196		17	
10 MGD Phase II	Inlet	7.2	268	182	696	-	35	5	

Yamuna Vihar	10 MGD Phase-II	outlet	7.4	56	28	152	-	10	2
	Real Time Reading at Outlet		7.3	38	23	72		17	
	25 MGD Phase-III	Inlet	7.2	516	308	928	-	45	4.5
		outlet	7.5	28	23	96	-	30	2
Real Time Reading at Outlet		7.2	26	23	52		24		
Rithala	40 MGD	Inlet	7.2	280	178	360	-	38	1.8
		outlet	7.9	27	17	70	-	27	1.4
	Real Time Reading at Outlet		7.31	50.15	18.27	77.94		25.52	
	40 MGD	Inlet	7.2	280	178	360	-	38	1.8
Outlet		7.8	16	11	50	-	20	0.8	
Real Time Reading at Outlet		7.29	18.44	12.6	64.74		14.89		
Keshopur	12 MGD	Inlet	7.4	336	211	613	-	27	2.8
		outlet	7.7	8	5	32	-	4	1.3
	Real Time Reading at Outlet								
	40 MGD	Inlet	7.4	432	191	587	-	32	3.2
		outlet	7.6	108	102	280	-	29	2.5
	Real Time Reading at Outlet		7.11	202.1	102.63	268.6		7	
20 MGD	Inlet	7.4	432	191	587	-	32	3.2	
	outlet	7.6	94	94	260	-	26	1.9	
Real Time Reading at Outlet									
Nilothi	40 MGD Phase-I	Inlet	7.4	260	124	390	6.2	26	3
		outlet	7.5	22	18	70	Nil	16	2.4
	Real Time Reading at Outlet		7.42	28.94	22.07	98.38		20.4	
Pappankalan	20 MGD Phase-II	Inlet	7.3	361	185	-	14	34	4.4
		outlet	7.6	36	27	-	Nil	26	0.9
	Real Time Reading at Outlet								
	20 MGD Phase-II	Inlet	7.3	480	204	-	18	36	4.6
		outlet	7.7	8	7	-	Nil	1.9	2.4
Real Time Reading at Outlet		7.03	10.06	8.47	36.02		1.54		
Najafgarh	5 MGD Phase-II	Inlet	7.3	339	153	-	-	32	4
		outlet	7.5	23	20	-	-	10	1
	Real Time Reading at Outlet		7.57	34.19	29.64	85.53		18.3	
Corronation pillar	20 MGD Phase-I & II	Inlet	7.2	242	215	364	7.6	38	2.3
		outlet	7.5	62	49	108	2	23	1.2
	Real Time Reading at Outlet		7.4	59	31	132		18	
	10 MGD Phase-III	Inlet	7.1	315	288	442	-	56	2.8
		outlet	7.4	80	57	132	-	38	1.6
Real Time Reading at Outlet		7.3	219	60	319		22		
Narela	10 MGD Phase-III	Inlet	7.4	190	195	298	8	62	2.9
		outlet	7.7	59	47	98	3.1	40	1.8
	Real Time Reading at Outlet		7.4	59	32	111		28	

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	26.07.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
		50	30	250
Okhla	12 MGD	28	19	72
	45 MGD	27	16	72
	37 MGD	28	20	80
	16 MGD	20	15	56
	New 30 MGD	5	6	24
Delhi Gate-I	2.2 MGD	5	6	24
Delhi Gate-II	15 MGD	14	9	40
Sen Nursing Home	2.2 MGD	6	6	24
Kondli	25 MGD	17	10	42
	45 MGD	29	17	64
Chilla	9 MGD	5	3	-
CWG Village	1 MGD	Bdl	0.68	-
Yamuna Vihar	10 MGD	37	24	112
	10 MGD	56	28	152
	25 MGD	28	23	96
Rithala	40 MGD	27	17	70
	40 MGD	16	11	50
Keshopur	12 MGD	8	5	32
	40 MGD	108	102	280
	20 MGD	94	94	260
Nilothi	40 MGD	22	18	70
Najafgarh	5 MGD	23	20	-
Pappankalan	20 MGD	36	27	-
	20 MGD	8	7	-
Corronation pillar	20 MGD	62	49	108
	10 MGD	80	57	132
Narela	10 MGD	59	47	98



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	Parameters of STPs of Delhi as on					27.07.2019		
		Parameter							
		DPPC limits	pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
Okhla	12 MGD	Inlet	7.2	272	186	384	4	30	2.8
		outlet	7.6	26	21	80	2	26	0.8
	Real Time Reading at Outlet								
	45 MGD	Inlet	7.3	370	173	448	4	32	2.5
		outlet	7.6	32	22	88	2	26	1
	Real Time Reading at Outlet								
	37 MGD	Inlet	7.3	370	173	448	4	32	2.5
		outlet	7.7	13	10	40	1	25	0.5
	Real Time Reading at Outlet								
	16 MGD	Inlet	7.3	370	173	448	4	32	2.5
outlet		7.6	16	12	48	2	25	Nil	
Real Time Reading at Outlet									
Kondli	25 MGD Phase-II	Inlet	7.3	312	167	-	-	39	7
		outlet	7.6	16	9	-	-	29	3.6
	Real Time Reading at Outlet		7.3	16	18	50		27.87	
	45 MGD Phase-IV	Inlet	7.2	278	152	-	-	38	7
outlet		7.5	30	18	-	-	31	3.4	
Real Time Reading at Outlet		7.9	29	22	59		114.87		
Yamuna Vihar	10 MGD Phase-I	Inlet	7.2	344	198	1072	-	50	5.5
		outlet	7.6	22	17	64	-	20	3.5
	Real Time Reading at Outlet		7.2	36	24	76		21	
	10 MGD Phase-II	Inlet	7.1	412	149	1203	-	40	4.5
		outlet	7.5	25	14	112	-	15	2
	Real Time Reading at Outlet								
25 MGD Phase-III	Inlet	7.2	384	257	1312	-	45	4.5	
	outlet	7.6	19	12	72	-	25	2	
Real Time Reading at Outlet									
Rithala	40 MGD	Inlet	7	264	168	350	23	24	0.7
		outlet	7.6	28	17	90	6	23	0.5
	Real Time Reading at Outlet		7.54	28.02	18.25	69.47		17.87	
	40 MGD	Inlet	7	264	168	350	23	24	0.7
Outlet		7.5	18	14	50	3	15	0.3	
Real Time Reading at Outlet		7.24	17.9	11.84	62.63		14.78		
Keshopur	12 MGD	Inlet	7.4	132	127	-	-	28	3
		outlet	7.6	9	5	-	-	5	1.5
	Real Time Reading at Outlet								
	40 MGD	Inlet	7.4	376	187	-	-	30	3.1
		outlet	7.5	86	84	-	-	29	2.8
	Real Time Reading at Outlet		7.06	226.47	87.27	256.93		5.9	
20 MGD	Inlet	7.4	376	187	-	-	30	3.1	
	outlet	7.6	88	95	-	-	27	2.2	
Real Time Reading at Outlet		7.55	417.86	112.19			65.88		
40 MGD Phase-	Inlet	7.3	192	105	-	-	24	3	

Nilothi	I	outlet	7.5	25	19	-	-	16	2.5
	Real Time Reading at Outlet		7.43	34.14	23.86	102.99		20.75	
Pappankalan	20 MGD Phase-II	Inlet	7.3	400	261	-	-	32	5
		outlet	7.6	12	15	-	-	26	0.5
	Real Time Reading at Outlet		7.13	13.19	16.67	81.8		22	
	20 MGD Phase-II	Inlet	7.2	626	318	-	20	34	4.2
		outlet	7.6	6	5	-	Nil	1	0.8
Real Time Reading at Outlet		7.01	10.05	3.66	28.22		1.56		
Najafgarh	5 MGD Phase-II	Inlet	7.3	194	141	-	-	28	2
		outlet	7.7	31	27	-	-	10	1.7
	Real Time Reading at Outlet								
Corronation pillar	20 MGD Phase-I & II	Inlet	7.2	188	190	302	-	36	2
		outlet	7.5	56	46	92	-	22	1.2
	Real Time Reading at Outlet		7.5	59	31	132		13	
	10 MGD Phase-III	Inlet	7	276	280	384	8	57	2.2
		outlet	7.4	74	56	128	3.3	36	1
Real Time Reading at Outlet		7.3	233	60	329		21		

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	27.07.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
		50	30	250
Okhla	12 MGD	26	21	80
	45 MGD	32	22	88
	37 MGD	13	10	40
	16 MGD	16	12	48
Kondli	25 MGD	16	9	-
	45 MGD	30	18	-
Yamuna Vihar	10 MGD	22	17	64
	10 MGD	25	14	112
	25 MGD	19	12	72
Rithala	40 MGD	28	17	90
	40 MGD	18	14	50
Keshopur	12 MGD	9	5	-
	40 MGD	86	84	-
	20 MGD	88	95	-
Nilothi	40 MGD	25	19	-
Najafgarh	5 MGD	31	27	-
Pappankalan	20 MGD	12	15	-
	20 MGD	6	5	-
Corronation pillar	20 MGD	56	46	92
	10 MGD	74	56	128



**OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054**



Name of the Plant	Capacity (in MGD)	Parameters of STPs of Delhi as on					28.07.2019		
		Parameter							
		DPPC limits	pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
Okhla	12 MGD	Inlet	7.3	284	220	456	3	30	2.2
		outlet	7.7	23	16	56	1	25	0.4
	Real Time Reading at Outlet								
	45 MGD	Inlet	7.3	290	203	512	3	35	1.9
		outlet	7.7	29	19	72	1	27	0.8
	Real Time Reading at Outlet								
	37 MGD	Inlet	7.3	290	203	512	3	35	1.9
		outlet	7.6	18	13	48	1	26	0.4
	Real Time Reading at Outlet								
	16 MGD	Inlet	7.3	290	203	512	3	35	1.9
outlet		7.7	15	10	40	Nil	25	Nil	
Real Time Reading at Outlet									
Kondli	25 MGD Phase-II	Inlet	7.3	308	210	350	-	37	6.8
		outlet	7.6	18	12	46	-	28	3.4
	Real Time Reading at Outlet		7.4	15	9	26		27	
	45 MGD Phase-IV	Inlet	7.2	288	196	312	-	37	6.9
		outlet	7.5	28	14	72	-	31	3.1
Real Time Reading at Outlet		7.8	35	21	68		124		
Yamuna Vihar	10 MGD Phase-I	Inlet	7.6	272	100	-	-	50	5
		outlet	7.5	32	18	-	-	25	3
	Real Time Reading at Outlet		7.3	37	51	161		22	
	10 MGD Phase-II	Inlet	7.6	272	190	-	-	40	4.5
		outlet	7.5	32	22	-	-	20	2
	Real Time Reading at Outlet		7.3	39	23	72		17	
	25 MGD Phase-III	Inlet	7.3	316	219	-	-	55	5
		outlet	7.5	37	24	-	-	25	2.5
Real Time Reading at Outlet									
Rithala	40 MGD	Inlet	7	224	179	360	-	32	1.3
		outlet	7.7	26	16	80	-	24	0.5
	Real Time Reading at Outlet		7.43	34.94	19.21	74.47		24.1	
	40 MGD	Inlet	7	224	179	360	-	32	1.3
		Outlet	7.5	19	13	50	-	15	0.3
Real Time Reading at Outlet		7.18	17.81	11.5	61.99		14.67		
Rohiini 15 MGD	15 MGD	Inlet	7.3	180	148		-	45	7.5
		Outlet	7.8	26	15		-	11	2.5
	Real Time Reading at Outlet		7.01	24.99	12.18	110.98		11.8	
Keshopur	12 MGD	Inlet	7.3	150	157	-	-	25	2.6
		outlet	7.5	14	7	-	-	5	1.2
	Real Time Reading at Outlet								
	40 MGD	Inlet	7.3	204	177	-	-	25	2.2
		outlet	7.4	74	81	-	-	27	2.4
Real Time Reading at Outlet		7.18	337.18	100.41	329.24		5.1		

	20 MGD	Inlet	7.3	204	177	-	-	25	2.2
		outlet	7.5	72	66	-	-	24	1.7
	Real Time Reading at Outlet		7.52	89.47	54.4	165.31		31.67	
Nilothi	40 MGD Phase-I	Inlet	7.4	178	138	-	-	26	2.5
		outlet	7.5	24	20	-	-	17	2
	Real Time Reading at Outlet		7.39	30.91	22.89	100.34		21.1	
Pappankalan	20 MGD Phase-II	Inlet	7.2	380	245	-	-	34	4.5
		outlet	7.6	24	19	-	-	24	0.6
	Real Time Reading at Outlet								
	20 MGD Phase-II	Inlet	7.3	440	262	-	-	36	4.2
		outlet	7.7	5	5	-	-	1	1
	Real Time Reading at Outlet		6.99	10.05	5.81	31.74		1.49	
Corronation pillar	20 MGD Phase-I & II	Inlet	7	236	220	338	8	35	2.2
		outlet	7.3	58	47	98	2.9	21	1.1
	Real Time Reading at Outlet		7.5	59	31	132		15	
	10 MGD Phase-III	Inlet	6.8	320	305	448	-	55	2.4
		outlet	7.2	68	51	124	-	34	0.9
	Real Time Reading at Outlet		6.7	65	33	111		7	

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	28.07.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
		50	30	250
Okhla	12 MGD	23	16	56
	45 MGD	29	19	72
	37 MGD	18	13	48
	16 MGD	15	10	40
Kondli	25 MGD	18	12	46
	45 MGD	28	14	72
Yamuna Vihar	10 MGD	32	18	-
	10 MGD	32	22	-
	25 MGD	37	24	-
Rithala	40 MGD	26	16	80
	40 MGD	19	13	50
Rohiini	15 MGD	26	15	-
Keshopur	12 MGD	14	7	-
	40 MGD	74	81	-
	20 MGD	72	66	-
Nilothi	40 MGD	24	20	-
Pappankalan	20 MGD	24	19	-
	20 MGD	5	5	-
Corronation pillar	20 MGD	58	47	98
	10 MGD	68	51	124