



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD, DELHI - 110054

DAILY WATER QUALITY SURVEILLANCE REPORT ON DTD. 29.01.2024

S. No.	ZONAL LAB	TOTAL NOS OF SAMPLES COLLECTION	SATISFACTORY	TOTAL NOS OF UNSATISFACTORY	DETAILS OF UNSATISFACTORY WATER SAMPLES		
					Address	Clarity	R/Cl ₂
1	Wazirabad	34	30	04	Burari ugr Opp. Ranney Well A-5 (Tank-1) Burari UGR Opp. Ranney Well A-5 (Tank-2) Ranney Well A-1 Palla Ranney Well A-2 Palla	Turbid / Clear	Nil
2	Haiderpur	43	43	NIL			
3	Bhagirathi / TYR	54	54	NIL			
4	Greater Kailash	25	22	03	H.No.-503, Gali No.-9, Rao Fateh singh marg, Kapashera H.No.-504, Gali No.-9, Rao Fateh singh marg, Kapashera H.No.-505, Gali No.-9, Rao Fateh singh marg, Kapashera	Clear	NIL
5	Okhla	18	18	NIL		-	-
6	Nangloi	125	125	NIL	-	-	-
7	Dwarka	08	08	Nil	--	-	-
8.	Bawana	NIL	NIL	-	--	-	-
	Total	307	300	07			

% of Unsatisfactory Samples = 2.28


NARESH KUMAR DARGAN
Director (T&QC)



DAILY WATER QUALITY SURVEILLANCE REPORT ON DTD. 30.01.2024

S. No.	ZONAL LAB	TOTAL NOS OF SAMPLES COLLECTION	SATISFACTORY	TOTAL NOS OF UNSATISFACTORY	DETAILS OF UNSATISFACTORY WATER SAMPLES		
					Address	Clarity	R/C ₂
1	Wazirabad	33	33	Nil			
2	Haiderpur	55	49	06	H.NO. WZ1319, NANGAL RAYA H.NO. L-173, VIJAY VIHAR PH-II H.NO. E-98A, VIJAY VIHAR H.NO. F-53, VIJAY VIHAR H.NO. F-107, VIJAY VIHAR PH-I UGR/BPS CREATIVE APARTMENT SECTOR-29, ROHINI	HAZY CLEAR HAZY	NIL
3	Bhagirathi / TYR	42	40	02	H.NO-S-698, S-697 SCHOOL BLK SHAKARPUR	HAZY	NIL
4	Greater Kailash	46	43	03	H.No.B-696 J.J. colony Tigr H.No. B-699 —do— BPS C-Block Tigr	Clear Clear Clear	0.15 0.13 0.16
5	Okhla	34	30	04	H.No. 260/5 Gali No. 5 Jamia Nagar H.No. J67 I Floor Srinivasपुर H.No. K-27 Backside Srinivasपुर H.No. B-30 I Floor Dayanand Colony	Clear Clear Clear Clear	NIL NIL NIL NIL
6	Nangloi	120	119	01	K - 94, G. No. 08, Arya Samaj road, Uttam Nagar	Sewage	NIL
7	Dwarka	09	09	Nil	-	-	-
8.	Bawana	Nil	-	-	-	-	-
	Total	339	323	16			

% of Unsatisfactory Samples 4.71


NARESH KUMAR DARGAN
Director (T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD, DELHI - 110054

DAILY WATER QUALITY SURVEILLANCE REPORT ON DTD. 31.01.2024

S. No.	ZONAL LAB	TOTAL NOS OF SAMPLES COLLECTION	SATISFACTORY	TOTAL NOS OF UNSATISFACTORY	DETAILS OF UNSATISFACTORY WATER SAMPLES		
					Address	Clarity	R/C _{l2}
1	Wazirabad	39	38	01	Subhash Park New UGR	Clear	Nil
2	Haiderpur	47	46	01	H.NO. D-338, SECTOR-1, ROHINI	HAZY	NIL
3	Bhagirathi / TYR	37	37	Nil	-	-	-
4	Greater Kailash	26	24	02	H.No. 84A/14 ward no.2 near prince public school Mehrauli H.No.705A/19 ward no.3 opp. Kutiya wali gali Mehrauli	Clear Clear	0.04 0.03
5	Okhla	25	25	NIL	-	-	-
6	Nangloi	114	114	NIL	-	-	-
7	Dwarka	05	05	Nil	-	-	-
8.	Bawana	Nil	-	-	-	-	-
	Total	293	289	04			

% of Unsatisfactory Samples - 1.36


NARESH KUMAR DARGAN
Director (T&QC)