



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Parameters of STPs of Delhi as on							01.06.2019		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Okhla	12 MGD	Inlet	7	354	245	416	4	42	1.8
		outlet	7.7	48	29	120	2	35	0.5
	Real Time Reading at Outlet								
	45 MGD	Inlet	7.3	206	178	352	3	44	1.8
		outlet	7.6	33	22	88	Nil	33	1.5
	Real Time Reading at Outlet		7.6	33	23	84	-	27	-
	37 MGD	Inlet	7.3	206	178	352	3	44	1.8
		outlet	7.7	33	20	80	2	34	0.5
	Real Time Reading at Outlet								
	16 MGD	Inlet	7.3	206	178	352	3	44	1.8
		outlet	7.8	18	13	48	1	33	0.8
	Real Time Reading at Outlet								
Kondli	25 MGD Phase-II	Inlet	7.1	290	161	304	-	40	7
		outlet	7.6	13	8	32	-	29	3.2
	Real Time Reading at Outlet		7.2	20	16	50		25	
	45 MGD Phase-IV	Inlet	7.1	316	192	366	-	41	6.9
		outlet	7.5	54	36	112	-	32	3.8
	Real Time Reading at Outlet		6.6	27	15	40		51	
Chilla	9 MGD	Inlet	7.1	104	89	120	-	43	7.1
		outlet	7.6	9	4	22	-	0.38	4.8
	Real Time Reading at Outlet		7.2	10	0.75	18		4	
CWG Village	1 MGD	Inlet	7.2	268	161	312	-	27	4.7
		outlet	7.6	1	Bdl	Bdl	-	0.2	1.8
	Real Time Reading at Outlet		7.6	0.13	0.12	1.3		0.08	
Yamuna Vihar	10 MGD Phase-I	Inlet	7.1	336	204	832	-	60	4
		outlet	7.6	41	26	123	-	55	2
	Real Time Reading at Outlet								
	10 MGD Phase-II	Inlet	7.2	256	165	651	-	55	4
		outlet	7.6	43	27	134	-	35	1.5
	Real Time Reading at Outlet						-		
	25 MGD Phase-III	Inlet	7.1	372	232	932	-	50	5
outlet		7.4	23	15	71	-	35	2.5	
Real Time Reading at Outlet									
Rithala	40 MGD	Inlet	7.1	292	159	420	-	34	1.3
		outlet	7.7	27	24	90	-	20	1.1
	Real Time Reading at Outlet								
	40 MGD	Inlet	7.1	292	159	420	-	34	1.3
		Outlet	7.8	16	11	50	-	15	0.8
Real Time Reading at Outlet									
	12 MGD	Inlet	7.3	288	192	-	-	30	3.1
		outlet	7.6	13	9	-	-	12	1.1
	Real Time Reading at Outlet		7.6	7.3	5.2	27.8		7.6	

Keshopur	40 MGD	Inlet	7.3	368	288	-	-	32	3.4
		outlet	7.5	104	102	-	-	28	2.1
	Real Time Reading at Outlet		7.8	61	48.7	133.6		24.7	
	20 MGD	Inlet	7.3	368	288	-	-	32	3.4
		outlet	7.5	94	146	-	-	27	2.7
	Real Time Reading at Outlet		6.8	182.3	105	269.7		22	
Nilothe	40 MGD Phase-I	Inlet	7.3	138	133	-	4.2	28	2.8
		outlet	7.4	48	33	-	0.5	24	2.2
	Real Time Reading at Outlet		7.4	45.1	27.6	116.55		22.6	
Najafgarh	5 MGD Phase-II	Inlet	7.3	203	112	-	-	22	3
		outlet	7.6	29	17	-	-	8	2.5
	Real Time Reading at Outlet		7.5	39.1	28.5	97.6	-	31.8	
Pappankalan	20 MGD Phase-II	Inlet	7.2	243	200	400	-	34	4.5
		outlet	7.8	37	18	80	-	14	1.5
	Real Time Reading at Outlet		7.5	26.7	21.5	133.1	-	14.6	
	20 MGD Phase-II	Inlet	7.1	353	260	440	-	38	4.5
		outlet	7.7	14	12	60	-	24	4.5
	Real Time Reading at Outlet		6.6	11.6	8.6	36.9	-	1.8	
Corronation pillar	20 MGD Phase-I & II	Inlet	7	257	240	368	-	38	2.3
		outlet	7.6	69	37	108	-	23	12
	Real Time Reading at Outlet		7.5	48	28	102		24	
	10 MGD Phase-III	Inlet	7.2	462	345	486	8.5	59	2
		outlet	7.6	76	40	134	3.4	41	0.8
	Real Time Reading at Outlet		7.5	69	38	144		34	

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	01.06.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC limits	50	30	250
Okhla	12 MGD	48	29	120
	45 MGD	33	22	88
	37 MGD	33	20	80
	16 MGD	18	13	48
Kondli	25 MGD	13	8	32
	45 MGD	54	36	112
Chilla	9 MGD	9	4	22
CWG Village	1 MGD	1	Bdl	Bdl
Yamuna Vihar	10 MGD	41	26	123
	10 MGD	43	27	134
	25 MGD	23	15	71
Rithala	40 MGD	27	24	90
	40 MGD	16	11	50
Keshopur	12 MGD	13	9	-
	40 MGD	104	102	-
	20 MGD	94	146	-
Nilothi	40 MGD	48	33	-
Najafgarh	5 MGD	29	17	-
Pappankalan	20 MGD	37	18	80
	20 MGD	14	12	60
Corronation pillar	20 MGD	69	37	108
	10 MGD	76	40	134



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Parameters of STPs of Delhi as on							02.06.2019		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Okhla	12 MGD	Inlet	7.3	220	148	424	3	40	1.7
		outlet	7.6	42	28	112	2	32	0.8
	Real Time Reading at Outlet								
	45 MGD	Inlet	7.4	236	175	432	3	41	1.7
		outlet	7.6	30	21	72	Nil	32	0.8
	Real Time Reading at Outlet								
	37 MGD	Inlet	7.4	236	175	432	3	41	1.7
		outlet	7.7	35	24	80	Nil	30	0.6
	Real Time Reading at Outlet								
	16 MGD	Inlet	7.4	236	175	432	3	41	1.7
outlet		7.8	20	15	56	Nil	29	0.4	
Real Time Reading at Outlet									
Kondli	25 MGD Phase-II	Inlet	7.2	254	143	284	-	36	6.8
		outlet	7.6	15	9	38	-	31	3.1
	Real Time Reading at Outlet		7.2	20	21	62		26	
	45 MGD Phase-IV	Inlet	7.2	228	159	256	-	39	6.9
		outlet	7.5	51	26	104	-	33	3.5
	Real Time Reading at Outlet		6.3	27	15	39		91	
Yamuna Vihar	10 MGD Phase-I	Inlet	7.3	296	182	560	13.6	55	4.5
		outlet	7.7	43	27	130	5.8	35	2.5
	Real Time Reading at Outlet								
	10 MGD Phase-II	Inlet	7.4	272	173	810	11.2	45	5
		outlet	7.8	35	22	100	5.4	25	4
	Real Time Reading at Outlet								
	25 MGD Phase-III	Inlet	7.3	296	182	560	13.6	55	4.5
		outlet	7.7	43	27	130	5.8	35	2.5
	Real Time Reading at Outlet								
Rithala	40 MGD	Inlet	7.1	276	156	390	-	38	1.7
		outlet	7.7	28	25	90	-	28	1
	Real Time Reading at Outlet								
	40 MGD	Inlet	7.1	276	156	390	-	38	1.7
		Outlet	7.5	19	14	60	-	16	0.6
	Real Time Reading at Outlet								
Keshopur	12 MGD	Inlet	7.2	228	200	-	-	27	2.9
		outlet	7.6	12	8	-	-	10	1
	Real Time Reading at Outlet		7.6	7.3	5.2	28		7.4	
	40 MGD	Inlet	7.3	260	199	-	-	30	3.2
		outlet	7.5	110	95	-	-	27	1.9
	Real Time Reading at Outlet								
	20 MGD	Inlet	7.3	260	199	-	-	30	3.2
outlet		7.5	92	136	-	-	26	2.4	
Real Time Reading at Outlet		7.2	292.6	109.7	328.5		8		
	40 MGD Phase-	Inlet	7.4	148	129	-	-	26	2.5

Nilothe	I	outlet	7.4	46	34	-	-	23	2
	Real Time Reading at Outlet		6.5	43.1	33.1	103.84		23.6	
Pappankalan	20 MGD Phase-II	Inlet	7.3	272	212	-	-	36	4.2
		outlet	7.8	30	21	-	-	16	1.6
	Real Time Reading at Outlet		7.5	25.8	16.7	127.6		23.1	
	20 MGD Phase-II	Inlet	7.3	340	238	-	-	36	4.8
		outlet	7.7	13	9	-	-	22	4
	Real Time Reading at Outlet		6.7	12.5	6.9	37.1		1..89	
Corronation pillar	20 MGD Phase-I &II	Inlet	6.9	296	245	414	-	40	2.2
		outlet	7.3	72	38	110	-	25	1
	Real Time Reading at Outlet								
	10 MGD Phase-III	Inlet	6.8	476	348	566	9	60	2.4
		outlet	7.4	62	35	96	3.4	38	1.5
	Real Time Reading at Outlet								

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	02.06.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC limits	50	30	250
Okhla	12 MGD	42	28	112
	45 MGD	30	21	72
	37 MGD	35	24	80
	16 MGD	20	15	56
Kondli	25 MGD	15	9	38
	45 MGD	51	26	104
Yamuna Vihar	10 MGD	43	27	130
	10 MGD	35	22	100
	25 MGD	43	27	130
Rithala	40 MGD	28	25	90
	40 MGD	19	14	60
Keshopur	12 MGD	12	8	-
	40 MGD	110	95	-
	20 MGD	92	136	-
Nilothi	40 MGD	46	34	-
Pappankalan	20 MGD	30	21	-
	20 MGD	13	9	-
Corronation pillar	20 MGD	72	38	110
	10 MGD	62	35	96



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Parameters of STPs of Delhi as on							29.05.2019		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Okhla	12 MGD	Inlet	7.3	264	205	400	3	40	1.2
		outlet	7.7	48	28	112	2	35	0.5
	Real Time Reading at Outlet								
	45 MGD	Inlet	7.3	306	218	464	4	42	1.8
		outlet	7.7	21	15	56	Nil	33	1.5
	Real Time Reading at Outlet								
	37 MGD	Inlet	7.3	306	218	464	4	42	1.8
		outlet	7.7	39	22	88	Nil	33	0.5
	Real Time Reading at Outlet								
	16 MGD	Inlet	7.3	306	218	464	4	42	1.8
		outlet	7.8	17	11	40	Nil	30	1.8
	Real Time Reading at Outlet								
Kondli	25 MGD Phase-II	Inlet	7.2	336	228	384	-	41	7
		outlet	7.6	15	10	32	-	31	2.3
	Real Time Reading at Outlet		7.3	20	10	36		40	
	45 MGD Phase-IV	Inlet	7.2	330	204	368	-	42	7.1
		outlet	7.5	30	18	67	-	33	3.5
	Real Time Reading at Outlet		6.6	26	15	39		32	
Chilla	9 MGD	Inlet	7.1	208	126	240	-	42	6.9
		outlet	7.6	9	4	22	-	0.38	4.9
	Real Time Reading at Outlet		7.3	9	0.56	18		10	
CWG Village	1 MGD	Inlet	7.1	700	381	752	-	23	4.7
		outlet	7.7	1	Bdl	0.8	-	5	1.2
	Real Time Reading at Outlet		7.5	0.15	0.12	1.4		0.09	
Yamuna Vihar	10 MGD Phase-I	Inlet	7.2	352	264	880	18	65	5
		outlet	7.6	48	30	80	8	40	2
	Real Time Reading at Outlet								
	10 MGD Phase-II	Inlet	7.1	308	206	688	-	40	6
		outlet	7.7	30	18	56	-	25	3
	Real Time Reading at Outlet								
	25 MGD Phase-III	Inlet	7	308	301	544	19	55	6.5
outlet		7.5	29	14	80	9	45	2.5	
Real Time Reading at Outlet									
Rithala	40 MGD	Inlet	7	900	165	330	26	32	1.1
		outlet	7.6	29	21	90	5	17	0.8
	Real Time Reading at Outlet								
	40 MGD	Inlet	7	900	165	330	26	32	1.1
		Outlet	7.5	18	13	50	3	14	0.3
Real Time Reading at Outlet									
	12 MGD	Inlet	7.3	432	239	-	-	30	3.4
		outlet	7.6	17	8	-	-	12	1.3
	Real Time Reading at Outlet		7.6	7.4	5.3	28.6		7.5	

Keshopur	40 MGD	Inlet	7.3	456	264	-	-	33	3.5
		outlet	7.6	100	91	-	-	27	2.9
	Real Time Reading at Outlet		6.7	83	38.4	125.2		54	
	20 MGD	Inlet	7.3	456	264	-	-	33	3.5
		outlet	7.5	132	129	-	-	28	3
	Real Time Reading at Outlet		6.4	162.3	99.2	245.9		40.4	3.8
Nilothe	40 MGD Phase-I	Inlet	7.3	200	107	480	6.8	29	2.5
		outlet	7.5	30	22	100	0.5	22	
	Real Time Reading at Outlet		7.4	35.1	21.9	103.2		22.9	
Najafgarh	5 MGD Phase-II	Inlet	7.3	162	115	440	-	22	2.2
		outlet	7.6	48	26	96	-	16	2
	Real Time Reading at Outlet		7.7	34.9	28.2	84.3	-	25.2	
Pappankalan	20 MGD Phase-II	Inlet	7.4	379	228	520	-	42	4.6
		outlet	7.6	17	11	60	-	18	0.1
	Real Time Reading at Outlet		7.3	16	18.9	125.5	-	16.2	
	20 MGD Phase-II	Inlet	7.3	277	207	-	-	40	4.2
		outlet	7.5	8	6	-	-	22	1.8
	Real Time Reading at Outlet		6.6	24.6	8.9	37.5	-	8.7	
Corronation pillar	20 MGD Phase-I & II	Inlet	7	278	235	386	-	36	2.2
		outlet	7.3	56	33	92	-	21	1
	Real Time Reading at Outlet		7.7	48	28	102	-	22	
	10 MGD Phase-III	Inlet	7.1	334	305	482	7.7	52	2.5
		outlet	7.5	72	39	128	2.4	37	1.3
	Real Time Reading at Outlet		6.9	70	38	137	-	35	

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	29.05.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC limits	50	30	250
Okhla	12 MGD	48	28	112
	45 MGD	21	15	56
	37 MGD	39	22	88
	16 MGD	17	11	40
Kondli	25 MGD	15	10	32
	45 MGD	30	18	67
Chilla	9 MGD	9	4	22
CWG Village	1 MGD	1	Bdl	0.8
Yamuna Vihar	10 MGD	48	30	80
	10 MGD	30	18	56
	25 MGD	29	14	80
Rithala	40 MGD	29	21	90
	40 MGD	18	13	50
Keshopur	12 MGD	17	8	-
	40 MGD	100	91	-
	20 MGD	132	129	-
Nilothi	40 MGD	30	22	100
Najafgarh	5 MGD	48	26	96
Pappankalan	20 MGD	17	11	60
	20 MGD	8	6	-
Corronation pillar	20 MGD	56	33	92
	10 MGD	72	39	128



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Parameters of STPs of Delhi as on							30.05.2019		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Okhla	12 MGD	Inlet	7.3	232	183	432	4	42	1.5
		outlet	7	40	27	112	2	36	0.5
	Real Time Reading at Outlet								
	45 MGD	Inlet	7.4	262	194	416	4	40	2
		outlet	7.8	23	18	56	1	34	1
	Real Time Reading at Outlet								
	37 MGD	Inlet	7.4	262	194	416	4	40	2
		outlet	7.8	27	20	80	1	34	0.8
	Real Time Reading at Outlet								
	16 MGD	Inlet	7.4	262	194	416	4	40	2
		outlet	7.7	15	10	40	Nil	30	1.5
	Real Time Reading at Outlet								
Kondli	25 MGD Phase-II	Inlet	7.3	254	138	312	-	44	7.2
		outlet	7.6	16	11	36	-	34	3.3
	Real Time Reading at Outlet		7	23	15	53		46	
	45 MGD Phase-IV	Inlet	7.2	282	164	336	-	43	7.1
		outlet	7.5	29	17	64	-	34	3.4
	Real Time Reading at Outlet		6.6	27	15	40		31	
Chilla	9 MGD	Inlet	7.1	200	119	264	-	43	7.4
		outlet	7.6	8	3	18	-	0.42	5.4
	Real Time Reading at Outlet		7.2	9	0.68	18		9	
CWG Village	1 MGD	Inlet	7.1	824	417	704	-	29	5.1
		outlet	7.7	1	0.24	14	-	0.2	1.9
	Real Time Reading at Outlet		7.5	0.16	0.12	1.4		0.09	
Yamuna Vihar	10 MGD Phase-I	Inlet	7.4	340	190	710	-	60	6
		outlet	7.6	39	23	98	-	40	5
	Real Time Reading at Outlet								
	10 MGD Phase-II	Inlet	7.4	290	188	670	-	70	6.5
		outlet	7.6	42	28	80	-	35	3.5
	Real Time Reading at Outlet								
	25 MGD Phase-III	Inlet	7.3	476	245	820	-	60	6.5
outlet		7.5	32	21	108	-	20	5	
Real Time Reading at Outlet									
Rithala	40 MGD	Inlet	7.1	276	165	390	-	35	1.3
		outlet	7.6	30	20	100	-	19	0.8
	Real Time Reading at Outlet								
	40 MGD	Inlet	7.1	276	165	390	-	35	1.3
		Outlet	7.7	19	12	60	-	12	0.7
Real Time Reading at Outlet									
	12 MGD	Inlet	7.5	480	190	613	11.4	31	3.2
		outlet	7.8	10	7	34	-	12	1.5
	Real Time Reading at Outlet		7.6	7.3	5.6	29.3		7.4	

Keshopur	40 MGD	Inlet	7.4	304	172	560	8.2	33	3.4
		outlet	7.6	100	75	232	0.6	27	2.8
	Real Time Reading at Outlet		7.7	70.9	51	145.2		15.8	
	20 MGD	Inlet	7.3	304	172	560	8.2	33	3.4
		outlet	7.6	94	120	240	2.8	30	2.6
	Real Time Reading at Outlet		6.5	300.4	108.7	330.6		41.8	
Nilothi	40 MGD Phase-I	Inlet	7.2	166	122	-	-	26	3
		outlet	7.4	38	24	-	-	21	2
	Real Time Reading at Outlet		7.5	35.9	21.8	103.3		19.9	
Najafgarh	5 MGD Phase-II	Inlet	7.3	222	162	-	-	24	2.4
		outlet	7.6	63	49	-	-	16	2
	Real Time Reading at Outlet		7.7	34.5	28.1	82.8		25.4	
Pappankalan	20 MGD Phase-II	Inlet	7.3	324	218	-	-	42	4.4
		outlet	7.7	22	13	-	-	16	0.1
	Real Time Reading at Outlet		7.3	14.9	19.4	125.8		17.5	
	20 MGD Phase-II	Inlet	7.3	302	208	-	-	40	4
		outlet	7.6	10	7	-	-	20	1.8
	Real Time Reading at Outlet		6.6	11.9	8.4	37.5		2.1	
Corronation pillar	20 MGD Phase-I & II	Inlet	7.1	230	210	366	7.4	40	2.6
		outlet	7.4	54	32	96	3.1	24	2.4
	Real Time Reading at Outlet		7.6	48	29	103		22	
	10 MGD Phase-III	Inlet	7.2	324	295	414	-	54	2.7
		outlet	7.5	65	36	102	-	34	1.2
	Real Time Reading at Outlet		6.9	66	39	120		34	
Narela	10 MGD Phase-III	Inlet	6.7	176	180	288	6.8	57	2.4
		outlet	7.5	58	34	112	2.5	35	1.3
	Real Time Reading at Outlet		7.5	57	33	115		17	

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	30.05.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC limits	50	30	250
Okhla	12 MGD	40	27	112
	45 MGD	23	18	56
	37 MGD	27	20	80
	16 MGD	15	10	40
Kondli	25 MGD	16	11	36
	45 MGD	29	17	64
Chilla	9 MGD	8	3	18
CWG Village	1 MGD	1	0.24	14
Yamuna Vihar	10 MGD	39	23	98
	10 MGD	42	28	80
	25 MGD	32	21	108
Rithala	40 MGD	30	20	100
	40 MGD	19	12	60
Keshopur	12 MGD	10	7	34
	40 MGD	100	75	232
	20 MGD	94	120	240
Nilothi	40 MGD	38	24	-
Najafgarh	5 MGD	63	49	-
Pappankalan	20 MGD	22	13	-
	20 MGD	10	7	-
Corronation pillar	20 MGD	54	32	96
	10 MGD	65	36	102
Narela	10 MGD	58	34	112



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Parameters of STPs of Delhi as on							31.05.2019		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Okhla	12 MGD	Inlet	7.2	268	203	392	3	40	1
		outlet	7.6	32	26	104	2	32	0.8
	Real Time Reading at Outlet								
	45 MGD	Inlet	7.2	294	212	416	4	45	1
		outlet	7.8	27	15	64	Nil	33	0.8
	Real Time Reading at Outlet								
	37 MGD	Inlet	7.2	294	212	416	4	45	1
		outlet	7.7	21	14	56	Nil	34	0.8
	Real Time Reading at Outlet								
	16 MGD	Inlet	7.2	294	212	416	4	45	1
		outlet	7.8	16	12	48	Nil	35	0.5
	Real Time Reading at Outlet								
Kondli	25 MGD Phase-II	Inlet	7.2	298	158	304	-	40	6.8
		outlet	7.6	18	10	42	-	30	3
	Real Time Reading at Outlet		7.1	21	12	42		26	
	45 MGD Phase-IV	Inlet	7.2	256	146	284	-	42	7
		outlet	7.5	53	34	122	-	35	3.5
	Real Time Reading at Outlet		6.6	27	15	41		63	
Yamuna Vihar	10 MGD Phase-I	Inlet	7.2	320	204	568	-	60	6
		outlet	7.6	38	24	160	-	40	5
	Real Time Reading at Outlet								
	10 MGD Phase-II	Inlet	7.3	208	145	688	-	40	5.5
		outlet	7.6	41	26	102	-	20	2.5
	Real Time Reading at Outlet								
	25 MGD Phase-III	Inlet	7.2	404	258	1040	-	55	6.5
		outlet	7.7	26	20	80	-	45	4
	Real Time Reading at Outlet								
Rithala	40 MGD	Inlet	7.2	252	158	350	-	32	1.5
		outlet	7.9	29	22	90	-	21	1.1
	Real Time Reading at Outlet								
	40 MGD	Inlet	7.2	252	158	350	-	32	1.5
		Outlet	7.8	17	11	60	-	12	0.8
	Real Time Reading at Outlet								
Keshopur	12 MGD	Inlet	7.3	204	181	-	-	32	3.4
		outlet	7.6	14	8	-	-	13	1.2
	Real Time Reading at Outlet		7.6	7.3	5.6	29.6		7.7	
	40 MGD	Inlet	7.3	560	281	-	-	34	3.7
		outlet	7.6	120	113	-	-	28	2.9
	Real Time Reading at Outlet		7.7	68.6	50.2	143.1		21.7	
	20 MGD	Inlet	7.3	560	281	-	-	34	3.7
outlet		7.5	84	84	-	-	30	2.8	
Real Time Reading at Outlet		6.6	344.1	107.2	348.8		27.7		
	40 MGD Phase-	Inlet	7.4	184	139	-	5.2	28	2.5

Nilothe	I outlet		7.5	4	25	-	0.5	20	2
	Real Time Reading at Outlet		7.4	43.7	25.6	112.2		21.9	
Najafgarh	5 MGD Phase-II	Inlet	7.3	112	110	-	-	20	2.4
		outlet	7.6	13	11	-	-	6	2
	Real Time Reading at Outlet		7.4	39.9	27.9	99.8		41.7	
Pappankalan	20 MGD Phase-II	Inlet	7.2	368	220	-	-	32	4.5
		outlet	7.8	29	20	-	-	12	1
	Real Time Reading at Outlet		7.3	21.7	14.5	123.5		15.2	
	20 MGD Phase-II	Inlet	7.1	360	224	-	-	36	4.5
		outlet	7.7	10	8	-	-	24	1.8
	Real Time Reading at Outlet		6.6	12.5	8.8	39.1		1.9	
Corronation pillar	20 MGD Phase-I & II	Inlet	6.8	246	238	328	-	37	2.6
		outlet	7.3	56	34	104	-	24	1.3
	Real Time Reading at Outlet		7.5	48	28	102		25	
	10 MGD Phase-III	Inlet	7.1	339	295	428	-	48	1.9
		outlet	7.6	66	38	105	-	38	1.2
	Real Time Reading at Outlet		6.8	61	40	114		35	

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	31.05.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC limits	50	30	250
Okhla	12 MGD	32	26	104
	45 MGD	27	15	64
	37 MGD	21	14	56
	16 MGD	16	12	48
Kondli	25 MGD	18	10	42
	45 MGD	53	34	122
Yamuna Vihar	10 MGD	38	24	160
	10 MGD	41	26	102
	25 MGD	26	20	80
Rithala	40 MGD	29	22	90
	40 MGD	17	11	60
Keshopur	12 MGD	14	8	-
	40 MGD	120	113	-
	20 MGD	84	84	-
Nilothi	40 MGD	4	25	-
Najafgarh	5 MGD	13	11	-
Pappankalan	20 MGD	29	20	-
	20 MGD	10	8	-
Corronation pillar	20 MGD	56	34	104
	10 MGD	66	38	105