



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



		Parameters of STPs of Delhi as on					29.07.2019		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Okhla	12 MGD	Inlet	7.3	206	184	384	4	36	2.6
		outlet	7.4	31	21	80	2	30	0.5
	Real Time Reading at Outlet								
	45 MGD	Inlet	7.3	196	187	360	3	36	2.8
		outlet	7.5	21	15	64	1	32	0.5
	Real Time Reading at Outlet								
	37 MGD	Inlet	7.3	196	187	360	3	36	2.8
		outlet	7.6	14	11	40	1	30	0.8
	Real Time Reading at Outlet								
	16 MGD	Inlet	7.3	196	187	360	3	36	2.8
		outlet	7.5	13	11	40	Nil	36	0.5
	Real Time Reading at Outlet								
	New 30 MGD	Inlet	7.4	228	215	408	5	35	3
		Outlet	7.4	3	3	16	Nil	5	2.5
Real Time Reading at Outlet									
Mehrauli	5 MGD	Inlet	7.4	252	141	336	-	36	2.5
		outlet	7.6	7	4	16	-	20	2
	Real Time Reading at Outlet								
Vasant Kunj	2.2 MGD	Inlet	7.3	164	141	320	-	30	3
		outlet	7.6	4	3	16	-	28	2.8
	Real Time Reading at Outlet								
	3 MGD	Inlet	7.4	256	253	368	-	35	2.2
		outlet	7.6	5	4	16	-	5	1.5
Real Time Reading at Outlet									
Ghitorni	5 MGD	Inlet	7.4	208	185	400	-	36	4
		outlet	7.7	46	25	112	-	25	2.8
	Real Time Reading at Outlet								
Kondli	25 MGD Phase-II	Inlet	7.2	308	180	352	-	39	7
		outlet	7.5	11	8	27	-	30	3.8
	Real Time Reading at Outlet		7.3	15	20	54		28	
	45 MGD Phase-IV	Inlet	7.2	222	135	256	-	40	7.1
		outlet	7.6	26	15	56	-	33	3.3
Real Time Reading at Outlet		7.8	31	23	64		73.88		
Yamuna Vihar	10 MGD Phase-I	Inlet	7.4	300	159	820	21.2	55	6.5
		outlet	7.8	32	22	90	12.4	45	4.5
	Real Time Reading at Outlet		7.3	177	63	196		21	
	10 MGD Phase-II	Inlet	7.3	252	151	-	20.4	40	5
		outlet	7.8	50	31	-	3.2	20	1
	Real Time Reading at Outlet		7.3	79	35	162		8	
	25 MGD Phase-III	Inlet	7.5	334	161	780	26.6	50	4.5
outlet		7.7	44	25	110	6.8	35	3	
Real Time Reading at Outlet									

Rithala	40 MGD	Inlet	7.1	312	183	410	-	36	0.9
		outlet	7.7	29	18	80	-	27	0.8
	Real Time Reading at Outlet		7.38	37.31	17.5	72.72		25.24	
	40 MGD	Inlet	7.1	312	183	410	-	36	0.9
		Outlet	7.5	18	12	60		16	0.3
	Real Time Reading at Outlet		7.22	17.86	9.09	60.66		14.74	
Rohiini 15 MGD	15 MGD	Inlet	7.3	252	170	496	-	52	8.5
		Outlet	7.8	27	17	86	-	15	4
	Real Time Reading at Outlet		7.01	-	12.65	110.88	-	11.8	
Keshopur	12 MGD	Inlet	7.3	200	173	-	-	28	3.2
		outlet	7.8	10	4	-	-	5	2.7
	Real Time Reading at Outlet		NA	NA	NA	NA	-	NA	-
	40 MGD	Inlet	7.3	336	210	-	-	30	3.1
		outlet	7.5	94	96	-	-	28	2.9
	Real Time Reading at Outlet		7.2	398.27	106.99	369.1	-	5.3	-
	20 MGD	Inlet	7.3	336	210	-	-	30	3.1
		outlet	7.6	82	96	-	-	26	2.5
	Real Time Reading at Outlet		NA	NA	NA	NA	-	NA	-
Nilothi	40 MGD Phase-I	Inlet	7.3	204	117	-	4.9	27	2.8
		outlet	7.5	26	19	-	NIL	16	2.2
	Real Time Reading at Outlet		7.36	31.14	23.79	102.34	-	20.13	-
Pappankalan	20 MGD Phase-II	Inlet	7.3	374	242	520	15.6	36	5.2
		outlet	7.7	33	26	70	NIL	16	0.4
	Real Time Reading at Outlet		NA	NA	NA	NA	-	NA	-
	20 MGD Phase-II	Inlet	7.3	424	270	560	-	46	3.6
		outlet	7.6	10	8	30	-	0.8	2.8
	Real Time Reading at Outlet		7	11.41	9.17	38.92	-	1.52	-
Najafgarh	5 MGD Phase-II	Inlet	7.3	293	174	480	-	22	4
		outlet	7.7	25	18	64	-	9	3.6
	Real Time Reading at Outlet		7.44	34.23	30.11	86.92	-	18.58	-
Corronation pillar	20 MGD Phase-I & II	Inlet	7	210	180	324	-	38	2.4
		outlet	7.4	60	48	98	-	22	1.3
	Real Time Reading at Outlet		7.6	58	31	132		13	
	10 MGD Phase-III	Inlet	7	284	285	424	8.2	59	2.6
		outlet	7.4	64	49	112	2.3	36	1.3
	Real Time Reading at Outlet		7.8	73	35	126		12	

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	29.07.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC limits	50	30	250
Okhla	12 MGD	31	21	80
	45 MGD	21	15	64
	37 MGD	14	11	40
	16 MGD	13	11	40
	New 30 MGD	3	3	16
Mehrauli	5 MGD	7	4	16
Vasant Kunj	2.2 MGD	4	3	16
	3 MGD	5	4	16
Ghitorni	5 MGD	46	25	112
Kondli	25 MGD	11	8	27
	45 MGD	26	15	56
Yamuna Vihar	10 MGD	32	22	90
	10 MGD	50	31	-
	25 MGD	44	25	110
Rithala	40 MGD	29	18	80
	40 MGD	18	12	60
Rohiini	15 MGD	27	17	86
Keshopur	12 MGD	10	4	-
	40 MGD	94	96	-
	20 MGD	82	96	-
Nilothi	40 MGD	26	19	-
Najafgarh	5 MGD	25	18	64
Pappankalan	20 MGD	33	26	70
	20 MGD	10	8	30
Corronation pillar	20 MGD	60	48	98
	10 MGD	64	49	112



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Parameters of STPs of Delhi as on							30.07.2019		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Okhla	12 MGD	Inlet	7.2	224	112	384	3	40	3
		outlet	7.6	39	24	96	2	32	2.2
	Real Time Reading at Outlet								
	45 MGD	Inlet	7.3	156	188	368	4	42	3
		outlet	7.6	23	16	64	NIL	36	0.8
	Real Time Reading at Outlet								
	37 MGD	Inlet	7.3	156	188	368	4	42	3
		outlet	7.6	22	13	56	NIL	33	0.5
	Real Time Reading at Outlet								
	16 MGD	Inlet	7.3	156	188	368	4	42	3
		outlet	7.6	35	22	88	NIL	35	Nil
	Real Time Reading at Outlet								
Kondli	25 MGD Phase-II	Inlet	7.3	612	186	368	-	39	6.2
		outlet	7.7	14	9	36	-	29	2.6
	Real Time Reading at Outlet		7.3	15	20	53		27.3	
	45 MGD Phase-IV	Inlet	7.2	298	171	350	-	40	7
		outlet	7.5	30	16	66	-	31	3.8
	Real Time Reading at Outlet		7.8	28	25	66		92.66	
Yamuna Vihar	10 MGD Phase-I	Inlet	7.5	284	212	-	-	45	5
		outlet	7.6	64	24	-	-	20	3
	Real Time Reading at Outlet		7.3	48	70	257		21	
	10 MGD Phase-II	Inlet	7.5	280	184	-	-	30	4
		outlet	7.5	39	24	-	-	10	2.5
	Real Time Reading at Outlet		7.4	27	21	60		9	
	25 MGD Phase-III	Inlet	7.6	284	181	-	-	50	5.5
		outlet	7.7	63	31	-	-	25	2.5
Real Time Reading at Outlet									
Rithala	40 MGD	Inlet	7	272	164	370	-	38	1.2
		outlet	7.8	27	17	70	-	24	0.9
	Real Time Reading at Outlet		7.36	30.13	17.33	71.17		25.91	
	40 MGD	Inlet	7	272	164	370	-	38	1.2
		Outlet	7.7	17	12	50	-	17	0.5
Real Time Reading at Outlet		7.22	17.86	9.09	60.97		14.74		
Rohiini 15 MGD	15 MGD	Inlet	7.4	240	173	-	-	45	7.5
		Outlet	7.9	30	18	-	-	14	2.5
	Real Time Reading at Outlet								
Keshopur	12 MGD	Inlet	7.4	248	178	453	23.4	27	3.4
		outlet	7.7	10	5	30	NIL	6	2.4
	Real Time Reading at Outlet		NA	NA	NA	NA	-	NA	-
	40 MGD	Inlet	7.3	348	190	480	19	28	3
		outlet	7.5	94	89	240	5.6	26	3.1
Real Time Reading at Outlet		7.1	229.71	103.62	286.89	-	55.2	-	

	20 MGD	Inlet	7.3	348	190	480	19	28	3
		outlet	7.6	114	98	240	3.2	25	2.4
	Real Time Reading at Outlet		7.54	67.58	51.78	142.53	-	22.84	-
Nilothi	40 MGD Phase-I	Inlet	7.2	188	124	380	-	28	3
		outlet	7.5	28	21	74	-	18	2.4
	Real Time Reading at Outlet		7.41	31.48	24.27	103.41	-	20.08	-
	20 MGD Phase-II	Inlet	7.2	290	152	470	7.9	30	2.8
		outlet	7.3	8	5	32	NIL	7	2.1
	Real Time Reading at Outlet		NA	NA	NA	NA	-	NA	-
Pappankalan	20 MGD Phase-II	Inlet	7.2	337	260	640	-	42	5
		outlet	7.6	26	19	60	-	17	0.4
	Real Time Reading at Outlet		7.27	24.89	41.31	64.53	-	32.2	-
	20 MGD Phase-II	Inlet	7.3	290	225	600	-	42	3.4
		outlet	7.6	4	4	20	-	0.8	2.4
	Real Time Reading at Outlet		6.99	11.16	6.76	35.05	-	1.49	-
Najafgarh	5 MGD Phase-II	Inlet	7.4	356	252	-	-	25	3.8
		outlet	7.6	35	26	-	-	6	3.2
	Real Time Reading at Outlet		7.55	34.17	30.5	87.66	-	18.72	-
Corronation pillar	20 MGD Phase-I & II	Inlet	7.1	268	205	304	7.9	36	2.3
		outlet	7.5	57	41	86	2.5	24	1.2
	Real Time Reading at Outlet		7.7	59	31	133		12	
	10 MGD Phase-III	Inlet	7.1	390	310	516	-	56	2.8
		outlet	7.4	60	42	108	-	32	1.5
	Real Time Reading at Outlet		7.7	72	34	123		14	
Narela	10 MGD Phase-III	Inlet	7.2	184	185	314	7.3	50	2.5
		outlet	7.5	48	33	92	2.4	46	1.3
	Real Time Reading at Outlet		7.5	56	31	109		13	

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	30.07.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC limits	50	30	250
Okhla	12 MGD	39	24	96
	45 MGD	23	16	64
	37 MGD	22	13	56
	16 MGD	35	22	88
Kondli	25 MGD	14	9	36
	45 MGD	30	16	66
Yamuna Vihar	10 MGD	64	24	-
	10 MGD	39	24	-
	25 MGD	63	31	-
Rithala	40 MGD	27	17	70
	40 MGD	17	12	50
Rohiini	15 MGD	30	18	-
Keshopur	12 MGD	10	5	30
	40 MGD	94	89	240
	20 MGD	114	98	240
Nilothi	40 MGD	28	21	74
	20 MGD	8	5	32
Najafgarh	5 MGD	35	26	-
Pappankalan	20 MGD	26	19	60
	20 MGD	4	4	20
Corronation pillar	20 MGD	57	41	86
	10 MGD	60	42	108
Narela	10 MGD	48	33	92



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Parameters of STPs of Delhi as on							31.07.2019		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Okhla	12 MGD	Inlet	7.2	252	207	400	4	44	2.8
		outlet	7.5	44	29	120	2	38	2.2
	Real Time Reading at Outlet								
	45 MGD	Inlet	7.3	234	240	-	3	40	2
		outlet	7.6	27	19	-	Nil	35	0.5
	Real Time Reading at Outlet								
	37 MGD	Inlet	7.3	234	240	-	3	40	2
		outlet	7.6	24	17	-	1	35	0.5
	Real Time Reading at Outlet								
	16 MGD	Inlet	7.3	234	240	-	3	40	2
		outlet	7.6	24	16	-	Nil	36	Nil
	Real Time Reading at Outlet								
Kondli	25 MGD Phase-II	Inlet	7.2	326	184	307	-	40	6.4
		outlet	7.7	14	10	32	-	30	3
	Real Time Reading at Outlet		7.4	15	10	31		25.34	
	45 MGD Phase-IV	Inlet	7.2	290	164	298	-	40	7.1
		outlet	7.5	28	18	60	-	32	4.2
	Real Time Reading at Outlet		7.8	28	28	74		68.89	
Yamuna Vihar	10 MGD Phase-I	Inlet	7.4	260	187	-	-	55	5.5
		outlet	7.5	24	17	-	-	40	2.5
	Real Time Reading at Outlet		7.3	34	106	375		7.2	
	10 MGD Phase-II	Inlet	7.3	272	205	-	-	45	3.5
		outlet	7.5	26	15	-	-	30	1.5
	Real Time Reading at Outlet		7.4	25	23	63		10	
	25 MGD Phase-III	Inlet	7.3	408	237	-	-	55	6.5
		outlet	7.5	62	24	-	-	45	3
	Real Time Reading at Outlet								
Rithala	40 MGD	Inlet	6.9	264	163	340	-	29	0.6
		outlet	7.6	26	16	70	-	16	0.4
	Real Time Reading at Outlet		7.46	84.65	17.43	81.49		22.75	
	40 MGD	Inlet	6.9	264	163	340	-	29	0.6
		Outlet	7.5	18	13	50	-	11	0.3
	Real Time Reading at Outlet		7.24	17.95	10.2	61.7		14.78	
Keshopur	12 MGD	Inlet	7.3	232	155	-	-	25	2.7
		outlet	7.7	11	7	-	-	5	2
	Real Time Reading at Outlet		NA	NA	NA	NA	NA	NA	NA
	40 MGD	Inlet	7.4	316	191	-	-	27	3.2
		outlet	7.5	88	106	-	-	28	3.1
	Real Time Reading at Outlet		6.89	382.08	105.48	359.92	-	81.1	-
	20 MGD	Inlet	7.4	316	191	-	-	27	3.2
outlet		7.6	86	93	-	-	26	2.5	
Real Time Reading at Outlet		7.58	75.91	49.01	131.9	-	30.23	-	
	40 MGD Phase-	Inlet	7.1	210	126	-	-	25	2.8

Nilothe	I	outlet	7.4	24	18	-	-	17	2.4
	Real Time Reading at Outlet		7.43	30.46	24.12	102.99	-	20.7	-
Pappankalan	20 MGD Phase-II	Inlet	7.2	568	248	-	13	42	4.4
		outlet	7.5	31	27	-	2.2	16	0.5
	Real Time Reading at Outlet		NA	NA	NA	NA	NA	NA	NA
	20 MGD Phase-II	Inlet	7.3	483	256	-	13	43	3.3
		outlet	7.6	7	6	-	0	0.6	1.2
	Real Time Reading at Outlet		6.99	10.77	5.94	33.22	-	1.48	-
Najafgarh	5 MGD Phase-II	Inlet	7.3	140	128	-	-	23	3.8
		outlet	7.5	18	15	-	-	4	1.6
	Real Time Reading at Outlet		7.64	34.02	30.43	86.82	-	18.75	-
Corronation pillar	20 MGD Phase-I & II	Inlet	6.9	266	248	324	-	38	2
		outlet	7.3	59	45	104	-	23	1
	Real Time Reading at Outlet		7.6	59	31	133		11	
	10 MGD Phase-III	Inlet	7	304	288	482	8	58	2.5
		outlet	7.5	58	39	94	2	34	1.3
	Real Time Reading at Outlet		7.6	121	43	197		13	

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	31.07.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC limits	50	30	250
Okhla	12 MGD	44	29	120
	45 MGD	27	19	-
	37 MGD	24	17	-
	16 MGD	24	16	-
Kondli	25 MGD	14	10	32
	45 MGD	28	18	60
Yamuna Vihar	10 MGD	24	17	-
	10 MGD	26	15	-
	25 MGD	62	24	-
Rithala	40 MGD	26	16	70
	40 MGD	18	13	50
Keshopur	12 MGD	11	7	-
	40 MGD	88	106	-
	20 MGD	86	93	-
Nilothi	40 MGD	24	18	-
Najafgarh	5 MGD	18	15	-
Pappankalan	20 MGD	31	27	-
	20 MGD	7	6	-
Corronation pillar	20 MGD	59	45	104
	10 MGD	58	39	94



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Parameters of STPs of Delhi as on							01.08.2019		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Okhla	12 MGD	Inlet	7.4	226	160	400	5	44	2
		outlet	7.6	35	26	104	2	40	1.8
	Real Time Reading at Outlet								
	45 MGD	Inlet	7.5	236	175	-	4	42	3.5
		outlet	7.6	21	15	-	1	39	0.2
	Real Time Reading at Outlet								
	37 MGD	Inlet	7.5	236	175	-	4	42	3.5
		outlet	7.6	17	12	-	2	38	0.8
	Real Time Reading at Outlet								
	16 MGD	Inlet	7.5	236	175	-	4	42	3.5
		outlet	7.6	22	15	-	Nil	37	0.4
	Real Time Reading at Outlet								
Kondli	25 MGD Phase-II	Inlet	7.2	338	180	349	-	39	6.5
		outlet	7.7	15	9	40	-	29	3.2
	Real Time Reading at Outlet		7.3	16	17	48		28.32	
	45 MGD Phase-IV	Inlet	7.3	270	167	296	-	39	7
		outlet	7.5	26	15	56	-	30	4.8
	Real Time Reading at Outlet		7.9	29	27	72		70.3	
Yamuna Vihar	10 MGD Phase-I	Inlet	7.3	292	190	738	-	65	5.5
		outlet	7.6	31	22	86	-	50	3
	Real Time Reading at Outlet		7.3	48	70	257		21	
	10 MGD Phase-II	Inlet	7.2	344	195	820	-	55	4.5
		outlet	7.7	123	65	320	-	25	3
	Real Time Reading at Outlet		7.4	346	127	361		22	
	25 MGD Phase-III	Inlet	7.3	316	194	460	-	60	5
		outlet	7.6	41	24	94	-	45	2.5
	Real Time Reading at Outlet		7.3	48	70	257		22	
Rithala	40 MGD	Inlet	7	256	144	320	-	27	0.7
		outlet	7.5	29	16	80	-	18	0.6
	Real Time Reading at Outlet		7.5	36.54	17.34	71.29		21.52	
	40 MGD	Inlet	7	256	144	320	-	27	0.7
		Outlet	7.6	17	11	50	-	11	0.4
	Real Time Reading at Outlet		7.27	18.01	10.99	62.38		14.85	
Keshopur	12 MGD	Inlet	7.3	656	209	747	-	28	2.9
		outlet	7.8	14	6	32	-	6	2.3
	Real Time Reading at Outlet		NA	NA	NA	NA	NA	NA	NA
	40 MGD	Inlet	7.3	432	230	760	-	29	3
		outlet	7.5	82	111	312	-	27	3
	Real Time Reading at Outlet		6.83	525.24	106.36	426.93	-	76.9	-
	20 MGD	Inlet	7.3	432	230	760	-	29	3
		outlet	7.6	92	93	264	-	24	2.6
Real Time Reading at Outlet		7.64	59.3	47.67	126.87	-	22.26	-	
	40 MGD Phase-	Inlet	7.3	192	131	-	6.2	27	2.5

Nilothi	I	outlet	7.5	22	16	-	0.4	16	2
	Real Time Reading at Outlet		7.47	31.1	24.18	103.26	-	20.72	-
Pappankalan	20 MGD Phase-II	Inlet	7.3	318	215	-	-	44	4.8
		outlet	7.6	30	19	-	-	18	0.6
	Real Time Reading at Outlet		7.43	29.87	22.86	76.73	-	18.9	-
	20 MGD Phase-II	Inlet	7.3	394	235	-	-	43	3.5
		outlet	7.7	8	6	-	-	0.8	1.4
	Real Time Reading at Outlet		7.01	13.93	10.33	44.9	-	1.5	-
Najafgarh	5 MGD Phase-II	Inlet	7.3	186	133	-	8	24	4
		outlet	7.6	28	20	-	0.8	6	1.8
	Real Time Reading at Outlet		7.72	34.43	32.73	94.49	-	19.15	-
Corronation pillar	20 MGD Phase-I & II	Inlet	6.8	282	250	302	8.2	36	2.4
		outlet	7.3	54	38	98	2.8	21	1.1
	Real Time Reading at Outlet		7.2	59	31	133		28	
	10 MGD Phase-III	Inlet	6.9	314	280	504	-	50	2.8
		outlet	7.4	84	54	116	-	36	1.6
	Real Time Reading at Outlet		7.7	176	48	246		17	

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	01.08.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC limits	50	30	250
Okhla	12 MGD	35	26	104
	45 MGD	21	15	-
	37 MGD	17	12	-
	16 MGD	22	15	-
Kondli	25 MGD	15	9	40
	45 MGD	26	15	56
Yamuna Vihar	10 MGD	31	22	86
	10 MGD	123	65	320
	25 MGD	41	24	94
Rithala	40 MGD	29	16	80
	40 MGD	17	11	50
Keshopur	12 MGD	14	6	32
	40 MGD	82	111	312
	20 MGD	92	93	264
Nilothi	40 MGD	22	16	-
Najafgarh	5 MGD	28	20	-
Pappankalan	20 MGD	30	19	-
	20 MGD	8	6	-
Corronation pillar	20 MGD	54	38	98
	10 MGD	84	54	116



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Parameters of STPs of Delhi as on							02.08.2019		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Okhla	12 MGD	Inlet	7.4	240	230	424	-	35	2.8
		outlet	7.7	41	28	112	-	30	0.2
	Real Time Reading at Outlet								
	45 MGD	Inlet	7.5	278	268	424	-	32	2.5
		outlet	7.9	28	22	80	-	28	Nil
	Real Time Reading at Outlet								
	37 MGD	Inlet	7.5	278	268	424	-	32	2.5
		outlet	7.6	16	13	48	-	25	2.3
	Real Time Reading at Outlet					-			
	16 MGD	Inlet	7.5	278	268	424	-	32	2.5
		outlet	7.6	30	21	80	-	26	0.3
	Real Time Reading at Outlet								
	New 30 MGD	Inlet	7.1	266	208	400	-	28	2.8
		Outlet	7.7	4	3	16	-	5	1.8
	Real Time Reading at Outlet								
Kondli	25 MGD Phase-II	Inlet	7.3	298	212	347	-	40	6.2
		outlet	7.7	13	8	32	-	33	3.1
	Real Time Reading at Outlet		7.3	16	20	55		28.05	
	45 MGD Phase-IV	Inlet	7.3	262	170	323	-	42	7
		outlet	7.6	39	22	74	-	34	4.4
	Real Time Reading at Outlet		7.9	31	24	69		77.36	
Yamuna Vihar	10 MGD Phase-I	Inlet	7.3	376	174	973	-	60	5.5
		outlet	7.6	30	24	91	-	50	2.5
	Real Time Reading at Outlet		7.3	44	27	121		16	
	10 MGD Phase-II	Inlet	7.3	532	200	1119	-	55	5
		outlet	7.6	27	23	122	-	30	3
	Real Time Reading at Outlet								
	25 MGD Phase-III	Inlet	7.3	428	231	1035	-	60	4
		outlet	7.5	42	32	139	-	40	2
Real Time Reading at Outlet		7.6	39	23	79		25		
Rithala	40 MGD	Inlet	7	272	169	360	-	32	1
		outlet	7.6	28	17	80	-	28	0.6
	Real Time Reading at Outlet		7.55	49.72	17.97	77.39		20.2	
	40 MGD	Inlet	7	272	169	360	-	32	1
		Outlet	7.7	18	13	70	-	16	0.4
Real Time Reading at Outlet		7.33	17.92	10.63	61.83		14.97		
Keshopur	12 MGD	Inlet	7.4	252	201	-	17.4	26	2.7
		outlet	7.8	12	6	-	0	4	1.6
	40 MGD	Inlet	7.3	400	244	-	20.8	29	2.8
		outlet	7.5	92	98	-	6.2	27	2.5
	Real Time Reading at Outlet		6.87	246.86	102.15	288.22	-	38.3	-
	20 MGD	Inlet	7.3	400	244	-	20.8	29	2.8
outlet		7.6	102	89	-	1.6	25	2.3	

	Real Time Reading at Outlet		7.7	78.88	53.35	154.83	-	22.15	-
Nilothi	40 MGD Phase-I	Inlet	7.2	286	141	420	7.2	22	2.2
		outlet	7.5	28	21	82	0.5	15	1.7
	Real Time Reading at Outlet		7.5	31.06	24.8	104.51	-	20.61	-
Pappankalan	20 MGD Phase-II	Inlet	7.2	365	188	-	-	38	4.8
		outlet	7.6	43	28	-	-	28	0.9
	20 MGD Phase-II	Inlet	7.3	342	182	-	-	40	3.6
		outlet	7.6	10	7	-	-	0.5	1
	Real Time Reading at Outlet		7.01	10.68	5.41	31.52	-	1.58	-
Najafgarh	5 MGD Phase-II	Inlet	7.2	290	174	-	-	30	3.8
		outlet	7.5	33	27	-	-	12	1.6
	Real Time Reading at Outlet		7.69	34.3	31.98	92.13	-	19.15	-
Corronation pillar	20 MGD Phase-I & II	Inlet	7	242	215	326		34	1.9
		outlet	7.4	52	41	88		24	0.8
	Real Time Reading at Outlet		7.2	59	31	133		27	
	10 MGD Phase-III	Inlet	6.8	278	250	456	7.5	54	2.6
		outlet	7.3	82	56	102	2.2	38	1.3
	Real Time Reading at Outlet		7.7	145	47	217		16	
Narela	10 MGD Phase-III	Inlet	7.1	148	162	288	6.8	48	2.8
		outlet	7.4	42	40	84	2.6	34	1.4
	Real Time Reading at Outlet		7.8	57	33	115		10	

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	02.08.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
	DPCC limits	50	30	250
Okhla	12 MGD	41	28	112
	45 MGD	28	22	80
	37 MGD	16	13	48
	16 MGD	30	21	80
	New 30 MGD	4	3	16
Kondli	25 MGD	13	8	32
	45 MGD	39	22	74
Yamuna Vihar	10 MGD	30	24	91
	10 MGD	27	23	122
	25 MGD	42	32	139
Rithala	40 MGD	28	17	80
	40 MGD	18	13	70
Keshopur	12 MGD	12	6	-
	40 MGD	92	98	-
	20 MGD	102	89	-
Nilothi	40 MGD	28	21	82
Najafgarh	5 MGD	33	27	-
Pappankalan	20 MGD	43	28	-
	20 MGD	10	7	-
Corronation pillar	20 MGD	52	41	88
	10 MGD	82	56	102
Narela	10 MGD	42	40	84