

	DELHI JAL BOARD: GOVT. OF N.C.T. OF DELHI OFFICE OF THE EE (PROJECT) WATER-I ROOM NO. 511, VARUNALAYA PHASE-I JHANDEWALAN, DELHI-110005 E-mail: ee1.djb@gmail.com	 INTERNATIONAL YEAR OF THE WOMAN FARMER 2026
---	---	--

CORRIGENDUM NO. 03

N.O.W.: 4th Expression of interest (EOI) for empanelment of manufacturers of 15 mm dia water meters.

Ref.: Tender ID: 2026_DJB_289863_1 dated 13.04.2026

Sl. No.	Tender Reference	Amendments
1.	Water meters eligibility and selection criteria, Clause No. 5.1.1 (Page No. 03 of EOI) The water meter shall be, inferential type, multi jet, magnetically coupled, having dry dial, Class 'B' conforming to IS-779 with up to date amendments and MID Certification or ISO 4064:2005 standards with EEC/OIML/MID certification mark and shall be with protection class of IP-68	Water meters eligibility and selection criteria, Clause No. 5.1.1 (Page No. 03 of EOI) 'The water meter shall be, inferential type, multi jet, magnetically coupled, having dry dial, Class 'B' conforming to IS-779 with up to date amendments with ISI certification mark and protection class of IP-68 compliant' The requirement of MID Certification or ISO 4064:2005 with EEC/OIML/MID certification mark stands deleted.
2.	Markings On The Body Of The Meter Clause No. 6.2.2 (Page No. 04 of EOI): iv) As per IS: 779 with up to date amendments and MID certification OR ISO: 4064- with up to date amendments with EEC/OIML/MID Code No.	Markings On The Body Of The Meter Clause No. 6.2.2 (Page No. 04 of EOI): iv) As per IS: 779 with up to date amendments. The requirement of MID certification or EEC/OIML/MID Code No. on the body marking stands deleted. All other markings will remain the same.
3.	Water meters eligibility and selection criteria, Clause No. 6.6 (Page No. 06 of EOI) Specification of Polycarbonate Triple Lock Seal: The water meter shall be sealed with Polycarbonate Triple Lock Seal having SS 304 wire of appropriate length. The unique number of the seal, brand name of water meter and the word 'DJB' shall be engraved on the polycarbonate seal which shall be easily readable. The manufacture will also provide an additional similar Polycarbonate Triple Lock	Water meters eligibility and selection criteria, Clause No. 6.6 (Page No. 06 of EOI) Specification of Polycarbonate Double Lock Seal and Anti magnetic ring: The water meter shall be sealed with Polycarbonate Double Lock Seal having SS 304 wire of appropriate length. The unique ID of the seal, QR code, brand name of water meter and the word 'DJB' shall be engraved on the polycarbonate seal which shall be easily readable. Manufacturers shall submit the proposals in the EOI regarding seal design, exact engraving format; wire length, QR code etc. Anti-magnetic ring of suitable specifications shall be provided in the body of the water meter.



	Seal with a different unique number having SS 304 wire in the box for sealing of the meter with the brass extension nut through the twin holes provided in the brass nut by the plumber during installation of meter at the consumer end.	The requirement of an additional seal for sealing the meter with the brass extension nut stands deleted. The other conditions will remain the same.
4.	Terms & Conditions of Empanelment (Page No. 11 & 12 of EOI) After passing of sample meters, the manufacturer will be asked to submit bank guarantee money of Rs. 5.0 Lakh valid initially for a period of 5 years. In case of complaints of consumers are not satisfactorily resolved, DJB reserves the right to liquidate BG and attend the same at the risk and cost of manufacturer including delisting of the manufacturer. During random sampling by DJB, if an empanelled model fails, bank guarantee money of Rs. 5.0 Lakh (To be validated 15 days before expiry otherwise will be en-cashed) will be retained by DJB uptill the guarantee of last meter sold/ date of de-empanelment.	Terms & Conditions of Empanelment (Page No. 11 & 12 of EOI) The amount of bank guarantee has been increased to 15 Lakh. After passing of sample meters, the manufacturer will be asked to submit this bank guarantee of Rs. 15 Lakh valid for a period of 5 years. DJB reserves the right to encash & forfeit the BG in addition to blacklisting and de-empanelment of the manufacturers in the following conditions: 1. In case of complaints of consumers are not satisfactorily resolved 2. During random sampling by DJB, if an empanelled model of water meter does not meet the required IS standards/ EOI conditions. If at any stage, any inferior or substandard quality substitute of DJB approved model of the water meters of a particular manufacturer are found to be sold in Delhi.

All other terms and conditions will remain the same.

(D.K. Jain)
EE (Project) W-I

No.: DJB/EE (Project) W-I/EOI/2026/ 822 to 848

Date 24.06.2026

Copy to for kind information:

1. PA to chairman, DJB
2. P.S. to CEO/ Mem.(A)/Mem.(F)/CEN(Water)/CEN(Dr.)/CVO
3. C.E.(Water)Projects-I/II/CE(P&D)/CE(WW)-I/CE(M)-1/CE(M)-2
4. Dir. (F&A)/DOV/DOR
5. SE(Proj.)W-II
6. Dy.Dir(F&A)-I/Jt. Dir. (Rev) HQ/AO(Project)W-II
7. EE(Plg.)W-II
8. DD (IT) with a scanned copy on E-mail:dditdjb@gmail.com
9. DD (PR)
10. AE-IV/AAO(Project)W-I
11. Office Copy/Tender File/ Notice Board

EE (Project) W-I

O/c