

SUMMER BULLETIN

09.06.2024

WATER PRODUCTION-990.01 MGD

S. No.	Name of WTP	Capacity (In MGD)	Actual Production (In MGD)	Remarks on reduction in production (if any)
1	Haiderpur	216	241.67	
2	Sonia Vihar	140	142.60	
3	Wazirabad	131	119.52	
4	Bhagirathi	110	112.76	
5	Chandrawal	94	99.87	
6	Dwarka	50	52.38	
7	Nangloi	40	44.30	
8	Okhla	20	21.87	
9	Bawana	20	20.04	
A	Production from WTPs	821	855.01	
B	Ranney Wells & Tube Wells	135 (Tentative)	135	
	Total	956	990.01	There is shortage of raw water at Wazirabad WTP results into less production.

❖ Actual production of water was 990.01 MGD which is 34.01 MGD more than the actual capacity

CE/NODAL OFFICER (SAP)