



DELHI JAL BOARD

GOVT. OF NCT OF DELHI

SUMMER BULLETIN

09.08.2024

WATER PRODUCTION- 973 MGD

S. No.	Name of WTP	Capacity (In MGD)	Actual Production (In MGD)	Remarks on reduction in production (if any)
1	Haiderpur	216	242	
2	Sonia Vihar	140	134	
3	Wazirabad	131	113	
4	Bhagirathi	110	111	
5	Chandrawal	94	100	
6	Dwarka	50	53	
7	Nangloi	40	44	
8	Okhla	20	21	
9	Bawana	20	20	
A	Production from WTPs	821	838	
B	Ranney Wells & Tube Wells	135 (Tentative)	135	
	Total	956	973	<ul style="list-style-type: none">• Less treatment at Sonia Vihar due to replacement of valve work being carried out by DMRC in Tahirpur mains which ended at 3:25 AM. Also, power failure from 11 :02 AM to 11:22 AM at the plant.• Less treatment at Wazirabad due to shutdown taken for interconnection work on Punjabi bagh rising main and repair work of LT panel at 40 MGD plant

❖ Actual production of water was 973 MGD which is 17 MGD more than the actual capacity

CE/NODAL OFFICER (SAP)