

SUMMER BULLETIN

10.06.2024

WATER PRODUCTION-978.59 MGD

| S. No. | Name of WTP | Capacity (In MGD) | Actual Production (In MGD) | Remarks on reduction in production (if any) |
|----------|--------------------------------------|-------------------|----------------------------|---|
| 1 | Haiderpur | 216 | 241.67 | |
| 2 | Sonia Vihar | 140 | 142.73 | |
| 3 | Wazirabad | 131 | 108.72 | |
| 4 | Bhagirathi | 110 | 112.07 | |
| 5 | Chandrawal | 94 | 99.90 | |
| 6 | Dwarka | 50 | 52.42 | |
| 7 | Nangloi | 40 | 44.25 | |
| 8 | Okhla | 20 | 21.78 | |
| 9 | Bawana | 20 | 20.05 | |
| A | Production from WTPs | 821 | 843.59 | |
| B | Ranney Wells & Tube Wells | 135 (Tentative) | 135 | |
| | Total | 956 | 978.59 | There is shortage of raw water at Wazirabad WTP results into less production. |

❖ Actual production of water was 978.59 MGD which is 22.59 MGD more than the actual capacity

CE/NODAL OFFICER (SAP)